

MORRIS PLAINS BORO POLICE DEPARTMENT

Incident Redaction Report

INCIDENT INFORMATION

Case No	Report Date / Time	Reported Method	Created By
2025-10578	04/28/2025 16:41	VIA CAD	CAD
CAD Incident CFS Type	Agency Incident / Actual CFS Type	Incident: From Date / Time	Incident: To Date / Time
FIRE CALL	ALARMS (FIRE ALARMS)	04/28/2025 16:41	
Crime / Arrest Location	Area / Post		
INCIDENT(CAD)			
Address	Common Place / POI	Bldg / Apt / Suite	
361 SPEEDWELL AVE	ARBOR TERRACE OF MORRIS PLAINS (23)		
City	State	Zip	
MORRIS PLAINS	NJ	07950	
County	Municipality		
MORRIS	MORRIS PLAINS BORO		

DISPATCH NOTES

Date & Time	Description	Posted By
04/28/2025 16:41:08	Chief Complaint Text: Alarm monitoring company Caller Statement: COMM SMOKE ALARM Dispatch Code: 86C01 (HIGH LIFE HAZARD) Suffix: S (Smoke detector) CAD Response: CHARLIE-1 -- The caller is an alarm monitoring company. -- It is a smoke detector alarm. -- The area or zone/room activated is: EVERGREEN DINING -- The phone number of the business/resident/owner is: 973 718 3636 -- The name of the business/resident/owner is: SA -- The type of structure (environment) involves a HIGH LIFE HAZARD. -- The reference number for this alarm is: 5248	343
04/28/2025 16:41:16	Interrogation is complete for F251180043.	343
04/28/2025 16:41:35	Talkgroup Assigned: MC FIRE 6	234
04/28/2025 16:45:32	2336 ADV FD STEAM FROM STEAM TRAY NO FIRE	343

CALL INFORMATION

Phone #	Call Date&Time	Caller	Location
*****	04/28/2025 16:39	OP 5248	*****
Requested Action	Call Taker	Source Type	
	343	1	

Brief Synopsis of Incident

FIRE CALL

DISPATCH INFORMATION

Unit Name	Action
HOCHMAN, JEFFREY R.	ARRIVED ON-SCENE (04/28/2025 16:43) ENROUTE TO SCENE (04/28/2025 16:41) HOLD (04/28/2025 16:41) READY (04/28/2025 16:52)

MORRIS PLAINS BORO POLICE DEPARTMENT

SUBJECT INFORMATION

No Record Found

VEHICLE INFORMATION

No Record Found

INDIVIDUAL CONTACT INFORMATION

No Record Found

PD CASE DISPOSITION INFORMATION

Disposition	Closed Date	Closed By
FALSE ALARM FIRE	04/29/2025	HOCHMAN, JEFFREY R.

Disposition

RESPONDED TO ARBOR TERRACE FOR SMOKE ALARM ACTIVATION. DETERMINED TO BE SET OFF BY STEAM IN THE KITCHEN. NO PROBLEM AT LOCATION. MPFD RESET THE ALARM.

NOTES

No Record Found

Officer Signature _____

Date of Report _____