

Borough of Red Bank
32 Monmouth Street
Red Bank, NJ 07701
(908) 530-2760



Date Received
Date Issued
Control #
Permit #
7/15/92
92-0233

A. IDENTIFICATION—APPLICANT: COMPLETE ALL APPLICABLE INFORMATION. WHEN CHANGING CONTRACTORS, NOTIFY THIS OFFICE. CALL UTILITY DIG NO: 1-800-272-1000.

Block 41.1 lot 3
Work Site Location 62 Mitchell Place
Owner in Fee Little Creek NJ - 07739
Address Little Creek NJ - 07739

Tele. (908) 747-7688
Contractor SAGGI, EMCO ELECTRIC
Address 6820 Parkway Court DR
Plainsboro NJ 08536
Tele. (609) 799-1466
Lic. No. 101821
Federal Emp. No. 156-64-8194 or Social Security No. 156-64-8194

B. ELECTRICAL CHARACTERISTICS

☐ Reinspection ☐ Resale ☐ Meter Set
☐ Pole/Pad # ☐ Temporary ☐ Other
Building Occupied as Utility Co.
Est. Cost of Elec. Work \$ 1,875.00

JOB SUMMARY (Office Use Only)

PLAN REVIEW:		INSPECTIONS:	
	Type:	Failure	Dates (Month/Day)
☐ No Plans Required			
Joint Plan Review Required:			
☐ Bldg. ☐ Plumb. ☐ Fire	Rough		Approval <u>7-2-92</u> Initial <u>RB</u>
☐ Elec. Plans Approved	Temporary		
Date: <u>7-2-92</u>	Constr. Serv.		
	TCO		
Approved by: <u>[Signature]</u>	Other		
	Service		
SUBCODE APPROVAL:	Final		
☒ CO ☐ CCO ☐ CA	Temp. Cut-in-Card Date Issued		
Date: <u>7-2-92</u>	Final Cut-in-Card Date Issued		
Approved by: <u>[Signature]</u>	Line Dept.		

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner of record and am authorized to make this application and perform the work listed on this application.

Electrical Contractor ☐ Exempt Applicant

Signature/Contractor Seal

D. TECHNICAL SITE DATA

NO.	SIZE	ITEM	FEE (Office Use Only)
<u>0</u>		Fixtures (1)	
<u>1</u>		Receptacles (2)	
<u>1</u>		Switches (3)	
<u>8</u>		Total 1 + 2 + 3	<u>20-</u>
		Range	<u>4</u>
		Oven(s)	<u>4</u>
		Surface Unit	<u>4</u>
		Dishwasher	
		Garbage Disposal	
		Dryer	
		A/C Unit	
		Burglar Alarms	
		Intercoms Panels	
		Smoke Detectors	
		Whirlpool/spa	
		Pool Bonding	
		Pool Filter Motor	
		Pool Lights	
		Water Heater(s)	
		Central heat:	
		oil, gas or elec.	
		Baseboard Heat Units	
		Thermostats	
		Heat Pump	
		Pump(s)	
		Motor Control Center/Sub Panels	
		Signs	
		Light Standards	
		Motors—Fractional H.P.	
		Motors—All Others	
		Transformers	
		Generators	
		Service Entrance	
		Other	

Administrative Surcharge \$
Paid ☐ Check # 105 Minimum Fee \$
Collected by: [Signature] TOTAL FEE \$ 47.00

Township of Red Bank

32 Monmouth Street
Red Bank, NJ 07701

(201) 530-2760



PERMIT UPDATE

Date Update Issued
Control #
Permit #
Date Permit Issued

IDENTIFICATION Block 44.1 Lot 3

Block Site Location 62 Mitchell Place
Little Silver, NJ 07739

Owner in Fee Hohmann
Address Same as above

Telephone (908) 747-7688

Lic. No. or Bldrs. Reg. No. 2A-2532258

Federal Emp. No. 2A-2532258

or Social Security No. 2A-2532258

I hereby granted permission to perform the following work:

BUILDING ☒ PLUMBING ☐ Other ☐
ELECTRICAL ☐ FIRE PROTECTION ☐

DESCRIPTION OF WORK:

REMODELING OF KITCHEN

Estimated Cost of Work \$ 23,000

Stanley J. Siegel
CONSTRUCTION OFFICIAL

PAYMENTS (Office Use Only)

Building	17.00
Plumbing	49.00
Electrical	
Fire Protection	
Other	
DCA Training Fee	
Cert. of Occ.	
Other	
Total	64.00
Check No.	
Cash	
Collected By:	<u>Stanley J. Siegel</u>



PLUMBING SUBCODE TECHNICAL SECTION

COMPLETE ALL APPLICABLE INFORMATION. WHEN CHANGING, CALL UTILITY DIG NO: 1-800-272-1000.

Lot 3
Address HELL PLAGE
07739

Phone (TEL) (508 - 747-7688)

Owner BOG HTG

City RT NJ

or Social Security No. _____

Proposed _____

875.00

INSPECTIONS:			Dates (Month/Day)	
Type:	Failure	Failure	Approval	Initial
Slab	_____	_____	_____	_____
Rough	_____	_____	_____	_____
Water	_____	_____	_____	_____
Sewer	_____	_____	_____	_____
Fixtures	_____	_____	_____	_____
Gas Equipment	_____	_____	_____	_____
Gas Final	_____	_____	_____	_____
Solar	_____	_____	_____	_____
TCO	_____	_____	_____	_____
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____

Signature of owner of application _____
Signature-Contractor Seal _____

Exempt Applicant



Date Received 6-15-92
Date Issued _____
Control # _____
Permit # 92-D433

D. TECHNICAL SITE DATA (List all fixtures.)

NO.	FIXTURE/EQUIPMENT	FEE (Office Use Only)
_____	Water Closet	_____
_____	Urinal/Bidet	_____
_____	Bath Tub	_____
_____	Lavatory	_____
_____	Shower	_____
_____	Floor Drain	_____
<u>27</u>	Sink	<u>84</u>
_____	Dishwasher	_____
_____	Drinking Fountain	_____
_____	Washing Machine	_____
_____	Hose Bibb	_____
_____	Gas Piping	_____
_____	Fuel Oil Piping	_____
_____	Water Heater	_____
_____	Steam Boiler	_____
_____	Hot Water Boiler	_____
_____	Sewer Pump	_____
_____	Interceptor/Separator	_____
_____	Backflow Preventer	_____
_____	Greasetrap	_____
_____	Water Cooled A/C	_____
_____	or Refrigeration Unit	_____
_____	Sewer Connection	_____
_____	Water Service Connection	_____
_____	Gas Service Connection	_____
_____	Active Solar System	_____
_____	Other	_____

Paid [☒] Check # 1770 Minimum Fee \$ 1770
Collected by: PLUMBING TOTAL \$ 1770

RBBB 1A

U.C.C. Form F-130A 1 Original = Applicant Copy 2 Canary = Office Copy
3 Pink = Office Copy 4 White = Inspector's Copy

Date Issued 04/05/2002

Control # 02-0075
Permit #

UCC NEW JERSEY CERTIFICATE

LOCATION

Qual

ALL PLACE

IN, GERARD

Home Warranty No. _____
Type of Warranty Plan: [] State [] Private

Use Group R-3

Maximum Live Load 0

Construction Classification

Maximum Occupancy Load 0

Description of Work/Use:

REMOVAL INGROUND POOL
FINAL INSPECTION 3/13/02 TOTAL COST \$3500.00

701-

Fax ()

5

OCCUPANCY

_____ or structure has been constructed in
_____ Construction Code and is approved

APPROVAL

_____ completed has been constructed or installed in
_____ Construction Code and is approved.
work, this certificate was based upon what

CERTIFICATE OF OCCUPANCY/COMPLIANCE

_____ of Occupancy or Compliance, the following
_____ or the owner will be

[] CERTIFICATE OF CLEARANCE - LEAD ABATEMENT 5:17

This serves notice that based on written certification, lead abatement was
performed as per NJAC 5:17, to the following extent:

[] Total removal of lead-based paint hazards in scope of work
[] Partial or limited time period (____ years); see file

[] CERTIFICATE OF CONTINUED OCCUPANCY

This serves notice that based on a general inspection of the visible parts of
the building there are no imminent hazards and the building is approved for
continued occupancy.

[] CERTIFICATE OF COMPLIANCE

This serves notice that said potentially hazardous equipment has been installed
and/or maintained in accordance with the New Jersey Uniform Construction
Code and is approved for use until _____.

Fee \$ 0
Paid [X] check No. 2710
Collected by: MM

UCC NEW JERSEY
BUILDING
SUBCODE
TECHNICAL SECTION

Date Received 02/28/2002
Date Issued 02/28/2002
Control #
Permit # 02-0075

COMPLETE ALL APPLICABLE INFORMATION WHEN CHANGING
B. CALL UTILITY DIG NO: 1-800-272-1000

Qual
PLACE

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner
of record and am authorized to make this application.

Signature

D. TECHNICAL SITE DATA
DESCRIPTION OF WORK

REMOVAL INGROUND POOL

al	INSPECTIONS	Dates (Month/Day)	TYPE OF WORK	FEE (Office Use Only)
	Type	Failure	☐ New Building	\$
	Footings	Approval	☐ Addition	0
	Foundation	Initial	☐ Alteration	0
	Slab		☐ Roofing	0
	Frame		☐ Siding	0
	BarrierFree		☐ Fence	0
	Insulation		☐ Sign	0
	Finishes		☐ Pool	0
	Energy		☐ Asbestos Abatement Subchapter 8	0
	Mechanical		☐ Lead Haz. Abatement NJAC 5:17	0
	TCO		☐ Other	0
	Other		☐ Other	0
	Final		☒ Demolition	75
	BarrierFree			

Proposed R-3	Est. Cost of Bldg. Work:	Administrative Surcharge	\$	0
Proposed	1. New Bldg. \$	Minimum Fee	\$	75
0	2. Alteration \$	TOTAL FEE	\$	150
0	3. Total (1+2) \$	DCA Training Fee	\$	0
0				
0				
0				
0				
0				
0				
0				

U.C.C. F110 (rev. 3/96)

UGC NEW JERSEY
CONSTRUCTION
PERMIT

IDENTIFICATION Block 44.01 Lot 3 Qual

Work Site Location 62 MITCHELL PLACE

Contractor RED BANK RECYCLING

Owner in Fee HOHMANN, GERARD

Address 64 CENTRAL AVE

Address SAME

RED BANK, NJ 07701-

Telephone SAME, NJ 07739-

Telephone (732)747-7667

Telephone (732)747-7688

Lic. No. or Bldrs. Reg. No.
Federal Emp. No. 22-2890205

Is hereby granted permission to perform the following work:

- | | | |
|--|---|--|
| ☒ BUILDING | ☐ PLUMBING | ☐ LEAD HAZARD ABATEMENT |
| ☐ ELECTRICAL | ☐ FIRE PROTECTION | ☒ DEMOLITION |
| ☐ ELEVATOR DEVICES | ☐ ASBESTOS ABATEMENT | ☐ OTHER <u></u> |
- (Subchapter 8 only)

DESCRIPTION OF WORK:
REMOVAL INGROUND POOL

NOTE: If construction does not commence within one (1) year of date of issuance, or if construction ceases for a period of six (6) months, this permit is void.

Estimated Cost of Work \$ 3,500

Construction Official

02/28/2002
Date



**BUILDING
SUBCODE
TECHNICAL SECTION**

COMPLETE ALL APPLICABLE INFORMATION. WHEN CHANGING
CALL UTILITY DIG NO: 1-800-272-1000.

Lot 398

11 Place
ver, N.J. 07739

Recycling Demolition, Inc.
26 64 Central Avenue
N.J. 07701

Fax (732) 747-4965
E.P.E. Lic#8823 N.J.S.W.A. Lic#1613
0205

INSPECTIONS

Type:	Failure	Dates (Month/Day)	Approval	Initial
Footings	—	—	—	—
Foundation	—	—	—	—
Slab	—	—	—	—
Frame	—	—	—	—
Barrier-Free	—	—	—	—
Insulation	—	—	—	—
Finishes	—	—	—	—
Energy	—	—	—	—
Mechanical	—	—	—	—
TCO	—	—	—	—
Other	—	—	—	—
Final	—	—	—	—
Barrier-Free	—	—	—	—

Proposed _____
Proposed _____

Est. Cost of Bldg. Work:

1. New Bldg. \$ _____
2. Alteration \$ _____
3. Total (1+2) \$ 3,500.00

Ft. _____
Sq. Ft. _____
Sq. Ft. _____
Cu. Ft. _____
Sq. Ft. _____



Date Received
Date Issued
Control #
Permit #

2/28/02
2/28/02
00-0075

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner of
record and am authorized to make this application.

Signature _____

D. TECHNICAL SITE DATA

DESCRIPTION OF WORK

Removal
background pool

TYPE OF WORK:

☐ New Building
☐ Addition
☒ Alteration
☐ Roofing
☐ Siding
☐ Fence _____ Height (exceeds 6')
☐ Sign _____ Sq. Ft.
☒ Pool Removal
☐ Asbestos Abatement Subchapter 8
☐ Lead Haz. Abatement NJAC 5:17
☐ Other _____
☒ Demolition

FEE (Office Use Only)

\$ _____

Administrative Surcharge \$ _____
Minimum Fee \$ _____
DCA Training Fee \$ _____
TOTAL FEE \$ _____

U.C.C. F110
(rev. 3/99)

1 White = Inspector Copy
3 Pink = Office Copy
2 Canary = Office Copy
4 Gold = Applicant Copy

Block 44.1 LOT 3

Work Site Location:

62 Mitchell Place Little Silver, N.J.

Owner Name:

Hahmann

Address:

62 Mitchell Place Little Silver, N.J.

Telephone:

732-747-7667

Name of Contractor:

Red Bank Recycling Demolition, Inc.

Address of Contractor:

PO Box 2126 64 Central Avenue

Telephone:

Red Bank, N.J. 07701

732-747-7667

Type of Construction/Demolition Debris:

Construction Debris (Wood)-Delaware Recyclable Pr.
Concrete - Stavola Recycling Yard Tinton Falls, N.J.
Metal - Red Bank Recycling Yard Red Bank, N.J.

Where it is being Disposed of:

Delaware Recyclable Products

Address:

198 Marsh Lane

New Castle, DE 19720

Phone:

302-655-1360

Name of Disposal Firm:

~~Where it is being Disposed of:~~

Name:

Red Bank Recycling Demolition, Inc.

Address:

PO Box 2126 64 Central Avenue

Red Bank, N.J. 07701

Phone:

732-747-7667

Signature of Owner, Contractor or Agent:

Signature

Date

2/25/02

Disposal/pav/form ltr.

To all persons involved in the removal/filling of the pool at the above said address:

This letter is to certify that to the best of my professional knowledge, all electric and telephone wires are disconnected and removed from their source. For convenience and assurance of this, all wires have been left visible, tied and bonded to themselves, and clearly labeled with permanent marker and white tape. Please take note that you will find fourteen (14) areas that have been cut, safed off and labeled. I determined a total of two (2) electrical wires, two (2) grounding bonds and one (1) telephone wire. All are explained below.

- Circuit for pool is labeled "dead wire #1 pool." This wire is disconnected, tested and found to be safe. To my best knowledge, it travels from its point at pool area, westward toward the house and can be found above ground at the location of the a/c unit. This has been determined to be the same wire at both ends and is clearly marked.

- Running parallel with above "dead wire #1" is a "green ground bond" and is labeled as such.
- At poolside can be found wire labeled "dead wire jumper." This wire travels northward approximately 15 feet to the pool motor. This wire is disconnected, tested and found to be safe.
- Running parallel with above "dead wire jumper" is a "green ground bond" and is labeled as such.
- Circuit for deck receptacles is labeled "dead wire #2." This wire is disconnected, tested and found to be safe. To the best of my knowledge, it travels from the right side of deck steps westward toward the house and can be found above ground under the bay window. This has been determined to be same wire at both ends and is clearly marked.

- Running parallel with "dead wire #2" is a telephone wire. This wire has been disconnected from its source and is clearly marked on both ends.
- All above said wires are underground except for 2 points each for tagging. These wires can be considered dead and may be buried or removed.

- Running visibly under the right side of deck are wires labeled "dead wire deck receptacles" and "phone." These wires travel to existing deck receptacles and phone jack and are disconnected from their source.

Above description will prove out the fourteen (14) labeled wires. ANY other wire found or uncovered that is not clearly marked should be considered potentially "LIVE" and all work should stop until this wire is identified by myself or a qualified electrician. For emergencies only, I can be contacted at (732) 740-1688.

Sincerely,



Henry M. Gregerson