



Morristown Fire Department

Station: 0
Shifts Or Platoon: Tour 2

Location:
40 SPEEDWELL AVE
Morristown NJ 07960

Lat/Long:
N 40° 47' 57.37"
W 74° 28' 53.97"

Location Type: **1 - Street address**

Incident Type:
111 - Building fire

FDID: **14240**
Incident #: **2021-00149**
Exposure ID: **55164517**
Exposure #: **0**
Incident Date: **02/05/2021**
Dispatch Run #: **F210360019**

Report Completed by:	DeGroot , Thomas (Tex)	ID: 1147	Date: 02/05/2021
Report Reviewed by:	Not Reviewed		
Report Printed by:	Doyle, Lindsay	ID:	Date: 2/8/2021 Time: 12:04

Structure Type: Enclosed building	Property Use: 429 - Multifamily dwelling
Automatic Extinguishment System Present: ☐	Detectors Present: ☒ Cause of Ignition: Unintentional
Aid Given or Received: Automatic aid received	Primary action taken: 11 - Extinguishment by fire service personnel
Additional actions: 12 - Salvage & overhaul , 21 - Search	
Losses	Pre-Incident Values
Property:	Property:
Contents:	Contents:
Total:	Total:
Civilian Injuries: 0	Fire Service Injuries: 0
Civilian Fatalities: 0	Fire Service Fatalities: 0
Total Casualties: 0	Total Fire Service Casualties: 0
Total # of apparatus on call: 8	Total # of personnel on call: 28

Special Studies
COVID 19 was a factor in this incident. Unknown.

Neighboring Agencies
Agency Name: Madison Fire
Agency ID: 14170
Agency Type: Fire
Agency Name: Morris Plains Fire
Agency ID: 14230
Agency Type: Fire
Agency Name: Morris Township Fire
Agency ID: 14220
Agency Type: Fire

Narrative from dispatch:
2021/02/05 11:02:06
[02/05/21 11:02:06 354] COM FIRE ALARM- FIRE ALARM 2ND FL HALLWAY AND 3RD FL HALLWAY
2021/02/05 11:02:42
[02/05/21 11:02:42 344] PR 24 LT FD ONLY
2021/02/05 11:03:29
[02/05/21 11:03:29 294] CAPT 1 DELAYED RESPONSE

2021/02/05 11:04:53
[02/05/21 11:04:53 354] ADDITIONAL ALARM FRONT DINING ROOM
2021/02/05 11:06:32
[02/05/21 11:06:32 294] PER FIRE MARSHALL UPGRADE TO SECOND ALARM
2021/02/05 11:06:55
[02/05/21 11:06:55 270] Situation Updated: 79 (COMMERCIAL STRUCTURE FIRE [69])
2021/02/05 11:07:00
[02/05/21 11:07:00 190] PER FD COMMAND HAVE PD CLOSE R202
2021/02/05 11:07:04
[02/05/21 11:07:04 294] FD RQST PD TO SHUT DOWN 202 FOR WORKING STRUCTURE FIRE
2021/02/05 11:07:15
[02/05/21 11:07:15 270] Updated to ALARM LEVEL 2.
2021/02/05 11:07:42
[02/05/21 11:07:42 190] Updated to ALARM LEVEL 3.
2021/02/05 11:08:09
[02/05/21 11:08:09 344] PTL ENROUTE FOR TRAFFIC CONTROL
2021/02/05 11:09:10
[02/05/21 11:09:10 190] HAVE PD SHUT DOWN CLINTON PL PER FD COMMAND
2021/02/05 11:09:13
[02/05/21 11:09:13 344] P24136 STOPPING TRAFFIC AT CATTANO
2021/02/05 11:12:06
[02/05/21 11:12:06 294] MIGHT GET ALARM FOR 7 PROSPECT OR 44 SPEEDWELL DUE TO FIRE
2021/02/05 11:14:48
[02/05/21 11:14:48 190] EMS 4 AND EMS 5 ON SCENE IFO HYATT
2021/02/05 11:18:26
[02/05/21 11:18:26 294] PER CH1 THIRD ALARM FOR MANPOWER
2021/02/05 11:21:18
[02/05/21 11:21:18 294] PER CH1 TONES FOR MANPOWER TO STANDBY AT QUARTERS
2021/02/05 11:22:36
[02/05/21 11:22:36 294] 20 MIN UPDATE- ALL ACCOUNTED FOR
2021/02/05 11:22:47
[02/05/21 11:22:47 250] SAM JUDSON ACO NOTIFIED SHE IS ALSO NOTIFIED HEALTH OFFICER
2021/02/05 11:24:49
[02/05/21 11:24:49 294] PER 23CH2 CREW ASSEMBLING NO NEED FOR REALERTS
2021/02/05 11:26:18
[02/05/21 11:26:18 294] MORRIS PLAINS AIR TRUCK TO ASSEMBLE IFO HYATT
2021/02/05 11:28:55
[02/05/21 11:28:55 294] 22L1 STANDING BY IN QUARTERS
2021/02/05 11:29:29
[02/05/21 11:29:29 250] PARSIPPANY FD ADVISED
2021/02/05 11:30:50
[02/05/21 11:30:50 344] MORRISTOWN TRANSPORTATION ADVISED OF ROAD CLOSURE - SPEEDWELL AVE FROM THE GREEN TO WATER ST
2021/02/05 11:32:19
[02/05/21 11:32:19 294] FM RQST HEATH DEPT NTFD FOR WATER DAMAGE FROM FIRE
2021/02/05 11:33:12
[02/05/21 11:33:12 190] WEST SIDE TASK FORCE WILL ALL BE STANDING BY AT HQ'S
2021/02/05 11:41:43
[02/05/21 11:41:43 344] OIC CONFIRMED ACO NOT NEEDED - ACO SAM JUDSON ADVISED
2021/02/05 11:42:43
[02/05/21 11:42:43 294] 40 MIN- ALL ACCOUNTED FOR
2021/02/05 11:44:15
[02/05/21 11:44:15 294] MT TABOR ENG MOVE UP TO FAIRCHILD
2021/02/05 11:46:13
[02/05/21 11:46:13 250] PARSIPPANY PD UPDATED ON MOVE UP
2021/02/05 11:48:15
[02/05/21 11:48:15 344] HEALTH DEPT NTFD FOR WATER DAMAGE
2021/02/05 11:51:00
[02/05/21 11:51:00 344] BLDG INSPECTOR FRITZ REUSS NTFD - WILL REACH OUT TO FD
2021/02/05 12:03:09
[02/05/21 12:03:09 294] 1 HOUR NO UPDATE
2021/02/05 12:05:31
[02/05/21 12:05:31 294] MORRIS PLAINS FD MEMBERS GOING TO WORK ON SPEEDWELL
2021/02/05 12:06:02
[02/05/21 12:06:02 304] CSI NTFD
2021/02/05 12:07:32
[02/05/21 12:07:32 304] V/M LEFT FOR DET GONCALVES ARSON DET
2021/02/05 12:22:54

[02/05/21 12:22:54 294] 1 HOUR 20 MIN- ALL ACCOUNTED FOR
 2021/02/05 12:31:20
 [02/05/21 12:31:20 304] SGT STANTON NTFD, WILL SEND A TEAM RIGHT OUT
 2021/02/05 12:32:16
 [02/05/21 12:32:16 304] DET PAPAMARKOS CONTACTED DET WEAVER FOR ARSON
 2021/02/05 12:32:54
 [02/05/21 12:32:54 294] CONSTRUCTION AND PROPERTY MAINT ON SCENE
 2021/02/05 12:33:28
 [02/05/21 12:33:28 304] SGT STANTON NTFD, WILL HAVE A TEAM RESPOND OUT TO ASSIST
 2021/02/05 12:43:21
 [02/05/21 12:43:21 304] S711 AND S620 SHUTTING DOWN CATTANO / WASHINGTON
 2021/02/05 12:43:30
 [02/05/21 12:43:30 294] 1 HOUR 40 MIN- ALL ACCOUNTED FOR
 2021/02/05 12:44:02
 [02/05/21 12:44:02 304] S732 S710 AT PROSPECT / CLINTON DIVERTING TRAFFIC
 2021/02/05 12:48:11
 [02/05/21 12:48:11 304] CSI ON LOCATION
 2021/02/05 13:02:42
 [02/05/21 13:02:42 294] 2 HOURS- ALL ACCOUNTED FOR
 2021/02/05 13:20:52
 [02/05/21 13:20:52 234] RED CROSS NTFD. 12 PEOPLE AFFECTED. AT LEAST 1 FAMILY OF 3 NEED HOUSING
 2021/02/05 13:22:43
 [02/05/21 13:22:43 294] 2 HOUR 20 MIN- NO UPDATE
 2021/02/05 14:02:57
 [02/05/21 14:02:57 294] 3 HOUR-FD CLEARING UP

NARRATIVE (2)

Narrative Title: n/a

Narrative Author: DeGroot, Thomas (Tex)

Narrative Date: 02/08/2021 10:26:04

Narrative Apparatus ID: n/a

Narrative:

Fire department responded for a commercial fire alarm, upon arrival members witness smoke coming from the roof area, towards the A side.

Morris County Communications Center was notified to strike an additional (2nd) alarm for a R.I.C. team and manpower.

Morristown Chief 1 established command and requested an additional alarm (3rd) for manpower to respond to the scene. Accountability was established. Safety Officer was assigned.

Engine 1 operator secured a water supply with L.D.H while engine 3's crew advanced a 1 3/4 hose line to the kitchen of a second floor apartment to locate, confine and extinguish the fire.

A second 1 3/4 hose line was advanced to the third floor to check for extension in the apartment directly above and the cock loft. Inspection holes were made in the walls and ceilings and any hot spots were extinguished.

Fire Department members conducted both a primary and secondary search of building with negative results.

Notifications were made to the Building Dept, Property Maintenance Dept., and Health Dept to respond to the scene.

Fire Department members began to vent the building using positive pressure fan and monitor the air quality with meters. The buildings utilities were shut off.

Once the fire was placed under control members began to deploy salvage tarps and T.I.C's were used to check for any hot spots on second, third floors and the cock loft.

Morristown Chief 1 transferred command to Morristown Captain 1.

Detectives from Morristown police and Morris County Sheriff dept were on location to conduct an investigation. The Red Cross was notified and responding for displaced tenants and the town Health officer for the food establishment.

After the building was checked and determined to be safe, tenants were allowed to retrieve personnel items.

Morristown Fire Department was cleared and command terminated, the scene was turned over to the property owner.

APPARATUS			
Fire Controlled Date / Time:		2/5/2021 2:10:47 PM	
Unit	F24CA	Unit	F24E1
Type:	Mobile command post	Type:	Engine
Use:	Suppression	Use:	Suppression
Response Mode:	Lights and Sirens	Response Mode:	()
# of People	1	# of People	1
Alarm	02 /05/2021 11:01:09	Alarm	02 /05/2021 11:01:09
Dispatched	02 /05/2021 11:02:17	Dispatched	02 /05/2021 11:02:17
Enroute	02 /05/2021 11:05:45	Enroute	02 /05/2021 11:03:49
Arrived	02 /05/2021 11:09:05	Arrived	02 /05/2021 11:05:30
Cancelled	-- / -- / -- -- : -- : --	Cancelled	-- / -- / -- -- : -- : --
Cleared Scene	02 /05/2021 14:10:39	Cleared Scene	02 /05/2021 13:47:16
In Quarters	-- / -- / -- -- : -- : --	In Quarters	-- / -- / -- -- : -- : --
In Service	02 /05/2021 14:10:39	In Service	02 /05/2021 13:47:16
Unit	F24E3	Unit	F24L1
Type:	Engine	Type:	Truck or aerial
Use:	Suppression	Use:	Suppression
Response Mode:	Lights and Sirens	Response Mode:	()
# of People	2	# of People	2
Alarm	02 /05/2021 11:01:09	Alarm	02 /05/2021 11:01:09
Dispatched	02 /05/2021 11:02:17	Dispatched	02 /05/2021 11:02:17
Enroute	02 /05/2021 11:04:22	Enroute	02 /05/2021 11:03:53
Arrived	02 /05/2021 11:05:57	Arrived	02 /05/2021 12:08:44
Cancelled	-- / -- / -- -- : -- : --	Cancelled	-- / -- / -- -- : -- : --
Cleared Scene	02 /05/2021 14:09:05	Cleared Scene	02 /05/2021 13:47:19
In Quarters	-- / -- / -- -- : -- : --	In Quarters	-- / -- / -- -- : -- : --
In Service	02 /05/2021 14:09:05	In Service	02 /05/2021 13:47:19
Unit	F24E7	Unit	24FM1
Type:	BLS unit	Type:	Chief officer car
Use:	EMS	Use:	Suppression
Response Mode:	()	Response Mode:	()
# of People	8	# of People	2
Alarm	02 /05/2021 11:01:09	Alarm	02 /05/2021 11:01:09
Dispatched	02 /05/2021 11:14:57	Dispatched	02 /05/2021 11:14:57
Enroute	02 /05/2021 11:14:57	Enroute	02 /05/2021 11:14:57
Arrived	02 /05/2021 11:17:08	Arrived	02 /05/2021 11:17:08
Cancelled	-- / -- / -- -- : -- : --	Cancelled	-- / -- / -- -- : -- : --
Cleared Scene	02 /05/2021 14:10:47	Cleared Scene	02 /05/2021 14:10:47
In Quarters	-- / -- / -- -- : -- : --	In Quarters	-- / -- / -- -- : -- : --
In Service	02 /05/2021 14:10:47	In Service	02 /05/2021 14:10:47
Unit	Car 1	Unit	P O V
Type:	Chief officer car	Type:	Privately owned vehicle
Use:	Suppression	Use:	Suppression
Response Mode:	()	Response Mode:	No Lights or Sirens
# of People	1	# of People	11
Alarm	02 /05/2021 11:01:09	Alarm	02 /05/2021 11:01:09
Dispatched	02 /05/2021 11:14:57	Dispatched	02 /05/2021 11:14:57
Enroute	02 /05/2021 11:14:57	Enroute	02 /05/2021 11:14:57
Arrived	02 /05/2021 11:17:08	Arrived	02 /05/2021 11:17:08
Cancelled	-- / -- / -- -- : -- : --	Cancelled	-- / -- / -- -- : -- : --
Cleared Scene	02 /05/2021 14:10:47	Cleared Scene	02 /05/2021 14:10:47
In Quarters	-- / -- / -- -- : -- : --	In Quarters	-- / -- / -- -- : -- : --
In Service	02 /05/2021 14:10:47	In Service	02 /05/2021 14:10:47
Number Of People not on apparatus: 0			

FIRE			
Acres Burned	None or Less Than One	Acres Burn From Wildland Form	False
Area Of Fire Origin	Cooking area, kitchen	Heat Source	Heat from powered equipment, other
Item First Ignited	Undetermined	Fire Is Confined To Object Of Origin	
Type Of Material	Multiple types of material	Cause Of Ignition	Unintentional
Factor Contributing To Ignition	Undetermined		
Human Factors Contributing	None		
Equipment Involved In Ignition Flag	True	Equipment Involved	Stove, heating
Equipment Power Source	Natural gas or other lighter-than-air gas	Equipment Portability	Stationary

STRUCTURE FIRE			
Structure Type	Enclosed building	Building Status	Undetermined
# Of Stories At Above Grade	3	# Of Stories Below Grade	1
Square Feet		Length	100
Width	50	Floor Of Origin	02
Fire Spread	Confined to building of origin		
Minor Damage	0	Significant Damage	0
Heavy Damage	0	Extreme Damage	0
Item Contributing Most To Spread	Undetermined	Type Of Material Contributing Most To Spread	
Presence Of Detectors	Present	Type Of Detection System	Smoke
Detector Power Supply	Undetermined	Detector Operation	Detector operated
Detector Effectiveness	Detector alerted occupants, occupants responded	Detector Failure Reason	

PEOPLE -- PERSON 1			
Telephone Number	8888698220	Involvement	Caller
Name	DIVERSIFIED CENTRAL STATI	Date of Birth	
Address			