

CERTIFICATION IN LIEU OF OATH

I. OWNER SECTION (to be completed if the applicant is the owner in fee)

I hereby certify that I am the owner in fee of the property listed on Page 1.

Mark the following applicable boxes:

- A. ☐ I further certify that a new home (private residence) will be constructed on this property for my own use and occupancy. This dwelling is to be occupied by myself and is not to be used for any purpose other than single family residential use. I attest that all construction, plumbing, or electrical work will be done, in whole or in part, by me or by subcontractors under my supervision, in accordance with all applicable laws; and, I further acknowledge that said new home is not covered under the New Home Warranty and Builders Registration Act (N.J.S.A. 46:3B-1 et seq.) and that such fact shall be disclosed to any person purchasing this property within ten years of the date of issuance of a certificate of occupancy.

I UNDERSTAND THAT IN MARKING BOX A, I ACKNOWLEDGE THAT I AM ASSUMING RESPONSIBILITY FOR THE WORK DONE ON SAID PROPERTY, THE CONDITION OF THE PROPERTY PRIOR TO, DURING, AND AFTER ANY WORK PERFORMED, AND FOR THE PERFORMANCE OF THE SUBCONTRACTORS I HIRE, EMPLOY, OR OTHERWISE CONTRACT OR WITH WHOM I MAKE AGREEMENTS TO PERFORM WORK. I AM VOLUNTARILY AND KNOWINGLY ASSUMING THIS RESPONSIBILITY.

- B. ☐ I further certify the following as required by the New Jersey Uniform Construction Code, N.J.A.C. 5:23-2.15(e)1.vii:

I personally prepared the plans submitted for: 1) the new home referred to in A.; or, 2) an addition, alteration, renovation, or repair to an existing single family residence owned and occupied by myself and located on the property listed on Page 1; or, 3) a new structure that will be physically separate from, but that will be deemed part of, an existing single family residence that is owned and occupied by myself and located on the property listed on Page 1.

- C. ☐ I further certify that I will perform or supervise the following work:

C.1. ☐ Building C.2. ☐ Fire Protection

I further certify that I will perform the following work:

C.3. ☐ Electrical C.4. ☐ Plumbing

- D. ☐ I agree to advise all contractors on this project that they are required to be registered with the New Jersey Division of Taxation and to comply with all New Jersey tax laws.

I further certify the following as required by the Uniform Construction Code, N.J.A.C. 5:23-2.15(a)5: All required State, county, and local prior approvals have been given, including such certification as the construction official may require.

I understand that if any of the above statements are willfully false, I am subject to punishment.

Signature _____ Date _____

II. AGENT SECTION (to be completed if the applicant is not the owner in fee)

I hereby certify the following as required by the Uniform Construction Code, N.J.A.C. 5:32-2.15(d): the proposed work is authorized by the owner in fee; and I have been authorized by the owner in fee to make this application as his agent.

I further certify the following as required by the Uniform Construction Code, N.J.A.C. 5:23-2.15(a)5: All required State, county, and local prior approvals have been given, including such certification as the construction official may require.

I agree to advise all contractors on this project that they are required to be registered with the New Jersey Division of Taxation and to comply with all New Jersey tax laws.

I understand that if any of the above statements are willfully false, I am subject to punishment.

☒ Check if contractor.

Agent Name Maureen Swint - permit coordinator for Anchor Sign, Inc.

Address 2200 Discher Avenue
Charleston, SC 29405

Telephone (843) 576-3208

Signature [Signature]

III. ☐ LEAD HAZARD ABATEMENT: Include Homeowner or Building Owner Affidavit as per N.J.A.C. 5:17.



Brick Township
401 Chambersbridge Rd
Brick, NJ 08723

Date Issued 06/22/2010
Control Number C-10-000879
Permit Number 10-0951
Permit Issue Date 05/03/2010
Certificate Number 10-0951

Certificate

Construction Code Division

(Certificate of Approval)

Identification

Work Site Location: 744 ROUTE 70 Brick Township, NJ Block: 701 Lot: 7 Qual: _____
Owner in Fee: BRICKTOWN VF LLC %VORNADO REALTY
Owner Address: 210 ROUTE 4 EAST PARAMUS NJ 07652
Telephone: (201) 587-1000
Contractor ANCHOR SIGN INC
Address 3300 DISCHER AVENUE CHARLESTON SC 07652
Telephone: (800) 213-3331 Fax: (843) 576-7208
License Number or Builders Registration Number: _____ Federal Emp. Number: 57-0933824

Home Warranty Number: _____

Type of Warranty Plan: ☐ State ☐ Private

Use Group: U Construction Classification: _____

Maximum Live Load: 0 Maximum Occupancy Load: 0

Description of Work/Use: SIGN INSTALLATION INSTALL 2 WALL SIGNS FOR FIVE BELOW.
WAS LANE BRYANT STORE NOW TO BE FIVE BELOW STORE.

Certificate Comments:

☐ **Certificate of Occupancy**

This serves notice that said building or structure has been constructed in accordance with the New Jersey Uniform Construction Code and is approved for occupancy.

☒ **Certificate of Approval**

This serves notice that the work completed has been constructed or installed in accordance with the New Jersey Uniform Construction Code and is approved. If the permit was issued for minor work, this certificate was based upon what was visible at the time of inspection.

☐ **Certificate of Continued Occupancy**

This serves notice that based on a general inspection of the visible parts of the building there are no imminent hazards and the building is approved for continued occupancy.

☐ **Temporary Certificate of Compliance**

The following conditions must be met no later than or the owner will be subject to fine or order to vacate:
This certificate has an expiration date of:

Conditions to be met:

☐ **Certificate of Clearance - Lead Abatement 5:17**

This serves notice that based on written certification, lead abatement was performed as per NJAC5:17 to the following extent.

- ☐ Total removal of lead-based paint hazards in scope of work
☐ Partial or limited time period (years); see file

☐ **Certificate of Clearance - Asbestos Abatement**

This serves notice that based on written certification, asbestos abatement was performed to the following extent.

- ☐ Total removal of asbestos hazards in scope of work
☐ Partial or limited time period (years); see file

☐ **Certificate of Compliance**

This serves notice that said potentially hazardous equipment has been installed and/or maintained in accordance with the New Jersey Uniform Construction Code and is approved for use until

☐ **Temporary Certificate of Occupancy**

The following conditions must be met no later than:
or the owner will be subject to fine or order to vacate:
This certificate has an expiration date of:

Conditions to be met:

Construction Official

Fee: \$0.00

Check Number: _____

Collected By: _____



CONSTRUCTION PERMIT

Date Issued

Control #

Permit #

C-10-000879

5/3/10
10-0957

IDENTIFICATION Block: 701 Lot: 7 Qualifier
Work Site Location: 744 ROUTE 70 Brick Township, NJ Contractor: ANCHOR SIGN INC
Address: 3300 DISCHER AVENUE CHARLESTON SC 07652
Owner in Fee: BRICKTOWN VF LLC %VORNADO REALTY
210 ROUTE 4 EAST PARAMUS NJ 07652 Telephone: (800) 213-3331
Telephone: (201) 587-1000 Lic. No. or Bldrs. Reg. No.
Federal Employee No. 57-0933824

Is hereby granted permission to perform the following work:

- ☒ BUILDING ☐ PLUMBING ☐ LEAD HAZARD ABATEMENT
☒ ELECTRICAL ☐ FIRE PROTECTION ☐ DEMOLITION
☐ ELEVATOR DEVICES ☐ ASBESTOS ABATEMENT (Subchapter 8 only) ☐ OTHER

DESCRIPTION OF WORK:

SIGN INSTALLATION INSTALL 2 WALL SIGNS FOR FIVE BELOW.
WAS LANE BRYANT STORE NOW TO BE FIVE BELOW STORE.

Note: If construction does not commence within one (1) year of date of issuance, or if construction ceases for a period of six (6) months, this permit is void.

Estimated Cost of Work \$4,450

Construction Official

Date

4-23-10

U.C.C. F170
equiv (rev 8/03)

1 WHITE - INSPECTOR

2 CANARY - OFFICE

3 PINK - TAX ASSESSOR

4 GOLD - APPLICANT

PAYMENTS (Office Use Only)

Building	\$81
Electrical	\$40
Plumbing	\$0
Fire Protection	\$0
Elevator Devices	\$0
Other	\$0.00
DCA Training Fee	\$8
CO Fee	
Other	\$0
Total	\$129
Check No.	0111683
Cash	\$0
Credit	\$0
Collected By	

REQUIRED INSPECTIONS

Construction work must be inspected in accordance with the State Uniform Construction Code Regulations N.J.A.C. 5:23-2.18. This agency will carry out such periodic inspections during the progress of work as are necessary to insure that the work installed conforms with the requirements of the Uniform Construction Code.

The owner or other responsible person in charge of work must notify this agency when work is ready for any required inspections specified below. Requests for inspections must be made at least 24 hours prior to the time the inspection is desired. Inspections will be performed within three business days of the time for which they are requested. The work must not proceed in a manner which will preclude the inspection until it has been made and approval granted.

- ☐ Required inspections for all subcodes for one- and two-family dwellings are as follows:

- The bottom of footing trenches before placement of footings, except that in cases of pile foundations, inspections shall be made in accordance with the requirements of the building subcode.
- Foundations and all walls up to grade level prior to back filling.
- All structural framing, connections, wall and roof sheathing and insulation; electrical rough wiring, panel and service installation; rough plumbing. The framing inspection shall take place after the rough electrical and plumbing inspections and after the installation of the heating, ventilation and /or air conditioning duct system. The insulation inspection shall be performed after all other subcode rough inspections and prior to the installation of any interior finish material.
- Installation of all finished materials, sealings of exterior joints, plumbing piping, trim and fixtures; electrical wiring, devices and fixtures; mechanical systems equipment.

Additional required inspections for all subcodes of construction, for other than one- and two-family dwellings, are fire suppression systems, heat producing devices and Barrier Free subcode accessibility, if applicable.

- ☐ Required special inspections. The applicant by accepting the permit will be deemed to have consented to these requirements:

- ☐ A final inspection is required for each applicable subcode area before a final Certificate of Occupancy or Approval may be issued. The final inspections include the installation of all interior and exterior finish materials, sealing of exterior joints, mechanical system and other required equipment; electrical wiring, devices and fixtures; plumbing pipes, trim and fixtures; tests required by any provision of the adopted subcodes, Barrier Free accessibility, if applicable; and verification of compliance with NJAC 5:23-3.5, "Posting structures".

- ☐ A complete copy of released plans must be kept on the job site.

If you do not understand any of this information, please ask.



BUILDING SUBCODE
TECHNICAL SECTION



ORIGINAL

Date Received
Control #
Date Issued
Permit #

10-0951
5/3/10

A. IDENTIFICATION—APPLICANT: COMPLETE ALL APPLICABLE INFORMATION. WHEN CHANGING CONTRACTORS, NOTIFY THIS OFFICE. CALL UTILITY DIG NO: 1-800-272-1000.

Block 701 Lot 7 Qualification Code
Work Site Location 666 State Road Route 70, Brick, NJ 08723 (Bricktown Plaza)

Owner in Fee: Bricktown VF LLC c/o Vornado Realty
Tel. (201) 587-1000 e-mail pnatale@vno.com
Address 210 Route 4 East Paramus, NJ 07652
Contractor: Anchor Sign, Inc. Tel. (800) 213-3331
Address 2200 Discher Avenue e-mail mswint@anchorsign.com
Charleston, SC 29405

Contractor License No. or Builder Registration No. n/a Exp. Date _____
Home Improvement Contractor Registration No. or Exemption Reason (if applicable): _____
Federal Emp. ID No. 57-0933824 FAX: (843) 576-7208

JOB SUMMARY (Office Use Only)

PLAN REVIEW	Date	Initial	INSPECTIONS	Type	Dates (Month/Day)	Failure	Approval	Initial
☒ No Plans Required								
☒ All	<u>4/22/10</u>	<u>msw</u>		Footings				
				Footings/Bonding				
				Foundation				
				Slab				
				Frame				
				Truss Sys./Bracing				
				Barrier-Free				
Joint Plan Review Required:								
				Insulation				
				Finishes-Base Layer				
				Finishes-Final				
				Energy				
				Mechanical				
				TCO				
				Other				
				Final				
Barrier-Free								
SUBCODE APPROVAL for CERTIFICATE								
				CO				
				CCO				
				Other				
				Final				
Approved by: <u>msw</u>								
SUBCODE APPROVAL for PERMIT								
				Plumb				
				Fire				
				Elevator				
				Insulation				
				Finishes-Base Layer				
				Finishes-Final				
				Energy				
				Mechanical				
				TCO				
				Other				
				Final				
Barrier-Free								
Approved by: <u>msw</u>								

B. BUILDING CHARACTERISTICS

Use Group	Present	Proposed	Constr. Class	Present	Proposed
No. of Stories			If Industrialized Building:		
Height of Structure			State Approved		HUD
Area — Largest Floor			Est. Cost of Building Work:		
New Bldg. Area/All Floors			1. New Bldg.	\$ <u>3,950</u>	
Volume of New Structure			2. Rehabilitation	\$ <u>n/a</u>	
Max. Live Load			3. Total (1+2)	\$ <u>3,950</u>	
Max. Occupancy Load					

U.C.C. F110 (rev. 11/09)
Internet version

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner of record and am authorized to make this application.

Sign here: Maureen Swint

Print name here: Maureen Swint - agent for Anchor Sign, Inc.

D. TECHNICAL SITE DATA

DESCRIPTION OF WORK

Install (2) wall signs for Five Below per the attached plans.

COMMERCIAL

FEE (Office Use Only)
\$

- TYPE OF WORK:
- ☐ New Building
 - ☐ Addition
 - ☐ Rehabilitation
 - ☐ Roofing
 - ☐ Siding
 - ☐ Fence
 - ☒ Sign 80.85 Sq. Ft.
 - ☐ Pool
 - ☐ Retaining Wall 80.85 Sq. Ft.
 - ☐ Asbestos Abatement Subchapter 8
 - ☐ Lead Haz. Abatement NJAC 5:17
 - ☐ Radon Remediation
 - ☐ Other
 - ☐ Demolition

Administrative Surcharge \$
Minimum Fee \$
State Permit Surcharge Fee \$
TOTAL FEE \$

Applicant: When submitting this form to your Local Construction Code Enforcement Office, please provide one original plus three photocopies.



ELECTRICAL SUBCODE -TECHNICAL SECTION



A. IDENTIFICATION—APPLICANT: COMPLETE ALL APPLICABLE INFORMATION. WHEN CHANGING CONTRACTORS, NOTIFY THIS OFFICE. CALL UTILITY DIG NO: 1-800-272-1000.

Block **701** Lot **7** Qualification Code **666 State Road Route 70 (Bricktown Plaza), Brick, NJ 08723**

Work Site Location **210**

Owner in Fee: **Bricktown VF LLC c/o Vornado Realty**

Tel. (**201**) **587-1000** e-mail **pnatale@vno.com**

Address **210 Route 4 East** **Paramus, NJ** **07652**

Contractor: **Engr. Elec. Co. Inc.** Zip code **07652**

Address **4130 Wall St. Ave** Tel. (**201**) **681-1115**

Contractor License No. **138434** Exp. Date **3/12**

Home Improvement Contractor Registration No. or Exemption Reason (if applicable):

Federal Emp. ID No. **20-0088355** FAX: ()

B. ELECTRICAL CHARACTERISTICS

Use Group Present Proposed

[] Pole/Pad # [] Temporary [] Other

Building Occupied as Utility Co.

Est. Cost of Elec. Work \$ **500.00**

JOB SUMMARY (Office Use Only)		INSTRUCTIONS		Dates (Month/Day)	
PLAN REVIEW		Type	Failure	Approval	Initial
[] No Plans Required		Rough			
[] Partial - Underslab Utilities Approved		Barrier-Free			
Date	Approved by	Trench			
[] Electric Plans Approved		Temp. Serv.			
Date	Approved by	Constr. Serv.			
Joint Plan Review Required		TCO			
[] Bldg. [] Plumb. [] Fire [] Elev.		Other			
SUBCODE APPROVAL for PERMIT		Service			
Date: 4-13-10		Final			
Approved by: ST		Barrier-Free			
SUBCODE APPROVAL for CERTIFICATE		Temp. Cut-in-Card Date Issued			
[] CO [] CCO [] CA		Final Cut-in-Card Date Issued			
Date: 6-10-10		Annual Pool Inspection			
Approved by: ST		Date of Grounding and Bonding			
		Certification			

U.C.C. F120 (rev. 11/09) Applicant: When submitting this form to your Local Construction Code Enforcement Office, please provide one internet version original plus three photocopies.

Date Received
Control #
Date Issued
Permit #

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner of record and am authorized to make this application and perform the work listed on this application.

Applicant sign/Contractor sign and seal here:

Print name here: **Thomas T. Crader**

[] Licensed Elec. Contractor [] Certifd Landscape Irrigation Contr [] Exempt Applicant

D. TECHNICAL SITE DATA

DESCRIPTION OF WORK:

Connect (2) Five Below wall signs to the existing electrical circuit on the building

QTY. SIZE ITEMS

Lighting Fixtures

Receptacles

Switches

Detectors

Light Poles

Motors—Fract. HP

Emergency & Exit Lights

Communications Points

Alarm Devices/F.A.C. Panel

TOTAL NUMBERS

Pool Permit/with UW Lights

Storable Pool/Spa/Hot Tub

KW Elec. Range/Receptacle

KW Oven/Surface Unit

KW Elec. Water Heater

KW Elec. Dryer/Receptacle

KW Dishwasher

HP Garbage Disposal

KW Central A/C Unit

HP/KW Space Heater/Air Handler

KW Baseboard Heat

HP Motors 1/+ HP

KW Transformer/Generator

AMP Service

AMP Subpanels

AMP Motor Control Center

KW Elec. Sign/Outline Light

Sign Connections

2

Administrative Surcharge \$

Minimum Fee \$

State Permit Surcharge Fee \$

TOTAL FEE \$

COMMERCIAL

\$

FEE (Office Use Only)



ELECTRICAL SUBCODE TECHNICAL SECTION



A. IDENTIFICATION—APPLICANT: COMPLETE ALL APPLICABLE INFORMATION WHEN CHANGING CONTRACTORS. NOTIFY THIS OFFICE. CALL UTILITY DIG NO: 1-800-272-1000.

Block 701 Lot 7 Qualification Code _____
Work Site Location 744 RT. 70
Owner in Fee: BRICKTOWN VF LLC / VORONADO REALTY
Tel. () e-mail _____

Address _____
Contractor: R + K VOICE + DATA, INC. Municipality BRICKTOWN Tel. (215) 565-0313
Address 234 W. BROAD ST e-mail RAY@RVOICEANDDATA.COM
Contractor License No. 1260 Exp. Date _____
Home Improvement Contractor Registration No. or Exemption Reason (if applicable): _____
Federal Emp. ID No. 23-3069946 FAX: (215) 565-0313

B. ELECTRICAL CHARACTERISTICS

Use Group Present _____ Proposed _____
() Pole/Pad # _____ () Temporary () Other _____
Building Occupied as RETAIL Utility Co. _____
Est. Cost of Elec. Work \$ 2000.00

JOB SUMMARY (Office Use Only)

PLAN REVIEW		INSPECTIONS		Dates (Month/Day)	
☒ No Plans Required		Type:	Failure	Approval	Initial
☐ Partial - Underslab Utilities Approved		Rough			
Date: _____	Approved by: _____	Barrier-Free			
☐ Electric Plans Approved		Trench			
Date: _____	Approved by: _____	Temp. Serv.			
Joint Plan Review Required:		Constr. Serv.			
() Bldg. () Plumb. () Fire. () Elev.		TCO			
SUBCODE APPROVAL FOR PERMIT		Other			
Date: <u>6-7-10</u>	Approved by: <u>97</u>	Service			
SUBCODE APPROVAL FOR CERTIFICATE		Final			
() CO () CCO () CA		Barrier-Free			
Date: <u>6-10-10</u>	Approved by: <u>97</u>	Temp. Cut-in-Card Date Issued			
Date of Grounding and Bonding		Final Cut-in-Card Date Issued			
Certification		Annual Pool Inspection			

U.C.C. F120 (rev. 11/05)
Internet version
Applicant: When submitting this form to your Local Construction Code Enforcement Office please provide one original plus three photocopies.

06/10/10
Date Received
Control #
Date Issued
Permit # 10-1059-0

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner of record and am authorized to make this application and perform the work listed on this application.

Applicant sign/Contractor sign and seal here:

Print name here: Ray Miller

() Licensed Elec. Contractor () Certifd Landscape Irrigation Contr (X) Exempt Applicant

D. TECHNICAL SITE DATA

DESCRIPTION OF WORK:

LOW VOLTAGE FOR VOICE, DATA, AUDIO

FEE (Office Use Only)

QTY. SIZE ITEMS

Lighting Fixtures

Receptacles

Switches

Detectors

Light Poles

Motors—Fract. HP

Emergency & Exit Lights

Communications Points

Alarm Devices/F.A.C. Panel

1/3

TOTAL NUMBERS

Pool Permit/With UW Lights

Storable Pool/Spa/Hot Tub

KW Elec. Range/Receptacle

KW Oven/Surface Unit

KW Elec. Water Heater

KW Elec. Dryer/Receptacle

KW Dishwasher

HP Garbage Disposal

KW Central A/C Unit

HP/KW Space Heater/Air Handler

KW Baseboard Heat

HP Motors 1/4 HP

KW Transformer/Generator

AMP Service

AMP Subpanels

AMP Motor Control Center

KW Elec. Sign/Outline Light

Administrative Surcharge \$

Minimum Fee \$

State Permit Surcharge Fee \$

TOTAL FEE \$



ELECTRICAL SUBCODE TECHNICAL SECTION



A. IDENTIFICATION—APPLICANT: COMPLETE ALL APPLICABLE INFORMATION. WHEN CHANGING CONTRACTORS, NOTIFY THIS OFFICE. CALL UTILITY DIG NO: 1-800-272-1000.

Block 101 Lot 7 Qualification Code _____
Work Site Location 744 Route 70
Owner in Fee BRICK TOWN VILLAGE VORNADO
Address 210 ROUTE 4 EAST
PARANUS, NJ 07652
Tel () _____
Contractor Heb Soto
Address 359 WAGNER AVE. RENTHAMBER NJ.
Tel (732) 261-5183 FAX () _____
Contractor License No. 348A0082900
Federal Emp. No. _____

B. ELECTRICAL CHARACTERISTICS

Use Group _____ Present _____ Proposed _____
☐ Pole/Pad # _____ ☐ Temporary ☐ Other _____
Building Occupied as _____ Utility Co. _____
Est. Cost of Elec. Work \$ 750.00

JOB SUMMARY (Office Use Only)

PLAN REVIEW		INSPECTIONS		DATES (Month/Day)	
Date	Initial	Type	Failure	Approval	Initial
☒ No Plans Required	<u>6/5/09</u>	Rough	_____	_____	_____
Joint Plan Review Required:		Barrier-Free	_____	_____	_____
☐ Building	☐ Plumbing	Trench	_____	_____	_____
☐ Fire	☐ Elevator	Temp. Serv.	_____	_____	_____
☐ Elec. Plans Approved	_____	Constr. Serv.	_____	_____	_____
Date: _____	_____	TCO	_____	_____	_____
Approved by: _____	_____	Other	_____	_____	_____
SUBCODE APPROVAL		Service	_____	_____	_____
☐ CO	☐ CCO	Final	_____	_____	_____
Date: <u>6-7-10</u>		Barrier-Free	_____	_____	_____
Approved by: <u>ST</u>	_____	Temp. Cut-in-Card Date Issued	_____	_____	_____
_____		Final Cut-in-Card Date Issued	_____	_____	_____
_____		Annual Pool Inspection	_____	_____	_____
_____		Date of Grounding and Bonding	_____	_____	_____
_____		Certification	_____	_____	_____

FIVE BELOW

update
Date Received Control #
Date Issued Permit #

10-1059+D
6/8/10

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner of record and am authorized to make this application and perform the work listed on this application.

Applicant's Signature/Contractor's Seal and Signature
[] Licensed Elec. Contractor [] Certifd Landscape Irrigation Contr'r [] Exempt Applicant

D. TECHNICAL SITE DATA

QTY.	SIZE	ITEMS
_____	_____	Lighting Fixtures
_____	_____	Receptacles
_____	_____	Switches
_____	_____	Detectors
_____	_____	Light Poles
_____	_____	Motors—Fract. HP
_____	_____	Emergency & Exit Lights
_____	_____	Communications Points
_____	_____	Alarm Devices/F.A.C. Panel
_____	_____	TOTAL NUMBERS
_____	_____	Pool Permit/with UW Lights
_____	_____	Storable Pool/Spa/Hot Tub
_____	_____	KW Elec. Range/Receptacle
_____	_____	KW Oven/Surface Unit
_____	_____	KW Elec. Water Heater
_____	_____	KW Elec. Dryer/Receptacle
_____	_____	KW Dishwasher
_____	_____	HP Garbage Disposal
_____	_____	KW Central A/C Unit
_____	_____	HP/KW Space Heater/Air Handler
_____	_____	KW Baseboard Heat
_____	_____	HP Motors 1/+ HP
_____	_____	KW Transformer/Generator
_____	_____	AMP Service
_____	_____	AMP Subpanels
_____	_____	AMP Motor Control Center
_____	_____	KW Elec. Sign/Outline Light

FEE (Office Use Only)

Administrative Surcharge \$
Minimum Fee \$
State Permit Surcharge Fee \$
TOTAL FEE \$



Receipt

Payment Date 05/03/2010

Transaction # PMT-10-01886

Receipt #

Issued To Brickatown VF LLC %Vornado Realty

Description Sign Five Below

Date Printed 05/03/2010

Check Number 0117683

Cash \$0.00

Check \$50.00

Charge \$0.00

Total Paid \$50.00

05/03/10 9:28AM 001552#7541

***01 SERV.001

#01886

ZPA

CHECK

\$50.00

\$50.00



BUILDING SUBCODE TECHNICAL SECTION



A. IDENTIFICATION—APPLICANT: COMPLETE ALL APPLICABLE INFORMATION. WHEN CHANGING CONTRACTORS, NOTIFY THIS OFFICE. CALL UTILITY DIG NO: 1-800-272-1000.

Block 701 Lot 7 Qualification Code
Work Site Location 666 State Road Route 70, Brick, NJ 08723 (Bricktown Plaza)

Owner in Fee: Bricktown VF LLC c/o Vornado Realty
Tel. (201) 587-1000 e-mail pnatale@vno.com
Address 210 Route 4 East Paramus, NJ 07652
street municipality zip code
Contractor: Anchor Sign, Inc. Tel. (800) 213-3331
Address 2200 Discher Avenue e-mail mswint@anchorsign.com
Charleston, SC 29405

Contractor License No. or Builder Registration No. n/a Exp. Date _____
Home Improvement Contractor Registration No. or Exemption Reason (if applicable): _____
Federal Emp. ID No. 57-0933824 FAX: (843) 576-7208

JOB SUMMARY (Office Use Only)					
PLAN REVIEW		INSPECTIONS		Dates (Month/Day)	
Date	Initial	Type:	Failure	Approval	Initial
☐ No Plans Required					
☐ All		Footings			
☐ Footings/Foundations		Footings Bonding			
☐ Structural/Framework		Foundation			
☐ Exterior		Slab			
☐ Interior		Frame			
		Truss Sys./Bracing			
		Barrier-Free			
Joint Plan Review Required:					
☐ Elec. [] Plumb. [] Fire [] Elevator		Insulation			
SUBCODE APPROVAL for PERMIT					
Date:		Finishes -Base Layer			
Approved by:		Finishes -Final			
SUBCODE APPROVAL for CERTIFICATE					
[] CO [] CCO [] CA		Energy			
Date:		Mechanical			
Approved by:		TCO			
		Other			
		Final			
		Barrier-Free			

B. BUILDING CHARACTERISTICS	
Use Group Present _____	Proposed _____
No. of Stories _____	Constr. Class Present _____
Height of Structure _____ ft.	If Industrialized Building: _____
Area — Largest Floor _____ sq. ft.	State Approved _____ HUD _____
New Bldg. Area/All Floors _____ sq. ft.	Sign _____
Volume of New Structure _____ cu. ft.	Est. Cost of Bldg-Work: \$ <u>3,950</u>
Max. Live Load _____	1. New Bldg. \$ <u>3,950</u>
Max. Occupancy Load _____	2. Rehabilitation \$ <u>n/a</u>
	3. Total (1 + 2) \$ <u>3,950</u>

Date Received 10-0951
Control # 5/3/10
Date Issued _____
Permit # _____

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner of record and am authorized to make this application.

Sign here: Maureen Swint

Print name here: Maureen Swint - agent for Anchor Sign, Inc.

D. TECHNICAL SITE DATA

DESCRIPTION OF WORK

Install (2) wall signs for Five Below per the attached plans.

TYPE OF WORK:

- ☐ New Building
- ☐ Addition
- ☐ Rehabilitation
- ☐ Roofing
- ☐ Siding
- ☒ Fence _____ Height (exceeds 6') _____ Sq. Ft.
- ☒ Sign 80.85 _____ Sq. Ft.
- ☐ Pool
- ☐ Retaining Wall _____ Sq. Ft.
- ☐ Asbestos Abatement Subchapter 8
- ☐ Lead Haz. Abatement NJAC 5:17
- ☐ Radon Remediation
- ☐ Other _____
- ☐ Demolition

FEE (Office Use Only)
\$ _____

Administrative Surcharge \$ _____
Minimum Fee \$ _____
State Permit Surcharge Fee \$ _____
TOTAL FEE \$ _____



BUILDING SUBCODE TECHNICAL SECTION



A. IDENTIFICATION—APPLICANT: COMPLETE ALL APPLICABLE INFORMATION. WHEN CHANGING CONTRACTORS, NOTIFY THIS OFFICE. CALL UTILITY DIG NO: 1-800-272-1000.

Block **701** Lot **7** Qualification Code
Work Site Location **666 State Road Route 70, Brick, NJ 08723 (Bricktown Plaza)**

Owner in Fee: **Bricktown VF LLC c/o Vornado Realty**
Tel. (**201**) **587-1000** e-mail **pnatale@vno.com**
Address **210 Route 4 East** **Paramus, NJ** **07652**
Contractor: **Anchor Sign, Inc.** zip code
Address **2200 Discher Avenue** Tel. (**800**) **213-3331**
Charleston, SC 29405 e-mail **mswint@anchorsign.com**

Contractor License No. or Builder Registration No. **n/a** Exp. Date
Home Improvement Contractor Registration No. or Exemption Reason (if applicable):
Federal Emp. ID No. **57-0933824** FAX: (**843**) **576-7208**

JOB SUMMARY (Office Use Only)			
PLAN REVIEW	Date	Initial	INSPECTIONS
☐ No Plans Required			Type:
☐ All			Footings
☐ Footings/Foundations			Footings Bonding
☐ Structural/Framework			Foundation
☐ Exterior			Slab
☐ Interior			Frame
			Truss Sys./Bracing
			Barrier-Free
Joint Plan Review Required:			
☐ Elec. ☐ Plumb. ☐ Fire ☐ Elevator			Insulation
SUBCODE APPROVAL for PERMIT			
Date:			
Approved by:			
SUBCODE APPROVAL for CERTIFICATE			
☐ CO ☐ CCO ☐ CA			
Date:			
Approved by:			

B. BUILDING CHARACTERISTICS	
Use Group Present	Proposed
No. of Stories	
Height of Structure	ft.
Area — Largest Floor	sq. ft.
New Bldg. Area/All Floors	sq. ft.
Volume of New Structure	cu. ft.
Max. Live Load	
Max. Occupancy Load	
Constr. Class Present	Proposed
If Industrialized Building:	
State Approved	HUD
Sign	
Est. Cost of Bldg-Work:	
1. New Bldg.	\$ 3,950
2. Rehabilitation	\$ n/a
3. Total (1 + 2)	\$ 3,950

U.C.C. F110 (rev. 11/09)
Internet version

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner of record and am authorized to make this application.

Sign here:

Print name here: **Maureen Swint - agent for Anchor Sign, Inc.**

D. TECHNICAL SITE DATA

DESCRIPTION OF WORK

Install (2) wall signs for Five Below per the attached plans.


TYPE OF WORK:

- ☐ New Building
- ☐ Addition
- ☐ Rehabilitation
- ☐ Roofing
- ☐ Siding
- ☒ Fence **80.85** Height (exceeds 6')
- ☒ Sign **80.85** Sq. Ft.
- ☐ Pool
- ☐ Retaining Wall _____ Sq. Ft.
- ☐ Asbestos Abatement Subchapter 8
- ☐ Lead Haz. Abatement NJAC 5:17
- ☐ Radon Remediation
- ☐ Other _____
- ☐ Demolition


FEE (Office Use Only)
\$ _____

Administrative Surcharge \$ _____
Minimum Fee \$ _____
State Permit Surcharge Fee \$ _____
TOTAL FEE \$ _____

Applicant: When submitting this form to your Local Construction Code Enforcement Office, please provide one original plus three photocopies.



ELECTRICAL SUBCODE TECHNICAL SECTION



A. IDENTIFICATION—APPLICANT: COMPLETE ALL APPLICABLE INFORMATION. WHEN CHANGING CONTRACTORS, NOTIFY THIS OFFICE. CALL UTILITY DIG NO: 1-800-272-1000.

Block **701** Lot **7** Qualification Code **701**
Work Site Location **666 State Road Route 70 (Bricktown Plaza), Brick, NJ 08723**

Owner in Fee: **Bricktown VF LLC c/o Vornado Realty**
Tel. (**201**) **587-1000** e-mail **pnatale@vno.com**
Address **210 Route 4 East** **Paramus, NJ** **07652**
Contractor: **Empire Electric Co Inc** street municipality zip code
Address **4130 W. 18th Ave** Tel. (**732**) **681 1115**
Wall NJ 07727 e-mail _____
Contractor License No. **13843A** Exp. Date **3/12**
Home Improvement Contractor Registration No. or Exemption Reason (if applicable): _____
Federal Emp. ID No. **20 0088355** FAX: () _____

B. ELECTRICAL CHARACTERISTICS

Use Group Present _____ Proposed _____
[] Pole/Pad # _____ [] Temporary [] Other _____
Building Occupied as _____ Utility Co. _____
Est. Cost of Elec. Work \$ **500.00**

JOB SUMMARY (Office Use Only)		INSPECTIONS		Dates (Month/Day)	
PLAN REVIEW	Type	Rough	Barrier-Free	Failure	Approval
[] No Plans Required					Initial
[] Partial - Underslab Utilities Approved					
Date _____	Approved by _____	Trench			
[] Electric Plans Approved		Temp. Serv.			
Date _____	Approved by _____	Constr. Serv.			
Joint Plan Review Required		TCO			
[] Bldg. [] Plumb. [] Fire [] Elev.		Other			
SUBCODE APPROVAL for PERMIT		Service Final			
Date 4-13-10		Barrier-Free			
Approved by JS		Temp. Cut-in-Card Date Issued			
SUBCODE APPROVAL for CERTIFICATE		Final Cut-in-Card Date Issued			
[] CO [] CCO [] CA		Annual Pool Inspection			
Date _____		Date of Grounding and Bonding			
Approved by _____		Certification			

Date Received _____
Control # _____
Date Issued _____
Permit # _____

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner of record and am authorized to make this application and perform the work listed on this application.

Applicant sign/Contractor sign and seal here: **Thomas T. Crader**

Print name here: _____

[X] Licensed Elec. Contractor [] Certifd Landscape Irrigation Contr'r [] Exempt Applicant

D. TECHNICAL SITE DATA

DESCRIPTION OF WORK:

Connect (2) Five Below wall signs to the existing electrical circuit on the building

QTY.	SIZE	ITEMS	Fee (Office Use Only)
_____	_____	Lighting Fixtures	_____
_____	_____	Receptacles	_____
_____	_____	Switches	_____
_____	_____	Detectors	_____
_____	_____	Light Poles	_____
_____	_____	Motors—Fract. HP	_____
_____	_____	Emergency & Exit Lights	_____
_____	_____	Communications Points	_____
_____	_____	Alarm Devices/F.A.C. Panel	_____
_____	_____	TOTAL NUMBERS	_____
_____	_____	Pool Permit/with UW Lights	_____
_____	_____	Storable Pool/Spa/Hot Tub	_____
_____	_____	KW Elec. Range/Receptacle	_____
_____	_____	KW Oven/Surface Unit	_____
_____	_____	KW Elec. Water Heater	_____
_____	_____	KW Elec. Dryer/Receptacle	_____
_____	_____	KW Dishwasher	_____
_____	_____	HP Garbage Disposal	_____
_____	_____	KW Central A/C Unit	_____
_____	_____	HP/KW Space Heater/Air Handler	_____
_____	_____	KW Baseboard Heat	_____
_____	_____	HP Motors 1/+ HP	_____
_____	_____	KW Transformer/Generator	_____
_____	_____	AMP Service	_____
_____	_____	AMP Subpanels	_____
_____	_____	AMP Motor Control Center	_____
_____	_____	KW Elec. Sign/Outline Light	_____
2	_____	Sign Connections	_____

Administrative Surcharge \$ _____
Minimum Fee \$ _____
State Permit Surcharge Fee \$ _____
TOTAL FEE \$ _____

SecureAccount (tm) AnchorSign.Com, Inc. – Charleston, SC 29413 (843) 747-59

0117683

Payment Detail

To Township of Brick, NJ

Your Invoice No.	Anchor PO No.	InvDate	Amount
FB-319 MS/PERMIT	0	4/26/2010	\$179.00

Check Total: \$179.00

This detail is provided for convenience, and is non-negotiable.



Permit Fee

April 27, 2010

Township of Brick, NJ
Attn.: Kim Bogan
Building Department
Municipal Building
Brick, NJ 08273

Dear Kim:

This permit request is in regards to:

Five Below (FB-319)
666 State Road Route 70
Brick, NJ 08723

Enclosed, please find a check in the amount of \$179.00 for the permit fee for the above-mentioned location.

Upon issuance, I would appreciate it if you could mail the permits and receipts back to:

Anchor Sign, Inc.
Attn: Maureen Swint
2200 Discher Avenue
Charleston, SC 29405

Thank you again for your time and assistance with this project, Kim! Please do not hesitate to call if you should have any questions.

Sincerely,

A handwritten signature in black ink, appearing to read "Maureen Swint".

Maureen Swint
Permit Coordinator
Toll-free: (800) 213-3331
Direct: (843) 576-3208
Fax: (843) 576-7208
mswint@anchorsign.com

RECEIVING CLERK
DATE REC'D 4-6-10

ZONING PERMIT APPLICATION

PERMIT # 2P-10-60186
DATE ISSUED 5/3/10

BLOCK: 70 LOT: 7 QUALIFIER: --- SITE ADDRESS: 744 Route 70 (666)

IDENTIFICATION:

1. NAME OF OWNER IN FEE: Bricktown VF Llc C/o Varnado Kelly
COMPLETE ADDRESS: 210 Route 4 East Pocom

PHONE # _____ EMAIL: _____

2. NAME OF APPLICANT: Archon Sign Company
APPLICANT ADDRESS: 3300 Distra Avenue
Marion NJ 08400

PHONE # 800-213-3331 EMAIL: _____

3. RESPONSIBLE PERSON FOR WORK: Marion Swift
PHONE # 800-213-3331 FAX # 843-576-7008

4. SIGNATURE OF APPLICANT: _____

FOR OFFICE USE ONLY

FEE SUMMARY:

APPLICATION FEE: \$ 50.00
OTHER: \$ _____
TOTAL: \$ _____

REQUIRED BY APPLICANT

RESIDENTIAL: _____
COMMERCIAL: X
EXISTING USE: Lane Bryant store
PROPOSED USE: five below store
BOARD APPROVAL: _____
RESOLUTION #: _____
APPROVAL DATE: _____

PROJECT DESCRIPTION: (PLEASE CHECK APPLICABLE WORK & DESCRIBE)

*NEW BUILDING: _____ *ADDITION _____ *ALTERATION _____ *PORCH _____ *DECK _____

POOL: ABOVE GROUND _____ IN GROUND _____ FENCE: HEIGHT _____ TYPE _____

HEIGHT: _____ (*APPLICABLE)

OTHER Wall signs

DESCRIPTION: five below wall signs - unit 3

ZONING REVIEW: 4-12-10 DATE DENIED: _____ DATE APPROVED: 4-12-10 INTLS: SKZ (SEE BACK PAGE)

RECEIVED
APR 6 2010
K-12

DATE REVIEWED: 4-12-10 DATE DENIED: _____ DATE APPROVED: 4-12-10 INTLS: OK

[illegible][illegible]



Brick Township
401 Chambers Bridge Rd.

Brick, NJ 08723
(732) 262-1027

Date Issued: _____
Application Number: ZA-10-00206
Application Date: 04/12/2010
Project Number: _____
Permit Number: _____
Fee: \$50

Zoning Permit

Worksite **744 (666) ROUTE 70**
Location: **Bricktown Plaza, Unit 3**
Brick Township, NJ 08723

Block: 701
Lot: 7 & 9.03
Qualifier: _____
Zone: B-3

Owner: **BRICKTOWN VF LLC %VORNADO REALTY**
Address: **210 ROUTE 4 EAST**
PARAMUS, NJ 07652

Applicant: **Maureen Swint; Anchor Sign Company**
Address: **2200 Discher Avenue**
Charleston, SC 29405

Application Approved Date: 04/12/2010

This Certifies that an application for the issuance of a Zoning Permit has been examined.

Use is: Retail Store --"five below" store. (former "Lane Bryant" store).

Nonconforming Use is: _____

Work Description:

Sign - Wall signs, (1) Channel letters, 33" x 19'7", "five below"; (2) Box sign, 18" x 18', "hot stuff. cool prices."

The total sign area may not exceed 15% of the total facade area.

An additional zoning permit is required for alterations for a tenant fit-up, and for any other additional work.

Upon review it was determined that:

- ☒ Use is permitted by Ordinance
- ☐ Use is permitted by Variance approved on: _____
- ☐ Valid Nonconforming Use is established by
 - ☐ Zoning Board of Adjustment
 - ☐ Zoning Officer

Sean Kinney
Sean Kinney, Zoning Officer

Michael P. Fowler
Michael P. Fowler, Township Planner

04/12/2010

Date

4/12/10
Date



Zoning, Building, & Electrical Permit Request

April 1, 2010

Township of Brick, NJ
Planning & Zoning Department
Municipal Building
401 Chambers Bridge Road
Brick, NJ 08273

To Whom It May Concern:

These permit requests are in regards to:

Five Below (FB-319)
Route 70 and Chambers Bridge Road
744 ~~666~~ State Road Route 70
Brick, NJ 08723

Enclosed, please find a completed zoning permit application, building subcode application, electrical subcode application, property information, and (3) sets of renderings for the above-referenced location. If I have failed to send any important information needed to process this request, please contact me as soon as possible so that I may get it to you.

Upon approval, I would appreciate it if you could contact me with the permit fee(s) due so that I may mail in a check for that exact amount.

Thank you for your time and efforts with this project! Please do not hesitate to call if you should have any questions.

Sincerely,

A handwritten signature in black ink, appearing to read "Maureen Swint", written over a horizontal line.

Maureen Swint
Permit Coordinator
Toll-free: (800) 213-3331
Direct: (843) 576-3208
Fax: (843) 576-7208
mswint@anchorsign.com

19'-7"

33"

five BELOW

Top of sign to grade = 16'-3"

Bottom of sign to grade = 13'-6"

18" **hot stuff. cool prices.**

18'-0"

Top of sign to grade = 15'-4"

Bottom of sign to grade = 13'-10"

60'-0"

Lease Line

to be painted SW #6959 Blue

26'-0"

19'-7"

18'-0"

five BELOW

hot stuff. cool prices.

18"

4'-0"

30'-0"

13'-6"

5'-6"

Front (North) Elevation

APPROVED FOR ZONING ONLY
SEAN KINNEVY, ZONING OFFICER

FB # 319 (Bricktown Plaza)

APR 12 2010 *SK*

02/23/10

AnchorSign.
1.800.213.3331

666 State Route 70
Brick, NJ 08723


Drawing by: Darin Houston
Revised by: Bascom Judy

five BELOW

19'-7"


33"

five BELOW



Sign Specifications
Sign A

Attachment Detail:



Electrical Detail:

AGILIGHT WHITE TUFFRAYZ LED
(3) Xtanium 60 WATT transformers
@ .85 AMPS EA
total amps = 2.55

Specifications: Channel Letters

1. Existing Facade: EIFS over Plywood over Metal studs
2. .040 Aluminum letter returns painted to match white
3. 3mm Signabond Lite composite backs
(interior of sign can painted white for maximum illumination)
4. .125" x 1" trim cap to match white
5. White LEDs
6. 3/16" White Acrylic faces
7. Waterproof disconnect switch per NEC 600-6
8. Primary electrical feed
9. Transformers

General Notes:

- This sign is to be installed in accordance with the requirements of Article 600 of the National Electrical Code.
- 1) Grounded and bonded per NEC 600.7/NEC 250
 - 2) Existing branch circuit in compliance with NEC 600.5, not to exceed 20 amps
 - 3) Sign is to be UL listed per NEC 600.3
 - 4) UL disconnect switch per NEC 600.6- required per sign component before leaving manufacturer*
- *For multiple signs, a disconnect is permitted but not required for each section.

APPROVED FOR ZONING ONLY
SEAN KINNEY, ZONING OFFICER

APR 12 2010 *SK*

FB # 319 (Bricktown Plaza)

666 State Route 70
Brick, NJ 08723



five BELOW

02/23/10
Drawing by: Darin Houston
Revised by: Bascom Judy



AnchorSign.
1.800.213.3331

18" 18'-0" **hot stuff. cool prices.**



Electrical Detail: Box Sign

EESB832-16L @ 2.4 AMPS
BULBS = (4) F96T12CWHO

Sign Specifications: Box Sign

1. Facade Materials: EIFS over Plywood over Metal studs
2. Internally illuminated box sign constructed of .080 aluminum, return painted to match White
3. Routed aluminum face painted to match White
4. Lexan backing with first surface applied vinyl graphics: PMS Blue 230-167
5. Sign cabinet containing lamps, ballast, & raceways
6. External waterproof disconnect switch
7. Flex conduit running to primary electrical source

General Notes:

This sign is to be installed in accordance with the requirements of Article 600 of the National Electrical Code.

- 1) Grounded and bonded per NEC 600.7/NEC 250
- 2) Existing branch circuit in compliance with NEC 600.5, not to exceed 20 amps
- 3) Sign is to be UL listed per NEC 600.3
- 4) UL disconnect switch per NEC 600.6- required per sign component before leaving manufacturer*

*For multiple signs, a disconnect is permitted but not required for each section.

Sign Specifications
Sign B

APPROVED FOR ZONING ONLY
SEAN KINNEY, ZONING OFFICER

APR 12 2010
SK

FB # 319 (Bricktown Plaza)

FIVE BELOW


666 State Route 70
Brick, NJ 08723

02/23/10 **AnchorSign.**

Drawing by: Darin Houston
Revised by: Bascom Judy

1.800.213.3331

FIVE BELOW



APPROVED FOR ZONING ONLY
SEAN KINNEY, ZONING OFFICER

APR 12 2010


scj

20000	6.3 HRS. DEVELOPMENT	20,000
10000	3.1 HRS. DEVELOPMENT	10,000
5000	1.5 HRS. DEVELOPMENT	5,000
2500	0.8 HRS. DEVELOPMENT	2,500
1250	0.4 HRS. DEVELOPMENT	1,250
625	0.2 HRS. DEVELOPMENT	625
312	0.1 HRS. DEVELOPMENT	312
156	0.05 HRS. DEVELOPMENT	156
78	0.025 HRS. DEVELOPMENT	78
39	0.0125 HRS. DEVELOPMENT	39
19	0.00625 HRS. DEVELOPMENT	19
9	0.003125 HRS. DEVELOPMENT	9
4	0.0015625 HRS. DEVELOPMENT	4
2	0.00078125 HRS. DEVELOPMENT	2
1	0.000390625 HRS. DEVELOPMENT	1
0.5	0.0001953125 HRS. DEVELOPMENT	0.5
0.25	0.00009765625 HRS. DEVELOPMENT	0.25
0.125	0.000048828125 HRS. DEVELOPMENT	0.125
0.0625	0.0000244140625 HRS. DEVELOPMENT	0.0625
0.03125	0.00001220703125 HRS. DEVELOPMENT	0.03125
0.015625	0.000006103515625 HRS. DEVELOPMENT	0.015625
0.0078125	0.0000030517578125 HRS. DEVELOPMENT	0.0078125
0.00390625	0.00000152587890625 HRS. DEVELOPMENT	0.00390625
0.001953125	0.000000762939453125 HRS. DEVELOPMENT	0.001953125
0.0009765625	0.0000003814697265625 HRS. DEVELOPMENT	0.0009765625
0.00048828125	0.00000019073486328125 HRS. DEVELOPMENT	0.00048828125
0.000244140625	0.000000095367431640625 HRS. DEVELOPMENT	0.000244140625
0.0001220703125	0.0000000476837158203125 HRS. DEVELOPMENT	0.0001220703125
0.00006103515625	0.00000002384185791015625 HRS. DEVELOPMENT	0.00006103515625
0.000030517578125	0.000000011920928955078125 HRS. DEVELOPMENT	0.000030517578125
0.0000152587890625	0.0000000059604644775390625 HRS. DEVELOPMENT	0.0000152587890625
0.00000762939453125	0.00000000298023223876953125 HRS. DEVELOPMENT	0.00000762939453125
0.000003814697265625	0.000000001490116119384765625 HRS. DEVELOPMENT	0.000003814697265625
0.0000019073486328125	0.0000000007450580596923828125 HRS. DEVELOPMENT	0.0000019073486328125
0.00000095367431640625	0.00000000037252902984619140625 HRS. DEVELOPMENT	0.00000095367431640625
0.000000476837158203125	0.000000000186264514923095703125 HRS. DEVELOPMENT	0.000000476837158203125
0.0000002384185791015625	0.0000000000931322574615478515625 HRS. DEVELOPMENT	0.0000002384185791015625
0.00000011920928955078125	0.00000000004656612873077392578125 HRS. DEVELOPMENT	0.00000011920928955078125
0.000000059604644775390625	0.000000000023283064365386962890625 HRS. DEVELOPMENT	0.000000059604644775390625
0.0000000298023223876953125	0.0000000000116415321826934846453125 HRS. DEVELOPMENT	0.0000000298023223876953125
0.00000001490116119384765625	0.00000000000582076609134674232265625 HRS. DEVELOPMENT	0.00000001490116119384765625
0.000000007450580596923828125	0.000000000002910383045673121161328125 HRS. DEVELOPMENT	0.000000007450580596923828125
0.0000000037252902984619140625	0.0000000000014551915228365605806640625 HRS. DEVELOPMENT	0.0000000037252902984619140625
0.00000000186264514923095703125	0.00000000000072759576141828029033203125 HRS. DEVELOPMENT	0.00000000186264514923095703125
0.000000000931322574615478515625	0.000000000000363797880709140145166015625 HRS. DEVELOPMENT	0.000000000931322574615478515625
0.0000000004656612873077392578125	0.0000000000001818989403545700725830078125 HRS. DEVELOPMENT	0.0000000004656612873077392578125
0.00000000023283064365386962890625	0.00000000000009094947017728503629150390625 HRS. DEVELOPMENT	0.00000000023283064365386962890625
0.000000000116415321826934846453125	0.000000000000045474735088642518145751953125 HRS. DEVELOPMENT	0.000000000116415321826934846453125
0.0000000000582076609134674232265625	0.0000000000000227373675443212590728759765625 HRS. DEVELOPMENT	0.0000000000582076609134674232265625
0.00000000002910383045673121161328125	0.00000000000001136868377216062953643798828125 HRS. DEVELOPMENT	0.00000000002910383045673121161328125
0.000000000014551915228365605806640625	0.000000000000005684341886080314768218994140625 HRS. DEVELOPMENT	0.000000000014551915228365605806640625
0.0000000000072759576141828029033203125	0.000000000000002842170943040157384109497078125 HRS. DEVELOPMENT	0.0000000000072759576141828029033203125
0.00000000000363797880709140145166015625	0.0000000000000014210854715200786920547485390625 HRS. DEVELOPMENT	0.00000000000363797880709140145166015625
0.000000000001818989403545700725830078125	0.00000000000000071054273576003934602737426953125 HRS. DEVELOPMENT	0.000000000001818989403545700725830078125
0.0000000000009094947017728503629150390625	0.000000000000000355271367880019673013687134765625 HRS. DEVELOPMENT	0.0000000000009094947017728503629150390625
0.0000000000004547473576003934602737426953125	0.0000000000000001776356839400098365068435692890625 HRS. DEVELOPMENT	0.0000000000004547473576003934602737426953125
0.00000000000022737367880019673013687134765625	0.000000000000000088817841970004918253421783696453125 HRS. DEVELOPMENT	0.00000000000022737367880019673013687134765625
0.0000000000001136868377216062953643798828125	0.000000000000000044408920985002459126710891834765625 HRS. DEVELOPMENT	0.0000000000001136868377216062953643798828125
0.00000000000005684341886080314768218994140625	0.0000000000000000222044604925012295633554459173828125 HRS. DEVELOPMENT	0.00000000000005684341886080314768218994140625
0.00000000000002842170943040157384109497078125	0.000000000000000011102230246250614781677722958696453125 HRS. DEVELOPMENT	0.00000000000002842170943040157384109497078125
0.000000000000014210854715200786920547485390625	0.00000000000000000555111512312530739083886147934765625 HRS. DEVELOPMENT	0.000000000000014210854715200786920547485390625
0.0000000000000071054273576003934602737426953125	0.000000000000000002775557561562653695194443099673828125 HRS. DEVELOPMENT	0.0000000000000071054273576003934602737426953125
0.00000000000000355271367880019673013687134765625	0.00000000000000000138777878078132684759722154983696453125 HRS. DEVELOPMENT	0.00000000000000355271367880019673013687134765625
0.000000000000001776356839400098365068435692890625	0.00000000000000000069388939039066342379861077491834765625 HRS. DEVELOPMENT	0.000000000000001776356839400098365068435692890625
0.00000000000000088817841970004918253421783696453125	0.0000000000000000003469446951953317118993053874591834765625 HRS. DEVELOPMENT	0.00000000000000088817841970004918253421783696453125
0.00000000000000044408920985002459126710891834765625	0.000000000000000000173472347597665855949652693729591834765625 HRS. DEVELOPMENT	0.00000000000000044408920985002459126710891834765625
0.000000000000000222044604925012295633554459173828125	0.00000000000000000008673617379883292797482634686479591834765625 HRS. DEVELOPMENT	0.000000000000000222044604925012295633554459173828125
0.00000000000000011102230246250614781677722958696453125	0.0000000000000000000433680868994164639874131734323979591834765625 HRS. DEVELOPMENT	0.00000000000000011102230246250614781677722958696453125
0.0000000000000000555111512312530739083886147934765625	0.0000000000000000000216840434497082319968532933580994979591834765625 HRS. DEVELOPMENT	0.0000000000000000555111512312530739083886147934765625
0.00000000000000002775557561562653695194443099673828125	0.0000000000000000000108420217248541159968532933580994979591834765625 HRS. DEVELOPMENT	0.00000000000000002775557561562653695194443099673828125
0.0000000000000000138777878078132684759722154983696453125	0.00000000000000000000542101086242705799842664667904979591834765625 HRS. DEVELOPMENT	0.0000000000000000138777878078132684759722154983696453125
0.0000000000000000069388939039066342379861077491834765625	0.000000000000000000002710505431213528999213323339524979591834765625 HRS. DEVELOPMENT	0.0000000000000000069388939039066342379861077491834765625
0.000000000000000003469446951953317118993053874591834765625	0.000000000000000000001355252715606764499606654172440624979591834765625 HRS. DEVELOPMENT	0.000000000000000003469446951953317118993053874591834765625
0.00000000000000000173472347597665855949652693729591834765625	0.00000000000000000000067762635780338224980333083488124979591834765625 HRS. DEVELOPMENT	0.00000000000000000173472347597665855949652693729591834765625
0.0000000000000000008673617379883292797482634686479591834765625	0.0000000000000000000003388131789016911249016654172440624979591834765625 HRS. DEVELOPMENT	0.0000000000000000008673617379883292797482634686479591834765625
0.000000000000000000433680868994164639874131734323979591834765625	0.00000000000000000000016940658945084556245083270862203124979591834765625 HRS. DEVELOPMENT	0.000000000000000000433680868994164639874131734323979591834765625
0.000000000000000000216840434497082319968532933580994979591834765625	0.000000000000000000000084703294725422778984266354311015624979591834765625 HRS. DEVELOPMENT	0.000000000000000000216840434497082319968532933580994979591834765625
0.000000000000000000108420217248541159968532933580994979591834765625	0.000000000000000000000042351647362711389492133177155528124979591834765625 HRS. DEVELOPMENT	0.000000000000000000108420217248541159968532933580994979591834765625
0.0000000000000000000542101086242705799842664667904979591834765625	0.000000000000000000000021175823681355694723033294288888124979591834765625 HRS. DEVELOPMENT	0.0000000000000000000542101086242705799842664667904979591834765625
0.00000000000000000002710505431213528999213323339524979591834765625	0.000000000000000000000010587911840677784723033294288888124979591834765625 HRS. DEVELOPMENT	0.00000000000000000002710505431213528999213323339524979591834765625
0.00000000000000000001355252715606764499606654172440624979591834765625	0.0000000000000000000000052939559203388923611516646444444124979591834765625 HRS. DEVELOPMENT	0.00000000000000000001355252715606764499606654172440624979591834765625
0.0000000000000000000067762635780338224980333083488124979591834765625	0.0000000000000000000000026469779601694461557578323222222124979591834765625 HRS. DEVELOPMENT	0.0000000000000000000067762635780338224980333083488124979591834765625

TOWNSHIP OF BRICK ZONING PERMIT APPLICATION

(Please Type or Print Neatly in Ink, Not Pencil)

Applications missing any of the following information will delay processing and may be returned to you.



BLOCK 701 LOT 7 QUALIFIER 701

PROPERTY ADDRESS 666 State Road Route 70

PERSONAL NAME OF APPLICANT Maureen Swint

BUSINESS NAME OF APPLICANT Anchor Sign, Inc.

MAILING ADDRESS OF APPLICANT 2200 Discher Avenue, Charleston, SC 29405

PROPERTY OWNER'S FULL NAME Bricktown VF LLC c/o Vornado Realty

PRESENT USE OF PROPERTY (check all that apply)

- ☐ Vacant Lot ☐ Single-family dwelling ☐ Multi-family dwelling
☒ Commercial (please describe) Lane Bryant (retail store in Bricktown Plaza)

PROPOSED USE OF PROPERTY (check all that apply)

- ☐ Vacant Lot ☐ Single-family dwelling ☐ Multi-dwelling
☒ Commercial (please describe) Five Below (retail store in Bricktown Plaza)

PROPOSED CONSTRUCTION (check all that apply)

- ☐ New Building (please describe) _____ Height _____
☐ Addition - Height _____
☐ Alteration _____
☐ Porch or deck - Height _____
☐ Shed - Height _____
☐ Fence - Type _____ Height _____
☐ Swimming Pool ☐ in-ground ☐ above-ground
☒ Other (please describe) Sign Installation

CHECKLIST

- ☒ All information completed above
☒ Two (2) copies of a plot plan containing:
☒ All existing and proposed structures
☒ All dimensions of the lot and structures
☐ All setbacks from the structures to the property lines
☐ All adjacent streets and waterways
☐ If applicable, include a copy of the Zoning Board of Adjustment Resolution, the date that the map was signed, and/or the date that the subdivision map was filed with the Ocean County Clerk, along with the file map and number.

Note: No partial, taped, faxed, reduced or enlarged copies can be accepted.

The applicant certifies that all statements and information made and provided as part of this application are true to the best of the applicant's knowledge, information and belief. The applicant further states that the applicant will comply with all other Municipal approvals and ordinances, and all County, State, and Federal Regulations.

SIGNATURE OF APPLICANT Maureen Swint Date 03/11/2010

Reviewed by Zoning Office 4-12-10 Date 4-12-10 (X) Approved () Denied

March 2003

COMMERCIAL



Zoning, Building, & Electrical Permit Request

April 1, 2010

Township of Brick, NJ
Planning & Zoning Department
Municipal Building
401 Chambers Bridge Road
Brick, NJ 08273

To Whom It May Concern:

These permit requests are in regards to:

744 Five Below (FB-319)
Route 70 and Chambers Bridge Road
~~666~~ State Road Route 70
Brick, NJ 08723

Enclosed, please find a completed zoning permit application, building subcode application, electrical subcode application, property information, and (3) sets of renderings for the above-referenced location. If I have failed to send any important information needed to process this request, please contact me as soon as possible so that I may get it to you.

Upon approval, I would appreciate it if you could contact me with the permit fee(s) due so that I may mail in a check for that exact amount.

Thank you for your time and efforts with this project! Please do not hesitate to call if you should have any questions.

Sincerely,

A handwritten signature in black ink, appearing to read "Maureen Swint", written over a horizontal line.

Maureen Swint
Permit Coordinator
Toll-free: (800) 213-3331
Direct: (843) 576-3208
Fax: (843) 576-7208
mswint@anchorsign.com

(1) set of 33" Five Below internally illuminated channel letters mounted directly to the facade = 53.85 square feet

(1) 27 square foot hot stuff. cool prices internally illuminated box sign mounted directly to the facade = 27 square feet

All signs are UL listed




Drawing by: Darin Houston
Revised by: Bascom Judy


19'-7"

33"

five BELOW



Attachment Detail:



Electrical Detail:

AGILIGHT WHITE TUFFRAYZ LED
(3) Xitanium 60 WATT transformers
@ .85 AMPS EA
total amps = 2.55

Specifications: Channel Letters

1. Existing Facade: EIFS over Plywood over Metal studs
2. .040 Aluminum letter returns painted to match white
3. 3mm Signabond Lite composite backs
(interior of sign can painted white for maximum illumination)
4. .125" x 1" trim cap to match white
5. White LEDs
6. 3/16" White Acrylic faces
7. Waterproof disconnect switch per NEC 600-6
8. Primary electrical feed
9. Transformers

General Notes:

This sign is to be installed in accordance with the requirements of Article 600 of the National Electrical Code.

- 1) Grounded and bonded per NEC 600.7/NEC 250
- 2) Existing branch circuit in compliance with NEC 600.5, not to exceed 20 amps
- 3) Sign is to be UL listed per NEC 600.3
- 4) UL disconnect switch per NEC 600.6- required per sign component before leaving manufacturer*

*For multiple signs, a disconnect is permitted but not required for each section.

Sign Specifications
Sign A

APPROVED FOR ZONING ONLY
SEAN KINNEVY, ZONING OFFICER

APR 12 2010

SEK







FB # 319 (Bricktown Plaza)

666 State Route 70
Brick, NJ 08723

02/23/10 **AnchorSign.**
1.800.213.3331

Drawing by: Darin Houston
Revised by: Bascom Judy

five BELOW



Sign Specifications
Sign B

APPROVED FOR ZONING ONLY
SEAN KINNEVY, ZONING OFFICER

APR 12 2010
SK

FB # 319 (Bricktown Plaza)


666 State Route 70
Brick, NJ 08723

FIVE BELOW

02/23/10
Drawing by: Darin Houston
Revised by: Bascom Judy

AnchorSign.
1.800.213.3331

five BELOW

[illegible]

APR 12 2010

02/23/10

Drawing by: Darin Houston
Revised by: Bascom Judy

Sign A




(1) set of 33" Five Below internally illuminated channel letters mounted directly to the facade = 53.85 square feet

Sign B

(1) 27 square foot hot stuff. cool prices internally illuminated box sign mounted directly to the facade = 27 square feet

Total signage this elevation = 80.85 square feet

All signs are UL listed



Front (North) Elevation

APPROVED FOR ZONING ONLY
SEAN KINNEY, ZONING OFFICER

FB # 319 (Bricktown Plaza)

APR 12 2010

02/23/10

AnchorSign.
1.800.213.3331


666 State Route 70
Brick, NJ 08723

Drawing by: Darin Houston
Revised by: Bascom Judy

19'-7"

33"

five BELOW



Sign Specifications
Sign A

APPROVED FOR ZONING ONLY
SEAN KINNEVY, ZONING OFFICER

APR 12 2010
SKZ


FB # 319 (Bricktown Plaza)

666 State Route 70
Brick, NJ 08723

02/23/10 **AnchorSign.**
1-800-213-3331

Drawing by: Darin Houston
Revised by: Bascom Judy

Attachment Detail:



Electrical Detail:





AGILIGHT WHITE TUFFRAYZ LED
(3) Xtanium 60 WATT transformers
@ .85 AMPS EA
total amps = 2.55

Specifications: Channel Letters

1. Existing Facade: EIFS over Plywood over Metal studs
2. .040 Aluminum letter returns painted to match white
3. 3mm Signabond Lite composite backs
(interior of sign can painted white for maximum illumination)
4. .125" x 1" trim cap to match white
5. White LEDs
6. 3/16" White Acrylic faces
7. Waterproof disconnect switch per NEC 600-6
8. Primary electrical feed
9. Transformers

General Notes:

- This sign is to be installed in accordance with the requirements of Article 600 of the National Electrical Code.
- 1) Grounded and bonded per NEC 600.7/NEC 250
 - 2) Existing branch circuit in compliance with NEC 600.5, not to exceed 20 amps
 - 3) Sign is to be UL listed per NEC 600.3
 - 4) UL disconnect switch per NEC 600.6- required per sign component before leaving manufacturer*
- *For multiple signs, a disconnect is permitted but not required for each section.



Side view

Sign Specifications: Box Sign

1. Facade Materials: EIFS over Plywood over Metal studs
2. Internally illuminated box sign constructed of .080 aluminum, return painted to match White
3. Routed aluminum face painted to match White
4. Lexan backing with first surface applied vinyl graphics: PMS Blue 230-167
5. Sign cabinet containing lamps, ballast, & raceways
6. External waterproof disconnect switch
7. Flex conduit running to primary electrical source

General Notes:

This sign is to be installed in accordance with the requirements of Article 600 of the National Electrical Code.

- 1) Grounded and bonded per NEC 600.7/NEC 250
- 2) Existing branch circuit in compliance with NEC 600.5, not to exceed 20 amps
- 3) Sign is to be UL listed per NEC 600.3
- 4) UL disconnect switch per NEC 600.6- required per sign component before leaving manufacturer*

*For multiple signs, a disconnect is permitted but not required for each section.

Sign Specifications
Sign B

APPROVED FOR ZONING ONLY
SEAN KINNEVY, ZONING OFFICER

APR 12 2010
SK


FB # 319 (Bricktown Plaza)

666 State Route 70
Brick, NJ 08723

AnchorSign.
1-800-213-3331

02/23/10
Drawing by: Darin Houston
Revised by: Bascom Judy

FIVE BELOW



APPROVED FOR ZONING ONLY
SEAN KINNEVY, ZONING OFFICER

APR 12 2010

FB # 319 (Bricktown Plaza)

666 State Route 70
Brick, NJ 08723

02/23/10

Drawing by: Darin Houston
Revised by: Bascom Judy



AnchorSign.

1.800.213.3331



RECD APR 22 2010

Permit Control Number C-10-000879

April 21, 2010

Township of Brick, NJ
Attn.: Kenneth Anderson – Subcode Official
Building Department
Municipal Building
Brick Township, NJ 08273

Dear Kenneth:

RE: Five Below #319
Route 70 and Chambers Bridge Road
666 State Road Route 70
Brick, NJ 08723
Permit Control Number C-10-000879

Enclosed, please find t(3) sets of engineered plans per your request for the above-referenced project. If you need anything else additional for your review, please contact me as soon as possible so that I may get it to you.

Upon approval, I would appreciate it if you could contact me with the permit fee(s) due prior to issuance.

Thank you for your time and assistance with this project, Kenneth! Please do not hesitate to call if you should have any questions.

Sincerely,

A handwritten signature in black ink, appearing to read "Maureen Swint".

Maureen Swint
Permit Coordinator
Toll-free: (800) 213-3331
Direct: (843) 576-3208
Fax: (843) 576-7208
mswint@anchorsign.com

Date:	4/20/10	City, State:	Brick, NJ	SHEET:	1 OF 1
Client:	Anchor Sign	Overall Height:	20'-0"	Sean M. McFarland, P.E.	
Sign:	Five Below	Wind Speed	120 mph		

Project Description

666 State Route 70

Table of Contents

ME Job: 10-18301 A

Overall Size: 4'-0" x 50'-0" +/-

Mounting Height: 20'-0"

Mounting Style: Channel Letters Mounted with Sheet Metal Screws to Metal Wall Panel

Content:	Page
Design Loads.	1
Connection Design.	1
Installation Details.	(Numbered Separately)

Structural Variables and Code Loading Specifications

Sign Type:	Channel Letters / Wall Signs	Code:	2006 IBC/ NJ State
Existing Wall Material:	Other	Wind Speed:	120
Sign Weight Per Foot:	15	Wind Exposure:	C

Wind Loads Per ASCE 7-05

Connection Design

Using ASCE 7-05 (Simplified Procedure)	I =	1.15 (Table 6-1)
Topography: Homogeneous	lambda =	1.29 (Figure 6-3, Exp. C, height=20 ft)
Exposure: C		
Enclosure: Enclosed / Open	Zone =	5 (End-Wall - Worst Case)
Structure: Components and Cladding	Effective Wind Area =	10 Sq. Ft.
Building: Category III	Net Wind Pressure =	-34.7 (Figure 6-3)

Total Load Pnet = (lambda)*I*Pnet

Pnet (20)= -51.48 PSF

Sign Loads	Area	Pressure (Suction)	Force
Sign A - Letter	3.92 FT^2	-51.48 PSF	-202 LBF (Each Letter)
Sign A - "I" and "o"	1.96 FT^2	-51.48 PSF	-101 LBF
Sign B - Hot Stuff	27.00 FT^2	-51.48 PSF	-1390 LBF
Wall Panel	200 FT^2	-51.48 PSF	-10295 LBF

Connection Design	Connections	Force Per Connection	1/2" Dia. Toggles	3/8" Dia. Lags (Ply)	#12 Sheet Metal Screws	
Sign A	4	-50 LBF			65 LBS	(OK)
Sign A - "I" and "o"	3	-34 LBF			65 LBS	(OK)
Sign B	24	-58 LBF			65 LBS	(OK)
Wall Panel	56	-184 LBF	195 LBS	195 LBS		(OK)

Connection Specification

Total Connections - Sign A (Letters) - Use (4) #12 Sheet Metal Screws to Attach Letters to Sign Panel. Use (3) #12 Sheet Metal Screws to Attach Letter I and O to Sign Panel. Sign B (Cabinet) - Use (24) #12 Sheet Metal Screws to Attach Cabinet to Sign Panel. Attach Sign Panel to Wall with (56) 1/2" Dia. Toggles OR 3/8" Dia. Lags into Min. 5/8" Thick Plywood. Space All Connectors Evenly. Screw Letter Trimcap or Retainer @ 6" O.C. Max.

TOWNSHIP OF BRICK
RELEASED FOR PERMIT
 Building Subcode _____
 Fire Subcode _____
 Electrical Subcode _____
 Plans Released _____
 Construction Official _____

APR 20 2010


exp. 4/30/12

Extra Set

(1) set of 33" Five Below internally illuminated channel letters mounted directly to the facade = 53.85 square feet

(1) 27 square foot hot stuff. cool prices internally illuminated box sign mounted directly to the facade = 27 square feet

All signs are UL listed



FIVE BELOW

666 State Route 70
Brick, NJ 08723

APR 20 2010

Pay careful attention to all text boxes with light grey shaded backgrounds. These text boxes contain important engineering information.

McFarland Engineering
Texas Firm Registration: F-6996
New Jersey License Number: GE45451
New Jersey Expiration Date: 4/30/2012

Sheet 1 of 4
ME #10-18301
4/20/2010

02/23/10


AnchorSign[®]

1.800.213.3331

Drawing by: Darin Houston
Revised by: Bascom Judy

Sign A




(1) set of 33" Five Below internally illuminated channel letters mounted directly to the facade = 53.85 square feet

Sign B

(1) 27 square foot hot stuff. cool prices internally illuminated box sign mounted directly to the facade = 27 square feet

Total signage this elevation = 80.85 square feet

All signs are UL listed



Front (North) Elevation

five BELOW

FB # 319 (Bricktown Plaza)

666 State Route 70
Brick, NJ 08723

02/23/10


AnchorSign.
1.800.213.3331

Drawing by: Darin Houston
Revised by: Bascom Judy


19'-7"

33"

five BELOW



Sign Specifications
Sign A



Electrical Detail:

AGILIGHT WHITE TUFFRAYZ LED
(3) Xitanium 60 WATT transformers
@ .85 AMPS EA
total amps = 2.55

Specifications: Channel Letters

1. Existing Facade: EIFS over Plywood over Metal studs
2. .040 Aluminum letter returns painted to match white
3. 3mm Signabond Lite composite backs
(interior of sign can be painted white for maximum illumination)
4. .125" x 1" trim cap to match white
5. White LEDs
6. 3/16" White Acrylic faces
7. Waterproof disconnect switch per NEC 600-6
8. Primary electrical feed
9. Transformers

General Notes:

This sign is to be installed in accordance with the requirements of Article 600 of the National Electrical Code.

- 1) Grounded and bonded per NEC 600.7/NEC 250
- 2) Existing branch circuit in compliance with NEC 600.5, not to exceed 20 amps
- 3) Sign is to be UL listed per NEC 600.3
- 4) UL disconnect switch per NEC 600.6- required per sign component before leaving manufacturer*

*For multiple signs, a disconnect is permitted but not required for each section.

APR 20 2010

McFarland Engineering
Texas Firm Registration: F-6936
New Jersey License Number: GE45451
New Jersey Expiration Date: 4/30/2012

Pay careful attention to all text boxes with light grey shaded backgrounds. These text boxes contain important engineering information.

Sheet 2 of 4
ME #10-18301
4/20/2010

FB # 319 (Bricktown Plaza)

five BELOW

666 State Route 70
Brick, NJ 08723

Drawing by: Darin Houston
Revised by: Bascom Judy

02/23/10




AnchorSign
1.800.213.3331

19'-7"


33"

five BELOW



Sign Specifications
Sign A

Attachment Detail:



Electrical Detail:

AGILIGHT WHITE TUFFRAYZ LED
(3) Titanium 60 WATT transformers
@ .85 AMPS EA
total amps = 2.55

Specifications: Channel Letters

1. Existing Facade: EIFS over Plywood over Metal studs
2. .040 Aluminum letter returns painted to match white
3. 3mm Signabond Lite composite backs
(interior of sign can painted white for maximum illumination)
4. .125" x 1" trim cap to match white
5. White LEDs
6. 3/16" White Acrylic faces
7. Waterproof disconnect switch per NEC 600-6
8. Primary electrical feed
9. Transformers

General Notes:

This sign is to be installed in accordance with the requirements of Article 600 of the National Electrical Code.

- 1) Grounded and bonded per NEC 600.7/NEC 250
- 2) Existing branch circuit in compliance with NEC 600.5, not to exceed 20 amps
- 3) Sign is to be UL listed per NEC 600.3
- 4) UL disconnect switch per NEC 600.6- required per sign component before leaving manufacturer*

*For multiple signs, a disconnect is permitted but not required for each section.

five BELOW


FB # 319 (Bricktown Plaza)

666 State Route 70
Brick, NJ 08723


02/23/10

Drawing by: Darin Houston
Revised by: Bascom Judy

18" 18'-0" **hot stuff. cool prices.**



Side view



Electrical Detail: Box Sign
EESB832-16L @ 2.4 AMPS
BULBS = (4) F96T12CWHO



- Sign Specifications: Box Sign**
1. Facade Materials: EIFS over Plywood over Metal studs
 2. Internally illuminated box sign constructed of .080 aluminum, return painted to match White
 3. Routed aluminum face painted to match White
 4. Lexan backing with first surface applied vinyl graphics: PMS Blue 230-167
 5. Sign cabinet containing lamps, ballast, & raceways
 6. External waterproof disconnect switch
 7. Flex conduit running to primary electrical source

General Notes:
This sign is to be installed in accordance with the requirements of Article 600 of the National Electrical Code.
1) Grounded and bonded per NEC 600.7/NEC 250
2) Existing branch circuit in compliance with NEC 600.5, not to exceed 20 amps
3) Sign is to be UL listed per NEC 600.3
4) UL disconnect switch per NEC 600.6- required per sign component before leaving manufacturer*
*For multiple signs, a disconnect is permitted but not required for each section.


APR 20 2010

McFarland Engineering Texas Firm Registration: F-6996 New Jersey License Number: GE45451 New Jersey Expiration Date: 4/30/2012	Pay careful attention to all text boxes with light grey shaded backgrounds. These text boxes contain important engineering information.	Sheet 3 of 4 ME #10-183017 4/20/2010
---	---	--

Sign Specifications
Sign B



Side view



Electrical Detail: Box Sign
 EESB832-16L @ 2.4 AMPS
 BULBS = (4) F96T12CWHO

Sign Specifications: Box Sign

1. Facade Materials: EIFS over Plywood over Metal studs
2. Internally illuminated box sign constructed of .080 aluminum, return painted to match White
3. Routed aluminum face painted to match White
4. Lexan backing with first surface applied vinyl graphics: PMS Blue 230-167
5. Sign cabinet containing lamps, ballast, & raceways
6. External waterproof disconnect switch
7. Flex conduit running to primary electrical source

General Notes:

This sign is to be installed in accordance with the requirements of Article 600 of the National Electrical Code.




- 1) Grounded and bonded per NEC 600.7/NEC 250
- 2) Existing branch circuit in compliance with NEC 600.5, not to exceed 20 amps
- 3) Sign is to be UL listed per NEC 600.3
- 4) UL disconnect switch per NEC 600.6- required per sign component before leaving manufacturer*

*For multiple signs, a disconnect is permitted but not required for each section.

Sign Specifications
Sign B

Connection Specification

Total Connections - Sign A (Letters) - Use (4) #12 Sheet Metal Screws to Attach Letters to Sign Panel. Use (3) #12 Sheet Metal Screws to Attach Letters I and O to Sign Panel. Sign B (Cabinet) - Use (24) #12 Sheet Metal Screws to Attach Cabinet to Sign Panel. Attach Sign Panel to Wall with (56) 1/2" Dia. Toggles OR 3/8" Dia. Lags into Min. 5/8" Thick Plywood. Space All Connectors Evenly. Screw Letter Trimcap or Retainer @ 6" O.C. Max.



APR 20 2010

FIVE BELOW

FB # 319 (Bricktown Plaza)

666 State Route 70
Brick, NJ 08723

McFarland Engineering
Texas Firm Registration: F-6996
New Jersey License Number: GE45451
New Jersey Expiration Date: 4/30/2012


Pay careful attention to all text boxes with light grey shaded backgrounds. These text boxes contain important engineering information.

Sheet 4 of 4
ME #10-18301
4/20/2010

02/23/10

AnchorSign
1.800.213.3331

Drawing by: Darin Houston
Revised by: Bascom Judy

[illegible]

666 State Route 70
Brick, NJ 08723

02/23/10
Drawing by: Darin Houston
Revised by: Bascom Judy

AnchorSign.
1.800.213.3331

Date:	4/20/10	City, State:	Brick, NJ	SHEET:	1 OF 1
Client:	Anchor Sign	Overall Height:	20'-0"	Sean M. McFarland, P.E.	
Sign:	Five Below	Wind Speed	120 mph		

Project Description	666 State Route 70	Table of Contents
ME Job:	10-18301 A	Content: Page
Overall Size:	4'-0" x 50'-0" +/-	Design Loads. 1
Mounting Height:	20'-0"	Connection Design. 1
Mounting Style:	Channel Letters Mounted with Sheet Metal Screws to Metal Wall Panel	Installation Details. (Numbered Separately)

Structural Variables and Code Loading Specifications

Sign Type:	Channel Letters / Wall Signs	Code:	2006 IBC/ NJ State
Existing Wall Material:	Other	Wind Speed:	120
Sign Weight Per Foot:	15	Wind Exposure:	C

Wind Loads Per ASCE 7-05

Connection Design

Using ASCE 7-05 (Simplified Procedure)	I =	1.15 (Table 6-1)
Topography: Homogeneous	lambda =	1.29 (Figure 6-3, Exp. C, height=20 ft)
Exposure: C		
Enclosure: Enclosed / Open	Zone =	5 (End-Wall - Worst Case)
Structure: Components and Cladding	Effective Wind Area =	10 Sq. Ft.
Building: Category III	Net Wind Pressure =	-34.7 (Figure 6-3)

Total Load Pnet = (lambda)*I*Pnet

Pnet (20)= -51.48 PSF

Sign Loads

	Area	Pressure (Suction)	Force
Sign A - Letter	3.92 FT^2	-51.48 PSF	-202 LBF (Each Letter)
Sign A - "I" and "o"	1.96 FT^2	-51.48 PSF	-101 LBF
Sign B - Hot Stuff	27.00 FT^2	-51.48 PSF	-1390 LBF
Wall Panel	200 FT^2	-51.48 PSF	-10295 LBF

Connection Design

	Connections	Force Per Connection	1/2" Dia. Toggles	3/8" Dia. Lags (Ply)	#12 Sheet Metal Screws
Sign A	4	-50 LBF	65 LBS	(OK)	
Sign A - "I" and "o"	3	-34 LBF	65 LBS	(OK)	
Sign B	24	-58 LBF	65 LBS	(OK)	
Wall Panel	56	-184 LBF	195 LBS	195 LBS	(OK)

Connection Specification

Total Connections - Sign A (Letters) - Use (4) #12 Sheet Metal Screws to Attach Letters to Sign Panel. Use (3) #12 Sheet Metal Screws to Attach Letters I and O to Sign Panel. Sign B (Cabinet) - Use (24) #12 Sheet Metal Screws to Attach Cabinet to Sign Panel. Attach Sign Panel to Wall with (56) 1/2" Dia. Toggles OR 3/8" Dia. Lags into Min. 5/8" Thick Plywood. Space All Connectors Evenly. Screw Letter Trimcap or Retainer @ 6" O.C. Max.

APR 20 2010

exp. 4/30/12

Sign A

(1) set of 33" Five Below internally illuminated channel letters mounted directly to the facade = 53.85 square feet

Sign B

(1) 27 square foot hot stuff, cool prices internally illuminated box sign mounted directly to the facade = 27 square feet


Total signage this elevation = 80.85 square feet

All signs are UL listed

13'-7"
33"
five BELOW

Top of sign to grade = 16'-3"
Bottom of sign to grade = 13'-6"

18"
hot stuff. cool prices.
18'-0"
Top of sign to grade = 15'-4"
Bottom of sign to grade = 13'-10"



Front (North) Elevation

APR 20 2010

McFarland Engineering Texas Firm Registration: F-6996 New Jersey License Number: GE45451 New Jersey Expiration Date: 4/30/2012	Pay careful attention to all text boxes with light grey shaded backgrounds. These text boxes contain important engineering information.	Sheet 1 of 4 ME #10-18301 4/20/2010
---	---	---

five BELOW

FB # 319 (Bricktown Plaza)

666 State Route 70
Brick, NJ 08723

Drawing by: Darin Houston
Revised by: Bascom Judy

02/23/10

AnchorSign.
1.800.213.3331

Sign A




(1) set of 33" Five Below internally illuminated channel letters mounted directly to the facade = 53.85 square feet

Sign B

(1) 27 square foot hot stuff, cool prices internally illuminated box sign mounted directly to the facade = 27 square feet

Total signage this elevation = 80.85 square feet

All signs are UL listed



Front (North) Elevation

five BELOW

FB # 319 (Bricktown Plaza)


666 State Route 70
Brick, NJ 08723

02/23/10 **AnchorSign.**
Drawing by: Darin Houston
Revised by: Bascom Judy
1.800.213.3331

19'-7"

33"

five BELOW



Sign Specifications
Sign A

APR 20 2010

McFarland Engineering
Texas Firm Registration: F-6996
New Jersey License Number: GE45451
New Jersey Expiration Date: 4/30/2012

Pay careful attention to all text boxes with light grey shaded backgrounds. These text boxes contain important engineering information.

Sheet 2 of 4
ME #10-18301
4/20/2010

five BELOW

FB # 319 (Bricktown Plaza)

666 State Route 70
Brick, NJ 08723


Drawing by: Darin Houston
Revised by: Bascom Judy

02/23/10

AnchorSign
1-800-213-3331

(Signature)

Attachment Detail:



Electrical Detail:

AGILIGHT WHITE TUFFRAYZ LED
(3) Xitanium 60 WATT transformers
@ .85 AMPS EA
total amps = 2.55

Specifications: Channel Letters



1. Existing Facade: EIFS over Plywood over Metal studs
2. .040 Aluminum letter returns painted to match white
3. 3mm Signabond Lite composite backs
(interior of sign can be painted white for maximum illumination)
4. .125" x 1" trim cap to match white
5. White LEDs
6. 3/16" White Acrylic faces
7. Waterproof disconnect switch per NEC 600-6
8. Primary electrical feed
9. Transformers

General Notes:


This sign is to be installed in accordance with the requirements of Article 600 of the National Electrical Code.

- 1) Grounded and bonded per NEC 600.7/NEC 250
- 2) Existing branch circuit in compliance with NEC 600.5, not to exceed 20 amps
- 3) Sign is to be UL listed per NEC 600.3
- 4) UL disconnect switch per NEC 600.6- required per sign component before leaving manufacturer*

*For multiple signs, a disconnect is permitted but not required for each section.



Sign Specifications
Sign A




Electrical Detail:
AGILIGHT WHITE TUFFRAYZ LED
(3) Titanium 60 WATT transformers
@ .85 AMPS EA
total amps = 2.55

- Specifications: Channel Letters**
1. Existing Facade: EIFS over Plywood over Metal studs
 2. .040 Aluminum letter returns painted to match white
 3. 3mm Signabond Lite composite backs (interior of sign can painted white for maximum illumination)
 4. .125" x 1" trim cap to match white
 5. White LEDs
 6. 3/16" White Acrylic faces
 7. Waterproof disconnect switch per NEC 600-6
 8. Primary electrical feed
 9. Transformers

General Notes:
This sign is to be installed in accordance with the requirements of Article 600 of the National Electrical Code.
1) Grounded and bonded per NEC 600.7/NEC 250
2) Existing branch circuit in compliance with NEC 600.5, not to exceed 20 amps
3) Sign is to be UL listed per NEC 600.3
4) UL disconnect switch per NEC 600.6- required per sign component before leaving manufacturer*
*For multiple signs, a disconnect is permitted but not required for each section.

18" 18'-0" **hot stuff. cool prices.**




Side view

Sign Specifications
Sign B

FIVE BELOW

FB # 319 (Bricktown Plaza)

666 State Route 70
Brick, NJ 08723



Electrical Detail: Box Sign
EESB832-16L @ 2.4 AMPS
BULBS = (4) F96T12CWHO

Sign Specifications: Box Sign

1. Facade Materials: EIFS over Plywood over Metal studs
2. Internally illuminated box sign constructed of .080 aluminum, return painted to match White
3. Routed aluminum face painted to match White
4. Lexan backing with first surface applied vinyl graphics: PMS Blue 230-167
5. Sign cabinet containing lamps, ballast, & raceways
6. External waterproof disconnect switch
7. Flex conduit running to primary electrical source

General Notes:

This sign is to be installed in accordance with the requirements of Article 600 of the National Electrical Code.

- 1) Grounded and bonded per NEC 600.7/NEC 250
- 2) Existing branch circuit in compliance with NEC 600.5, not to exceed 20 amps
- 3) Sign is to be UL listed per NEC 600.3
- 4) UL disconnect switch per NEC 600.6- required per sign component before leaving manufacturer*

*For multiple signs, a disconnect is permitted but not required for each section.

APR 20 2010

McFarland Engineering Texas Firm Registration: F-6996 New Jersey License Number: GE45451 New Jersey Expiration Date: 4/30/2012	Sheet 3 of 4 ME #10-18301 4/20/2010
---	---

Pay careful attention to all text boxes with light grey shaded backgrounds. These text boxes contain important engineering information.

[Signature]
02/23/10 **AnchorSign**
1.800.213.3331

Drawing by: Darin Houston
Revised by: Bascom Judy

hot stuff. cool prices.



five BELOW

666 State Route 70
Brick, NJ 08723

AnchorSign.
1.800.213.3331

#12 Sheet
Metal Screws

EESB832-16L @ 2.4 AMPS
BULBS = (4) F96T12CWHO

1. Facade Materials: EIFS over Plywood over Metal studs
2. Internally illuminated box sign constructed of .080 aluminum, return painted to match White
3. Routed aluminum face painted to match White
4. Lexan backing with first surface applied vinyl graphics: PMS Blue 230-167
5. Sign cabinet containing lamps, ballast, & raceways
6. External waterproof disconnect switch
7. Flex conduit running to primary electrical source


This sign is to be installed in accordance with the requirements of Article 600 of the National Electrical Code.

- 1) Grounded and bonded per NEC 600.7/NEC 250
- 2) Existing branch circuit in compliance with NEC 600.5, not to exceed 20 amperes
- 3) Sign is to be UL listed per NEC 600.3
- 4) UL disconnect switch per NEC 600.6- required per sign component before leaving manufacturer*


*For multiple signs, a disconnect is permitted but not required for each section.

Connection Specification


Total Connections - Sign A (Letters) - Use (4) #12 Sheet Metal Screws to Attach Letters to Sign Panel. Use (3) #12 Sheet Metal Screws to Attach Letters I and O to Sign Panel. Sign B (Cabinet) - Use (24) #12 Sheet Metal Screws to Attach Cabinet to Sign Panel. Attach Sign Panel to Wall with (56) 1/2" Dia. Toggles OR 3/8" Dia. Lags into Min. 5/8" Thick Plywood. Space All Connectors Evenly. Screw Letter Trimcap or Retainer @ 6" O.C. Max.



TYPICAL WOOD SCREW CONNECTION
3"=1'-0"



TYPICAL LAG BOLT CONNECTION
3"=1'-0"



TYPICAL TOGGLE BOLT CONNECTION
3"=1'-0"

APR 20 2010

FIVE BELOW

FB # 319 (Bricktown Plaza)

666 State Route 70
Brick, NJ 08723

Pay careful attention to all text boxes with light grey shaded backgrounds. These text boxes contain important engineering information.

McFarland Engineering
Texas Firm Registration: F-6896
New Jersey License Number: GE45451
New Jersey Expiration Date: 4/30/2012

Sheet 4 of 4
ME #10-18301
4/20/2010

02/23/10

AnchorSign
1.800.213.3331

Drawing by: Darin Houston
Revised by: Bascom Judy

five BELOW



图例

Drawing by: Darin Houston
Revised by: Bascom Judy

AnchorSign.
1-800-213-3331

 *** FAX TX REPORT ***

TRANSMISSION OK

JOB NO. 1408
 DESTINATION ADDRESS 918435767208
 PSWD/SUBADDRESS
 DESTINATION ID
 ST. TIME 04/14 13:33
 USAGE T 00' 34
 PGS. 1
 RESULT OK

Handwritten:
 114-10 843-
 516-1208

Page 1

Brick Township
 401 Chambersbridge Rd
 Brick, NJ 08723
 (732) 262-1027



Subcode Official Review

To: 210 ROUTE 4 EAST PARAMUS, NJ 07652 CC:

RE: Building Subcode
 Block: 701 Lot: 7 Qual:
 744 ROUTE 70
 Permit Number: Control Number: C-10-000879
 Last Submit Date: Tuesday, April 13, 2010

Date: Wednesday, April 14, 2010

Dear BRICKTOWN VF LLC %VORNADO REALTY,

The following comments were made during the Plan Review process:
 Sign attachment details to be designed by a NJ Professional engineer or architect.
 Wind speed design of minimum 115mph, must be shown on plans.

Sincerely,

Handwritten signature: Kenneth Anderson 4/14/10

Kenneth Anderson, Subcode Official



Brick Township
401 Chambersbridge Rd
Brick, NJ 08723
(732) 262-1027

Subcode Official Review

To: 210 ROUTE 4 EAST PARAMUS, NJ 07652 CC:

RE: Building Subcode
Block: 701 Lot: 7 Qual:
744 ROUTE 70
Permit Number: Control Number: C-10-000879
Last Submit Date: Tuesday, April 13, 2010

Date: Wednesday, April 14, 2010

Dear BRICKTOWN VF LLC %VORNADO REALTY,

The following comments were made during the Plan Review process:


✓ Sign attachment details to be designed by a NJ Professional engineer or architect.

Wind speed design of minimum 115mph, must be shown on plans.

(attached)

44-10
12/13
576-
1208

Sincerely,

 4/14/10

Kenneth Anderson, Subcode Official



Brick Township
401 Chambersbridge Rd
Brick, NJ 08723
(732) 262-1027

Subcode Official Review

To: 210 ROUTE 4 EAST PARAMUS, NJ 07652 CC:

RE: Building Subcode
Block: 701 Lot: 7 Qual:
744 ROUTE 70
Permit Number: Control Number: C-10-000879
Last Submit Date: Tuesday, April 13, 2010

Date: Wednesday, April 14, 2010

Dear BRICKTOWN VF LLC %VORNADO REALTY,

The following comments were made during the Plan Review process:

Sign attachment details to be designed by a NJ Professional engineer or architect.

Wind speed design of minimum 115mph, must be shown on plans.

4/14/10
12 # 843-
576-
1208

Sincerely,

 4/14/10

Kenneth Anderson, Subcode Official

resubmit
4/22/10
