



I. IDENTIFICATION

1. Proposed Work at: HOOPER AVE + BRICK BLVD

2. Owner Name: KENHEPT MALL ASSOC Tel. (201) 467-3100 Frank
Address 241 MILLBURN HUE Millburn N.J.

3. Principal Contractor: Modular Structures Inc Tel. (201) 725 3528
Address Jerseyville New Jersey

Lic. No. or Builder Reg. No. _____ Federal Emp. No. _____

4. Architect or Engineer: Richard Drewes Tel. (201) 840 700
Address 1466 Route 88 West BRICK N.J.

5. Responsible Person in Charge of Work: FRANK COSENTINO Tel. (201) 467 3100
ARCHITECT - MARCETTA 925-4410

II. PROPOSED WORK

A. TYPE OF WORK

1. ☐ Minor Work (Single Trade)
2. ☐ Small Job (\$5,000 and no Prior Approvals)
Complete only II.B., III and IV.A. and Page 2
3. ☐ New Building
4. ☒ Addition
5. ☐ Alteration
6. ☐ Repair, Replacement
7. ☐ Demolition
8. ☐ Other

B. CATEGORIES OF WORK

Permit/Category	Estimated
1. ☒ Building/Structural	<u>\$640,000</u>
2. ☐ Plumbing	_____
3. ☐ Electrical	_____
4. ☐ Fire Protection	_____
5. ☐ Other	_____
6. ☐ Other	_____
TOTAL COST <u>\$640,000</u>	

C. DO YOU WANT:

1. ☐ Partial Releases 2. ☐ Prototype Processing

D. DOES OR WILL YOUR BUILDING CONTAIN ANY OF THE FOLLOWING?

1. ☐ Elevators/Dumbwaiters
2. ☐ High-Pressure Boilers
3. ☐ Refrigeration Systems
4. ☐ Pressure Vessels
5. ☐ Hazardous Uses/Places of Assembly
6. ☐ Cross-connections/Backflow Preventors
7. ☒ Sprinklers
8. ☐ Smoke Control Systems in Open Wells

III. DESCRIPTION OF BUILDING USE (USE GROUPS)

A. RESIDENTIAL

1. ☐ Hotels (R-1)
2. ☐ Multi-Family (R-2)
HMD Reg. No.: _____
3. ☐ Two Family (R-3b)
4. ☐ One-Family (R-3a)
- If new construction, enter no. of dwelling units _____
- If other than new construction, enter no. of dwelling units: _____
- Before Construction: _____
- After Construction: _____
- Net Gain (or loss): _____

B. NON-RESIDENTIAL

5. ☐ Theatres with Stage (A-1-A)
6. ☐ Movie Theatres (A-1-B)
7. ☐ Night Clubs (A-2)
8. ☐ Restaurants, Libraries, Museums (A-3)
9. ☐ Religious Assembly (A-4)
10. ☐ Outdoor Assembly (A-5)
11. ☒ Business (B)
12. ☐ Educational (E)
13. ☐ Moderate-Hazard Factory (F-1)
14. ☐ Low-Hazard Factory (F-2)
15. ☐ High-Hazard (H)
16. ☐ Institutional Detention Center (I-1)
17. ☐ Hospitals, Infirmarys (I-2)
18. ☐ Group Homes (I-3)
19. ☒ Mercantile (M)
20. ☐ Moderate-Hazard Warehouse (S-1)
21. ☐ Low-Hazard Warehouse (S-2)
22. ☐ Temporary, Misc. (U)
23. ☐ Other _____

State Specific Use: addition to existing mall

If Change in Use (), Indicate Former: _____

IV. BUILDING CHARACTERISTICS

A. OWNERSHIP

1. ☒ Private (Individual, Corp., Non-profit Inst., Etc.)
2. ☐ Public (State, County or Local Govt.)

B. HEATING FUEL

Principal	Secondary	Type
3. ☒	☐	Gas
4. ☐	☐	Oil
5. ☐	☐	Electric
6. ☐	☐	Solid (Wood, Coal, Etc.)
7. ☐	☐	Propane
8. ☐	☐	Solar
9. ☐	☐	Other _____

C. TYPE OF SEWAGE DISPOSAL

10. ☒ Public or Private Company
11. ☐ Private (Septic Tank, Etc.)

D. TYPE OF WATER SUPPLY

12. ☒ Public or Private Company
13. ☐ Private (Well, Etc.)

E. BUILDING CHARACTERISTICS

14. No. of Stories 1

15. Height of Structure 18 Ft.

16. Area—Largest Floor 37,900 Sq. Ft.

17. Bldg. Area—All Fls. 31,900 Sq. Ft.

18. Volume of Structure _____ Cu. Ft.

19. Total Land Area Disturbed 60,000 Sq. Ft.


CERTIFICATION IN LIEU OF OATH**I. OWNER SECTION**

I hereby certify that I am the owner of the property listed on Page 1. This dwelling is to be occupied by myself and is not to be used for any purpose, other than single family residential use.

- A. ☐ I further certify that I prepared the plans submitted. This statement is made in accordance with the New Jersey Uniform Construction Code, N.J.A.C. 5:23-2.15(e)vii.
- B. ☐ I further certify that I will perform the work below.
B1. ☐ Building B2. ☐ Electrical B3. ☐ Plumbing
- C. ☐ I further certify that a new home will be constructed on this property, for my use and occupancy. I attest that all design, construction, plumbing, or electrical work will be done by me or by subcontractors under my supervision, in accordance with all applicable laws; and further acknowledge that said new home is not covered under the New Home Warranty and Builders Registration Act (N.J.A.C. 46:3B-1 et. seq.) and that such fact shall be disclosed to any person purchasing this property within ten years of the date of issuance of a certificate of occupancy.
- D. ☐ I agree to advise all contractors on this project that they are required to be registered with the New Jersey Division of Taxation and to comply with all New Jersey tax laws.

I understand that if any of the above statements are willfully false, I am subject to punishment.

SIGNATURE



DATE

Mar 23, 1988

II. AGENT SECTION

I hereby certify that the work is authorized by the owner of record and I have been authorized by the owner to make this application as his agent.

I agree to advise all contractors on this project that they are required to be registered with the New Jersey Division of Taxation and to comply with all New Jersey tax laws.

I understand that if any of the above statements are willfully false, I am subject to punishment.

☐ Check if contractor.

AGENT NAME _____ TEL. () _____

ADDRESS _____

SIGNATURE _____

PERMIT CONTROL

I. PLAN REVIEW STATUS

Updated at time of receipt of drawings and when plans are approved.

- ☐ PARTIAL RELEASES
☐ PROTOTYPE PLAN - FILE LOCATION AND NO.

Plan Review Required	Type of Work	Plans Received By Date	Receiver	Approval Date	Reviewer	Comments
☐	BUILDING			5-18-88	KM	
☒	Footings/Foundations			3/23/88	✓	ED 3-23-88
	Framing					
	Architectural			4/2/88	OK	
	Other			7/20/88	OK	
☒	PLUMBING			7/20/88	OK	
☐	ELECTRICAL					
☐	FIRE PROTECTION			7/20/88	OK	
☐	OTHER					

Footings & Foundations ONLY - 3-23-88

II. PERMIT/INSPECTION STATUS

Updated at time of permit and after final approvals.

Issue Date	Category	Revisions	Final Inspection	Comments
	ALL CONSTRUCTION			Temp OK
	BUILDING			
	Footings/Foundations			
	Framing			
	Architectural			
	Other			
	PLUMBING	OK #13/10-23-89	OK entire site	#10 2/14/89 #76-7-89
	ELECTRICAL			
	FIRE PROTECTION			
	OTHER			

III. CERTIFICATES ISSUED

CERTIFICATES TO BE ISSUED:

- ☒ Temporary Certificate of Occupancy Date Issued 1-4-91
 Date Expired 3/31/91
☐ Temporary Certificate of Occupancy
 Date Expired _____
☐ Certificate of Occupancy
 No. _____
☐ Certificate of Continued Occupancy
 No. _____
☐ Certificate of Approval
 No. _____
☐ None

IV. ON-GOING INSPECTIONS

On-going Inspections Required
 (See Page 1, II.D.)

Date Posted to
 Log and Tickler

V. FEE SUMMARY

Initial fee collection recorded in A; all others in section B.

A. COLLECTED AT TIME OF CONSTRUCTION PERMIT ISSUANCE

BUILDING	4881.77		\$ 4881.77
PLUMBING	1010.00		1010.00
ELECTRICAL			
FIRE PROTECTION	330.00		330.00
OTHER			
	6221.77	SUBTOTAL	\$ 6221.77

- LESS: 20% of subtotal (when plan review performed by state agency) 622.18

D.C.A. TRAINING FEE .0006 x 6221.77 = 3.74

CERTIFICATE OF OCCUPANCY 933.27

OTHER Sprinkler

OTHER

TOTAL COLLECTED WHEN PERMIT ISSUED \$ 8193.66

DATE 8-5-88 Collected By

B. COLLECTED AFTER CONSTRUCTION PERMIT ISSUANCE

Date	Collected By	AMOUNT
CERTIFICATE OF OCCUPANCY		
OTHER		
OTHER		
- LESS: Refunds		()
TOTAL COLLECTED AFTER PERMIT ISSUED		\$

C. TOTAL CONSTRUCTION FEES COLLECTED

	AMOUNT
COLLECTED WITH PERMIT (VA)	\$
COLLECTED AFTER PERMIT (VB)	\$
TOTAL	\$



CERTIFICATE

Date Issued 1/4/91
Control #
Permit # 2156

IDENTIFICATION

Block 670 Lot 4, 5, 8, 23, 25
Work Site Location Hooper Ave. Kennedy Mall
Brick, N.J.
Owner in Fee Kennedy Mall Assoc.
Address 241-A Millburn Ave.
Millburn, N.J. 07041
Tele. ()
Contractor Modular Structures
Address
Tele. ()
Lic. No. or Bldrs. Reg. No.
Federal Emp. No.
or Social Security No.

Home Warranty No. N/A
Use Group B (retail) 2 hours
Maximum Live Load
Description of Work/Use:

Addition to existing mall
(shell only)

Type of Warranty Plan: [] State [] Private
Construction Classification
Maximum Occupancy Load

CERTIFICATE OF OCCUPANCY/APPROVAL

☐ CERTIFICATE OF OCCUPANCY

This serves notice that said building, structure, or equipment has been constructed or installed in accordance with the New Jersey Uniform Construction Code, and is approved for use and/or occupancy.

☐ CERTIFICATE OF CONTINUED OCCUPANCY

This serves notice that based on a general inspection of the visible parts of the building there are no imminent hazards and the building is approved for continued occupancy.

☒ TEMPORARY CERTIFICATE OF OCCUPANCY

If this is a Temporary Certificate of Occupancy the following conditions must be met no later than March 31, 19 91 or the owner will be subject to a fine or order to vacate: or until entire site is occupied. As per list attached.

*extend to
6-30-92
af*

CONSTRUCTION OFFICIAL

Arthur J. George

Fee \$
Paid [] Check No.
Collected by:

TOWNSHIP OF BRICK



BUILDING SUBCODE TECHNICAL SECTION



PERMIT NO. 2156
 DATE ISSUED 8-5-88
 REVISION DATE _____
 Block 676 Lot 4-5-8-23-25
 Subdivision _____

A. IDENTIFICATION

APPLICANT - Complete unshaded areas only When changing contractors, notify this office
 Owner HEHEBY MALL ASSOC Contractor _____
 Address 241 MILLBURN RD Address _____
MILBURN NJ, 07041
 Tel. (201) 467-3100 Tel. () _____
 Work Site Address HOOPER AVE + BRICK BLVD Lic. No. _____
 Federal Emp. No. _____

CERTIFICATION IN LIEU OF OATH:
 (Complete for Minor Work and Small Job Only)
 I hereby certify that the proposed work is authorized by the owner of record and I have been authorized by the owner to make this application as his agent.
 AGENT SIGNATURE _____

B. TECHNICAL SITE DATA

DESCRIPTION OF WORK Give detail description including materials used, dimensions, etc.
31,400 ADDITION
4 SITE WORK

TYPE OF WORK:	Fee Basis	Fee
☐ New Building		
☒ Addition		
☐ Alteration/Renovation		
☐ Roofing		
☐ Siding		
☐ Other _____		
☐ Demolition		
☐ Miscellaneous		
☐ Fence		
☐ Sign		
☐ Pool		
☐ Elevator		
☐ Other <u>3,474.00</u>		
SUBTOTAL	\$	
Minimum Building Fee (if applicable)	\$	
Total Building Fee (Greater of Minimum or Subtotal)	\$	

C. BUILDING CHARACTERISTICS

USE GROUP: _____ Present _____ Proposed _____
 No. of Stories _____ Total Building Area-All Floors _____ Sq. Ft.
 Height of Structure _____ Ft. Volume of Structure _____ Cu. Ft.
 Area-Largest Floor _____ Sq. Ft. Total Land Area Disturbed _____ Sq. Ft.
 Estimated Cost of Building Work: \$ 640,000

D. COMMENTS

☐ Partial Releases ☐ Prototype Processing

ready



Date Received
Date Issued
Control #
Permit #

001693

Brick

A. IDENTIFICATION—APPLICANT: COMPLETE ALL APPLICABLE INFORMATION, WHEN CHANGING CONTRACTORS, NOTIFY THIS OFFICE. CALL UTILITY DIG NO: 1-800-272-1000.

Block 670 Lot 4

Work Site Location Kennedy Mall Lower Westside

Owner in Fee [Redacted]

Address [Redacted]

Contractor T.C. House Electrical

Address 399 Joyce Avenue Apt 2

Tele. (908) 846 1414

Lic. No. 5389

Federal Emp. No. 22-2428427 or Social Security No. [Redacted]

B. ELECTRICAL CHARACTERISTICS

☐ Reinspection ☒ Resale ☐ Meter Set

☐ Pole/Pad # [Redacted] ☒ Temporary ☐ Other

Building Occupied as Temple Utility Co. JSCE

Est. Cost of Elec. Work \$ 1000-

JOB SUMMARY (Office Use Only)

PLAN REVIEW: ☐ No Plans Required ☐ Joint Plan Review Required

☐ Bldg. ☐ Plumb. ☐ Fire ☐ Elec. Plans Approved

Date: 5-22-91 Approved by: [Signature]

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner of record and am authorized to make this application and perform the work listed on this application

D. TECHNICAL SITE DATA

NO. SIZE

FEE (Office Use Only)

Fixtures (1) 91
Receptacles (2) 28
Switches (3) 13
Total 1 + 2 + 3 27

Range [Redacted]

Oven(s) [Redacted]

Surface Unit [Redacted]

Dishwasher [Redacted]

Garbage Disposal [Redacted]

Dryer [Redacted]

A/C Unit [Redacted]

Burglar Alarms [Redacted]

Intercoms Panels [Redacted]

Smoke Detectors [Redacted]

Whirlpool/spa [Redacted]

Pool Bonding [Redacted]

Pool Filter Motor [Redacted]

Pool Lights [Redacted]

Water Heater(s) [Redacted]

Central heat: [Redacted]

oil, gas or elec. [Redacted]

Baseboard Heat Units [Redacted]

Thermostats [Redacted]

Heat Pump [Redacted]

Pump(s) [Redacted]

Motor Control Center/Sub Panels [Redacted]

Signs [Redacted]

Light Standards [Redacted]

Motors—Fractional H.P. [Redacted]

Motors—All Others [Redacted]

Transformers [Redacted]

Generators [Redacted]

Service Entrance 2004 3p

Other [Redacted]

Paid ☒ Check # 4015 Administrative Surcharge \$ [Redacted]

Collected by: [Redacted] Minimum Fee \$ [Redacted]

TOTAL FEE \$ 20-

U.C.C. Form F-120A

1 White - Inspector Copy
2 Pink - Office Copy
3 Gold - Applicant Copy

Check of compliance



ELECTRICAL
SUBCODE
TECHNICAL SECTION



Date Received
Date Issued
Control #
Permit #

D. TECHNICAL SITE DATA

FEE (Office Use Only)

A. IDENTIFICATION—APPLICANT: COMPLETE ALL APPLICABLE INFORMATION. WHEN CHANGING CONTRACTORS, NOTIFY THIS OFFICE. CALL UTILITY DIG NO: 1-800-272-1000.

Block 670

Work Site Location LOWES COUNTRY CENTER 5

2760 HOOVER AVE BRICK TOWNSHIP 08723-3102

Owner In Fee

Addr

Tele

Contractor SHAN ELECTRICAL INC.

Address 51 SILVER LAKE BLVD.

SAVILLE NJ 08741

Tele (908) 869-0999

Lic. No. 9575

Federal Emp. No. 22-3071675 or Social Security No.

B. ELECTRICAL CHARACTERISTICS

☐ Reinspection ☐ Resale ☐ Meter Set
☐ Pole/Pad # ☐ Temporary ☐ Other Sound System
Building Occupied as Utility Co.
Est. Cost of Elec. Work \$ 9,500.00

JOB SUMMARY (Office Use Only)

PLAN REVIEW:		INSPECTIONS:		Dates (Month/Day)	
	Type:	Failure	Failure	Approval	Initial
☐ No Plans Required					
☐ Joint Plan Review Required:					
☐ Bldg. ☐ Plumb. ☐ Fire	Rough				
☐ Elec. Plans Approved	Temporary				
Date:	Constr. Serv.				
	TCO				
Approved by:	Other				
	Service				
	Final				
SUBCODE APPROVAL:					
170011880 by CA	Temp. Cut-in-Card Date Issued	1/25/91	1/24	1/20/91	
Date: 1/11/88	Final Cut-in-Card Date Issued	1/20/91	1/24	1/20/91	
Approved by: B. Raeburn	Line Dept.				

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner of record and am authorized to make this application and perform the work listed on this application.

☐ Licensed Electrical Contractor ☐ Exempt Applicant

Signature-Contractor Seal

Paid ☒ Check # 1754	Administrative Surcharge	\$
Collected by: 1984	Minimum Fee	\$
	TOTAL FEE	\$ 54.-

DEC 26 1984



FIRE SUBCODE TECHNICAL SECTION



PERMIT NO.	2156
DATE ISSUED	8-5-88
REVISION DATE	
Block	670 Lot 4-58-23-2
Subdivision	

A. IDENTIFICATION

APPLICANT - Complete unshaded areas only	When changing contractors, notify this office
Owner <u>Kennedy Mill Assoc</u>	Contractor <u>National Fire Protection Co</u>
Address <u>2414 Millburn Ave</u>	Address <u>24 At Phoebeville Pike</u>
<u>Millburn N.J. 07041</u>	<u>Millburn Pa</u>
Tel. <u>201, 467-3100</u>	Tel. <u>215, 647-8038</u>
Work Site Address _____	Lic. No. _____
	Federal Emp. No. <u>23-1943002</u>

CERTIFICATION IN LIEU OF OATH:
(Complete for Minor Work and Small Job Only)

I hereby certify that the proposed work is authorized by the owner of record and I have been authorized by the owner to make this application as his agent.

AGENT SIGNATURE _____

B. TECHNICAL FIRE DATA

B1. SPRINKLERS

TYPE: ☐ Wet ☒ Dry ☐ Other _____	FEE
Area Sprinkled: ☒ Full ☐ Partial (specify in comments) <u>20 sq ft</u>	
No. of Heads <u>12</u>	No. of Spare Heads: _____
☐ Valves Supervised - Method: _____	Size: <u>8"</u>
Water Supply - Source: <u>City</u>	
FD Connection Location: <u>Ken S.W.</u>	
Estimated Cost of Work: \$ <u>600.00</u>	\$ <u>300.00</u>

B3. ALARM

TYPE: ☐ Manual ☒ Automatic	FEE
Supervision Type: ☒ Local ☐ Central	
☐ Proprietary ☐ Remote Location	
Estimated Cost of Work: \$ _____	\$ <u>30</u>

B4. STAND PIPES

Pipe Size: _____	Pump Size: _____
Water Source: _____	Size: _____
FD Connection Location: _____	
Hose Station: ☐ Yes ☐ No	
Estimated Cost of Work: \$ <u>174</u>	\$ _____

B5. OTHER

<u>fee for sprinkles only</u>	\$ <u>300</u>
<u>for better doors</u>	\$ _____

Minimum Fire Protection Fee (If Applicable)	Subtotal
Total Fire Protection Fee (Greater of Minimum or Subtotal)	\$ <u>330.00</u>

C. FIRE PROTECTION CHARACTERISTICS

USE GROUP _____	Present _____	Proposed _____
Heating Systems - Location: _____		
Type: ☐ Gas ☐ Oil ☐ Electrical ☐ Solar ☐ Other _____		
Fuel Storage Tank - Location: _____	Fuel Type: _____	Capacity: _____
Total Estimated Cost of Fire Protection Work: \$ _____		

D. COMMENTS

Drawings used to follow
made app. for test.

☐ Partial Releases ☐ Prototype Processing



UNIFORM
CONSTRUCTION
CODE

PERMIT NO. 2156
DATE ISSUED 8-5-88
REVISION DATE _____
Block 670 Lot 45, 8, 23, 25
Subdivision _____

When changing contractors, notify this office

CERTIFICATION IN LIEU OF OATH:
(Complete for Minor Work and
Small Job Only)

I hereby certify that the proposed work
is authorized by the owner of record
and I have been authorized by the
owner to make this application as his
agent.

William R. Dunham

AGENT SIGNATURE

CARD WITH FEES FOR ~~TOTAL~~ BUILDING

[illegible]

USE GROUP:	<u>States</u>	Present	Proposed

Drainage -	Material	Sch 40 PVC	Size	1 1/2 - 4
Building Sewer -	Material	SDR 35	Size	4"
Water Service -	Material	160 PSI	Size	1"
Venting -	Material	Sch 40	Size	1 1/2 - 2
Estimated Cost of Plumbing Work: \$				

H.C.

☐ Partial Releases ☐ Prototype Processing

Work Site Address Hooper +
BRICK BLD UNIT 1
Lic.No./Bus. Permit 1727
Federal Emp. No. 22-1853417

AGENT SIGNATURE William R. Dwyer

4

No.	Fixture	Fee	No.	Fixture	Fee	Fee
1	Water Closet/ Bidet/Tub	\$		Garbage Disposal	\$	COLUMN 1 \$
	Bathub			Air Conditioner Unit		COLUMN 2 \$
1	Lavatory/ Sink			Indirect Connection		SUBTOTAL \$
	Shower/Floor Drain			Sewer Ejector		Minimum Plumbing Fee
	Washing Machine			Grease Trap		(If applicable)
	Dishwasher			Interceptor		Total Plumbing Fee
	Commercial Dishwasher			Backflow Device		(Greater of Minimum
1	Water Heater			Reduced Pressure		or Subtotal)
1	Domestic Boiler/ Furnace		1	Backflow Device		
	Steam Boiler			Vent Stack		
1	Water Util. Connection		1	Solar System		
1	Sewer Util. Connection			Other <u>Gas</u>		
	Hose Bibb			Other		
	Water Cooler			Other		
				Other		
	COLUMN 1 \$					
				COLUMN 2 \$		

FEES INCLUDED IN THIS SECTION FOR
TOTAL BUILDING.

☐ Partial Releases

Prototype Processing

PERMIT NO. 2156
DATE ISSUED 8-5-88
REVISION DATE _____
Block 670 Lot 4, 5, 8, 23, 25
Subdivision _____

When changing contractors, notify this office

Contractor PINELAND PLBG. & Htg., INC.
Address 807 MANTOLOKING RD.
BRICK TOWNSHIP, N.J. 08723
Tel. () 201 477-0854
Lic./No./Bus. Permit 1772
Federal Emp. No. 22-1853417

I hereby certify that the proposed work is authorized by the owner of record and I have been authorized by the owner to make this application as his agent.

Walter R. Dwyer
AGENT SIGNATURE

2#

No.	Fixture	Fee	No.	Fixture	Fee	Fee
1	Water Closer/Bidet/ Sink	\$_____		Garbage Disposal	\$_____	COLUMN 1 \$_____
	Bathub	_____		Air Conditioner Unit	_____	COLUMN 2 \$_____
1	Lavatory/ Sink	_____		Indirect Connection	_____	SUBTOTAL \$_____
	Shower/Floor Drain	_____		Sewer Ejector	_____	Minimum Plumbing Fee (If applicable) \$_____
	Washing Machine	_____		Grease Trap	_____	Total Plumbing Fee (Greater of Minimum or Subtotal) \$_____
	Dishwasher	_____		Interceptor	_____	
	Commercial Dishwasher	_____		Backflow Device	_____	
1	Water Heater	_____		Reduced Pressure Backflow Device	_____	
1	Domestic Boiler/ Furnace	_____	1	Vent Stack	_____	
	Steam Boiler	_____		Solar System	_____	
1	Water Util. Connection	_____	1	Other Gas	_____	
1	Sewer Util. Connection	_____		Other _____	_____	
	Hose Bibb	_____		Other _____	_____	
	Water Cooler	_____		Other _____	_____	
	COLUMN 1 \$_____			COLUMN 2 \$_____		

Proposed

D. COMMENTS

Fee included in total building

☐ Partial Releases


Fee included in tech section for total building.

☐ Partial Releases ☐ Prototype Processing



PLUMBING SUBCODE

TECHNICAL SECTION



PERMIT NO. 2156
 DATE ISSUED 8-5-88
 REVISION DATE _____
 Block 670 Lot 4, 5, 8, 23, 25
 Subdivision _____

A. IDENTIFICATION

APPLICANT - Complete unshaded areas only

When changing contractors, notify this office

Owner Kennedy Mall Associates

Contractor PINELAND PLBG. & HTG., INC.

Address 241A Millburn Ave.

Address 807 MANTOLOKING RD.

Millburn, NJ 07041

BRICK TOWNSHIP, N.J. 08723

Tel. () _____

Tel. () 201 477-0854

Work Site Address Hooper & Brick Blvd. UNIT 3

Lic.No./Bus. Permit 1722

Hooper & Brick Blvd. UNIT 3

Federal Emp. No. 22-1853417

CERTIFICATION IN LIEU OF OATH:

(Complete for Minor Work and Small Job Only)

I hereby certify that the proposed work is authorized by the owner of record and I have been authorized by the owner to make this application as his agent.

W. R. Dwyer
 AGENT SIGNATURE

B. TECHNICAL SITE DATA

List all fixtures

TYPE OF WORK: New

3

No.	Fixture	Fee	No.	Fixture	Fee	No.	Fee
1	Water Closet/Bidet/Urinal	\$		Garbage Disposal	\$	COLUMN 1	\$
	Bathrub			Air Conditioner Unit		COLUMN 2	\$
1	Lavatory/Sink			Indirect Connection		SUBTOTAL	\$
	Shower/Floor Drain			Sewer Ejector		Minimum Plumbing Fee	\$
	Washing Machine			Grease Trap		(if applicable)	\$
	Dishwasher			Interceptor		Total Plumbing Fee	\$
	Commercial Dishwasher			Backflow Device		(Greater of Minimum or Subtotal)	\$
1	Water Heater			Reduced Pressure			
	Domestic Boiler/			Backflow Device			
	Furnace			Vent Stack			
	Steam Boiler			Solar System			
1	Water Util. Connection		1	Other <u>Gas</u>			
1	Sewer Util. Connection			Other			
	Hose Bibb			Other			
	Water Cooler			Other			
COLUMN 1		\$	COLUMN 2		\$		

C. PLUMBING CHARACTERISTICS

USE GROUP: Store Present _____ Proposed _____
 Drainage - Material PVC Size 40 Size 1 1/2-3
 Building Sewer - Material PVC Size 40 Size 4
 Water Service - Material 1 1/2 Poly Size 1
 Venting - Material PVC Size 40 Size 1 1/2-2
 Estimated Cost of Plumbing Work: \$ _____

D. COMMENTS

Fee included in tech section for total building.

☐ Partial Releases

☐ Prototype Processing

Subdivision _____

Federal Emp. No. 22-1853417

AGENT SIGNATURE William R. Dwyer

47

	Fee
COLUMN 1	\$ _____
COLUMN 2	\$ _____
SUBTOTAL	\$ _____
Minimum Plumbing Fee (If applicable)	\$ _____
Total Plumbing Fee (Greater of Minimum or Subtotal)	\$ _____

Estimated Cost of Plumbing Work: \$

Fee included in tech section for total building.

☐ Partial Releases ☐ Prototype Processing

TOWNSHIP OF BRICK



PLUMBING SUBCODE TECHNICAL SECTION



PERMIT NO. 2156
 DATE ISSUED 8-5-85
 REVISION DATE _____
 Block 670 Lot 4, 5, 8, 23, 25
 Subdivision _____

A. IDENTIFICATION

APPLICANT — *Complete unshaded areas only* When changing contractors, notify this office

Owner Kennedy Mall Associates Contractor PINELAND PLBG. & HTG. INC.
 Address 241A Millburn Ave. Address 807 MANTOLOKING RD.
Millburn, NJ 07041 BRICK TOWNSHIP, N.J. 08723
 Tel. () _____ Tel. () _____ 201 477-0854
 Work Site Address _____ Lic. No./Bus. Permit 1722
Hooper & Brick Blvd. UNIT 5 Federal Emp. No. 22-1853417

CERTIFICATION IN LIEU OF OATH:

(Complete for Minor Work and
Small Job Only)

I hereby certify that the proposed work is authorized by the owner of record and I have been authorized by the owner to make this application as his agent.

William R. Dwyer
AGENT SIGNATURE

B. TECHNICAL SITE DATA

List all fixtures

TYPE OF WORK: NEW

No.	Fixture	Fee	No.	Fixture	Fee	Fee
1	Water Closet/ Bidet / <u>Urinal</u>	\$		Garbage Disposal	\$	COLUMN 1
	Bath tub			Air Conditioner Unit		COLUMN 2
1	Lavatory/ Sink			Indirect Connection		SUBTOTAL \$
	Shower/Floor Drain			Sewer Ejector		Minimum Plumbing Fee
	Washing Machine			Grease Trap		(If applicable)
	Dishwasher			Interceptor		Total Plumbing Fee
1	Commercial Dishwasher			Backflow Device		(Greater of Minimum
	Water Heater			Reduced Pressure		or Subtotal)
1	Domestic Boiler/ <u>Turnover</u>		1	Backflow Device		
	Steam Boiler			Vent Stack		
1	Water Util. Connection		1	Solar System		
	Sewer Util. Connection			Other <u>G43</u>		
1	Hose Bibb			Other		
	Water Cooler			Other		
	COLUMN 1	\$		COLUMN 2	\$	

C. PLUMBING CHARACTERISTICS

USE GROUP: STONE Present Proposed

Drainage — Material Pvc 40 Size 1 1/2-3

Building Sewer — Material " 4 Size 4

Water Service — Material 160 Pvc 1 Size 1

Venting — Material Pvc 40 Size 1 1/2-2

Estimated Cost of Plumbing Work: \$

D. COMMENTS

Fee included in tech section for
total building.

☐ Partial Releases

☐ Prototype Processing

TOWNSHIP OF BRICK



PLUMBING SUBCODE TECHNICAL SECTION



PERMIT NO. 2156
 DATE ISSUED 8-5-88
 REVISION DATE _____
 Block 670 Lot 4, 5, 8, 23, 25
 Subdivision _____

A. IDENTIFICATION

APPLICANT - Complete unshaded areas only

When changing contractors, notify this office

Owner Kennedy Mall Associates'Contractor PINELAND PLBG. & HTG., INC.Address 241A Millburn Ave.Address 807 MANTOLOKING RD.Millburn, NJ 07041BRICK TOWNSHIP, N.J. 08723

Tel. (____) _____

Tel. (____) 201 477-0854

Work Site Address _____

Lic.No./Bus. Permit 22-1853417Hooper & Brick Blvd. UNIT 6

Federal Emp. No. _____

CERTIFICATION IN LIEU OF OATH:

(Complete for Minor Work and
Small Job Only)

I hereby certify that the proposed work
is authorized by the owner of record
and I have been authorized by the
owner to make this application as his
agent.

William R. Dwyer
AGENT SIGNATURE

B. TECHNICAL SITE DATA

List all fixtures

TYPE OF WORK: New

No.	Fixture	Fee	No.	Fixture	Fee	Fee
1	Water Closet/Bath	\$		Garbage Disposal	\$	COLUMN 1 \$
	Bath tub			Air Conditioner Unit		COLUMN 2 \$
1	Lavatory/Sink			Indirect Connection		SUBTOTAL \$
	Shower/Floor Drain			Sewer Ejector		Minimum Plumbing Fee (if applicable) \$
	Washing Machine			Grease Trap		Total Plumbing Fee (Greater of Minimum or Subtotal) \$
	Dishwasher			Interceptor		
	Commercial Dishwasher			Backflow Device		
1	Water Heater			Reduced Pressure Backflow Device		
1	Domestic Boiler/ Furnace		1	Vent Stack		
	Steam Boiler			Solar System		
1	Water Util. Connection		1	Other <u>GAS</u>		
1	Sewer Util. Connection			Other		
	Hose Bibb			Other		
	Water Cooler			Other		
COLUMN 1 \$			COLUMN 2 \$			

C. PLUMBING CHARACTERISTICS

USE GROUP: Store Present _____ Proposed _____

Drainage - Material PVC 40 Size 1 1/2-3

Building Sewer - Material PVC 40 Size 4

Water Service - Material 1 1/2 Poly Size 1

Venting - Material PVC 40 Size 1 1/2-2

Estimated Cost of Plumbing Work: \$ _____

D. COMMENTS

Fee included in tech section for
total building.

☐ Partial Releases ☐ Prototype Processing



UNIFORM
CONSTRUCTION
CODE

PERMIT NO. 2156
DATE ISSUED 8-5-88
REVISION DATE _____
Block 670 Lot 4,5,8,23,25
Subdivision _____

When changing contractors, notify this office

Lic.No./Bus. Permit 1122
Federal Emp. No. 22-1853417

**CERTIFICATION IN LIEU OF OATH:
(Complete for Minor Work and
Small Job Only)**

I hereby certify that the proposed work is authorized by the owner of record and I have been authorized by the owner to make this application as his agent.

AGENT SIGNATURE

井

No.	Fixture	Fee	No.	Fixture	Fee	Fee
1	Water Closet/ Bidet <u>Urinal</u>	\$		Garbage Disposal	\$	COLUMN 1 \$
	Bath tub			Air Conditioner Unit		COLUMN 2 \$
1	Lavatory/ Sink			Indirect Connection		SUBTOTAL \$
	Shower/Floor Drain			Sewer Ejector		Minimum Plumbing Fee (If applicable)
	Washing Machine			Grease Trap		\$
	Dishwasher			Interceptor		
	Commercial Dishwasher			Backflow Device		Total Plumbing Fee (Greater of Minimum or Subtotal)
1	Water Heater			Reduced Pressure Backflow Device		\$
1	Domestic Boiler/ Furnace		1	Vent Stack		
	Steam Boiler			Solar System		
1	Water Util. Connection		1	Other <u>Gas</u>		
	Sewer Util. Connection			Other		
	Hose Bibb			Other		
	Water Cooler			Other		
COLUMN 1 \$			COLUMN 2 \$			

USE GROUP: STOA Present _____ Proposed _____

Drainage --	Material	PVC	40	Size	1 1/2" - 3
Building Sewer --	Material	PVC	40	Size	4
Water Service --	Material	160	PVC	Size	1
Venting --	Material	PVC	40	Size	1 1/2" - 2
Estimated Cost of Plumbing Work: \$					

D. COMMENTS

☐ Partial Releases ☐ Prototype Processing

#8

INTERNATIONAL CODE COUNCIL
UNIFORM CONSTRUCTION CODE

PERMIT NO. 2/56
DATE ISSUED 8-5-88
REVISION DATE _____
Block 670 Lot 4, 5, 8, 23, 25
Subdivision _____

When changing contractors, notify this office

CERTIFICATION IN LIEU OF OATH:
(Complete for Minor Work and
Small Job Only)

I hereby certify that the proposed work
is authorized by the owner of record
and I have been authorized by the
owner to make this application as his
agent.

Wesley R. Dwyer
AGENT SIGNATURE

6 ~~7~~

No.	Fixture	Fee	No.	Fixture	Fee	Fee
1	Water Closer/Bidet/Urinal	\$		Garbage Disposal	\$	COLUMN 1
	Bathub			Air Conditioner Unit		COLUMN 2
1	Lavatory/Sink			Indirect Connection		SUBTOTAL \$
	Shower/Floor Drain			Sewer Ejector		Minimum Plumbing Fee
	Washing Machine			Grease Trap		(If applicable)
	Dishwasher			Interceptor		Total Plumbing Fee
	Commercial Dishwasher			Backflow Device		(Greater of Minimum
1	Water Heater			Reduced Pressure		or Subtotal)
1	Domestic Boiler/ Furnace		1	Backflow Device		\$
				Vent Stack		
	Steam Boiler			Solar System		
1	Water Util. Connection		1	Other GAS		
	Sewer Util. Connection			Other		
	Hose Bibb			Other		
	Water Cooler			Other		
	COLUMN 1	\$		COLUMN 2	\$	

USE GROUP: Strane Present _____ Proposed _____

Fee included in tech section for total building.

☐ Partial Releases ☐ Prototype Processing

22-100041 /

AGENT SIGNATURE William A. Dwyer

Estimated Cost of Plumbing Work: \$ _____

☐	Partial Releases	☐	Prototype Processing
--------------------------	------------------	--------------------------	----------------------

8/12

PERMIT NO. 2156
DATE ISSUED 8-5-88
REVISION DATE _____
Block 670 Lot 4, 5, 8, 23, 25
Subdivision _____

When changing contractors, notify this office

Owner	Kennedy Mall Associates	Contractor	PINELAND PLBG. & HTG., INC.
Address	241A Millburn Ave.	Address	807 MANTOLOKING RD.
	Millburn, NJ 07041		BRICK TOWNSHIP, N.J. 08723
Tel. ()		Tel. ()	201 477-0854
Work Site Address		Lic./No./Bus. Permit	1722
Hooper & Brick BLVD.	201711	Federal Emp. No.	22-1853417

**CERTIFICATION IN LIEU OF OATH:
(Complete for Minor Work and
Small Job Only)**

I hereby certify that the proposed work is authorized by the owner of record and I have been authorized by the owner to make this application as his agent.

AGENT SIGNATURE William R. Dwyer

TYPE OF WORK: *new*

11/4

TYPE OF WORK:

No.	Fixture	Fee	No.	Fixture	Fee	Fee
1	Water Closet/ Bidet / Toilet	\$		Garbage Disposal	\$	COLUMN 1 \$
	Bathub			Air Conditioner Unit		COLUMN 2 \$
1	Lavatory/ Sink			Indirect Connection		SUBTOTAL \$
	Shower/Floor Drain			Sewer Ejector		Minimum Plumbing Fee (if applicable) \$-
	Washing Machine			Grease Trap		Total Plumbing Fee (Greater of Minimum or Subtotal) \$
	Dishwasher			Interceptor		
1	Commercial Dishwasher			Backflow Device		
1	Water Heater			Reduced Pressure Backflow Device		
1	Domestic Boiler/ <u>Furnace</u>		1	Vent Stack		
	Steam Boiler			Solar System		
1	Water Util. Connection		1	Other <u>Gas</u>		
	Sewer Util. Connection			Other		
	Hose Bibb			Other		
	Water Cooler			Other		
	COLUMN 1 \$			COLUMN 2 \$		

USE GROUP: Steel Present _____ Proposed _____

Drainage —	Material	Pvc	40	Size	1 1/2-3
Building Sewer—	Material	Pvc	40	Size	4
Water Service—	Material	160 Poly		Size	1
Venting —	Material	Pvc	40	Size	1 1/2-2
Estimated Cost of Plumbing Work: \$ _____					

Fee included in tech section for total building.

☐ Partial Releases

Prototype Processing

Block 670 Lot 4, 5, 8, 23, 25
Subdivision _____

When changing contractors, notify this office

22-1853417
Federal Emp. No.

12

Fee	
COLUMN 1	\$ _____
COLUMN 2	\$ _____
SUBTOTAL	\$ _____
Minimum Plumbing Fee (If applicable)	\$ _____
Total Plumbing Fee (Greater of Minimum or Subtotal)	\$ _____

1

☐ Prototype Processing

AGENT SIGNATURE William R. Dwyer



PLUMBING SUBCODE TECHNICAL SECTION



PERMIT NO. 2156
DATE ISSUED 8-5-88
REVISION DATE _____
Block 670 Lot 4,5,8,23,25
Subdivision _____

A. IDENTIFICATION

APPLICANT — *Complete unshaded areas only*

When changing contractors, notify this office

Owner Kennedy Mall Associates Contractor PINELAND PLBG. & HTG., INC.
Address 241A Millburn Ave. Address 807 MANTOLOKING RD.
Millburn, NJ 07041 BRICK TOWNSHIP, N.J. 08723
Tel. (____) _____ Tel. (____) 201 477-0854
Work Site Address _____ Lic. No./Bus. Permit 22-1853417 1722
Hooper & Brick Blvd. UNIT 13 Federal Emp. No. _____

CERTIFICATION IN LIEU OF OATH:

(Complete for Minor Work and Small Job Only)

I hereby certify that the proposed work is authorized by the owner of record and I have been authorized by the owner to make this application as his agent.

William R. Dwyer
AGENT SIGNATURE

B. TECHNICAL SITE DATA

List all fixtures

TYPE OF WORK: Rem

13

No.	Fixture	Fee	No.	Fixture	Fee	Fee
1	Water Closet/Bidet/Urinal	\$		Garbage Disposal	\$	COLUMN 1 \$
	Bathub			Air Conditioner Unit		COLUMN 2 \$
1	Lavatory/Sink			Indirect Connection		SUBTOTAL \$
	Shower/Floor Drain			Sewer Ejector		Minimum Plumbing Fee (if applicable) \$
	Washing Machine			Grease Trap		Total Plumbing Fee (Greater of Minimum or Subtotal) \$
	Dishwasher			Interceptor		
	Commercial Dishwasher			Backflow Device		
1	Water Heater			Reduced Pressure Backflow Device		
1	Domestic Boiler/ Furnace		1	Vent Stack		
	Steam Boiler			Solar System		
1	Water Util. Connection		1	Other <u>Gas</u>		
	Sewer Util. Connection			Other		
1	Hose Bibb			Other		
	Water Cooler			Other		
COLUMN 1 \$			COLUMN 2 \$			

C. PLUMBING CHARACTERISTICS

USE GROUP: Store Present _____ Proposed _____
Drainage — Material PVC 40 Size 1 1/4-3
Building Sewer — Material PVC 40 Size 4
Water Service — Material 160 Poly 1 Size 1
Venting — Material PVC 40 Size 1 1/2-2
Estimated Cost of Plumbing Work: \$ _____

D. COMMENTS

Fee included in tech section for total building.

☐ Partial Releases ☐ Prototype Processing

☐ Partial Releases ☐ Prototype Processing

PERMIT NO. 2156
DATE ISSUED 8-5-88
REVISION DATE _____
Block 670 Lot 4, 5, 8, 23, 25
Subdivision _____

When changing contractors, notify this office

Contractor PINELAND PLBG. & HTG., INC.

Address 807 MAIN BLOCKING RD.

BRICK TOWNSHIP, N.J. 08723

Tel. () 201 477-0854

Lic.No./Bus. Permit 11A
22 1823417

44-1033417
Federal Emp. No. _____

TYPE OF WORK: *News*

#15

TYPE OF WORK:

[illegible]

USE GROUP: Steel Present _____ Proposed _____

Proposed

Proposed

1

1

1

1

Fee included in tech section for total building.

☐ Partial Releases

Prototype Processing

CERTIFICATION IN LIEU OF OATH:
(Complete for Minor Work and

Small Job Only

I hereby certify that the proposed work is authorized by the owner of record and I have been authorized by the owner to make this application as his agent.

AGENT SIGNATURE

TOWNSHIP OF BRICK



BUILDING SUBCODE TECHNICAL SECTION



PERMIT NO. 4136
 DATE ISSUED 8-3-88
 REVISION DATE _____
 Block 610 Lot 4
 Subdivision _____

A. IDENTIFICATION

APPLICANT - Complete unshaded areas only When changing contractors, notify this office
 Owner KEVIN P. MALLINSON Contractor _____
 Address 241 MILLBORN RD Address _____
MILBORN N.J. 07041
 Tel. (201) 417-3100 Tel. () _____
 Work Site Address HOOPER RD + BRICK Bldg Lic. No. _____
 Federal Emp. No. _____

CERTIFICATION IN LIEU OF OATH:
 (Complete for Minor Work and Small Job Only)
 I hereby certify that the proposed work is authorized by the owner of record and I have been authorized by the owner to make this application as his agent.
 AGENT SIGNATURE _____

B. TECHNICAL SITE DATA

DESCRIPTION OF WORK Give detail description including materials used, dimensions, etc.
31,400 sq. ft. 40017000
4017000
TYPE OF WORK:
☐ New Building
☒ Addition
☐ Alteration/Renovation
☐ Roofing
☐ Siding
☐ Other _____
☐ Demolition
☐ Miscellaneous
☐ Fence
☐ Sign
☐ Pool
☐ Elevator
☐ Other _____
 Fee Basis _____ Fee _____
 SUBTOTAL \$ _____
 Minimum Building Fee (if applicable) \$ _____
 Total Building Fee (Greater of Minimum or Subtotal) \$ _____
☐ See Plans

C. BUILDING CHARACTERISTICS

USE GROUP: Present _____ Proposed _____
 No. of Stories _____ Total Building Area-All Floors _____ Sq. Ft.
 Height of Structure _____ Ft. Volume of Structure _____ Cu. Ft.
 Area-Largest Floor _____ Sq. Ft. Total Land Area Disturbed _____ Sq. Ft.
 Estimated Cost of Building Work: \$ 640,000

D. COMMENTS

☐ Partial Releases ☐ Prototype Processing

PLAN REVIEW AND INSPECTION — BUILDING

DATE

JOB CONDITION/COMMENTS

4/14/88 FOOTING FULL OF WATER MUST PUMP ~~full~~
 6/8/88 Footing back wall only O.K. - J.C.
 6-15-88 FOOTING O.K. TO POOR ~~full~~
 6-17-88 FOOTING O.K. FRONT ~~full~~
 6-28-88 FOOTING FRONT OVER HAN'E PIERS ~~full~~
 7/19/88 Footing - remainder of back wall - O.K.
 11-14-88 Called Richard & Bruce architect was told will not
 Partise trust's ~~full~~
 12-6-88 FRAMING INSP. NO ROOF ON ~~full~~
 12-14-88 Trusses O.K. to insul. from left side of bldg. to middle of structure
 12-15-88 FOOTING INSP. NOT EXCAVATED - 20" DEEP WSP FEE. ~~full~~
 12-16-88 Remainder of room O.K. to insulate bottom of truss ~~full~~

Fire Grading:

Maximum Live Load:

Maximum Occupancy Load:

JOB SUMMARY

PLAN REVIEW

☐ No Plans Required
☒ All
☐ Footing/Foundation
☐ Frame
☐ Architectural
☐ Other
 Date: 5-13-88 ~~12/14~~

Initials

INSPECTIONS FINAL

☐ CO ☐ CCO ☐ CA

Date:

Inspected By:

INSPECTIONS

Type

☒ Footing/Foundation

☐ Slab

☒ Frame

☐ Architectural

☐ Insulation

☒ Finishes

☐ Energy

☐ Mechanical

☐ TCO

☐ Other

Failure Dates

Approval Date

6-8-88 ~~12-16-88~~

WS

WS

WS-6-20-88

Built during 1st RAM
 only



FIRE SUBCODE TECHNICAL SECTION



PERMIT NO.	2154
DATE ISSUED	8-5-85
REVISION DATE	
Block	670
Lot	4-5-8-23-2
Subdivision	

A. IDENTIFICATION

APPLICANT - Complete unshaded areas only

When changing contractors, notify this office

Owner Kennedy Mall, Inc.
Address 300-7000 Wilshire Ave
Malibu, CA 90261
Tel. (310) 467-8160
Work Site Address _____

Contractor National Fire Protection
Address 24441 Phoenician Ave
Malibu, CA
Tel. (310) 647-8038
Lic. No. _____
Federal Emp. No. 23-174311

CERTIFICATION IN LIEU OF OATH:

(Complete for Minor Work and Small Job Only)

I hereby certify that the proposed work is authorized by the owner of record and I have been authorized by the owner to make this application as his agent.

AGENT SIGNATURE _____

B. TECHNICAL SITE DATA

B1. SPRINKLERS

TYPE: ☐ Wet ☒ Dry ☐ Other _____
Area Sprinkled: ☒ Full ☐ Partial (specify in comments)
No. of Heads: 100 No. of Spare Heads: 10
☐ Valves Supervised - Method: _____ Size: 1/2"
Water Supply - Source: City
FD Connection Location: Conn. S.W.
Estimated Cost of Work: \$ 5000

FEE

B2. SPECIAL SUPPRESSION SYSTEMS

TYPE: ☐ Dry Chemical ☐ CO₂
☐ Halon ☐ Foam
☐ Other _____
Manual Pull: ☐ Yes ☐ No
Locations: _____

Estimated Cost of Work: \$ _____

B3. ALARM

TYPE: ☐ Manual ☒ Automatic
Supervision Type: ☒ Local ☐ Central
☐ Proprietary ☐ Remote Location
Estimated Cost of Work: \$ 100

FEE

B4. STAND PIPES

Pipe Size: _____ Pump Size: _____
Water Source: _____ Size: _____
FD Connection Location: _____
Hose Station: ☐ Yes ☐ No
Estimated Cost of Work: \$ 1114

B5. OTHER

for fire sprinkler only
for fire alarm only

Subtotal

Minimum Fire Protection Fee (If Applicable)
Total Fire Protection Fee (Greater of Minimum or Subtotal)
5330

C. FIRE PROTECTION CHARACTERISTICS

USE GROUP _____ Present _____ Proposed _____
Heating Systems - Location: _____
Type: ☐ Gas ☐ Oil ☐ Electrical ☐ Solar ☐ Other _____
Fuel Storage Tank - Location: _____ Fuel Type: _____ Capacity: _____
Total Estimated Cost of Fire Protection Work: \$ _____

D. COMMENTS

make app for test
☐ Partial Releases ☐ Prototype Processing

PLAN REVIEW AND INSPECTION - FIRE

DATE

JOB CONDITION/COMMENTS

2-3-89

Cancelled Insps by phone JC

2-8-89

Witnessed Sprinkler Test. 200 PSI for
Two hrs. Contractors Manual & Test
Certificate att. to this Card JC

6/5/89

Final Blot Sheet & Sprinkles only JC

JOB SUMMARY

- ☐ No Plans Required
- ☐ Plan Review Approved

Date: 6/30/88

Approved By: JC

INSPECTIONS FINAL

CO ☐ CCO ☐ CA ☐

Date: 6/5/89 JC

Inspected By: JC

INSPECTIONS

Type

- ☒ Fire Suppression Test
- ☐ Fire Alarm Test
- ☐ Smoke Test
- ☐ TCO
- ☒ Other *Hand*
- ☐ Other
- ☐ Other
- ☐ Other

Failure Date

Approval Date

2-8-89

6/5/89



UNIFORM CONSTRUCTION CODE

**PLUMBING
SUBCODE
TECHNICAL SECTION**

PERMIT NO. 2156
DATE ISSUED 8-5-88
REVISION DATE _____
Block 670 Lot A, 5, 8, 23, 25
Subdivision _____

APPLICANT – Complete unshaded areas only

When changing contractors, notify this office

Kennedy Mall Associates

Contractor PINELAND PLBG. & HTG., INC.

Address 4514 MILLBURN AVE.

Address 807 MANTOLOKING RD.

Tel. (_____) _____

Tel. () 201 477-0854

Work Site Address
Hooper & Brick Blvd. Unit 8

Lic.No./Bus. Permit 22-1853417

B. TECHNICAL SITE DATA

List all fixtures

TYPE OF WORK: Adm

8#

No.	Fixture	Fee	No.	Fixture	Fee	Fee
1	Water Closer/Bidet/Urinal	\$		Garbage Disposal	\$	COLUMN 1
	Bathrub			Air Conditioner Unit		COLUMN 2
1	Lavatory/Sink			Indirect Connection		SUBTOTAL \$
	Shower/Floor Drain			Sewer Ejector		Minimum Plumbing Fee
	Washing Machine			Grease Trap		(If applicable)
	Dishwasher			Interceptor		Total Plumbing Fee
	Commercial Dishwasher			Backflow Device		(Greater of Minimum
1	Water Heater			Reduced Pressure		or Subtotal)
1	Domestic Boiler/ Furnace		1	Backflow Device		
	Steam Boiler			Vent Stack		
1	Water Util. Connection		1	Solar System		
	Sewer Util. Connection			Other GAS		
	Hose Bibb			Other		
	Water Cooler			Other		
				Other		

C. PLUMBING CHARACTERISTICS

STOR

STOR

D-40000

Drainage -	Material	PVC 40	Size
------------	----------	--------	------

Material PVC 40

1.

Building Sewer—	Material	Size
	<u>PVC</u>	<u>40</u>

PVC 40

1111

Water Service--	Material	Size

Material	Quantity	Unit Price	Total Price
...	...	...	...

1

Venting — Material PVC 90 Size _____

Material PVC 90

1

Estimated Cost of Plumbing Work: \$

D. COMMENTS

Fee included in tech section for total building.

☐ Partial Releases

Prototype Processing

U.C.C. Form F-130 (8/83)

Green = Office Copy

White = Applicant C

Blue = Inspector Copy

JOB CONDITION/COMMENTS

DATE _____

[illegible]

☐ No Plans Required
☒ Plan Review Approved

Date: 7-20-88

Approved By: X. W.

☒	CO
☐	CCO
☐	CA

Date: 7-12-87

Inspected By:

Type	
☒ Slab	
☐ Rough	
☐ Water	
☐ Sewer	
☐ Energy	
☐ Mechanical	
☐ TCO	
☐ Other	

[illegible]

Approval Date

TOWNSHIP OF BRICK



PLUMBING SUBCODE TECHNICAL SECTION



PERMIT NO. 2156
DATE ISSUED 8-5-88
REVISION DATE _____
Block 670 Lot A, 5, 8, 23, 25
Subdivision _____

A. IDENTIFICATION

APPLICANT - Complete unshaded areas only

When changing contractors, notify this office

Owner Kennedy Mail AssociatesContractor PINELAND PLBG. & HIG., INC.Address 241A Milburn Ave.Address 807 MANTOLOKING RD.Milburn, NJ 07041BRICK TOWNSHIP, N.J. 08723

Tel. () _____

Tel. () 201 477-0854

Work Site Address

Hooper & Bick Blvd. Unit 9Lic. No./Bus. Permit 1722Federal Emp. No. 22-1853417

CERTIFICATION IN LIEU OF OATH:

(Complete for Minor Work and Small Job Only)

I hereby certify that the proposed work is authorized by the owner of record and I have been authorized by the owner to make this application as his agent.

Willie R. Dwyer
AGENT SIGNATURE

B. TECHNICAL SITE DATA

List all fixtures

TYPE OF WORK: NEW

No.	Fixture	Fee	No.	Fixture	Fee	Fee
1	Water Closet/Bidet/Urinal	\$		Garbage Disposal	\$	COLUMN 1
	Bathrub			Air Conditioner Unit		COLUMN 2
1	Lavatory/Sink			Indirect Connection		SUBTOTAL \$
	Shower/Floor Drain			Sewer Elector		Minimum Plumbing Fee
	Washing Machine			Grease Trap		(if applicable)
	Dishwasher			Interceptor		Total Plumbing Fee
1	Commercial Dishwasher			Backflow Device		(Greater of Minimum
1	Water Heater			Reduced Pressure		or Subtotal)
	Domestic Boiler/		1	Backflow Device		
	Eutance			Vent Stack		
	Steam Boiler			Solar System		
1	Water Util. Connection		1	Other <u>GAS</u>		
	Sewer Util. Connection			Other		
	Hose Bibb			Other		
	Water Cooler			Other		
	COLUMN 1	\$		COLUMN 2	\$	

C. PLUMBING CHARACTERISTICS

USE GROUP: Store

Present

Proposed

Drainage - Material PVC 40 Size 1 1/2 - 3Building Sewer - Material PVC 40 Size 4Water Service - Material T60 PVC Size 1Venting - Material PVC 40 Size 1 1/2 - 2

Estimated Cost of Plumbing Work: \$

D. COMMENTS

Free included in tech section for total building.

☐ Partial Releases

☐ Prototype Processing

PLAN REVIEW AND INSPECTION - PLUMBING

DATE

JOB CONDITION/COMMENTS

3-30-90 LOCKED

JOB SUMMARY

- ☐ No Plans Required
☒ Plan Review Approved

Date: 7-20-88

Approved By: *[Signature]*

INSPECTIONS FINAL

☐ CO ☐ CCO ☐ CA

Date: 7-12-89

Inspected By: *[Signature]*

INSPECTIONS

- Type
- ☒ Slab
 - ☐ Rough
 - ☐ Water
 - ☐ Sewer
 - ☐ Energy
 - ☐ Mechanical
 - ☐ TCO
 - ☐ Other

Failure Dates


Approval Date

7-25-88

TOWNSHIP OF BRICK



PLUMBING SUBCODE TECHNICAL SECTION



PERMIT NO.	2154
DATE ISSUED	3-5-88
REVISION DATE	
Block	670
Lot	4,5,8,23,25
Subdivision	

A. IDENTIFICATION

APPLICANT — Complete unshaded areas only		When changing contractors, notify this office	
Owner	Kennedy Mail Associates'	Contractor	PINELAND PLBG. & HIG., INC.
Address	241A Milburn Ave. Milburn, NJ 07041	Address	807 MANTOLOKING RD., BRICK TOWNSHIP, N.J. 08723
Tel. ()	KAARTE STORE	Tel. ()	201 477-0854
Work Site Address	Hooper & Brick Blvd. UNIT 6	Lic. No./Bus. Permit	22-1853417
		Federal Emp. No.	

CERTIFICATION IN LIEU OF OATH:
(Complete for Minor Work and Small Job Only)

I hereby certify that the proposed work is authorized by the owner of record and I have been authorized by the owner to make this application as his agent.

William R. Dwyer
AGENT SIGNATURE

B. TECHNICAL SITE DATA

List all fixtures

TYPE OF WORK: *NEW*

No.	Fixture	Fee	No.	Fixture	Fee	Fee
1	Water Closet/Bidet/Urinal	\$		Garbage Disposal	\$	COLUMN 1 \$
	Bathrub			Air Conditioner Unit		COLUMN 2 \$
1	Lavatory/Sink			Indirect Connection		SUBTOTAL \$
	Shower/Floor Drain			Sewer Elector		Minimum Plumbing Fee (if applicable) \$
	Washing Machine			Grease Trap		Total Plumbing Fee (Greater of Minimum or Subtotal) \$
	Dishwasher			Interceptor		
	Commercial Dishwasher			Backflow Device		
1	Water Heater			Reduced Pressure Backflow Device		
1	Domestic Boiler/Furnace		1	Vent Stack		
	Steam Boiler			Solar System		
1	Water Util. Connection		1	Other <i>Gas</i>		
1	Sewer Util. Connection			Other		
	Hose Bibb			Other		
	Water Cooler			Other		
	COLUMN 1 \$			COLUMN 2 \$		

C. PLUMBING CHARACTERISTICS

USE GROUP:	<i>Store</i>	Present	Proposed
Drainage —	Material <i>PVC</i>	Size <i>40</i>	Size <i>1 1/2-3</i>
Building Sewer —	Material <i>PVC</i>	Size <i>40</i>	Size <i>4</i>
Water Service —	Material <i>1 1/2" PVC</i>	Size <i>1</i>	Size <i>1 1/2-2</i>
Venting —	Material <i>PVC</i>	Size <i>40</i>	Size <i>1 1/2-2</i>
Estimated Cost of Plumbing Work:	\$		

D. COMMENTS

Fee included in tech section for total building.

☐ Partial Releases

☐ Prototype Processing

PLAN REVIEW AND INSPECTION – PLUMBING

JOB CONDITION/COMMENTS[illegible]

JOB SUMMARY

- ☐ No Plans Required
☒ Plan Review Approved

Date: 7-20-88

Approved By:

INSPECTIONS FINAL

☒ CO	☐ CCO	☐ CA
--	------------------------------	-----------------------------

Date: 10-18-87

Inspected By:

INSPECTIONS

Type

- | | |
|-------------------------------------|------------|
| ☒ | Slab |
| ☒ | Rough |
| ☐ | Water |
| ☐ | Sewer |
| ☐ | Energy |
| ☐ | Mechanical |
| ☐ | TCO |
| ☐ | Other |

Failure Dates

Approval Date

7-2C-88

9/18/81

Block 10 Lot 4-3-8-25-25
Subdivision _____

Federal Emp. No. 42-1032417

agent.
W. R. Dwyer
AGENT SIGNATURE

#

No.	Figure
-----	--------

No.	Fixture	Fee	No.	Fixture	Fee	Fee
1	Water Closer/Bidet/Urinal	\$		Garbage Disposal	\$	COLUMN 1 \$
	Bathub			Air Conditioner Unit		COLUMN 2 \$
1	Lavatory/Sink			Indirect Connection		SUBTOTAL \$
	Shower/Floor Drain			Sewer Ejector		Minimum Plumbing Fee (if applicable)
	Washing Machine			Grease Trap		\$
	Dishwasher			Interceptor		
	Commercial Dishwasher			Backflow Device		Total Plumbing Fee (Greater of Minimum or Subtotal)
1	Water Heater			Reduced Pressure		\$
1	Domestic Boiler/ Furnace		1	Backflow Device		
	Steam Boiler			Vent Stack		
1	Water Util. Connection		1	Solar System		
	Sewer Util. Connection			Other GAS		
	Hose Bibb			Other		
	Water Cooler			Other		
				Other		

Cost of Plumbing Work: \$ _____

FEE INCLUDED IN TECH SECTION FOR
TOTAL BUILDING.

☐ Partial Releases -- ☐ Prototype Processing

JOB CONDITION/COMMENTS

DATE _____

[illegible]

☐ No Plans Required
☒ Plan Review Approved

Date: 7-20-88

Approved By: Shu

INSPECTIONS FINAL

CA ☐ CC ☐ CO ☒

Date: 2-20-90

Inspected By: S. W. D. J.

INSPECTIONS

Type	
☒ Slab	
☒ Rough	
☐ Water	
☐ Sewer	
☐ Energy	
☐ Mechanical	
☐ TCO	
☐ Other	

Failure Dates

Approval Date

86/86
86-52-2

CERTIFICATION IN LIEU OF OATH:
(Complete for Minor, Work and Small Job Only)

When changing contractors, notify this office

Federal Emp. No. 22-1000417
[Signature]

I hereby certify that the proposed work is authorized by the owner of record and I have been authorized by the owner to make this application as his agent.

No.	Fixture	Fee	No.	Fixture	Fee	Fee
3	Water Closet/Bidet/Urinal	\$ 10.-		Garbage Disposal	\$	COLUMN 1 \$ 60.- COLUMN 2 \$ 10.- SUBTOTAL \$ Minimum Plumbing Fee (if applicable) \$ Total Plumbing Fee (Greater of Minimum or Subtotal) \$ 70.-
	Bathtub			Air Conditioner Unit		
4	Lavatory/Sink	\$ 20.-		Indirect Connection		
2	Shower/Floor Drain	\$ 10.-		Sewer Ejector		
	Washing Machine			Grease Trap		
	Dishwasher			Interceptor		
	Commercial Dishwasher			Backflow Device		
1	Water Heater	\$ 5.-		Reduced Pressure		
1	Domestic Boiler/Furnace	\$ 15.-	1	Backflow Device	\$ 10.-	
	Steam Boiler			Vent Stack		
	Water Util. Connection			Solar System		
	Sewer Util. Connection			Other		
	Hose Bibb			Other		
	Water Cooler			Other		

Estimated Cost of Plumbing Work: \$ _____

Partial Releases	Prototype Processing
☐	☐

PLAN REVIEW AND INSPECTION – PLUMBING

DATE _____

JOB CONDITION/COMMENTS[illegible]

JOB SUMMARY

- ☐ No Plans Required
☒ Plan Review Approved

Date: 7-4-90

Approved By:

INSPECTIONS FINAL

☒	CO	☐	CCO	☐	CA
-------------------------------------	----	--------------------------	-----	--------------------------	----

Date: 7-20-90

Inspected By:

INSPECTIONS

Type

- | | |
|-------------------------------------|------------|
| ☒ | Slab |
| ☒ | Rough |
| ☐ | Water |
| ☐ | Sewer |
| ☐ | Energy |
| ☐ | Mechanical |
| ☐ | TCO |
| ☐ | Other |

Failure Dates

Approval Date

2/1/90

TOWNSHIP OF BRICK



PLUMBING SUBCODE TECHNICAL SECTION



PERMIT NO. 2156
 DATE ISSUED 8-5-88
 REVISION DATE _____
 Block 670 Lot A, 5, 8, 23, 25
 Subdivision _____

A. IDENTIFICATION

APPLICANT - Complete unshaded areas only When changing contractors, notify this office

Owner Kennedy Mail Associates Contractor PINELAND PLBG. & HTG., INC.
 Address 241A Milburn Ave. Address 807 MANTOLOKING RD.
Milburn, NJ 07041 BRICK TOWNSHIP, N.J. 08723

Tel. (____) _____ 201 477-0854
 Work Site Address D.E. Jones Store Lic. No./Bus. Permit 1722
Hooper & Brick Blvd. UNIT 13 Federal Emp. No. 22-1853417

CERTIFICATION IN LIEU OF OATH:

(Complete for Minor Work and Small Job Only)

I hereby certify that the proposed work is authorized by the owner of record and I have been authorized by the owner to make this application as his agent.

William R. Dwyer
 AGENT SIGNATURE

B. TECHNICAL SITE DATA

List all fixtures

TYPE OF WORK: NEW

13

No.	Fixture	Fee	No.	Fixture	Fee	Fee
1	Water Closet/Bidet/Urinal	\$		Garbage Disposal	\$	COLUMN 1 \$
	Bathrub			Air Conditioner Unit		COLUMN 2 \$
1	Lavatory/Sink			Indirect Connection		SUBTOTAL \$
	Shower/Floor Drain			Sewer Ejector		Minimum Plumbing Fee (if applicable) \$
	Washing Machine			Grease Trap		Total Plumbing Fee (Greater of Minimum or Subtotal) \$
	Dishwasher			Interceptor		
	Commercial Dishwasher			Backflow Device		
1	Water Heater			Reduced Pressure Backflow Device		
1	Domestic Boiler/Furnace		1	Vent Stack		
	Steam Boiler			Solar System		
1	Water Util. Connection		1	Other GAS		
	Sewer Util. Connection			Other		
	Hose Bibb			Other		
	Water Cooler			Other		
	COLUMN 1	\$		COLUMN 2	\$	

C. PLUMBING CHARACTERISTICS

USE GROUP: Store Present Proposed

Drainage - Material PVC 40 Size 1 1/2 - 3

Building Sewer - Material PVC 40 Size 4

Water Service - Material 60 Poly 1 Size 1

Venting - Material PVC 40 Size 1 1/2 - 2

Estimated Cost of Plumbing Work: \$

D. COMMENTS

Fee included in tech section for total building.

☐ Partial Releases

☐ Prototype Processing

PLAN REVIEW AND INSPECTION - PLUMBING

DATE

9/15/89

JOB CONDITION/COMMENTS

Bath Room Size

JOB SUMMARY

- ☐ No Plans Required
☒ Plan Review Approved

Date: 7-20-88

Approved By: *[Signature]*

INSPECTIONS FINAL

☒ CO ☐ CCO ☐ CA

Date: 10-23-89

Inspected By: *[Signature]*

INSPECTIONS

- Type
- ☒ Slab
 - ☒ Rough
 - ☒ Water
 - ☐ Sewer
 - ☐ Energy
 - ☐ Mechanical
 - ☐ TCO
 - ☐ Other

Failure Dates

Approval Date

9/15/89

7-25-88

JOB CONDITION/COMMENTS

DATE _____

[illegible]

☐ No Plans Required
☒ Plan Review Approved

Date: 7-20-88

Approved By: [Signature]

INSPECTIONS FINAL

☐ CO ☐ CCO ☐ CA

Date: _____

Inspected By: _____

INSPECTIONS

☒ Slab

☐ Rough

☐ Water

 Sewer

Energy

Mechanical

TCO

Other

Failure Dates

Approval Date

7-25-88



UNIFORM
CONSTRUCTION
CODE

A. IDENTIFICATION

When changing contractors, notify this office

Contractor: PINELAND PLBG. & HTG., INC.

Address 807 MAIN DLOKING RD.

Tel. (_____) 201 477-0854

Lic.No./Bus. Permit 22-1853417
Federal Emp. No. _____

(Complete for Minor Work and Small Job Only)

AGENT SIGNATURE

List all fixtures

TYPE OF WORK: *Acad*

No.	Fixture	Fee	No.	Fixture	Fee	Fee
1	Water Closer/Bidet/Urinal	\$		Garbage Disposal	\$	COLUMN 1 COLUMN 2 SUBTOTAL Minimum Plumbing Fee (If applicable) Total Plumbing Fee (Greater of Minimum or Subtotal)
	Bathrub			Air Conditioner Unit		
1	Lavatory/Sink			Indirect Connection		
	Shower/Floor Drain			Sewer Ejector		
	Washing Machine			Grease Trap		
	Dishwasher			Interceptor		
1	Commercial Dishwasher			Backflow Device		
1	Water Heater			Reduced Pressure		
1	Domestic Boiler/ Furnace		1	Backflow Device		
	Steam Boiler			Vent Stack		
1	Water Util. Connection		1	Solar System		
1	Sewer Util. Connection			Other GAS		
	Hose Bibb			Other		
	Water Cooler			Other		
COLUMN 1		\$	COLUMN 2		\$	

USE GROUP: ITC

Stue
Present

Proposed

Fee included in tech section for total building.

D. COMMENTS

Fee included in tech section for total building.

Plumbing Work:

1

☐ Partial Release

Prototype Processing

PLAN REVIEW AND INSPECTION – PLUMBING

DATE _____

JOB CONDITION/COMMENTS[illegible]

JOB SUMMARY

- ☐ No Plans Required
☒ Plan Review Approved

Date: 7-20-88

Approved By:

INSPECTIONS FINAL

☒	CO	☐	CCO	☐	CA
-------------------------------------	----	--------------------------	-----	--------------------------	----

Date: 2/14/89

Inspected By:

U.C.C. Form F-130 (8/83)

INSPECTIONS

Type

- | | |
|-------------------------------------|------------|
| ☒ | Slab |
| ☒ | Rough |
| ☐ | Water |
| ☐ | Sewer |
| ☐ | Energy |
| ☐ | Mechanical |
| ☐ | TCO |
| ☐ | Other |

Approval Date

7-25-88

169/10

7-5-1971

7

100

1

PLAN REVIEW AND INSPECTION - PLUMBING

DATE

3-30-90

JOB CONDITION/COMMENTS

LOCKED

JOB SUMMARY

☐ No Plans Required

☒ Plan Review Approved

Date: 7-20-88

Approved By: *[Signature]*

INSPECTIONS FINAL

☒ CO ☐ CCO ☐ CA

Date: 4-1-90

Inspected By: *[Signature]*

INSPECTIONS

Type
☒ Slab
☒ Rough
☐ Water
☐ Sewer
☐ Energy
☐ Mechanical
☐ TCO
☐ Other

Failure Dates

Approval Date


7-25-88

12-12-89

TOWNSHIP OF BRICK



PLUMBING SUBCODE TECHNICAL SECTION



PERMIT NO. 2128
DATE ISSUED 8-5-88
REVISION DATE _____
Block 610 Lot 458, 457, 45
Subdivision _____

A. IDENTIFICATION

APPLICANT - Complete unshaded areas only When changing contractors, notify this office

Owner Kennedy Mall Assoc Contractor PINELAND PLBG. & HIG., INC.
Address 241-A Millburn Ave Address 807 MANTOLOKING RD.
MILLBURN NJ, 07041 BRICK TOWNSHIP, N.J. 08723
Tel. 201, 467-3100 Tel. 201 477-0854 1722
Work Site Address Hooper Ave 9 Lic. No./Bus. Permit 22-1853417
Back Stop Truck, N.J. Federal Emp. No. _____

CERTIFICATION OF OATH:

(Complete for Minor Work and Small Job Only)

I hereby certify that the proposed work is authorized by the owner of record and has been authorized by the owner to make this application as his agent.

William R. Deffen
AGENT SIGNATURE

B. TECHNICAL SITE DATA

List all fixtures

TYPE OF WORK: New

CARD with FEES FOR TOTAL Building

No.	Fixture	Fee	No.	Fixture	Fee	Fee
15	Water Closer/Bidet/Urinal	75.-	15	Garbage Disposal	225.-	COLUMN 1 \$325.-
15	Bathrub	75.-		Air Conditioner Unit		COLUMN 2 \$465.-
15	Lavatory/Sink	75.-		Indirect Connection		SUBTOTAL \$1010.-
	Shower/Floor Drain			Sewer Ejector		Minimum Plumbing Fee (if applicable) \$1010.-
	Washing Machine			Grease Trap		Total Plumbing Fee (Greater of Minimum or Subtotal) \$1010.-
15	Dishwasher		1	Interceptor	25.-	
15	Commercial Dishwasher			Backflow Device	10.-	
15	Water Heater	225.-		Reduced Pressure Backflow Device		
	Domestic Boiler/Furnace		15	Vent Stack	225.-	
1	Steam Boiler			Solar System GAS Systems		
1	Water Util. Connection		15	Other		
	Sewer Util. Connection			Other		
	Hose Bibb			Other		
	Water Cooler			Other		
	COLUMN 1 \$225.-			COLUMN 2 \$485.-		
						\$7128.5

C. PLUMBING CHARACTERISTICS

USE GROUP: Stores Present PVC Proposed 1 1/2" - 4"

Drainage - Material Sch 40 Size 1 1/2"

Building Sewer - Material Sch 35 Size 4"

Water Service - Material 60 PSI Size 1"

Venting - Material Sch 40 Size 1 1/2" - 2"

Estimated Cost of Plumbing Work: \$ _____

D. COMMENTS

H.C.

☐ Partial Releases

☐ Prototype Processing

PLAN REVIEW AND INSPECTION - PLUMBING

DATE

JOB CONDITION/COMMENTS

ALL-15 BATH ARE A.W.D.I.C.P.

12-7-90

OPEN PIPES NOT CAPPED

JOB SUMMARY

- ☐ No Plans Required
☒ Plan Review Approved

Date: 7-20-88

Approved By: J.W. Spil

INSPECTIONS FINAL

☒ CO ☐ CCO ☐ CA

Date: 12-17-90

Inspected By: J.W. Spil

INSPECTIONS

- Type
- ☒ Slab
 - ☒ Rough
 - ☒ Water
 - ☒ Sewer
 - ☐ Energy
 - ☐ Mechanical
 - ☐ TCO
 - ☐ Other


Failure Dates

Approval Date


12-7-90

7-25-88
 12-17-90
 12-30-88
 12-30-88

TOWNSHIP OF BRICK



PLUMBING SUBCODE TECHNICAL SECTION



PERMIT NO. 2156
 DATE ISSUED 8-5-88
 REVISION DATE _____
 Block 670 Lot A, 5, 8, 23, 25
 Subdivision _____

A. IDENTIFICATION

APPLICANT — Complete unshaded areas only When changing contractors, notify this office

Owner Kennedy Mail Associates Contractor PINELAND PLBG. & HTG., INC.
 Address 241A Milburn Ave. Address 807 MANTOLOKING RD.
Milburn, NJ 07041 BRICK TOWNSHIP, N.J. 08723
 Tel. () _____ Tel. () 201 477-0854
1722
 Work Site Address Hooper & Brick Blvd. Unit 12 Lic. No./Bus. Permit 22-1853417
 Federal Emp. No. _____

CERTIFICATION IN LIEU OF OATH:

(Complete for Minor Work and
Small Job Only)

I hereby certify that the proposed work is authorized by the owner of record and I have been authorized by the owner to make this application as his agent.

William R. Dwyer
 AGENT SIGNATURE

B. TECHNICAL SITE DATA

List all fixtures

TYPE OF WORK: NEW

12

No.	Fixture	Fee	No.	Fixture	Fee	Fee
1	Water Closet/Bidet/Urinal	\$		Garbage Disposal	\$	COLUMN 1
	Bathrub			Air Conditioner Unit		COLUMN 2
1	Lavatory/Sink			Indirect Connection		SUBTOTAL \$
	Shower/Floor Drain			Sewer Elector		Minimum Plumbing Fee
	Washing Machine			Grease Trap		(If applicable)
	Dishwasher			Interceptor		Total Plumbing Fee
	Commercial Dishwasher			Backflow Device		(Greater of Minimum
1	Water Heater			Reduced Pressure		or Subtotal)
	Domestic Boiler/			Backflow Device		
	Furnace		1	Vent Stack		
	Steam Boiler			Solar System		
1	Water Util. Connection			Other <u>Gas</u>		
	Sewer Util. Connection			Other		
	Hose Bibb			Other		
	Water Cooler			Other		
	COLUMN 1	\$		COLUMN 2	\$	

C. PLUMBING CHARACTERISTICS

USE GROUP: Store Present Proposed

Drainage — Material PVC 40 Size 1 1/2 — 3

Building Sewer — Material PVC 40 Size 4

Water Service — Material 1 1/2 PVC 40 Size 1

Venting — Material PVC 40 Size 1 1/2 — 2

Estimated Cost of Plumbing Work: \$ _____

D. COMMENTS

Fee included in tech section for
total building.

☐ Partial Releases

☐ Prototype Processing

PLAN REVIEW AND INSPECTION - PLUMBING

DATE

12-7-90

OPEN PIPING NOT CAPPED

JOB CONDITION/COMMENTS

[Signature]

JOB SUMMARY

- ☐ No Plans Required
☒ Plan Review Approved

Date: 7-20-88

Approved By: *[Signature]*

INSPECTIONS FINAL

☐ CO ☐ CCO ☒ CA

Date: 12-17-90

Inspected By: *[Signature]*

INSPECTIONS

Type

- ☒ Slab
☒ Rough
☐ Water
☐ Sewer
☐ Energy
☐ Mechanical
☐ TCO
☐ Other

Failure Dates

12-7-90

Approval Date

7-25-88

12-17-90



UNIFORM CONSTRUCTION CODE

PERMIT NO. 6736
DATE ISSUED 8-3-68
REVISION DATE _____
Block 670 Lot 4,5,8,23,25
Subdivision _____

When changing contractors, notify this office

PINELAND PLBG. & HTG., INC.

Address 80/ MANICLOWING RD

BRICK TOWNSHIP, N.J. 08723

Tel. () 201 411-0854

Lic.No./Bus. Permit 00 1052417

List all fixtures

TYPE OF WORK: *new*

#2

No.	Fixture	Fee	No.	Fixture	Fee	Fee
1	Water Closet/Bidet/Urinal	\$		Garbage Disposal	\$	COLUMN 1
	Bathub			Air Conditioner Unit		COLUMN 2
1	Lavatory/Sink			Indirect Connection		SUBTOTAL \$
	Shower/Floor Drain			Sewer Ejector		Minimum Plumbing Fee
	Washing Machine			Grease Trap		(If applicable)
	Dishwasher			Interceptor		Total Plumbing Fee
	Commercial Dishwasher			Backflow Device		(Greater of Minimum
1	Water Heater			Reduced Pressure		or Subtotal)
1	Domestic Boiler/ Furnace		1	Backflow Device		\$
				Vent Stack		
	Steam Boiler			Solar System		
1	Water Util. Connection		1	Other <u>SA</u>		
1	Sewer Util. Connection			Other		
	Hose Bibb			Other		
	Water Cooler			Other		
	COLUMN 1	\$		COLUMN 2	\$	

USE GROUP, *Stu*

Drainage -		
Material	PVC	40
Size	1 1/2	3

2. COMMENTS

Fee included in tech section for total building.

Fee included in tech section for total building.

Building Sewer—	Material	Size
Water Service—	Material	Size
Venting —	Material	Size

☐ Partial Releases ☐ Prototype Processing

U.C.C. Form F-130 (8/83)

Green = Office Copy

White = Applicant Copy

Blue = Inspector Copy

PLAN REVIEW AND INSPECTION - PLUMBING

DATE

JOB CONDITION/COMMENTS

3-30-90

VACANT

12-7-90

OPEN LINES NOT CAPPED

JOB SUMMARY

- ☐ No Plans Required
☒ Plan Review Approved

Date: 7-20-88

Approved By: *J.W. Spl.*

INSPECTIONS FINAL

☐ CO ☐ CCO ☒ CA

Date: 12-17-90

Inspected By: *J.W. Spl.*

INSPECTIONS

- Type
- | | | | |
|---|--|--|--|
| ☒ Slab | | | |
| ☒ Rough | | | |
| ☐ Water | | | |
| ☐ Sewer | | | |
| ☐ Energy | | | |
| ☐ Mechanical | | | |
| ☐ TCO | | | |
| ☐ Other | | | |

Failure Dates

Approval Date

7-25-88

1-17-90



UNIFORM CONSTRUCTION CODE

PERMIT NO. 0138
DATE ISSUED 6-5-86
REVISION DATE _____
Block 670 Lot 4,5,8,23,25
Subdivision _____

When changing contractors, notify this office

Contractor **PINELAND P.L.B.G. & HTG. INC.**

Address 807 MANTOU OKING RD.

BRICK TOWNSHIP NJ 08723

Tel. () 201 477-0854

Lic.No./Bus. Permit _____

Federal Emp. No. 22-1853417

List all fixtures

TYPE OF WORK: *Adm*

#4

No.	Fixture	Fee	No.	Fixture	Fee
1	Water Closet/Bidet/Urinal	\$		Garbage Disposal	\$
	Bathrub			Air Conditioner Unit	
1	Lavatory/Sink			Indirect Connection	
	Shower/Floor Drain			Sewer Ejector	
	Washing Machine			Grease Trap	
	Dishwasher			Interceptor	
	Commercial Dishwasher			Backflow Device	
1	Water Heater			Reduced Pressure	
1	Domestic Boiler/ Furnace		1	Backflow Device	
				Vent Stack	
	Steam Boiler			Solar System	
1	Water Util. Connection		1	Other <u>Gas</u>	
	Sewer Util. Connection			Other	
1	Hose Bibb			Other	
	Water Cooler			Other	

COLUMN 1

COLUMN 2

SUBTOTAL \$

Minimum Plumbing Fee (if applicable) \$

Total Plumbing Fee (Greater of Minimum or Subtotal) \$

USE GROUP: STORM

10

Present

1

Proposed

Drainage –

Material

05

26

1

Building Sewer

Material

42

26

1

Water Service-

Material

۲۵

2e

Venting –

Material

213

26

1

Estimated Cost of Plumbing Work: \$

Fee included in tech section for total building.

☐ Partial Releases

Prototype Processing

U.C.C. Form F-130 (8/83)

Green = Office Copy

White = Applicant Copy

Blue = Inspector Copy

PLAN REVIEW AND INSPECTION - PLUMBING

DATE

JOB CONDITION/COMMENTS

3-30-90

not roughed

12-7-90

OPEN LINES NOT CHASED

JOB SUMMARY

- ☐ No Plans Required
☒ Plan Review Approved

Date: 7-20-88

Approved By: JED

INSPECTIONS FINAL

☐ CO ☐ CCO ☒ CA

Date: 12-17-90

Inspected By: JED

INSPECTIONS

- Type
- ☒ Slab
 - ☒ Rough
 - ☐ Water
 - ☐ Sewer
 - ☐ Energy
 - ☐ Mechanical
 - ☐ TCO
 - ☐ Other

Failure Dates


Approval Date

12-7-90


7-25-88

12-17-90

TOWNSHIP OF BRICK



PLUMBING SUBCODE TECHNICAL SECTION



PERMIT NO. 2156
 DATE ISSUED 8-3-88
 REVISION DATE _____
 Block 670 Lot A, 5, 8, 23, 25
 Subdivision _____

A. IDENTIFICATION

APPLICANT - Complete unshaded areas only

When changing contractors, notify this office

Owner Kennedy Mail AssociatesContractor PINELAND PLBG. & HTG., INC.Address 241A Milburn Ave.Address 807 MANTOLOKING RD.Milburn, NJ 07041BRICK TOWNSHIP, N.J. 08723

Tel. (____) _____

Tel. (____) _____ 201 477-0854

Work Site Address

Hooper & Brick Blvd. Unit 3Lic.No./Bus. Permit 22-1853417

Federal Emp. No. _____

CERTIFICATION IN LIEU OF OATH:

(Complete for Minor Work and Small Job Only)

I hereby certify that the proposed work is authorized by the owner of record and I have been authorized by the owner to make this application as his agent.

Wileen R. Daye
 AGENT SIGNATURE

B. TECHNICAL SHEET DATA

List all fixtures

TYPE OF WORK: W

3

No.	Fixture	Fee	No.	Fixture	Fee	Fee
1	Water Closet/Bidet/Urinal	\$		Garbage Disposal	\$	COLUMN 1 \$
	Bathtub			Air Conditioner Unit		COLUMN 2 \$
1	Lavatory/Sink			Indirect Connection		
	Shower/Floor Drain			Sewer Ejector		SUBTOTAL \$
	Washing Machine			Grease Trap		Minimum Plumbing Fee (if applicable) \$
	Dishwasher			Interceptor		Total Plumbing Fee (Greater of Minimum or Subtotal) \$
1	Commercial Dishwasher			Backflow Device		
1	Water Heater			Reduced Pressure Backflow Device		
1	Domestic Boiler/Furnace		1	Vent Stack		
	Steam Boiler			Solar System		
1	Water Util. Connection		1	Other <u>GAS</u>		
1	Sewer Util. Connection			Other		
	Hose Bibb			Other		
	Water Cooler			Other		
	COLUMN 1 \$			COLUMN 2 \$		

C. PLUMBING CHARACTERISTICSUSE GROUP 7000

Present

Proposed

Drainage - Material PVC Size 1 1/2 - 3Building Sewer - Material PVC Size 4Water Service - Material 1 1/2" Poly Size 1Venting - Material PVC Size 1 1/2 - 2

Estimated Cost of Plumbing Work: \$

D. COMMENTS

Fee included in tech section for total building.

☐ Partial Releases

☐ Prototype Processing

PLAN REVIEW AND INSPECTION - PLUMBING

DATE

JOB CONDITION/COMMENTS

3-30-90

not roughed

12-7-90

OPEN LINES NOT CAPPED

JOB SUMMARY

- ☐ No Plans Required
☒ Plan Review Approved

Date: 7-20-88

Approved By: *[Signature]*

INSPECTIONS FINAL

☐ CO ☐ CCO ☒ CA

Date: 12-17-90

Inspected By: *[Signature]*

INSPECTIONS

- Type
- ☒ Slab
 - ☒ Rough
 - ☐ Water
 - ☐ Sewer
 - ☐ Energy
 - ☐ Mechanical
 - ☐ TCO
 - ☐ Other

Failure Dates

Approval Date

7-25-88

12-17-90

12-7-90

fine ok all 4-5-89 3-30-90

Kennedy Mall

- | | | | | |
|------|-----------------------|---|---------------|---------------|
| # 1 | IMPACT ZONE | plb. 3-30-90 | elec 2/7/90 | bdg 2/9/90 |
| 2 | VACANT | ROUGHED | | |
| 3 | VACANT | N/R | | |
| 4 | VACANT | N/R | | |
| 5 | ICE CREAM WORKS | plb. 2/20/90 | elec 1/2/90 | bdg 3/16/90 |
| 6 | KARATE | plb. 10/18/89 | elec 1-18-90 | bdg. 11-20-89 |
| 7 | PET CENTER | plb. 6/7-89 | elec 1-22-90 | bdg. 6-15-89 |
| 8 | VACANT | } was ZEB'S | elec. 7/14/89 | bdg 8-14-89 |
| 9 | VACANT | | | |
| 10 | LITTLE CAESARS | plb. 2/14/89 | elec 2-8-89 | bdg 2-15-89 |
| 10-B | LE BRICK SILK FLOWERS | (looks like part of 10 & 11 plb. 4-2-90 | | |
| 11 | VACANT | (looks like part of 11 + 12 ^{all of}) elec. 1-22-90 | | |
| 12 | VACANT | bdg 2-9-90 | | |
| 13 | DE JONES | plb. | elec 12/4/89 | bdg. 10/26/89 |
| 14 | | | | |
| 15 | | | | |

Kennedy Mall Stores

<u>Store #</u>	<u>Store Name</u>
1	Impact Zone
2	Vacant
3	Vacant
4	Vacant
5	Ice Cream Works
6	Karate Studio
7	Pet Care Center
8	Zeb's Restaurant & Deli
9	"
10	Vacant
11	Le Brick Silk Flowers
12	Vacant
13	D.E. Jones
14	"
15	"

DATE OF INSPECTION 1/30/92

BLOCK ~~44.02~~ 44.08

LOT 1


ADDRESS

306 Bay Lane

DESCRIPTION OF WORK

rough plumbing

Sometime after Noon please



consulting engineers

June 17, 1988
H-2477-88

soils & foundations
land development
environmental

Mr. Sal DaVino
241 Millburn Avenue
Millburn, NJ 07041

RE: Inspection Summary Report
Kennedy Shopping Center Expansion
Brick Township, New Jersey

Dear Mr. DaVino:

In accordance with your request, we have been providing full-time engineering inspection during the building area preparation for the proposed 29,650± sq. ft. retail store addition to the Kennedy Plaza Shopping Center located at the intersection of Brick Boulevard and Hooper Avenue in Brick Township, New Jersey.

On May 2, 1988 the excavation and placement of a controlled compacted fill for foundation and slab-on-grade support was started. During the initial excavation of the northern portion of the building area we encountered a second layer of black organic silt with roots extending to a depth of approximately 8± feet. This second organic layer varied in thickness from 2 to 20± inches and became nonexistent during excavation of the southern portion of the building area. Attempts were made to reuse the suitable on-site excavated soils by mixing it with the off-site borrow fill in areas that were accessible to the construction equipment.

17 June 88

Our inspection services during the building area preparation have included visual inspection and approval of the bottom of the excavation prior to fill placement. Visual and laboratory testing of the proposed fill material, and the performance of 443 in-place field density tests using a nuclear-moisture density gauge. The depth of the compacted fill varied from 4 to 8+ feet and was placed in 12+ inch lifts with the initial lift approximately 18+ inches thick to get above the groundwater.


The off-site fill material consisted of brown coarse to fine sand with a little medium to fine gravel and a trace of silt. The density test results have been tabulated and are presented in Table 1.


In summary, the excavation of unsuitable material and placement of the controlled compacted fill has been completed and the work was performed under the inspection of personnel from this office. Based on our field inspection during construction and the results of the in-place density tests, it is our opinion that the work was performed in a satisfactory manner in accordance with our recommendations and will provide suitable support for the anticipated net bearing pressure of 2.0 tsf (4,000 psf).

If you have any questions, please do not hesitate to contact us.

Very truly yours,

SOILS ENGINEERING SERVICES, INC.


James J. Gazzale
Project Engineer


William J. St. Pierre, P.E.

JJG:WSP:tmp

FIELD DENSITY TEST SUMMARY

1234 PCF
Optimum M.C.
9.4%

TEST NUMBER	DATE OF TEST	DRY DENSITY (PCF)	MOISTURE CONTENT %	ELEV. OF TEST	PERCENT COMPACTION	TEST LOCATION
						Building Pad
1	5/3/88	117.4	7.5	1 ST LIFT	95.4	NORTH CENTRAL
2	"	118.7	7.4	"	96.5	NORTH CENTRAL
3	"	113.6	8.4	"	92.3	NORTH CENTRAL
4	"	113.4	8.1	2 ND LIFT	92.2	NORTH CENTRAL
5	"	111.0	8.1	"	90.2	NORTH CENTRAL
6	"	115.1	8.7	"	93.5	NORTH CENTRAL
7	"	120.8	8.9	3 RD LIFT	98.2	NORTH CENTRAL
8	"	112.5	8.0	"	91.5	NORTH CENTRAL
9	"	111.5	11.9	"	90.6	NORTH CENTRAL
10	"	118.7	8.3	4 TH LIFT	96.5	NORTH CENTRAL
11	"	115.3	10.9	"	93.7	NORTH CENTRAL
12	"	117.3	10.4	"	95.3	NORTH CENTRAL
13	"	122.6	8.6	5 TH LIFT	99.6	NORTH CENTRAL
14	"	112.7	9.4	"	91.6	NORTH CENTRAL
15	"	118.8	9.0	"	96.5	NORTH CENTRAL

FIELD DENSITY TEST SUMMARY

TEST NUMBER	DATE OF TEST	DRY DENSITY (PCF)	MOISTURE CONTENT %	ELEV. OF TEST	PERCENT COMPACTION	TEST LOCATION
						BUILDING PAD
16	5/4/88	113.8	10.0	1 ST LIFT	92.9	NORTH CENTRAL
17	"	117.2	11.2	"	95.7	NORTH CENTRAL
18	"	111.8	11.6	"	91.3	NORTH CENTRAL
19	"	117.5	11.3	2 ND LIFT	95.9	NORTH CENTRAL
20	"	115.5	11.1	"	94.3	NORTH CENTRAL
21	"	115.2	11.1	"	94.0	NORTH CENTRAL
22	"	120.1	11.6	"	98.0	NORTH CENTRAL
23	"	117.8	10.5	"	96.2	NORTH CENTRAL
24	5/6/88	114.4	16.4	3 RD LIFT	93.4	NORTH CENTRAL
25	"	112.6	16.2	"	92.0	NORTH CENTRAL
26	"	115.7	14.8	"	94.4	NORTH CENTRAL
27	5/7/88	117.1	11.6	1 ST LIFT	95.6	NORTH
28	"	116.5	10.5	"	95.1	NORTH
29	"	117.1	11.8	"	95.6	NORTH
30	"	115.0	14.2	2 ND LIFT	93.9	NORTH
31	"	115.0	14.0	"	93.9	NORTH

FIELD DENSITY TEST SUMMARY

TEST NUMBER	DATE OF TEST	DRY DENSITY (PCF)	MOISTURE CONTENT %	ELEV. OF TEST	PERCENT COMPACTION	TEST LOCATION
						Building PAD
32	5/7/88	116.3	14.8	2 ND LIFT	95.0	NORTH
33	5/9/88	117.0	8.7	"	95.5	NORTH
34	"	115.9	9.2	"	94.7	NORTH
35	"	117.3	10.0	"	95.8	NORTH
36	"	121.0	12.1	4 TH LIFT	98.8	NORTH CENTRAL
37	"	122.3	9.1	"	99.8	NORTH CENTRAL
38	"	117.6	10.7	"	96.0	NORTH CENTRAL
39	"	119.1	10.1	"	97.3	NORTH CENTRAL
40	"	116.6	13.4	3 RD LIFT	95.2	NORTH
41	"	117.9	12.1	"	96.2	NORTH
42	"	116.3	13.3	"	94.9	NORTH
43	"	116.2	14.1	"	94.8	NORTH
44	"	116.9	8.8	4 TH LIFT	95.5	NORTH
45	"	116.4	13.6	"	95.0	NORTH
46	"	116.4	12.2	"	95.0	NORTH
47	"	114.0	8.3	"	93.1	NORTH

FIELD DENSITY TEST SUMMARY

TEST NUMBER	DATE OF TEST	DRY DENSITY (PCF)	MOISTURE CONTENT %	ELEV. OF TEST	PERCENT COMPACTION	TEST LOCATION
						BUILDING PAD
48	5/10/88	114.3	11.6	1 ST LIFT	93.3	CENTER
49	"	117.2	13.0	"	95.7	CENTER
50	"	113.2	12.0	"	92.4	CENTER
51	"	116.6	10.5	"	95.2	CENTER
52	"	118.5	11.5	"	96.7	CENTER
53	"	117.4	9.1	"	95.9	CENTER
54	"	113.7	9.3	"	92.8	CENTER
55	"	116.4	9.2	"	95.1	CENTER
56	"	116.6	11.0	"	95.2	CENTER
57	"	115.8	8.3	"	94.6	CENTER
58	"	118.5	9.9	"	96.8	CENTER
59	"	117.6	10.4	"	96.0	CENTER
60	"	115.8	11.0	"	94.6	CENTER
61	"	118.8	10.5	2 ND LIFT	97.0	CENTER
62	"	117.4	12.6	"	95.8	CENTER
63	"	114.2	11.6	"	93.2	CENTER

FIELD DENSITY TEST SUMMARY

TEST NUMBER	DATE OF TEST	DRY DENSITY (PCF)	MOISTURE CONTENT %	ELEV. OF TEST	PERCENT COMPACTION	TEST LOCATION
64	5/10/88	116.8	10.6	2 ND LIFT	95.3	BUILDING PAD CENTER
65	"	117.5	10.4	"	96.0	CENTER
66	"	118.3	9.3	"	96.6	CENTER
67	"	115.6	9.4	"	94.4	CENTER
68	"	114.5	9.9	"	93.5	CENTER
69	"	115.9	10.6	"	94.6	CENTER
70	"	113.9	10.9	"	93.0	CENTER
71	"	112.4	9.3	"	91.8	CENTER
72	"	113.4	10.2	"	92.6	CENTER
73	"	117.1	9.4	"	95.6	CENTER
74	5/11/88	121.9	12.2	3 RD LIFT	99.5	CENTER
75	"	121.8	10.8	"	99.4	CENTER
76	"	115.8	10.8	"	94.6	CENTER
77	"	117.0	10.3	"	95.5	CENTER
78	"	117.7	9.8	"	96.1	CENTER
79	"	117.6	11.0	"	96.0	CENTER

FIELD DENSITY TEST SUMMARY

TEST NUMBER	DATE OF TEST	DRY DENSITY (PCF)	MOISTURE CONTENT %	ELEV. OF TEST	PERCENT COMPACTION	TEST LOCATION
80	5/11/88	122.0	10.3	3 RD LIFT	99.6	BUILDING PAD CENTER
81	"	116.4	10.5	"	95.0	CENTER
82	"	116.8	10.3	"	95.3	CENTER
83	"	116.6	9.9	"	95.2	CENTER
84	"	114.3	10.1	"	93.3	CENTER
85	"	114.6	11.7	"	93.6	CENTER
86	"	117.1	11.5	4 TH LIFT	95.6	CENTER
87	"	117.1	9.9	"	95.6	CENTER
88	"	114.9	9.2	"	93.8	CENTER
89	"	114.5	10.8	"	93.5	CENTER
90	"	112.8	12.2	"	92.1	CENTER
91	"	116.9	11.6	"	95.4	CENTER
92	"	113.9	10.3	"	93.0	CENTER
93	"	116.2	10.9	"	94.9	CENTER
94	"	117.3	9.2	"	95.8	CENTER
95	"	116.5	10.2	"	95.1	CENTER

FIELD DENSITY TEST SUMMARY

TEST NUMBER	DATE OF TEST	DRY DENSITY (PCF)	MOISTURE CONTENT %	ELEV. OF TEST	PERCENT COMPACTION	TEST LOCATION
96	5/11/88	115.7	10.2	5 TH LIFT	94.5	BUILDING PAD CENTER
97	"	116.0	10.9	"	94.7	CENTER
98	"	115.3	10.2	"	94.2	CENTER
99	"	116.5	9.4	"	95.1	CENTER
100	"	115.7	10.1	"	94.5	CENTER
101	"	118.4	9.5	"	96.7	CENTER
102	"	116.7	9.4	"	95.3	CENTER
103	"	114.6	9.7	"	93.5	CENTER
104	"	114.1	8.6	"	93.2	CENTER
105	"	115.2	10.2	"	94.1	CENTER
106	"	112.1	10.8	"	91.5	CENTER
107	"	116.0	8.8	6 TH LIFT	94.7	CENTER
108	"	117.5	9.6	"	96.0	CENTER
109	"	115.3	8.3	"	94.2	CENTER
110	"	116.8	10.7	"	95.4	CENTER
111	"	112.7	10.7	"	92.0	CENTER

FIELD DENSITY TEST SUMMARY

TEST NUMBER	DATE OF TEST	DRY DENSITY (PCF)	MOISTURE CONTENT %	ELEV. OF TEST	PERCENT COMPACTION	TEST LOCATION
112	5/11/88	114.7	10.5	6 TH LIFT	93.6	BUILDING PAD CENTER
113	"	116.9	9.2	"	95.4	CENTER
114	"	115.3	9.6	"	94.1	CENTER
115	"	116.7	10.9	"	95.3	CENTER
116	"	113.8	11.7	"	92.9	CENTER
117	"	118.5	10.6	"	96.8	CENTER
118	"	113.1	13.3	7 TH LIFT	92.3	CENTER
119	"	117.2	9.2	"	95.7	CENTER
120	"	114.9	9.5	"	93.8	CENTER
121	"	117.3	10.0	"	95.8	CENTER
122	"	115.6	10.9	"	94.4	CENTER
123	"	115.3	9.2	"	94.1	CENTER
124	"	115.4	8.8	"	94.2	CENTER
125	"	115.5	9.3	"	94.3	CENTER
126	"	115.8	11.4	"	94.6	CENTER
127	"	120.2	10.9	"	98.1	CENTER

FIELD DENSITY TEST SUMMARY

TEST NUMBER	DATE OF TEST	DRY DENSITY (PCF)	MOISTURE CONTENT %	ELEV. OF TEST	PERCENT COMPACTION	TEST LOCATION
						BUILDING PAD
128	5/12/88	115.4	8.8	1 ST LIFT	94.2	CENTER
129	"	115.5	9.3	"	94.3	CENTER
130	"	115.8	11.4	"	94.6	CENTER
131	"	120.2	10.9	"	98.1	CENTER
132	"	117.7	10.3	"	96.1	CENTER
133	"	114.8	9.2	"	93.3	CENTER
134	"	114.2	10.1	2 ND LIFT	92.8	CENTER
135	"	116.2	9.5	"	94.5	CENTER
136	"	120.7	10.0	"	98.2	CENTER
137	"	117.7	9.9	"	95.7	CENTER
138	"	116.9	10.6	"	95.1	CENTER
139	"	116.5	9.3	3 RD LIFT	94.7	CENTER
140	"	117.1	11.6	"	95.2	CENTER
141	"	114.5	13.6	"	93.1	CENTER
142	"	116.1	13.5	"	94.4	CENTER
143	"	114.8	13.6	"	93.4	CENTER

FIELD DENSITY TEST SUMMARY

TEST NUMBER	DATE OF TEST	DRY DENSITY (PCF)	MOISTURE CONTENT %	ELEV. OF TEST	PERCENT COMPACTION	TEST LOCATION
144	5/12/88	119.5	10.1	3 RD LIFT	97.1	BUILDING PAD CENTER
145	"	118.3	11.0	4 TH LIFT	96.2	CENTER
146	"	114.5	12.9	"	93.1	CENTER
147	"	114.4	14.2	"	93.0	CENTER
148	"	115.2	10.5	"	93.7	CENTER
149	"	119.5	10.9	"	97.2	CENTER
150	"	118.0	12.8	"	95.9	CENTER
151	"	115.4	15.4	"	93.8	CENTER
152	"	113.9	14.7	"	92.6	CENTER
153	"	119.2	9.6	"	96.9	CENTER
154	"	115.3	9.1	"	93.8	CENTER
155	"	119.6	9.0	"	97.3	CENTER
156	"	114.1	10.2	"	92.8	CENTER
157	5/13/88	120.4	10.7	5 TH LIFT	97.9	CENTER
158	"	113.9	10.4	"	92.6	CENTER
159	"	115.8	12.0	"	94.2	CENTER

FIELD DENSITY TEST SUMMARY

TEST NUMBER	DATE OF TEST	DRY DENSITY (PCF)	MOISTURE CONTENT %	ELEV. OF TEST	PERCENT COMPACTION	TEST LOCATION
160	5/3/88	118.2	10.0	5 TH LIFT	96.1	BUILDING PAD CENTER
161	"	114.7	11.9	"	93.3	CENTER
162	"	116.2	10.7	"	94.5	CENTER
163	"	117.6	9.5	"	95.2	CENTER
164	"	118.1	10.1	"	96.0	CENTER
165	"	113.8	9.6	"	92.6	CENTER
166	"	115.1	9.4	"	93.6	CENTER
167	"	116.4	12.4	"	94.7	CENTER
168	"	114.6	11.9	"	93.2	CENTER
169	"	113.9	8.8	6 TH LIFT	92.6	CENTER
170	"	120.6	9.9	"	98.1	CENTER
171	"	117.9	8.8	"	95.9	CENTER
172	"	116.9	11.1	"	95.1	CENTER
173	"	117.2	9.1	"	95.3	CENTER
174	"	113.8	10.4	"	92.6	CENTER
175	"	121.2	10.4	"	98.5	CENTER

FIELD DENSITY TEST SUMMARY

TEST NUMBER	DATE OF TEST	DRY DENSITY (PCF)	MOISTURE CONTENT %	ELEV. OF TEST	PERCENT COMPACTION	TEST LOCATION
176	5/13/88	122.3	9.5	6 TH L ₁ ET	99.4	BUILDING PAD CENTER
177	"	121.3	9.2	"	98.6	CENTER
178	"	116.6	10.6	"	94.8	CENTER
179	"	115.1	11.5	"	93.6	CENTER
180	"	114.6	11.2	"	93.2	CENTER
181	"	119.4	10.0	"	97.1	CENTER
182	"	114.2	8.1	7 TH L ₁ ET	92.9	CENTER
183	"	118.0	10.2	"	95.9	CENTER
184	"	120.5	9.4	"	98.0	CENTER
185	"	112.9	9.3	"	91.8	CENTER
186	"	124.8	9.2	"	100 +	CENTER
187	"	114.5	6.8	"	93.1	CENTER
188	"	117.5	7.6	"	95.5	CENTER
189	"	119.0	10.0	"	96.8	CENTER
190	"	118.1	9.9	"	96.0	CENTER
191	"	116.3	8.5	"	94.6	CENTER

FIELD DENSITY TEST SUMMARY

TEST NUMBER	DATE OF TEST	DRY DENSITY (PCF)	MOISTURE CONTENT %	ELEV. OF TEST	PERCENT COMPACTION	TEST LOCATION
						BUILDING PAD
192	5/13/88	122.5	8.6	7 TH FLOOR	99.6	CENTER
193	"	122.1	8.3	"	99.3	CENTER
194	"	119.5	9.3	"	97.1	CENTER
195	"	116.3	6.4	"	94.6	CENTER
196	"	115.4	7.8	"	93.8	CENTER
197	"	112.9	8.3	"	91.8	CENTER
198	"	117.4	8.1	"	95.5	CENTER
199	5/14/88	116.7	10.1	1 ST FLOOR	94.9	SOUTH CENTRAL
200	"	116.8	10.8	"	95.0	SOUTH CENTRAL
201	"	115.4	11.0	"	93.8	SOUTH CENTRAL
202	"	116.3	10.0	"	94.6	SOUTH CENTRAL
203	"	118.2	10.6	"	96.1	SOUTH CENTRAL
204	"	119.2	10.0	"	96.9	SOUTH CENTRAL
205	"	120.4	8.6	"	97.9	SOUTH CENTRAL
206	"	115.8	10.2	"	94.2	SOUTH CENTRAL
207	"	117.4	9.3	"	95.5	SOUTH CENTRAL

FIELD DENSITY TEST SUMMARY

TEST NUMBER	DATE OF TEST	DRY DENSITY (PCF)	MOISTURE CONTENT %	ELEV. OF TEST	PERCENT COMPACTION	TEST LOCATION
208	5/14/88	117.9	10.4	1 ST LIFT	95.9	BUILDING PAD SOUTH CENTRAL
209	"	117.3	11.2	2 ND LIFT	95.4	SOUTH CENTRAL
210	"	119.4	9.0	"	97.1	SOUTH CENTRAL
211	"	122.7	9.5	"	99.8	SOUTH CENTRAL
212	"	115.3	9.8	"	93.7	SOUTH CENTRAL
213	"	118.4	10.5	"	96.3	SOUTH CENTRAL
214	"	114.6	9.5	"	93.2	SOUTH CENTRAL
215	"	117.6	10.0	"	95.6	SOUTH CENTRAL
216	"	117.0	9.6	"	95.2	SOUTH CENTRAL
217	"	123.9	8.6	"	100 +	SOUTH CENTRAL
218	"	119.9	9.5	"	97.5	SOUTH CENTRAL
219	"	113.4	10.8	"	92.2	SOUTH CENTRAL
220	"	119.1	8.9	"	96.9	SOUTH CENTRAL
221	"	119.5	9.3	"	97.2	SOUTH CENTRAL
222	5/16/88	119.7	10.8	3 RD LIFT	97.3	SOUTH CENTRAL
223	"	119.9	6.8	"	97.5	SOUTH CENTRAL

FIELD DENSITY TEST SUMMARY

TEST NUMBER	DATE OF TEST	DRY DENSITY (PCF)	MOISTURE CONTENT %	ELEV. OF TEST	PERCENT COMPACTION	TEST LOCATION
224	5/16/88	122.6	10.1	3 RD LIFT	99.7	BUILDING PAD SOUTH CENTRAL
225	"	118.5	7.0	"	96.3	SOUTH CENTRAL
226	"	115.6	9.1	"	94.0	SOUTH CENTRAL
227	"	115.8	9.2	"	94.2	SOUTH CENTRAL
228	"	114.4	8.2	"	93.0	SOUTH CENTRAL
229	"	124.5	7.9	"	100+	SOUTH CENTRAL
230	"	113.4	7.8	"	92.2	SOUTH CENTRAL
231	"	116.3	7.6	"	94.5	SOUTH CENTRAL
232	"	116.8	6.4	4 TH LIFT	95.0	SOUTH CENTRAL
233	"	115.4	7.2	"	93.8	SOUTH CENTRAL
234	"	115.8	6.4	"	94.2	SOUTH CENTRAL
235	"	116.7	6.8	"	94.9	SOUTH CENTRAL
236	"	116.0	7.8	"	94.3	SOUTH CENTRAL
237	"	115.4	7.6	1 ST LIFT	93.9	SOUTH CENTRAL
238	"	120.5	8.3	4 TH LIFT	97.9	SOUTH CENTRAL
239	"	119.9	8.6	"	97.5	SOUTH CENTRAL

FIELD DENSITY TEST SUMMARY

TEST NUMBER	DATE OF TEST	DRY DENSITY (PCF)	MOISTURE CONTENT %	ELEV. OF TEST	PERCENT COMPACTION	TEST LOCATION
240	5/16/88	116.3	8.3	1 ST LIFT	94.6	BUILDING PAD SOUTH
241	"	118.8	6.5	4 TH LIFT	96.6	SOUTH CENTRAL
242	"	117.7	8.3	1 ST LIFT	95.7	SOUTH
243	"	117.7	7.2	4 TH LIFT	95.7	SOUTH CENTRAL
244	"	118.8	6.3	"	96.6	SOUTH CENTRAL
245	"	118.1	6.2	"	96.1	SOUTH CENTRAL
246	"	116.6	8.7	1 ST LIFT	94.8	SOUTH
247	"	118.7	7.7	"	96.5	SOUTH
248	5/17/88	118.1	8.3	1 ST LIFT	96.1	SOUTH
249	"	117.3	9.6	4 TH LIFT	95.4	SOUTH CENTRAL
250	"	116.0	8.1	1 ST LIFT	94.3	SOUTH
251	"	117.5	6.9	4 TH LIFT	95.5	SOUTH CENTRAL
252	"	116.6	6.8	1 ST LIFT	94.8	SOUTH
253	"	113.8	6.5	4 TH LIFT	92.5	SOUTH CENTRAL
254	"	118.8	8.0	1 ST LIFT	96.6	SOUTH
255	"	114.9	9.1	"	93.4	SOUTH

FIELD DENSITY TEST SUMMARY

TEST NUMBER	DATE OF TEST	DRY DENSITY (PCF)	MOISTURE CONTENT %	ELEV. OF TEST	PERCENT COMPACTION	TEST LOCATION
256	5/17/88	116.7	8.9	5 TH LIFT	94.9	BUILDING PAD
257	"	117.4	8.5	1 ST LIFT	95.5	SOUTH CENTRAL
258	"	114.9	9.8	"	93.4	SOUTH
259	"	115.1	9.5	5 TH LIFT	93.6	SOUTH CENTRAL
260	"	114.8	9.7	1 ST LIFT	93.4	SOUTH
261	"	114.2	9.2	"	92.9	SOUTH
262	"	118.3	8.2	5 TH LIFT	96.2	SOUTH CENTRAL
263	"	117.9	7.7	1 ST LIFT	95.9	SOUTH
264	"	117.3	8.4	"	95.4	SOUTH
265	"	118.4	9.4	5 TH LIFT	96.3	SOUTH CENTRAL
266	"	118.2	9.6	2 ND LIFT	96.1	SOUTH
267	"	118.3	10.1	"	96.2	SOUTH
268	"	116.1	9.4	"	94.4	SOUTH
269	"	116.3	10.2	"	94.6	SOUTH
270	"	119.6	9.4	"	97.3	SOUTH
271	"	115.9	8.9	"	94.2	SOUTH

FIELD DENSITY TEST SUMMARY

TEST NUMBER	DATE OF TEST	DRY DENSITY (PCF)	MOISTURE CONTENT %	ELEV. OF TEST	PERCENT COMPACTION	TEST LOCATION
272	5/17/88	119.8	8.5	5 TH LIFT	97.4	BUILDING PAD SOUTH CENTRAL
273	"	120.2	9.3	2 ND LIFT	97.7	SOUTH
274	"	118.0	9.9	"	95.9	SOUTH
275	"	121.3	8.0	"	98.6	SOUTH
276	"	117.9	9.0	5 TH LIFT	95.9	SOUTH CENTRAL
277	"	120.4	8.4	3 RD LIFT	97.9	SOUTH
278	"	114.3	10.0	"	92.9	SOUTH
279	"	115.7	9.6	"	94.1	SOUTH
280	"	115.6	9.2	"	94.0	SOUTH
281	"	119.6	9.5	"	97.2	SOUTH
282	"	116.0	9.2	"	94.3	SOUTH
283	"	117.6	9.4	"	95.6	SOUTH
284	"	116.7	10.4	"	94.9	SOUTH
285	"	115.3	9.7	"	93.8	SOUTH
286	"	117.7	10.4	"	95.7	SOUTH
287	"	116.1	9.4	"	94.4	SOUTH

FIELD DENSITY TEST SUMMARY

TEST NUMBER	DATE OF TEST	DRY DENSITY (PCF)	MOISTURE CONTENT %	ELEV. OF TEST	PERCENT COMPACTION	TEST LOCATION
288	5/23/88	118.0	11.4	1 ST LIFT	95.9	BUILDING PAD SOUTH
289	"	116.9	11.3	"	95.0	SOUTH
290	"	117.5	10.0	"	95.5	SOUTH
291	"	114.8	13.1	"	93.3	SOUTH
292	"	121.2	10.7	"	98.5	SOUTH
293	"	116.0	12.7	"	94.3	SOUTH
294	"	118.1	12.1	"	96.0	SOUTH
295	"	115.7	12.2	"	94.0	SOUTH
296	"	116.1	14.0	"	94.4	SOUTH
297	"	115.6	9.1	"	93.9	SOUTH
298	"	121.3	10.0	"	98.6	SOUTH
299	"	115.2	13.2	"	93.6	SOUTH
300	"	116.4	12.7	2 ND LIFT	94.6	SOUTH
301	"	118.2	10.4	"	96.1	SOUTH
302	"	114.9	9.7	"	93.4	SOUTH
303	"	118.4	10.3	"	96.2	SOUTH

FIELD DENSITY TEST SUMMARY

TEST NUMBER	DATE OF TEST	DRY DENSITY (PCF)	MOISTURE CONTENT %	ELEV. OF TEST	PERCENT COMPACTION	TEST LOCATION
304	5/23/88	117.3	12.1	2 ND LIFT	95.3	BUILDING PAD SOUTH
305	"	114.2	17.6	"	92.8	SOUTH
306	"	119.4	12.1	"	97.0	SOUTH
307	"	118.9	9.8	"	96.6	SOUTH
308	"	116.0	15.1	"	94.3	SOUTH
309	"	117.3	9.8	"	95.3	SOUTH
310	"	114.9	14.9	3 RD LIFT	93.4	SOUTH
311	"	118.3	10.3	"	96.1	SOUTH
312	"	117.7	11.6	"	95.7	SOUTH
313	"	118.9	10.3	"	96.6	SOUTH
314	"	116.9	10.9	"	95.0	SOUTH
315	"	115.0	10.1	"	93.5	SOUTH
316	"	116.6	11.4	"	94.8	SOUTH
317	"	120.1	9.7	"	97.6	SOUTH
318	"	116.2	10.0	"	94.4	SOUTH
319	"	115.0	14.4	"	93.5	SOUTH

FIELD DENSITY TEST SUMMARY

TEST NUMBER	DATE OF TEST	DRY DENSITY (PCF)	MOISTURE CONTENT %	ELEV. OF TEST	PERCENT COMPACTION	TEST LOCATION
320	5/23/88	118.1	10.9	3 RD LIFT	96.0	BUILDING PAD SOUTH
321	"	119.8	9.5	"	97.4	SOUTH
322	5/24/88	121.0	9.0	4 TH LIFT	98.3	SOUTH
323	"	120.1	10.8	"	97.6	SOUTH
324	"	115.5	14.7	"	93.9	SOUTH
325	"	118.7	12.2	"	96.5	SOUTH
326	"	119.4	12.4	"	97.0	SOUTH
327	"	121.6	10.8	"	98.8	SOUTH
328	"	115.7	12.0	"	94.4	SOUTH
329	"	119.5	11.2	"	97.1	SOUTH
330	"	118.7	10.9	"	96.5	SOUTH
331	"	119.2	10.9	"	96.9	SOUTH
332	"	122.2	8.4	"	99.3	SOUTH
333	"	116.8	7.8	"	94.9	SOUTH
334	"	118.2	7.0	5 TH LIFT	96.0	SOUTH
335	"	114.1	7.6	"	92.7	SOUTH

FIELD DENSITY TEST SUMMARY

TEST NUMBER	DATE OF TEST	DRY DENSITY (PCF)	MOISTURE CONTENT %	ELEV. OF TEST	PERCENT COMPACTION	TEST LOCATION
336	5/24/88	115.5	10.0	5 TH LIFT	93.9	Building PAD South
337	"	116.9	11.2	"	95.0	South
338	"	120.6	10.5	"	98.0	South
339	"	113.7	10.9	"	92.4	South
340	"	120.4	10.0	"	97.8	South
341	"	122.1	9.0	"	99.2	South
342	"	121.0	7.4	"	98.3	South
343	"	119.8	8.7	"	97.4	South
344	"	117.0	8.9	"	95.7	South
345	"	122.1	10.1	"	99.2	South
346	"	118.9	9.1	"	96.6	South
347	"	119.4	8.5	"	97.0	South
348	"	120.6	9.7	"	98.0	South
349	"	118.0	10.3	"	95.9	South
350	5/25/88	119.4	10.5	6 TH LIFT	97.0	South
351	"	119.9	11.5	"	97.4	South

FIELD DENSITY TEST SUMMARY

TEST NUMBER	DATE OF TEST	DRY DENSITY (PCF)	MOISTURE CONTENT %	ELEV. OF TEST	PERCENT COMPACTION	TEST LOCATION
352	5/25/88	117.9	10.2	6 TH LIFT	95.8	BUILDING PAD SOUTH
353	"	118.8	10.7	"	96.5	SOUTH
354	"	117.7	14.1	"	95.7	SOUTH
355	"	121.0	11.9	"	98.3	SOUTH
356	"	119.3	11.1	"	97.0	SOUTH
357	"	119.5	9.7	"	97.1	SOUTH
358	"	116.9	9.3	"	94.6	SOUTH
359	"	119.7	9.6	"	97.3	SOUTH
360	"	119.5	10.6	"	97.1	SOUTH
361	"	119.7	10.8	"	97.3	SOUTH
362	"	120.4	9.6	"	97.8	SOUTH
363	"	119.6	10.7	"	97.2	SOUTH
364	5/26/88	119.5	10.5	7 TH LIFT	97.1	SOUTH
365	"	115.9	14.6	"	94.2	SOUTH
366	"	118.9	13.2	"	96.6	SOUTH
367	"	115.8	10.5	"	94.1	SOUTH

FIELD DENSITY TEST SUMMARY

TEST NUMBER	DATE OF TEST	DRY DENSITY (PCF)	MOISTURE CONTENT %	ELEV. OF TEST	PERCENT COMPACTION	TEST LOCATION
368	5/26/88	122.8	12.1	7 TH LIFT	99.8	BUILDING PAD South
369	"	112.7	14.3	"	91.6	South
370	"	118.3	11.3	"	96.1	South
371	"	116.2	11.6	"	94.4	South
372	5/27/88	117.2	8.3	5 TH LIFT	95.2	NORTH CENTRAL
373	"	118.5	9.2	"	96.3	NORTH CENTRAL
374	"	118.6	9.4	"	96.4	NORTH CENTRAL
375	"	116.5	10.5	7 TH LIFT	94.7	CENTRAL
376	"	122.9	8.5	6 TH LIFT	99.9	SOUTH CENTRAL
377	"	117.1	12.6	7 TH LIFT	95.2	SOUTH
378	"	119.6	8.1	"	97.2	SOUTH
379	"	119.6	8.3	"	97.2	SOUTH
380	"	120.8	8.9	"	98.2	SOUTH
381	"	116.7	10.3	"	94.8	SOUTH
382	"	115.8	8.6	6 TH LIFT	94.1	SOUTH CENTRAL
383	"	122.2	7.8	"	99.3	SOUTH CENTRAL

FIELD DENSITY TEST SUMMARY

TEST NUMBER	DATE OF TEST	DRY DENSITY (PCF)	MOISTURE CONTENT %	ELEV. OF TEST	PERCENT COMPACTION	TEST LOCATION
384	5/27/88	122.1	11.0	7 TH LIFT	99.2	BUILDING PAD CENTRAL
385	"	122.0	10.1	5 TH LIFT	99.1	NORTH
386	"	120.9	10.8	"	98.3	NORTH
387	"	117.9	11.5	5 TH LIFT	95.8	NORTH CENTRAL
388	"	122.2	9.9	7 TH LIFT	99.3	CENTRAL
389	"	119.2	13.6	6 TH LIFT	96.9	SOUTH CENTRAL
390	"	123.2	7.5	7 TH LIFT	100+	SOUTH
391	"	118.4	9.5	"	96.2	SOUTH
392	"	114.9	9.0	6 TH LIFT	93.4	SOUTH CENTRAL
393	"	114.8	9.2	"	93.3	SOUTH CENTRAL
394	"	113.7	13.3	7 TH LIFT	92.4	CENTRAL
395	"	117.3	8.7	"	95.3	CENTRAL
396	"	118.7	8.9	5 TH LIFT	96.5	NORTH CENTRAL
397	"	116.6	9.3	"	94.8	NORTH CENTRAL
398	"	116.5	9.8	"	94.7	NORTH CENTRAL
399	"	115.0	10.0	"	93.5	NORTH CENTRAL

FIELD DENSITY TEST SUMMARY

TEST NUMBER	DATE OF TEST	DRY DENSITY (PCF)	MOISTURE CONTENT %	ELEV. OF TEST	PERCENT COMPACTION	TEST LOCATION
400	5/27/88	121.8	11.4	5 TH LIFT	99.0	Building PAD
401	"	120.8	11.6	5 TH LIFT	98.2	NORTH CENTRAL
402	"	123.7	10.0	"	100 +	NORTH
403	"	118.9	9.5	"	96.6	NORTH
404	"	120.2	12.5	"	97.7	NORTH
405	"	123.2	10.4	"	100 +	NORTH
406	"	118.8	12.0	"	96.5	NORTH
407	"	119.3	12.1	"	97.0	NORTH
408	"	120.9	9.7	"	98.3	NORTH
409	"	114.2	6.1	"	92.8	NORTH
410	"	116.4	13.8	5 TH LIFT	94.6	NORTH CENTRAL
411	"	120.6	11.9	"	98.0	NORTH CENTRAL
412	"	114.5	8.3	"	93.0	NORTH CENTRAL
413	"	120.8	10.9	"	98.2	NORTH CENTRAL
414	"	122.5	6.7	"	99.6	NORTH CENTRAL
415	"	121.0	10.4	"	98.3	NORTH CENTRAL

FIELD DENSITY TEST SUMMARY

TEST NUMBER	DATE OF TEST	DRY DENSITY (PCF)	MOISTURE CONTENT %	ELEV. OF TEST	PERCENT COMPACTION	TEST LOCATION
416	5/27/88	121.2	8.0	7 TH LIFT	98.5	BUILDING PAD CENTRAL
417	"	124.0	7.4	"	100+	CENTRAL
418	"	115.0	9.4	"	93.5	CENTRAL
419	"	118.0	9.9	"	95.9	CENTRAL
420	"	115.6	10.4	"	93.9	CENTRAL
421	"	117.8	10.9	"	95.7	CENTRAL
422	"	117.0	9.8	"	95.1	CENTRAL
423	"	116.5	9.2	"	94.7	CENTRAL
424	"	113.3	9.5	"	92.1	CENTRAL
425	5/31/88	115.7	9.4	6 TH LIFT	94.0	SOUTH CENTRAL
426	"	115.3	7.5	"	93.7	SOUTH CENTRAL
427	"	122.6	7.1	"	99.6	SOUTH CENTRAL
428	"	116.8	8.5	"	94.9	SOUTH CENTRAL
429	"	116.7	9.3	"	94.8	SOUTH CENTRAL
430	"	117.0	9.7	"	95.1	SOUTH CENTRAL
431	"	113.8	11.5	"	92.5	SOUTH CENTRAL

SUMMARY

TEST NUMBER	DATE OF TEST	DRY DENSITY (PCF)	MOISTURE CONTENT %	ELEV. OF TEST	PERCENT COMPACTION	TEST LOCATION
432	5/31/88	114.7	7.3	7 TH LIFT	93.2	BUILDING PAD SOUTH
433	"	116.9	8.1	"	95.0	SOUTH
434	"	116.0	7.6	"	94.3	SOUTH
435	"	118.3	9.0	"	96.1	SOUTH
436	"	119.0	5.5	"	96.7	SOUTH
437	"	118.9	7.2	"	96.6	SOUTH
438	"	116.4	10.6	"	94.6	SOUTH
439	"	116.3	9.5	"	94.5	SOUTH
440	"	118.9	10.1	"	96.6	SOUTH
441	"	120.1	6.3	"	97.6	SOUTH
442	"	117.0	10.0	"	95.1	SOUTH
443	"	118.1	9.9	"	96.0	SOUTH

ONE LIBERTY PLACE
SUITE 1800
1650 MARKET STREET
PHILADELPHIA, PENNSYLVANIA 19103-7395
215-864-7000
FAX: 215-864-7123

THE SOVEREIGN BUILDING
SUITE 300
609 HAMILTON MALL
ALLENTOWN, PENNSYLVANIA 18101-2111
215-435-8414
FAX: 215-435-8420

LAW OFFICES
WHITE AND WILLIAMS
SUITE 300
222 HADDON AVENUE
WESTMONT, NEW JERSEY 08108-2828

609-858-5300
FAX: 609-858-0722
CHRISTOPHER P. LEISE
MANAGING PARTNER
CERTIFIED CIVIL TRIAL ATTORNEY

SUITE 206
1500 LANCASTER AVENUE
PAOLI, PENNSYLVANIA 19301-1500
215-251-0466
FAX: 215-296-4628

THREE CHRISTINA CENTRE
SUITE 1202
201 NORTH WALNUT STREET
WILMINGTON, DELAWARE 19801-3933
302-654-0424
FAX: 302-654-0245

May 30, 1995

RECEIVED

JUN 05 1995

DIV. OF INSPECTION

Arthur J. Cierzo
Construction Official
Brick Municipal Building
Brick, NJ 08724

Re: Davino v. Weathervane

Dear Mr. Cierzo:


Please be advised that the above mentioned matter has been settled between the parties at issue, and therefore there will be no trial. Please accept our gratitude for your extensive cooperation during these proceedings.

If you have any questions or concerns, please do not hesitate to contact me.

Very truly yours,

WHITE AND WILLIAMS

BY:


Christopher P. Leise

CPL:sas

LAW OFFICES

WHITE AND WILLIAMS

ONE LIBERTY PLACE
SUITE 1800
1650 MARKET STREET
PHILADELPHIA, PENNSYLVANIA 19103-7395
215-864-7000
FAX: 215-864-7123

THE SOVEREIGN BUILDING
SUITE 300
609 HAMILTON MALL
ALLENTOWN, PENNSYLVANIA 18101-2111
215-435-8414
FAX: 215-435-8420

SUITE 300
222 HADDON AVENUE
WESTMONT, NEW JERSEY 08108-2828

609-858-5300
FAX: 609-858-0722
CHRISTOPHER P. LEISE
MANAGING PARTNER
CERTIFIED CIVIL TRIAL ATTORNEY

SUITE 206
1500 LANCASTER AVENUE
PAOLI, PENNSYLVANIA 19301-1500
215-251-0466
FAX: 215-296-4628

THREE CHRISTINA CENTRE
SUITE 1202
201 NORTH WALNUT STREET
WILMINGTON, DELAWARE 19801-3933
302-654-0424
FAX: 302-654-0245

May 2, 1995

Mr. Arthur J. Cierzo
Construction Official
Brick Municipal Building
Brick, NJ 08724

Re: Davino v. Weathervane, et al.

Dear Mr. Cierzo:

Please be advised that the trial in this matter is scheduled to commence on June 5, 1995. It is anticipated the trial will take approximately two weeks. In that regard, please contact me to discuss whether you have any anticipation of availability problems from June 5, through June 19, 1995.

Please note that the Subpoena which you have been served with is still in effect for the continued date of this trial. Thank you for your anticipated cooperation and continuing help in this matter.

Very truly yours,

WHITE AND WILLIAMS

BY: *Corrine Pressey*
Corrine B. Pressey,
Legal Assistant

CBP:sas

LAW OFFICES

WHITE AND WILLIAMS

ONE LIBERTY PLACE
SUITE 1800
1650 MARKET STREET
PHILADELPHIA, PENNSYLVANIA 19103-7395
215-864-7000
FAX: 215-864-7123

THE SOVEREIGN BUILDING
SUITE 300
609 HAMILTON MALL
ALLENTOWN, PENNSYLVANIA 18101-2111
215-435-8414
FAX: 215-435-8420

SUITE 300
222 HADDON AVENUE
WESTMONT, NEW JERSEY 08108-2828

609-858-5300
FAX: 609-858-0722
CHRISTOPHER P. LEISE
MANAGING PARTNER
CERTIFIED CIVIL TRIAL ATTORNEY

SUITE 206
1500 LANCASTER AVENUE
PAOLI, PENNSYLVANIA 19301-1500
215-251-0466
FAX: 215-296-4628

THREE CHRISTINA CENTRE
SUITE 1202
201 NORTH WALNUT STREET
WILMINGTON, DELAWARE 19801-3933
302-654-0424
FAX: 302-654-0245

March 14, 1995

RECEIVED

MAR 15 1995

DIV. OF INSPECTION

Arthur J. Cierzo
Construction Official
Brick Municipal Building
Brick, NJ 08724

Re: **Davino v. Weathervane, et al.**

Dear Mr. Cierzo:

Please be advised that the trial in this matter will now commence on May 30, 1995. It is anticipated the trial will take approximately two weeks. In that regard, please contact my legal assistant, Ms. Corrine Pressey, to discuss whether you have any anticipation of availability problems from May 30, through June 16, 1995.

Please note that the Subpoena which you have been served with is still in effect for the continued date of this trial. Thank you for your anticipated cooperation and continuing help in this matter.

Very truly yours,

WHITE AND WILLIAMS

BY:


Christopher P. Leise

CBP:sas

LAW OFFICES

WHITE AND WILLIAMS

ONE LIBERTY PLACE
SUITE 1800
1650 MARKET STREET
PHILADELPHIA, PENNSYLVANIA 19103-7395
215-864-7000
FAX: 215-864-7123

THE SOVEREIGN BUILDING
SUITE 300
609 HAMILTON MALL
ALLENTOWN, PENNSYLVANIA 18101-2111
215-435-8414
FAX: 215-435-8420

SUITE 300
222 HADDON AVENUE
WESTMONT, NEW JERSEY 08108-2828

609-858-5300
FAX: 609-858-0722
CHRISTOPHER P. LEISE
MANAGING PARTNER
CERTIFIED CIVIL TRIAL ATTORNEY
March 1, 1995

SUITE 206
1500 LANCASTER AVENUE
PAOLI, PENNSYLVANIA 19301-1500
215-251-0466
FAX: 215-296-4628

THREE CHRISTINA CENTRE
SUITE 1202
201 NORTH WALNUT STREET
WILMINGTON, DELAWARE 19801-3933
302-654-0424
FAX: 302-654-0245

Mr. Arthur J. Cierzo
Construction Official
Brick Municipal Building
Brick, NJ 08724

Re: **Davino v. Weathervane**
Our File No.: 10222.02-N5773

Dear Mr. Cierzo:

Enclosed please find a Subpoena Ad Testificandum for the trial in the above mentioned matter, which is scheduled to begin on March 6, 1995. As is indicated on the subpoena, your appearance on the starting date of the trial is not necessary if you contact this office prior to March 6, 1995. At that point we will place you on telephone notice so that we can better advise you when your testimony will be necessary.

Thank you for you anticipated cooperation in this regard, and please contact the undersigned upon receipt of this letter.

Very truly yours,

WHITE AND WILLIAMS

BY: *Corrine B. Pressey*
Corrine B. Pressey,
Legal Assistant to
Christopher P. Leise

CBP:sas

cc: All Counsel

*Trial will be
May 30, 1995*

WHITE AND WILLIAMS
Christopher Leise, Esquire
222 Haddon Avenue, Suite 300
Westmont, NJ 08108
(609)858-5300
Attorneys for Plaintiff

SALVATORE A. DAVINO, FIDELITY
MANAGEMENT COMPANY, INC., AND
KENNEDY MALL ASSOCIATES

v.

WEATHERVANE SERVICE, INC.
and M&M ROOFING CO., INC.
MUSIC MAKERS THEATER, INC.,
and LOEWS' THEATERS

:
: SUPERIOR COURT OF
: NEW JERSEY
:
: LAW DIVISION
: OCEAN COUNTY
:
: DOCKET NO.: OCN-L-5019-91
:
: CIVIL ACTION
:
:

SUBPOENA AD TESTIFICANDUM

The State of New Jersey, to:

Mr. Arthur J. Cierzo
Construction Official
Brick Municipal Building
Brick, NJ 08724

You are hereby commanded to attend and give testimony before the above named Court at the Honorable James D. Clyne's courtroom, Ocean County Court House, 118 Washington Street, Toms River, New Jersey, on Monday, March 6, 1995, at 9:00 o'clock A.M., on the part of plaintiffs in the above entitled action.

Please be advised that trial is scheduled to commence on March 6, 1995. However, the precise date upon which you will be called to provide testimony has not yet been established.

Therefore, on receipt of this subpoena, kindly contact the


Sial
May 30, 1995


undersigned so scheduling may be discussed.

Failure to appear according to the command of this Subpoena will subject you to a penalty, damages in a Civil Suit and punishment for contempt of Court.

Dated: March 1, 1995

WHITE AND WILLIAMS
Attorney for Plaintiff

By: 
CHRISTOPHER P. LEISE, ESQ.


CLERK

PROOF OF SERVICE

On 19 , I, the undersigned, being over the age of 18, served the within Subpoena by delivering a copy thereof to the person named therein, at
person the attendance fee of \$ and by tendering to such
as allowed by law. and mileage of \$

I certify that the foregoing statements made by me are true. I am aware that if any of the foregoing statements made by me are wilfully false, I am subject to punishment.

Dated: 19

.....

Address For Service:

Mr. Arthur J. Cierzo
Construction Official
Brick Municipal Building
Brick, NJ 08724

TOWNSHIP OF BRICK
OCEAN COUNTY, NEW JERSEY
401 CHAMBERS BRIDGE ROAD, BRICK, N. J. 08723

Stevan J. Zboyan, Mayor

Township Council:
Andrew R. Ciesla, President
Albert Chrobocinski
Helen Fayad
Lee Hartman
Thomas G. Maiorino
Warren H. Wolf
David W. Wolfe



Department of Administration & Finance

Division of Inspections
A.J. Cierzo
Construction Official
(201) 477-3000, Ext. 260
Fax: (201) 920-4850

December 7, 1990

Kennedy Mall Associates
241 Millburn Avenue
Millburn, New Jersey 07041

Re: Block 670, Lots 4,5,8,23 & 25


Dear Sir,

This week there were final inspections scheduled that were necessary to meet compliance for the receipt of a C/O for the Addition (shell only) at the above referenced site. The individual stores rented will be receiving a Certificate of Approval. All unoccupied stores when rented, should come to the Building Department for a permit with their floor plan and all the paper work i.e. building, plumbing, & fire Tech sections. Upon receipt of their final inspections they will receive a Certificate of Approval. Our records indicate the following rented stores and vacant stores:

Store # 1	Impact Zone
" 2	Vacant
" 3	Vacant
" 4	Vacant
" 5	Ice Cream Works
" 6	Karate Studio
" 7	Pet Care Center
" 8	Zeb's Restaurant & Deli
" 9	" " "
" 10	Vacant
" 11	Le Brick Silk Flowers
" 12	Vacant
" 13	D.E. Jones
" 14	" "
" 15	" "

Please check with your records, and advise me.

Very truly yours,


Arthur J. Cierzo, Construction Official

RECEIVED

YOU ARE MAKING THREE COPIES. USE A BALL POINT PEN
PRESS HARD, WRITE ON A HARD SURFACE

NOV 14 1988

DETAILED INSTRUCTIONS
ON BACK OF FORM

POLICE DEPARTMENT

INCIDENT **DIVE FOR INSPECTION**

BRICK TOWNSHIP

FILL OUT COMPLETE REPORT WHEN LISTED IN CLASSIFICATION LIST AND REPORT GUIDE AS 100 (NO ASTERISK). DO NOT FILL OUT SHADED PORTION WHEN LISTED 100* (WITH ASTERISK).

1. Victim's or Complainant's Name MODULAR CONST.		2. Telephone No. 920-5869		17. Statute or Ordinance		18. Dist. 3		19. Invest.		20. Complaint #45340-88	
3. Residence Number 1250		(Street) RT. 28 SOMERVILLE NJ		(Floor or Apt.)		21. Reporting Officer R.T. BERGEN		(Name)		(Badge No.) 56	
4. Sex —		5. Race 40		6. DOB —		7. Occupation BUILDER		8. Injury ☐ Yes ☐ No		22. Incident CONSTRUCTION ACCIDENT	
9. Sobriety of Victim ☐ Sober ☐ Had Been Drinking ☐ Intoxicated		10. Can Vict. Ident. Offender ☐ Yes ☐ No		23. Location KENNEDY MALL BRICK		24. Time of Occurrence (On or Bet.) Hour 27 Day of Week 33 Month 35 Day 37 Year 88		25. Was Force Used? ☐ Yes ☒ No ☐ Not Known		26. Was a Weapon Used? ☐ Yes ☒ No ☐ Not Known	
11. Person Reporting Crime JOHN LUKKA		12. Telephone No. ABOUB		13. Residence of Person Reporting Crime ABOUB		14. Time Rep't 11 10 88		15. Month Day Year		16. Occurred on View ☐ Yes ☐ No	
28. How Attacked PHYSICAL FORCE		29. Means of Attack PHYSICAL FORCE		30. Object of Attack ACCIDENT		31. Modus Operandi N/A		32. Vehicle Involved in Crime ☒ Stolen ☐ Used By Offender		33. Name of Suspect NONE	
34. Additional Information. (Do Not Repeat Information Listed in Numbered Blocks)		35. Estimated Value By Type of Property		A. Currency 41		B. Jewelry 45		C. Furs 49		D. Clothing 53	
36. Other Officers at Scene RANK: OFF. M. BEGYN SGT. D. HORBELT		37. Other Reports Submitted ☐ B.T. 101 Continuation ☐ B.T. 103 Arrest ☐ B.T. 104 Property ☐ B.T. 105 Vehicle ☐ B.T. Statement		38. Persons Arrested NONE		39. Witnesses NONE		40. Teletype Alarm Number		41. Name of Detective Notified	
42. Signature of Reporting Officer R.T. Bergen		43. Status of Offense ☐ Unfounded ☐ Cleared By Arrest ☐ Not Cleared		44. Cleared by Arrest of: (Check Appropriate Box or Boxes) ☐ Adult 71 ☐ Juvenile ☐ Adult and Juvenile ☐ Narcotic Offender 72		45. Status of Case ☐ Pending Active ☐ Pending Inactive ☐ Closed		46. Class 73		47. Re-Class 73	
48. Key-Punched By:		49. Verified By		50. Supervisor Approving & Classifying: SGT. D. H. #58		51. Time Approved		52. Indexed By:		53. Number of Pages	

WORKMEN WERE WORKING INSIDE AN UNFINISHED LUMBER STRUCTURE IN KENNEDY MALL. WHEN A SUDDEN GUST OF WIND BLEW IT COLLAPSED THE STRUCTURE ON TOP OF THE MEN. INJURED WERE CHUCK BAYHAM AGE 21, RON MORTON 18, 257 LESWING DR. DON ERICUS 21 209 WINCHESTER DR. & JEFF HELLBOUR 21 OF 97 BAY HARBOR BVD. ALL WERE BACK & NECK INJURIES. FORWARD COPY OF REPORT TO BLDG DEPT. BLDG INSPECTION STATED STOP ORDER PLACED ON JOB

35. Estimated Value By Type of Property		A. Currency 41		B. Jewelry 45		C. Furs 49		D. Clothing 53		E. Local Autos 57		F. Miscellaneous 61		G. Total 65	
36. Other Officers at Scene RANK: OFF. M. BEGYN SGT. D. HORBELT		37. Other Reports Submitted ☐ B.T. 101 Continuation ☐ B.T. 103 Arrest ☐ B.T. 104 Property ☐ B.T. 105 Vehicle ☐ B.T. Statement		38. Persons Arrested NONE		39. Witnesses NONE		40. Teletype Alarm Number		41. Name of Detective Notified		42. Signature of Reporting Officer R.T. Bergen		43. Status of Offense ☐ Unfounded ☐ Cleared By Arrest ☐ Not Cleared	
44. Cleared by Arrest of: (Check Appropriate Box or Boxes) ☐ Adult 71 ☐ Juvenile ☐ Adult and Juvenile ☐ Narcotic Offender 72		45. Status of Case ☐ Pending Active ☐ Pending Inactive ☐ Closed		46. Class 73		47. Re-Class 73		48. Key-Punched By:		49. Verified By		50. Supervisor Approving & Classifying: SGT. D. H. #58		51. Time Approved	
52. Indexed By:		53. Number of Pages		54. Date 11/10/88		55. Time Approved		56. Indexed By:		57. Number of Pages		58. Date		59. Time Approved	

(55)

1. STATION	2. CODE	4. STATION CASE NUMBER 45340-88	5. DIVISION NUMBER
------------	---------	------------------------------------	--------------------

PER JEROME J. TANSEY, P.E. ACTING
MUNICIPAL ENGINEER JOB WILL BE
STOPPED & AREA WILL BE SURROUNDED
BY SNOW FENCES. ALSO OSHA WILL
BE NOTIFIED & INVESTIGATE.

R.T. BERGEN 56

57 TYPE NAME	58 BADGE NUMBER	59 PAGE 2 OF 2 PAGES	60 DATE OF REPORT 11/10/88
Signature <u>R.T. Bergen</u>		61 STATION	62 TROOP
			63 DIVISION

804 7
331-2960

" J Husband
(H)

TOWNSHIP OF BRICK

OCEAN COUNTY, NEW JERSEY
401 CHAMBERS BRIDGE ROAD, BRICK, N.J. 08723



Stevan J. Zboyan, Mayor

Township Council:

Albert Chrobocinski, President
Victor Cantillo
Helen Fayad
Lee Hartman
Thomas G. Malorine
Mary Lou Powner
Warren H. Wolf

Department of Administration & Finance

Division of Inspections
A.J. Cierzo
Construction Official
(908) 477-3000, Ext. 260
Fax: (908) 920-4850

. TO: Arthur J. Cierzo, Construction Official

FROM: William Sutton, Building Inspector

DATE: November 21, 1988

RE: Truss Collapse at Kennedy Mall

On Thursday November 10, 1988 at approximately 11:45 a.m. I was called on the radio by the Brick police to investigate a truss collapse at the Brick-Kennedy Mall. It took approximately 7 minutes to respond. On my arrival I witnessed that approximately 12 roof trusses had collapsed while being preassembled in the parking lot and 4 workmen were trapped in the debris.

I immediately notified John Spahr, acting construction official who met with me at the site. After the injured workmen were removed I made an inspection of both the collapsed trusses and the entire truss system already installed on the buildings. There were braces in the debris of the collapsed trusses but it was impossible to determine if they had been properly assembled because of the collapse. The collapse occurred in the parking lot and not on the building under construction so I ruled against stopping work on the site. Stopping work, in my opinion, would have compounded the problem, by delaying the installation of the already preassembled trusses, bracing and sheathing to the section already in place. Other sections already assembled in the parking lot would create a hazard if not installed. I discussed the situation with the acting construction official and we were in complete agreement. I notified the construction forman to fence around the job site and it was done that day. On November 14, 1988 I performed a follow up inspection of this site and at that time I noticed that the collapsed trusses were installed on the roof structure. I notified the job super and met later with the engineer from the truss fabricator who informed me that the trusses are undamaged and comply to code. He said he would seal and certify these trusses.

WJS/vjg-s

TOWNSHIP OF BRICK
OCEAN COUNTY, NEW JERSEY
401 CHAMBERS BRIDGE ROAD, BRICK, N.J. 08723



Stevan J. Zboyan, Mayor

Township Council:

Albert Chrobocinski, President
Victor Cantillo
Helen Fayad
Lee Hartman
Thomas G. Majorine
Mary Lou Powner
Warren H. Wolf

Department of Administration & Finance

Division of Inspections
A.J. Cierzo
Construction Official
(908) 477-3000, Ext. 260
Fax: (908) 920-4850

November 21, 1988

To: Arthur J. Cierzo, Construction Official
From: John D. Spahr, Plumbing Inspector
Re: Kennedy Mall

On Thursday, November 10, 1988 at approximately 11:45 A.M., while serving in the capacity of acting construction official in the absence of the construction official, I was informed of a construction incident at the Kennedy Mall where a group of stores in a strip shopping center are being built. I met there with Mr. William Sutton, Building Inspector. The project supervisor informed me that a crew of men were assembling a group of roof trusses in the parking lot prior to moving them into place on the structure with a crane when a violent gust of wind caused the final member of the module to be blown into the already assembled standing trusses causing their collapse and the injury to four workers. I instructed Mr. Sutton to inspect the incomplete building. He found no violations of the Building Sub-Code. I advised the Municipal Building office to notify "OSHA" of the unfortunate accident. This was done and I decided no further action was necessary. Construction was allowed to continue.

JDS/tl

MODULAR STRUCTURES, INC.

P.O. Box 368
SOMERVILLE, NEW JERSEY 08876

attention: *Mr. J. C. C...*
(201) 725-3528

TO

Township of Brick

LETTER OF TRANSMITTAL

DATE	<i>7 June 88</i>	JOB NO.	<i>375</i>
ATTENTION	<i>Mr. Arthur J. C...</i>		
RE:	<i>Kennedy Mall Addition</i>		

WE ARE SENDING YOU ☒ Attached ☐ Under separate cover via _____ the following items:

- ☐ Shop drawings ☐ Prints ☐ Plans ☐ Samples ☐ Specifications
☐ Copy of letter ☐ Change order ☐ *Wood Truss Shop Draw*

COPIES	DATE	NO.	DESCRIPTION
<i>2</i>	<i>5/19/88</i>		<i>A-59230, FE 18444 Draw / Truss Draw</i>
			<i>signed & sealed</i>

THESE ARE TRANSMITTED as checked below:

- ☐ For approval ☐ Approved as submitted ☐ Resubmit _____ copies for approval
☐ For your use ☐ Approved as noted ☐ Submit _____ copies for distribution
☒ As requested ☐ Returned for corrections ☐ Return _____ corrected prints
☐ For review and comment ☐ _____
☐ FOR BIDS DUE _____ 19 _____ ☐ PRINTS RETURNED AFTER LOAN TO US

REMARKS



Attached Shop Draw are part of documents requested from Fidelity Land Develop. Corp re: Frank C. Corvettis


COPY TO _____

SIGNED:


J. C. C...

DATE	
TIME	
1000 1000	
1000	
1000 1000	
1000 1000	





Typical



Typical

MODULAR STRUCTURES, INC.

ENGINEERING • GENERAL CONSTRUCTION

===== P.O. BOX 368 • SOMERVILLE, NJ • 08876 • 201-725-3528 =====

June 1, 1989

RECEIVED
JUN 9 1989
DIV. OF INSPECTION

Municipal Building/Building Department
401 Chambersbridge Road
Brick, New Jersey 08723

Attention: Mr. Arthur Cierzo, Construction Code Official
Mr. Gerome Tansey, Town Engineer

RE: Kennedy Mall Addition
Permit No. 2156

Gentlemen:


Our forces have completed the maximum limits of our contract for the building and site construction work of the Kennedy Mall Addition. The following items, due to lack of building permits, are presently not completed.

1. Bulkhead, perimeter fence and area landscaping.
2. Mobile area curbing, landscaping and pavement striping.
Construction work for the above areas will be started when your authorization is available.

We now request Bricktown to issue a Certificate of Completion for the building shell construction and the site work. Both items were inspected and approved by your field inspectors. We are available to meet with you if required to expedite this request. Please call if addition information is required.

Very truly yours,

MODULAR STRUCTURES, INC.


Joseph Morelli
Construction Manager

JM/jp

DESIGN CRITERIA

TOP CH. LL=	30	PSF
DL=	10	PSF
BOT CH. LL=	0	PSF
DL=	10	PSF
TOTAL LOAD=	50	PSF


SPACING= 24 IN. C/C

INPUT DEF. L/240

NOTE: LATERAL BRACES AND PURLINS INDICATED FOR TRUSS MEMBERS ARE REQUIRED TO REDUCE BUCKLING LENGTH OF MEMBER AND CHORDS

ARE REQUIRED TO REDUCE BUCKLING LENGTH OF MEMBER, AND SHOULD BE NAILED TO TRUSS MEMBERS WITH MINIMUM OF 2-10D COMMON WIRE NAILS. PROVISIONS MUST BE MADE AT ENDS OR SPECIFIED INTERVALS TO RESTRAIN OR ANCHOR LATERAL BRACING, BY OTHERS.

GANG-NAIL "B7AG" RECOMMENDED FOR CONNECTION OF TRUSS TO BEARING WALLS




5/25/88

[illegible]

CAUTION:
USE CARE IN HANDLING AND
EJECTION OF THIS TUBES. REFER
TO BLU-70 FOR RECOMMENDATIONS
OF THE TUBES PLATE
INSTITUTE.

Devil's
5/19/58

REFER TO GANG NAIL TECHNICAL BULLETIN # 164 FOR FRAMING PRODUCTS APPLICATION




TDS **Digital Systems, Inc.**
P.O. Box 37-2021 Amd'g Station Florida 33186-0207
Toll Free 800-999-9999 or 813-281-1000 FAX 813-281-1001
Florida VARS : (800) 342-7666

CLEARFIELD AM MODEM DATE 12 / 1994

IP? FE18444

COE

MAIL VALUES(PST) NET	
CHORDS	WEBS
MAX MIN	MAX MIN
GM020 227 227	227 227



QUALIFIER

MEASUREMENT

TP1

A-592229

HW 23-1968

Yang-Hall Systems, Inc.
P.O. Box 30, 2017 44th & Midway, Florida 33146-2017
Local (305) 996-0230 National 1-813 (800 277 3383)
Facsimile 1-813 (800) 272-7888

[illegible]

Wm. A. A.
5/10/88

CROSS	BRC
JT REACT	IN-5A
1	5 - 8
10	5 - 6

CAMBER 0.3/8
OMI-R - - 8 P

Note: Verify all dimensions before fabrication

Gang-Nell Systems, Inc.
P.O. Box 18
2017 East Main Street
Ft. Collins CO 80501-9600
National WATS (800) 227-2081
Frontier WATS (970) 227-2080

50F6
FE18444

7- F3-18L

JT TYPE

W

LEN

Y

A (MEMBER)

MEMBER

FOR

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

MEMBER

DECISION CRITERIA

TOP CH. LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

LUMBER

Handling & Erection

Miscellaneous Information

Bracing Information

Connector Hardware

Lumber

Design Criteria

Gang-Nail Systems, Inc.


FE18444

REFER TO GANG-NAIL TECHNICAL BULLETIN #184 FOR FRAMING PRODUCTS APPLICATION

GANG-NAIL "B" TYPE RECOMMENDED FOR LATERAL RESTRAINT OF NON-BEARING PARTITION WALLS

Caution: Connector plates are designed for forces shown only. Increase plate sizes as necessary for handling on joints, such as heel, hip, peak, splices, etc.

Note: Verify all dimensions before fabrication.



LEFT OVERHANG = 1'-10" - 0

Don't know
5/17/85

Gang-Nail Systems, Inc.
P.O. Box 25, 2001 Ave. of the Americas, Suite 2015
New York, NY 10101
Tel: (212) 696-0200
Fax: (212) 696-0201

FE18444

40FC

IMPORTANT: READ ALL NOTES ON THIS DRAWING!

REFER TO GANG-MAIL TECHNICAL BULLETIN
164 FOR PAWING PRODUCTS APPLICATION
GANG-MAIL "BIL" RECOMMENDED FOR LATERAL
RESTRAINT OF NON-DEERING PARTITION WALLS

NOTE: LATERAL BRACES AND PURLINS INDICATED FOR TRUSS MEMBERS ARE REQUIRED TO REDUCE BUCKLING LENGTH OF MEMBER, AND SHOULD BE NAILED TO TRUSS MEMBERS WITH MINIMUM OF 4-100 COMMON WIRE NAILS. PROVISIONS MUST BE MADE AT ENDS OR SPECIFIED INTERVALS, TO RESTRAIN OR ANCHOR LATERAL BRACING BY OTHERS.

Note: Verify all dimensions before fabrication.

```

DECTION CRITERIA
TOP CH      DLA 30   PSE
              DLA 30   PSE
901 CH      DLA 30   PSE
              DLA 10   PSE
TOTAL LOAD= 50     PSE

SPACING= 24 IN. C/C


INPUT DEFL. C/240

INCREASES(PER CENT)
LUMBER= 15 NAIL= 15
TCH LSR= 15 BOH LSA= 15

NAIL VALUE$(PST) NET
CHOIDS          JECS
MAX MIN        MAX MIN
GNAZO 227 227 227 227 227

LEFT OVERHANG = 0 - 6 - 0

```




CROSS	BRG
JT REACT	IN-5A
1	5 - 8
5	427 5 - 8

REFL-4 4/16
OWI-R-25 - 0 P

[illegible]

CAUTION:
USE CARE IN HANDLING AND
DISPOSITION OF THIS RESIDUE
TO AVOID POSSIBLE CONTAMINATION
OF THE FUELS BEING
INSTALLED.



CAMBER: 0-2/8
CAMBER: - 8 P

W Gang-Nail Systems, Inc.
P.O. Box 207, Andover, Massachusetts 01810
Tel: 978-686-1111 Fax: 978-686-1112
E-mail: info@gnails.com
Internet: www.gnails.com

MADE IN THE U.S.A.

MA/ 11-1226 20F6

LISTEN TO THE MUSIC

W 701 FE18444


MAX. PULLING SPACE -	0 - 3 FT.	MAX. UNBRACED BOLT LENGTH -	10 - 12 IN.
PLYWOOD SHEATHING REQUIRED ON TOP CHORD -	***		
1-1/4" L.A.T. BRACE REQ'D.	AT 1/2 LEN. MEMBS	5 - 13	8 - 11
2-1/4" L.A.T. BRACE REQ'D.	AT 1/3 LEN. MEMBS	6 - 12	9 - 11
THE FOLLOWING BRACING APPLIES ONLY WHEN MEMBER(S) ARE NOT SHEATHED.			
2-1/4" L.A.T. BRACE REQ'D.	AT 1/3 LEN. MEMBS	9 - 10	

NOTE: LATERAL BRACES AND PURLINS INDICATED FOR TRUSS MEMBERS. AND SHOULD BE NEEDED TO REDUCE BUCKLING LENGTH OF MEMBERS. AND SHOULD BE NEEDED TO TRUSS MEMBERS WITH JOISTS OR 2 - 100 COMMON WIRE. PROVISIONS MUST BE MADE AT ENDS OR SPECIFIED INTERVALS TO RESTRAIN OR ANCHOR LATERAL BRACING BY OTHERS

David Allen
5/19/96

DO NOT RECOMMENDED FOR LATERAL
RESTRAINT OF NON-DEARING PARTITION WALLS

Caution: Connector plates are designed for loads shown only. Increase plate sizes as necessary for handling on joints, such as heel, hip, peak, splices, etc.



Note: Verify all dimensions before fabrication

[illegible]



OCEAN COUNTY SOIL CONSERVATION DISTRICT

6 Mott Place, CN. 2191, Toms River, NJ 08754
Telephone: 201-244-7048

RECEIVED
AUG 10 1989
DIV. OF INSPECTION

REPORT OF COMPLIANCE

TO: CONSTRUCTION CODE OFFICIAL MUNICIPALITY: BRICK TOWNSHIP
PROJECT: Kennedy Mall Expansion - ALL UNITS SCD NO.: 2275
BLOCK NO. (s) 670 LOT NO. (s) 5 & 25

Complete Compliance ☒

Temporary Compliance ☐

BLOCK NO.	LOT NO.	CONDITIONS
		The applicant shall remain responsible for proper stabilization of all areas until final bond release by the municipality. Applicant shall remain responsible to complete repairs to bulkhead as directed by the municipality. ALL areas disturbed during repairs to bulkhead will be permanently stabilized as per the certified plan.
		Total Fees Due: \$ <u>X</u>

This verifies that the soil erosion and sediment control measures for the above designated block and lot numbers are in compliance to the extent indicated above with the soil erosion and sediment control plan as certified by the Ocean County Soil Conservation District and required by Chapter 251, P.L. 1975 as amended, the Soil Erosion and Sediment Control Act. (N.J.S.A. 4:24-39 et. seq.)

AGENT RESPONSIBLE FOR PROJECT: _____

AUTHORIZED DISTRICT SIGNATURE: Kennedy

Date: 8/8/89

Distribution: White-Township Canary-Applicant Pink-District

A4687

SIZING FOR WATER AND SEWER SERVICES

Property Owner KENNEDY MALL ASSOC. Date 5-31-89

Property Address TOTAL BLDG KENNEDY MALL Block 670 Lot

Zoning Use Group

Contractor PINELAND License No. Registration 1722

Water Main Size Water Pressure Sewer Main Size

<u>Plumbing Fixtures</u>	<u>Number</u>	<u>(sfu) Water Units</u>	<u>(dfu) Drainage Units</u>
1. Water Closet	<u>15</u>	<u>(5) 75</u>	<u>()</u>
2. Lavatory	<u>15</u>	<u>(2) 30</u>	<u>()</u>
3. Bath Tub	<u></u>	<u>()</u>	<u>()</u>
4. Shower Stall	<u></u>	<u>()</u>	<u>()</u>
5. Kitchen Sink	<u></u>	<u>()</u>	<u>()</u>
6. Service Sink	<u></u>	<u>()</u>	<u>()</u>
7. Laundry Tray	<u></u>	<u>()</u>	<u>()</u>
8. Dishwasher	<u></u>	<u>()</u>	<u>()</u>
9. Washing Machine	<u></u>	<u>()</u>	<u>()</u>
10. Urinal	<u></u>	<u>()</u>	<u>()</u>
11. Floor Drain	<u></u>	<u>()</u>	<u>()</u>
12. Drinking Fountain	<u></u>	<u>()</u>	<u>()</u>
13. Air Conditioner (water cooled)	<u></u>	<u>()</u>	<u>()</u>
14. Dental Unit	<u></u>	<u>()</u>	<u>()</u>
15. Lawn Sprinkler No. of Heads	<u></u>	<u>()</u>	<u>()</u>
16. Fire Sprinkler No. of Heads	<u></u>	<u>()</u>	<u>()</u>
17. <u></u>	<u></u>	<u>()</u>	<u>()</u>
18. <u></u>	<u></u>	<u>()</u>	<u>()</u>

Total 105

Gallons per minute 44.5

Size of Service 1 1/2"

Date: 5-31-89

Approved: J. D. Spil
Brick Township Plumbing Inspector

SIZING FOR WATER AND SEWER SERVICES

Property Owner KENNEDY MALL ASSOC. Date 5-31-89
 Property Address KENNEDY MALL UNIT #1 Block 670 Lot 4-5-8-23-25
 Zoning _____ Use Group _____
 Contractor PINELAND License No. Registration 1722
 Water Main Size _____ Water Pressure _____ Sewer Main Size _____

<u>Plumbing Fixtures</u>	<u>Number</u>	<u>(sfu) Water Units</u>	<u>(dfu) Drainage Units</u>
1. Water Closet	<u>1</u>	<u>(5) 5</u>	<u>()</u>
2. Lavatory	<u>1</u>	<u>(2) 2</u>	<u>()</u>
3. Bath Tub	_____	<u>()</u>	<u>()</u>
4. Shower Stall	_____	<u>()</u>	<u>()</u>
5. Kitchen Sink	_____	<u>()</u>	<u>()</u>
6. Service Sink	_____	<u>()</u>	<u>()</u>
7. Laundry Tray	_____	<u>()</u>	<u>()</u>
8. Dishwasher	_____	<u>()</u>	<u>()</u>
9. Washing Machine	_____	<u>()</u>	<u>()</u>
10. Urinal	_____	<u>()</u>	<u>()</u>
11. Floor Drain	_____	<u>()</u>	<u>()</u>
12. Drinking Fountain	_____	<u>()</u>	<u>()</u>
13. Air Conditioner (water cooled)	_____	<u>()</u>	<u>()</u>
14. Dental Unit	_____	<u>()</u>	<u>()</u>
15. Lawn Sprinkler No. of Heads	_____	<u>()</u>	<u>()</u>
16. Fire Sprinkler No. of Heads	_____	<u>()</u>	<u>()</u>
17. _____	_____	<u>()</u>	<u>()</u>
18. _____	_____	<u>()</u>	<u>()</u>

Total 7

Gallons per minute 5.7

Size of Service 3/4"

Date: 5-31-89

Approved: J. W. Spivey
 Brick Township Plumbing Inspector

SIZING FOR WATER AND SEWER SERVICES

Property Owner KENNEDY MALL ASSOC. Date 5-31-89
 Property Address KENNEDY MALL UNIT #2 Block 670 Lot 4-5-8-23-25
 Zoning 1 Use Group _____
 Contractor PINELAND License No. Registration 1722

Water Main Size _____ Water Pressure _____ Sewer Main Size _____

<u>Plumbing Fixtures</u>	<u>Number</u>	<u>(sfu) Water Units</u>	<u>(dfu) Drainage Units</u>
1. Water Closet	<u>1</u>	<u>(5) 5</u>	<u>()</u>
2. Lavatory	<u>1</u>	<u>(2) 2</u>	<u>()</u>
3. Bath Tub	_____	<u>()</u>	<u>()</u>
4. Shower Stall	_____	<u>()</u>	<u>()</u>
5. Kitchen Sink	_____	<u>()</u>	<u>()</u>
6. Service Sink	_____	<u>()</u>	<u>()</u>
7. Laundry Tray	_____	<u>()</u>	<u>()</u>
8. Dishwasher	_____	<u>()</u>	<u>()</u>
9. Washing Machine	_____	<u>()</u>	<u>()</u>
10. Urinal	_____	<u>()</u>	<u>()</u>
11. Floor Drain	_____	<u>()</u>	<u>()</u>
12. Drinking Fountain	_____	<u>()</u>	<u>()</u>
13. Air Conditioner (water cooled)	_____	<u>()</u>	<u>()</u>
14. Dental Unit	_____	<u>()</u>	<u>()</u>
15. Lawn Sprinkler No. of Heads	_____	<u>()</u>	<u>()</u>
16. Fire Sprinkler No. of Heads	_____	<u>()</u>	<u>()</u>
17. _____	_____	<u>()</u>	<u>()</u>
18. _____	_____	<u>()</u>	<u>()</u>

Total 7

Gallons per minute 5.7

Size of Service 3/4"

Date: 5-31-89

Approved: J. W. [Signature]
 Brick Township Plumbing Inspector

SIZING FOR WATER AND SEWER SERVICES

Property Owner KENNEDY MALL ASSOC. Date 5-31-89
 Property Address KENNEDY MALL UNIT #3 Block 670 Lot 4-5-8-23-25
 Zoning _____ Use Group _____
 Contractor PINELAND License No. Registration 1722
 Water Main Size _____ Water Pressure _____ Sewer Main Size _____

Plumbing Fixtures	Number	(sfu)	Water Units	(dfu)	Drainage Units
1. Water Closet	<u>1</u>	<u>(5)</u>	<u>5</u>	<u>()</u>	_____
2. Lavatory	<u>1</u>	<u>(2)</u>	<u>2</u>	<u>()</u>	_____
3. Bath Tub	_____	<u>()</u>	_____	<u>()</u>	_____
4. Shower Stall	_____	<u>()</u>	_____	<u>()</u>	_____
5. Kitchen Sink	_____	<u>()</u>	_____	<u>()</u>	_____
6. Service Sink	_____	<u>()</u>	_____	<u>()</u>	_____
7. Laundry Tray	_____	<u>()</u>	_____	<u>()</u>	_____
8. Dishwasher	_____	<u>()</u>	_____	<u>()</u>	_____
9. Washing Machine	_____	<u>()</u>	_____	<u>()</u>	_____
10. Urinal	_____	<u>()</u>	_____	<u>()</u>	_____
11. Floor Drain	_____	<u>()</u>	_____	<u>()</u>	_____
12. Drinking Fountain	_____	<u>()</u>	_____	<u>()</u>	_____
13. Air Conditioner (water cooled)	_____	<u>()</u>	_____	<u>()</u>	_____
14. Dental Unit	_____	<u>()</u>	_____	<u>()</u>	_____
15. Lawn Sprinkler No. of Heads	_____	<u>()</u>	_____	<u>()</u>	_____
16. Fire Sprinkler No. of Heads	_____	<u>()</u>	_____	<u>()</u>	_____
17. _____	_____	<u>()</u>	_____	<u>()</u>	_____
18. _____	_____	<u>()</u>	_____	<u>()</u>	_____

Total 7

Gallons per minute 5.7

Size of Service 3/4"

Date: 5-31-89

Approved: J. W. Spill
 Brick Township Plumbing Inspector

SIZING FOR WATER AND SEWER SERVICES

Property Owner KENNEDY MALL ASSOC. Date 5-31-89
 Property Address KENNEDY MALL UNIT #4 Block 670 Lot 4-5-8-23-25

Zoning _____ Use Group _____

Contractor PINELAND License No. Registration 1722

Water Main Size _____ Water Pressure _____ Sewer Main Size _____

Plumbing Fixtures	Number	(sfu)	Water Units	(dfu)	Drainage Units
1. Water Closet	<u>1</u>	<u>(5)</u>	<u>5</u>	<u>()</u>	_____
2. Lavatory	<u>1</u>	<u>(2)</u>	<u>2</u>	<u>()</u>	_____
3. Bath Tub	_____	<u>()</u>	_____	<u>()</u>	_____
4. Shower Stall	_____	<u>()</u>	_____	<u>()</u>	_____
5. Kitchen Sink	_____	<u>()</u>	_____	<u>()</u>	_____
6. Service Sink	_____	<u>()</u>	_____	<u>()</u>	_____
7. Laundry Tray	_____	<u>()</u>	_____	<u>()</u>	_____
8. Dishwasher	_____	<u>()</u>	_____	<u>()</u>	_____
9. Washing Machine	_____	<u>()</u>	_____	<u>()</u>	_____
10. Urinal	_____	<u>()</u>	_____	<u>()</u>	_____
11. Floor Drain	_____	<u>()</u>	_____	<u>()</u>	_____
12. Drinking Fountain	_____	<u>()</u>	_____	<u>()</u>	_____
13. Air Conditioner (water cooled)	_____	<u>()</u>	_____	<u>()</u>	_____
14. Dental Unit	_____	<u>()</u>	_____	<u>()</u>	_____
15. Lawn Sprinkler No. of Heads	_____	<u>()</u>	_____	<u>()</u>	_____
16. Fire Sprinkler No. of Heads	_____	<u>()</u>	_____	<u>()</u>	_____
17. _____	_____	<u>()</u>	_____	<u>()</u>	_____
18. _____	_____	<u>()</u>	_____	<u>()</u>	_____

Total 7

Gallons per minute 5.7

Size of Service 3/4"

Date: 5-31-89

Approved: J. W. Sp...
 Brick Township Plumbing Inspector

SIZING FOR WATER AND SEWER SERVICES

Property Owner KENNEDY MALL ASSOC. Date 5-31-89
 Property Address KENNEDY MALL UNIT #5 Block 670 Lot 4-5-8-23-25
 Zoning _____ Use Group _____
 Contractor PINELAND License No. Registration 1722

Water Main Size _____ Water Pressure _____ Sewer Main Size _____

<u>Plumbing Fixtures</u>	<u>Number</u>	<u>(sfu)</u>	<u>Water Units</u>	<u>(dfu)</u>	<u>Drainage Units</u>
1. Water Closet	<u>1</u>	<u>(5)</u>	<u>5</u>	<u>()</u>	_____
2. Lavatory	<u>1</u>	<u>(2)</u>	<u>2</u>	<u>()</u>	_____
3. Bath Tub	_____	<u>()</u>	_____	<u>()</u>	_____
4. Shower Stall	_____	<u>()</u>	_____	<u>()</u>	_____
5. Kitchen Sink	_____	<u>()</u>	_____	<u>()</u>	_____
6. Service Sink	_____	<u>()</u>	_____	<u>()</u>	_____
7. Laundry Tray	_____	<u>()</u>	_____	<u>()</u>	_____
8. Dishwasher	_____	<u>()</u>	_____	<u>()</u>	_____
9. Washing Machine	_____	<u>()</u>	_____	<u>()</u>	_____
10. Urinal	_____	<u>()</u>	_____	<u>()</u>	_____
11. Floor Drain	_____	<u>()</u>	_____	<u>()</u>	_____
12. Drinking Fountain	_____	<u>()</u>	_____	<u>()</u>	_____
13. Air Conditioner (water cooled)	_____	<u>()</u>	_____	<u>()</u>	_____
14. Dental Unit	_____	<u>()</u>	_____	<u>()</u>	_____
15. Lawn Sprinkler No. of Heads	_____	<u>()</u>	_____	<u>()</u>	_____
16. Fire Sprinkler No. of Heads	_____	<u>()</u>	_____	<u>()</u>	_____
17. _____	_____	<u>()</u>	_____	<u>()</u>	_____
18. _____	_____	<u>()</u>	_____	<u>()</u>	_____

Total 7
 Gallons per minute 5.7
 Size of Service 3/4"

Date: 5-31-89 Approved: J. W. Sp...
 Brick Township Plumbing Inspector

SIZING FOR WATER AND SEWER SERVICES

Property Owner KENNEDY MALL ASSOC. Date 5-31-89
 Property Address KENNEDY MALL UNIT #6 Block 670 Lot 4-5-8-23-25
 Zoning _____ Use Group _____
 Contractor PINELAND License No. Registration 1722
 Water Main Size _____ Water Pressure _____ Sewer Main Size _____

<u>Plumbing Fixtures</u>	<u>Number</u>	<u>(sfu) Water Units</u>	<u>(dfu) Drainage Units</u>
1. Water Closet	<u>1</u>	<u>(5) 5</u>	<u>()</u>
2. Lavatory	<u>1</u>	<u>(2) 2</u>	<u>()</u>
3. Bath Tub	_____	<u>()</u>	<u>()</u>
4. Shower Stall	_____	<u>()</u>	<u>()</u>
5. Kitchen Sink	_____	<u>()</u>	<u>()</u>
6. Service Sink	_____	<u>()</u>	<u>()</u>
7. Laundry Tray	_____	<u>()</u>	<u>()</u>
8. Dishwasher	_____	<u>()</u>	<u>()</u>
9. Washing Machine	_____	<u>()</u>	<u>()</u>
10. Urinal	_____	<u>()</u>	<u>()</u>
11. Floor Drain	_____	<u>()</u>	<u>()</u>
12. Drinking Fountain	_____	<u>()</u>	<u>()</u>
13. Air Conditioner (water cooled)	_____	<u>()</u>	<u>()</u>
14. Dental Unit	_____	<u>()</u>	<u>()</u>
15. Lawn Sprinkler No. of Heads	_____	<u>()</u>	<u>()</u>
16. Fire Sprinkler No. of Heads	_____	<u>()</u>	<u>()</u>
17. _____	_____	<u>()</u>	<u>()</u>
18. _____	_____	<u>()</u>	<u>()</u>

Total 7

Gallons per minute 5.7

Size of Service 3/4"

Date: 5-31-89 Approved: J.W. Spahn
 Brick Township Plumbing Inspector

SIZING FOR WATER AND SEWER SERVICES

Property Owner KENNEDY MALL ASSOC. Date 5-31-89
 Property Address KENNEDY MALL UNIT #7 Block 670 Lot 4-5-8-23-25

Zoning _____ Use Group _____

Contractor PINELAND License No. Registration 1722

Water Main Size _____ Water Pressure _____ Sewer Main Size _____

<u>Plumbing Fixtures</u>	<u>Number</u>	<u>(sfu) Water Units</u>	<u>(dfu) Drainage Units</u>
1. Water Closet	<u>1</u>	<u>(5) 5</u>	<u>()</u>
2. Lavatory	<u>1</u>	<u>(2) 2</u>	<u>()</u>
3. Bath Tub	_____	<u>()</u>	<u>()</u>
4. Shower Stall	_____	<u>()</u>	<u>()</u>
5. Kitchen Sink	_____	<u>()</u>	<u>()</u>
6. Service Sink	_____	<u>()</u>	<u>()</u>
7. Laundry Tray	_____	<u>()</u>	<u>()</u>
8. Dishwasher	_____	<u>()</u>	<u>()</u>
9. Washing Machine	_____	<u>()</u>	<u>()</u>
10. Urinal	_____	<u>()</u>	<u>()</u>
11. Floor Drain	_____	<u>()</u>	<u>()</u>
12. Drinking Fountain	_____	<u>()</u>	<u>()</u>
13. Air Conditioner (water cooled)	_____	<u>()</u>	<u>()</u>
14. Dental Unit	_____	<u>()</u>	<u>()</u>
15. Lawn Sprinkler No. of Heads	_____	<u>()</u>	<u>()</u>
16. Fire Sprinkler No. of Heads	_____	<u>()</u>	<u>()</u>
17. _____	_____	<u>()</u>	<u>()</u>
18. _____	_____	<u>()</u>	<u>()</u>

Total 7

Gallons per minute 5.7

Size of Service 3/4"

Date: 5-31-89

Approved: J. W. Spil
 Brick Township Plumbing Inspector

SIZING FOR WATER AND SEWER SERVICES

Property Owner KENNEDY MALL ASSOC. Date 5-31-89

Property Address KENNEDY MALL UNIT #8 Block 670 Lot 4-5-8-23-25

Zoning _____ Use Group _____

Contractor PINELAND License No. Registration 1722

Water Main Size _____ Water Pressure _____ Sewer Main Size _____

<u>Plumbing Fixtures</u>	<u>Number</u>	<u>(sfu) Water Units</u>	<u>(dfu) Drainage Units</u>
1. Water Closet	<u>1</u>	<u>(5) 5</u>	<u>()</u>
2. Lavatory	<u>1</u>	<u>(2) 2</u>	<u>()</u>
3. Bath Tub	<u> </u>	<u>()</u>	<u>()</u>
4. Shower Stall	<u> </u>	<u>()</u>	<u>()</u>
5. Kitchen Sink	<u> </u>	<u>()</u>	<u>()</u>
6. Service Sink	<u> </u>	<u>()</u>	<u>()</u>
7. Laundry Tray	<u> </u>	<u>()</u>	<u>()</u>
8. Dishwasher	<u> </u>	<u>()</u>	<u>()</u>
9. Washing Machine	<u> </u>	<u>()</u>	<u>()</u>
10. Urinal	<u> </u>	<u>()</u>	<u>()</u>
11. Floor Drain	<u> </u>	<u>()</u>	<u>()</u>
12. Drinking Fountain	<u> </u>	<u>()</u>	<u>()</u>
13. Air Conditioner (water cooled)	<u> </u>	<u>()</u>	<u>()</u>
14. Dental Unit	<u> </u>	<u>()</u>	<u>()</u>
15. Lawn Sprinkler No. of Heads	<u> </u>	<u>()</u>	<u>()</u>
16. Fire Sprinkler No. of Heads	<u> </u>	<u>()</u>	<u>()</u>
17. _____	<u> </u>	<u>()</u>	<u>()</u>
18. _____	<u> </u>	<u>()</u>	<u>()</u>

Total 7

Gallons per minute 5.7

Size of Service 3/4"

Date: 5-31-89

Approved: J. W. [Signature]
Brick Township Plumbing Inspector

SIZING FOR WATER AND SEWER SERVICES

Property Owner KENNEDY MALL ASSOC. Date 5-31-89
 Property Address KENNEDY MALL UNIT #9 Block 670 Lot 4-5-8-23-25
 Zoning _____ Use Group _____
 Contractor PINELAND License No. Registration 1722
 Water Main Size _____ Water Pressure _____ Sewer Main Size _____

<u>Plumbing Fixtures</u>	<u>Number</u>	<u>(sfu)</u>	<u>Water Units</u>	<u>(dfu)</u>	<u>Drainage Units</u>
1. Water Closet	<u>1</u>	<u>(5)</u>	<u>5</u>	<u>()</u>	_____
2. Lavatory	<u>1</u>	<u>(2)</u>	<u>2</u>	<u>()</u>	_____
3. Bath Tub	_____	<u>()</u>	_____	<u>()</u>	_____
4. Shower Stall	_____	<u>()</u>	_____	<u>()</u>	_____
5. Kitchen Sink	_____	<u>()</u>	_____	<u>()</u>	_____
6. Service Sink	_____	<u>()</u>	_____	<u>()</u>	_____
7. Laundry Tray	_____	<u>()</u>	_____	<u>()</u>	_____
8. Dishwasher	_____	<u>()</u>	_____	<u>()</u>	_____
9. Washing Machine	_____	<u>()</u>	_____	<u>()</u>	_____
10. Urinal	_____	<u>()</u>	_____	<u>()</u>	_____
11. Floor Drain	_____	<u>()</u>	_____	<u>()</u>	_____
12. Drinking Fountain	_____	<u>()</u>	_____	<u>()</u>	_____
13. Air Conditioner (water cooled)	_____	<u>()</u>	_____	<u>()</u>	_____
14. Dental Unit	_____	<u>()</u>	_____	<u>()</u>	_____
15. Lawn Sprinkler No. of Heads	_____	<u>()</u>	_____	<u>()</u>	_____
16. Fire Sprinkler No. of Heads	_____	<u>()</u>	_____	<u>()</u>	_____
17. _____	_____	<u>()</u>	_____	<u>()</u>	_____
18. _____	_____	<u>()</u>	_____	<u>()</u>	_____

Total 7
 Gallons per minute 5.7
 Size of Service 3/4"

Date: 5-31-89 Approved: J. W. Spil
 Brick Township Plumbing Inspector

SIZING FOR WATER AND SEWER SERVICES

Property Owner KENNEDY MALL ASSOC. Date 5-31-89
 Property Address KENNEDY MALL UNIT #10 Block 670 Lot 4-5-8-23-2
 Zoning _____ Use Group _____
 Contractor PINELAND License No. Registration 1722
 Water Main Size _____ Water Pressure _____ Sewer Main Size _____

<u>Plumbing Fixtures</u>	<u>Number</u>	<u>(sfu) Water Units</u>	<u>(dfu) Drainage Units</u>
1. Water Closet	<u>1</u>	<u>(5) 5</u>	<u>()</u>
2. Lavatory	<u>1</u>	<u>(2) 2</u>	<u>()</u>
3. Bath Tub	_____	<u>()</u>	<u>()</u>
4. Shower Stall	_____	<u>()</u>	<u>()</u>
5. Kitchen Sink	_____	<u>()</u>	<u>()</u>
6. Service Sink	_____	<u>()</u>	<u>()</u>
7. Laundry Tray	_____	<u>()</u>	<u>()</u>
8. Dishwasher	_____	<u>()</u>	<u>()</u>
9. Washing Machine	_____	<u>()</u>	<u>()</u>
10. Urinal	_____	<u>()</u>	<u>()</u>
11. Floor Drain	_____	<u>()</u>	<u>()</u>
12. Drinking Fountain	_____	<u>()</u>	<u>()</u>
13. Air Conditioner (water cooled)	_____	<u>()</u>	<u>()</u>
14. Dental Unit	_____	<u>()</u>	<u>()</u>
15. Lawn Sprinkler No. of Heads	_____	<u>()</u>	<u>()</u>
16. Fire Sprinkler No. of Heads	_____	<u>()</u>	<u>()</u>
17. _____	_____	<u>()</u>	<u>()</u>
18. _____	_____	<u>()</u>	<u>()</u>

Total 7

Gallons per minute 5.7

Size of Service 3/4"

Date: 5-31-89

Approved: J. W. [Signature]
 Brick Township Plumbing Inspector

SIZING FOR WATER AND SEWER SERVICES

Property Owner KENNEDY MALL ASSOC. Date 5-31-89
 Property Address KENNEDY MALL UNIT #11 Block 670 Lot 4-5-8-23-2
 Zoning _____ Use Group _____
 Contractor PINELAND License No. Registration 1722

Water Main Size _____ Water Pressure _____ Sewer Main Size _____

Plumbing Fixtures	Number	(sfu) Water Units	(dfu) Drainage Units
1. Water Closet	<u>1</u>	(<u>5</u>) <u>5</u>	() _____
2. Lavatory	<u>1</u>	(<u>2</u>) <u>2</u>	() _____
3. Bath Tub	_____	() _____	() _____
4. Shower Stall	_____	() _____	() _____
5. Kitchen Sink	_____	() _____	() _____
6. Service Sink	_____	() _____	() _____
7. Laundry Tray	_____	() _____	() _____
8. Dishwasher	_____	() _____	() _____
9. Washing Machine	_____	() _____	() _____
10. Urinal	_____	() _____	() _____
11. Floor Drain	_____	() _____	() _____
12. Drinking Fountain	_____	() _____	() _____
13. Air Conditioner (water cooled)	_____	() _____	() _____
14. Dental Unit	_____	() _____	() _____
15. Lawn Sprinkler No. of Heads	_____	() _____	() _____
16. Fire Sprinkler No. of Heads	_____	() _____	() _____
17. _____	_____	() _____	() _____
18. _____	_____	() _____	() _____

Total 7

Gallons per minute 5.7

Size of Service 3/4"

Date: 5-31-89

Approved: J. W. Spil
 Brick Township Plumbing Inspector

SIZING FOR WATER AND SEWER SERVICES

Property Owner KENNEDY MALL ASSOC. Date 5-31-89
 Property Address KENNEDY MALL UNIT #12 Block 670 Lot 4-5-8-23-25
 Zoning _____ Use Group _____
 Contractor PINELAND License No. Registration 1722
 Water Main Size _____ Water Pressure _____ Sewer Main Size _____

<u>Plumbing Fixtures</u>	<u>Number</u>	<u>(sfu) Water Units</u>	<u>(dfu) Drainage Units</u>
1. Water Closet	<u>1</u>	<u>(5) 5</u>	<u>()</u>
2. Lavatory	<u>1</u>	<u>(2) 2</u>	<u>()</u>
3. Bath Tub	_____	<u>()</u>	<u>()</u>
4. Shower Stall	_____	<u>()</u>	<u>()</u>
5. Kitchen Sink	_____	<u>()</u>	<u>()</u>
6. Service Sink	_____	<u>()</u>	<u>()</u>
7. Laundry Tray	_____	<u>()</u>	<u>()</u>
8. Dishwasher	_____	<u>()</u>	<u>()</u>
9. Washing Machine	_____	<u>()</u>	<u>()</u>
10. Urinal	_____	<u>()</u>	<u>()</u>
11. Floor Drain	_____	<u>()</u>	<u>()</u>
12. Drinking Fountain	_____	<u>()</u>	<u>()</u>
13. Air Conditioner (water cooled)	_____	<u>()</u>	<u>()</u>
14. Dental Unit	_____	<u>()</u>	<u>()</u>
15. Lawn Sprinkler No. of Heads	_____	<u>()</u>	<u>()</u>
16. Fire Sprinkler No. of Heads	_____	<u>()</u>	<u>()</u>
17. _____	_____	<u>()</u>	<u>()</u>
18. _____	_____	<u>()</u>	<u>()</u>

Total 7
 Gallons per minute 5.7
 Size of Service 3/4"

Date: 5-31-89 Approved: J.W. Spill
 Brick Township Plumbing Inspector

SIZING FOR WATER AND SEWER SERVICES

Property Owner KENNEDY MALL ASSOC. Date 5-31-89
 Property Address KENNEDY MALL UNIT #13 Block 670 Lot 4-5-8-23-2
 Zoning _____ Use Group _____
 Contractor PINELAND License No. Registration 1722

Water Main Size _____ Water Pressure _____ Sewer Main Size _____

Plumbing Fixtures	Number	(sfu)	Water Units	(dfu)	Drainage Units
1. Water Closet	<u>1</u>	<u>(5)</u>	<u>5</u>	<u>()</u>	
2. Lavatory	<u>1</u>	<u>(2)</u>	<u>2</u>	<u>()</u>	
3. Bath Tub		<u>()</u>		<u>()</u>	
4. Shower Stall		<u>()</u>		<u>()</u>	
5. Kitchen Sink		<u>()</u>		<u>()</u>	
6. Service Sink		<u>()</u>		<u>()</u>	
7. Laundry Tray		<u>()</u>		<u>()</u>	
8. Dishwasher		<u>()</u>		<u>()</u>	
9. Washing Machine		<u>()</u>		<u>()</u>	
10. Urinal		<u>()</u>		<u>()</u>	
11. Floor Drain		<u>()</u>		<u>()</u>	
12. Drinking Fountain		<u>()</u>		<u>()</u>	
13. Air Conditioner (water cooled)		<u>()</u>		<u>()</u>	
14. Dental Unit		<u>()</u>		<u>()</u>	
15. Lawn Sprinkler No. of Heads		<u>()</u>		<u>()</u>	
16. Fire Sprinkler No. of Heads		<u>()</u>		<u>()</u>	
17. _____		<u>()</u>		<u>()</u>	
18. _____		<u>()</u>		<u>()</u>	

Total 7

Gallons per minute 5.7

Size of Service 3/4"

Date: 5-31-89

Approved: J. W. Spill
 Brick Township Plumbing Inspector

SIZING FOR WATER AND SEWER SERVICES

Property Owner KENNEDY MALL ASSOC. Date 5-31-89
 Property Address KENNEDY MALL UNIT #14 Block 670 Lot 4-5-8-23-2
 Zoning _____ Use Group _____
 Contractor PINELAND License No. Registration 1722
 Water Main Size _____ Water Pressure _____ Sewer Main Size _____

<u>Plumbing Fixtures</u>	<u>Number</u>	<u>(sfu)</u>	<u>Water Units</u>	<u>(dfu)</u>	<u>Drainage Units</u>
1. Water Closet	<u>1</u>	<u>(5)</u>	<u>5</u>	<u>()</u>	_____
2. Lavatory	<u>1</u>	<u>(2)</u>	<u>2</u>	<u>()</u>	_____
3. Bath Tub	_____	<u>()</u>	_____	<u>()</u>	_____
4. Shower Stall	_____	<u>()</u>	_____	<u>()</u>	_____
5. Kitchen Sink	_____	<u>()</u>	_____	<u>()</u>	_____
6. Service Sink	_____	<u>()</u>	_____	<u>()</u>	_____
7. Laundry Tray	_____	<u>()</u>	_____	<u>()</u>	_____
8. Dishwasher	_____	<u>()</u>	_____	<u>()</u>	_____
9. Washing Machine	_____	<u>()</u>	_____	<u>()</u>	_____
10. Urinal	_____	<u>()</u>	_____	<u>()</u>	_____
11. Floor Drain	_____	<u>()</u>	_____	<u>()</u>	_____
12. Drinking Fountain	_____	<u>()</u>	_____	<u>()</u>	_____
13. Air Conditioner (water cooled)	_____	<u>()</u>	_____	<u>()</u>	_____
14. Dental Unit	_____	<u>()</u>	_____	<u>()</u>	_____
15. Lawn Sprinkler No. of Heads	_____	<u>()</u>	_____	<u>()</u>	_____
16. Fire Sprinkler No. of Heads	_____	<u>()</u>	_____	<u>()</u>	_____
17. _____	_____	<u>()</u>	_____	<u>()</u>	_____
18. _____	_____	<u>()</u>	_____	<u>()</u>	_____

Total 7
 Gallons per minute 5.7
 Size of Service 3/4"

Date: 5-31-89 Approved: [Signature]
 Brick Township Plumbing Inspector

SIZING FOR WATER AND SEWER SERVICES

Property Owner KENNEDY MALL ASSOC. Date 5-31-89
 Property Address KENNEDY MALL UNIT #15 Block 670 Lot 4-5-8-23-2
 Zoning _____ Use Group _____
 Contractor PINELAND License No. Registration 1722

Water Main Size _____ Water Pressure _____ Sewer Main Size _____

<u>Plumbing Fixtures</u>	<u>Number</u>	<u>(sfu)</u>	<u>Water Units</u>	<u>(dfu)</u>	<u>Drainage Units</u>
1. Water Closet	<u>1</u>	<u>(5)</u>	<u>5</u>	<u>()</u>	_____
2. Lavatory	<u>1</u>	<u>(2)</u>	<u>2</u>	<u>()</u>	_____
3. Bath Tub	_____	<u>()</u>	_____	<u>()</u>	_____
4. Shower Stall	_____	<u>()</u>	_____	<u>()</u>	_____
5. Kitchen Sink	_____	<u>()</u>	_____	<u>()</u>	_____
6. Service Sink	_____	<u>()</u>	_____	<u>()</u>	_____
7. Laundry Tray	_____	<u>()</u>	_____	<u>()</u>	_____
8. Dishwasher	_____	<u>()</u>	_____	<u>()</u>	_____
9. Washing Machine	_____	<u>()</u>	_____	<u>()</u>	_____
10. Urinal	_____	<u>()</u>	_____	<u>()</u>	_____
11. Floor Drain	_____	<u>()</u>	_____	<u>()</u>	_____
12. Drinking Fountain	_____	<u>()</u>	_____	<u>()</u>	_____
13. Air Conditioner (water cooled)	_____	<u>()</u>	_____	<u>()</u>	_____
14. Dental Unit	_____	<u>()</u>	_____	<u>()</u>	_____
15. Lawn Sprinkler No. of Heads	_____	<u>()</u>	_____	<u>()</u>	_____
16. Fire Sprinkler No. of Heads	_____	<u>()</u>	_____	<u>()</u>	_____
17. _____	_____	<u>()</u>	_____	<u>()</u>	_____
18. _____	_____	<u>()</u>	_____	<u>()</u>	_____

Total 7

Gallons per minute 5.7

Size of Service 3/4"

Date: 5-31-89

Approved: J.W. Spill
 Brick Township Plumbing Inspector



The Schoor DePalma & Canger Group Inc.
McSWEENEY & DREWES
 Consulting and Municipal Engineers

201/840-1700
 1466 Route Eighty Eight West, Brick, NJ 08724

RECEIVED

APR 8 1988

ENGINEERING

TO BRICK TOWNSHIP
401 CHAMBERS BRIDGE ROAD
BRICK, N.J. 08724

Block 670
LETTER OF TRANSMITTAL
 Lot 4, 5, 8, 23-25.

DATE	APRIL 8, 1988	JOB NO.	800190
ATTENTION	JERRY TANSEY		
RE:	KENNEDY MALL EXPANSION		
	APPROVALS REC'D.		

WE ARE SENDING YOU ☒ Attached ☐ Under separate cover via _____ the following items:

- ☐ Shop drawings ☐ Prints ☐ Plans ☐ Samples ☐ Specifications
☒ Copy of letter ☐ Change order ☐ _____

COPIES	DATE	NO.	DESCRIPTION
1	6/24/87		APPROVAL LETTER - FIRE SAFETY
1	2/18/87		" " - OCEAN CTY. SOIL CONS. DISTRICT
1	5/18/87		LETTER - SHADE TREE COMMISSION

THESE ARE TRANSMITTED as checked below:

- ☐ For approval ☐ Approved as submitted ☐ Resubmit _____ copies for approval
☒ For your use ☐ Approved as noted ☐ Submit _____ copies for distribution
☒ As requested ☐ Returned for corrections ☐ Return _____ corrected prints
☐ For review and comment ☐ _____
☐ FOR BIDS DUE _____ 19 _____ ☐ PRINTS RETURNED AFTER LOAN TO US

REMARKS

IF YOU HAVE ANY QUESTIONS, PLEASE CALL.

[Signature]

RECEIVED

APR 11 1988

ENGINEERING

COPY TO _____

SIGNED:

Victoria K Goldberg

BRICK TOWNSHIP BUREAU OF FIRE SAFETY



500 Herbertsville Road
Brick Township, New Jersey 08724
(201) 458-4100

JUN 26

BRICK TOWNSHIP PLANNING BOARD

RECEIVED

June 24, 1987
District 1 JUL 1 1987

McSWEENEY & DREWES

Office of the Planning Board
401 Chambers Bridge Road
Brick, NJ 08723

BLOCK: 670 LOT: 4,5,8,23,8,25 APPLICANT: Kennedy Mall Assoc.
241 Milburn Ave.
Milburn, NJ 07041

ENGINEER/FILE: McSweeney & Drewes
#86019A

B.T.P.B.#: 1731

SITE PLAN FEE: REVISION

LOCATION: Hooper Ave. & Brick Blvd.

PROPOSED USE: Addition to existing shopping mall

DESCRIPTION: 25,830 sq.ft. addition-Retail Stores

The above mentioned revised site plan has been reviewed and stamped approved and 1 copy sent to the Board Secretary.

Sincerely,

William P. Edwards,
Fire Inspector

RECEIVED

APR 11 1988

ENGINEERING

WPE/dle



OCEAN COUNTY SOIL CONSERVATION DISTRICT

6 Mott Place, C.N. 2191,
Toms River, N.J. 08753
Telephone: (201) 244-7048

SUPERVISORS:

FRANK BARTOLF, CHAIRMAN
GEORGE EMLEY, VICE CHAIRMAN
SIGMOND ZSOLDOS, TREASURER
ALBERT E. NEWBY
A. JEROME WALNUT

February 16, 1987

February 18, 1987

Mr. Sal Davino
Kennedy Mall Associates
241 Millburn Avenue
Millburn, NJ 07041

Soil Conservation District
6 Mott Place

Re: SCD #2275; Kennedy Mall Expansion; Block 670; Lots 5 and
25; Brick Boulevard & Hooper Avenue; Brick Township

Dear Mr. Davino:

Attention: Alan Perry, Soil Conservation Associate

Pursuant to Chapter 251, Soil Erosion and Sediment Control Act, P.L. 1975, the Ocean County Soil Conservation District hereby grants certification of the soil erosion and sediment control plan for the above captioned project, subject to the following:

1. That the applicant carries out all land disturbance activities in accordance with the Standards for Soil Erosion and Sediment Control in New Jersey promulgated by the State Soil Conservation Committee.

2. The applicant must notify the District office, by mail, at least 72 hours prior to initial land disturbance.

3. A letter must be written notifying the District office of project completion within 48 hours immediately following completion.

4. Changes in the certified plan relating to or that will affect land disturbance on the site must be submitted to the District office for reevaluation and approval.

5. A copy of the certified plan and a copy of these provisions must be kept on the job site at all times.

Failure to comply with any of the above conditions may result in the issuance of a stop construction order.

NOTE: Extra measures will be required if existing erosion problems become worse due to additional runoff.

SAR/laj
Enclosure
cc: Sal Davino

AP:rp

Sincerely,

A. E. Newby
RECEIVED

RECEIVED


Distribution: White - Applicant
Green - Construction Official
Canary - Planning Board
Pink - Township Engineer
Goldenrod - District

APR 11 1988

ENGINEERING

TOWNSHIP OF BRICK
OCEAN COUNTY, NEW JERSEY
401 CHAMBERS BRIDGE ROAD, BRICK, N. J. 08723

OFFICE OF: the SHADE TREE COMMISSION



(201) 477-3000

RECEIVED

JUN 11 1987

W. J. Doyle, Jr. Clerk


TO: Planning Board
FROM: Lonna Doyle, Commissioner
DATE: May 18, 1987
RE: Case 1731 - Kennedy Mall Expansion

We recommend that some type of islands be incorporated to interrupt the large amount of black top area; as many as possible as recommended by the Township Engineer since this is a large open space without vegetation.

We also recommend the elimination of weeping forsythia and instead substituting another type of plant that will remain green year round. Forsythia bushes lose all of their leaves during the winter and also create a mess after flowering.

We recommend planting some type of shrubbery under the Sgt. Cherry Trees, Brick Blvd. to avoid weeds growing.

We must remind you that Brick Blvd. is one of the main access roads throughout Brick Township and we want to make it as attractive as possible with shade tree plantings.



June 22, 1988

Rec. 6-23-88
[Signature]

P.A. MARCHETTA
A I A P P
ARCHITECT - PLANNER

SIXTY-THREE RIDGE ROAD
P.O. BOX 802
LYNDHURST, N.J. 07071
(201) 935-4410

Township of Brick
401 Chamber Ridge Road
Brick, New Jersey 08723

Attn: Mr. Suttan

Re: Kennedy Shopping Center
Brick, New Jersey

J#83-012-A

Dear Mr. Suttan:

As per our telephone conversation with the contractor I am Hereby forwarding a letter to you expressing some minor changes that will be made from the plans as approved.

Item #1: Regarding the toilets and lavatories as indicated on plans: size and provision should be made to allow for the number as indicated however, the owner intends to just rough in the plumbing for a number of the fixtures as indicated. As per my telephone conversation with Mr. Art Ceirro he saw no problem in doing this because for certificate of occupancy the occupant loads will be calculated and the number of fixtures per tenant will be verified before issuance.

Item #2: Rear wall construction: as per attached detail we have modified the re-enforcement and finish of the wall. This will not change any of the foundation details nor foot print of the building. We have elected to do the additional re-enforcement thereby not obligating us to construct interior divider partitions until the tenants move in and set up.

If you see any problem with thi please do not hesitate to contact our office.

Respectfully,











































[Signature of Melvin E. Lamp]
Melvin E. Lamp

MEL/jk

This transparency device and the method of producing drawings and data sheets, using same, are covered by patents pending.
(N) = Number of Webs = 1, 2 or 3
ALL JOINTS AT A SUPPORT MAY HAVE A BEARING PLATE (BR01)

AUTO TRUSS

Gang-Nail Systems, Inc.
P.O. Box 59, 2037 Ave.
Miami, Florida 33159-2037



Plant Adams
5/25/88

```

MAIL VALUES(PSI) NET
      CHDRS      HEBS
      MAX MIN    MAX MIN
GN20  227 227  227 227

```













































IT
Gang-Nail Systems, Inc.
P.O. Box 49 2031 Aulife Miami, Florida 33156-2007
Local (305) 695-0900 • National WATS (800) 337-3000
Florida WATS (800) 432-2900

IMPORTANT: READ ALL NOTES ON THIS DRAWING!

AUTO TRUSS

Gang-Nail Systems, Inc.
 Miami, Florida 33159-2027
 P.O. Box 58-2027 AMF
 P.O. Box 58-2027 AMF

(IN) = Number of Webs = 1, 2 or 3
 ALL JOINTS AT A SUPPORT MAY
 HAVE A BEARING PLATE (BR01)
 This transparency device and the method of producing drawings and data
 sheets, using same, are covered by patents pending.



Piggy Back tops

JT TYPE	H	LEN	Y	X (MEMBER)
1 HLI3 GNA20 3.0X 7.8			0.25	11.02(1- 2)
2 INI1 GNA20 2.0X 2.3				
3 PKI2 GNA20 4.0X 4.7				
4 INI1 GNA20 2.0X 2.3				
5 HLI3 GNA20 3.0X 7.8			0.25	11.02(5- 4)
6 INI2 GNA20 3.0X 3.9				
7 INI2 GNA20 3.0X 3.9				
SPICES				
6- 7 SP10 GNA20 3.0X 4.7				
DESIGN SPECS. FOR LIGHT METAL PLATE				
CONNECTED HOOD TRUSSES, TP1.1985				
REFER TO GANG-NAIL TECHNICAL BULLETIN				
= 164 FOR FRAMING PRODUCTS APPLICATION				
GANG-NAIL "BT" RECOMMENDED FOR LATERAL				
RESTRAINT OF NON-BEARING PARTITION WALLS				

MAX. PURLIN SPACE= 0.0 FT., MAX. UNBRACED BOT.CH. LEN.= 10.0 FT
*** PLYWOOD SHEATHING REQUIRED ON TOP CHORD ***

NOTE: LATERAL BRACES AND PURLINS INDICATED FOR TRUSS MEMBERS ARE REQUIRED TO REDUCE BUCKLING LENGTH OF MEMBER, AND SHOULD BE NAILED TO TRUSS MEMBERS WITH MINIMUM OF 2-100 COMMON WIRE NAILS. PROVISIONS MUST BE MADE AT ENDS OR SPECIFIED INTERVALS TO RESTRAIN OR ANCHOR LATERAL BRACING, BY OTHERS.

CHORDS	SIZE	LUMBER	DESCRIPTION
1- 3	2X 4	NO. 2	D. KD15 SO. PINE
3- 5	2X 4	NO. 2	D. KD15 SO. PINE
5- 1	2X 4	NO. 2	KD15 SO. PINE
ALL MEMS	2X 4	NO. 3	KD15 SO. PINE

THIS TRUSS IS DESIGNED TO SUPPORT VERTICAL LOADS AS DETERMINED BY OTHERS AND SHOWN ON INPUT LISTING. VERIFICATION OF LOADING, DEFLECTION, LIMITATIONS, FRAMING METHODS, HIND BRACING OR OTHER LATERAL BRACING THAT IS ALWAYS REQUIRED, IS THE RESPONSIBILITY OF THE PROJECT ARCHITECT OR ENGINEER.

```

DESIGN CRITERIA
TOP CH.  LI = 30  PSF
          DL = 10  PSF
BOT CH.  LI = 0   PSF
          DL = 10  PSF
TOTAL LOAD= 50   PSF


SPACING= 24 IN. C/C

INPUT DEFL. L/240

INCREASES(PER CENT)
TUBER = 15 BCL LS = 15
LCHB = 15 BCL LS = 15

MAIL VALUES(PST) NET
CHORDS      MEAS
MAX MIN     MAX MIN
GNA20 227 227 227 227

```



5/25/88

[illegible]


IMPORTANT: READ ALL NOTES ON THIS DRAWING

This transparency device and the method of producing drawings and data sheets, using same, are covered by patents pending.
 (N) = Number of Webs = 1, 2 or 3
 ALL JOINTS AT A SUPPORT MAY HAVE A BEARING PLATE (BR01)

AUTO TRUSS


Gang-Nail Systems, Inc.
 Miami, Florida 33159-2037
 P.O. Box 2037 AMF

BR02 BEARING DETAIL - PLAN VIEW	BR01 FLUSH PLATE LENGTH PARALLEL TO CHORD	ISO(N) FLUSH PLATE LENGTH PARALLEL TO CHORD	PK4(N) PLATE LENGTH PARALLEL TO LEFT CHORD	PK5(N) PLATE LENGTH PARALLEL TO RIGHT CHORD	SP10 FLUSH	SP11 FLUSH BLOCK	SP20 FLUSH BLOCK	VC2(N)	VC3(N)	VC1(N) FLUSH	PK3(N) PLATE LENGTH VERTICAL	PK2(N) PLATE LENGTH PERPENDICULAR TO CUT	PK1(N) PLATE LENGTH HORIZONTAL	PE4(N) PLATE LENGTH PARALLEL TO LEFT CHORD	PE2(N) PLATE LENGTH PARALLEL TO STEEPER SLOPED CHORD	HP1(N) PLATE LENGTH PARALLEL TO SHALLOWER SLOPED CHORD	HP2(N) PLATE LENGTH PARALLEL TO STEEPER SLOPED CHORD	HP3(N) PLATE LENGTH PERPENDICULAR TO CHORD	INO(N) FLUSH PLATE LENGTH PARALLEL TO CHORD	IN11 FLUSH PLATE LENGTH PARALLEL TO WEBS	HL7B FLUSH	HL21	HL24	HL31	HL41	HL48	HL71	HL13	HL14	HL15	HL16	ET00	ET01	ET11	ET01	ET04	ET01	ET01	ET01
---	---	---	--	---	------------------------------	--	--	----------------------	----------------------	--------------------------------	--	--	--	--	--	--	--	--	---	--	------------------------------	--------------------	--------------------	--------------------	--------------------	--------------------	--------------------	--------------------	--------------------	--------------------	--------------------	--------------------	--------------------	--------------------	--------------------	--------------------	--------------------	--------------------	--------------------



PAUL BECK ASSOCIATES

Structural Engineers

122 Parish Drive
Wayne, New Jersey 07470WOOD TRUSSED RAFTERS
BY OTHERSRec
6-23-88
[Signature]

Note: POUR CONCRETE SLABS IN ALTERNATING LANES MIN. LENGTH EXTENDING FROM WALL 60' AS SHOWN. WIRE MESH SHOULD BE CONTINUOUS OR USE MIN. 2'-0 LAP IF REQUIRED. BE CAREFUL NOT TO DISTURB MESH WHEN SAW CUTTING SLABS!

FE10444













































5/19/82

5 OF 6
18444

THIS PATENT DEVICE AND THE METHOD OF PRODUCING DRAWINGS AND DATA SHEETS, USING SAME, ARE COVERED BY PATENTS PENDING.
 (N) = NUMBER OF WEBS = 1, 2 OR 3. ALL JOINTS AT A SUPPORT MAY HAVE A BEARING PLATE (BR01)

AUTOTRUSS

Gang-Nail Systems, Inc.
 100 BOX 58-2037 AMF
 MARIETTA, GEORGIA 30158-2037

```

DESIGN CRITERIA
TOP CH.  L= 30  PSF
          DL= 10  PSF
BOI CH.  L= 0   PSF
          DL= 10  PSF
TOTAL LOAD= 50  PSF

SPACING= 24 IN. /C

INPUT DEF.  L/240

INCREASES(PERCENT)
LUMBER= 15 NAIL= 15
TCH L5= 15 BCH L5= 15

NAIL VALUE(S)PSI NET
CHORDS  WEBS
MAX MIN  MAX MIN
GNAD, 227 227 227 227

LEFT OVERHANG= 1-10'-8

```

Cautions: Connector plates are designed for forces shown only. Increase plate sizes as necessary for handling on joints, such as heel, hip, peak, splices, etc.

5/19/68




IT Gang-Mail Systems, Inc.
P.O. Box 39 2007 AMF • Miami, Florida 33156-2007
1 Local (305) 656-0900 • National WATS (800) 327-3206
Florida WATS (800) 432-7609

AUTOTRUS


Gang-Nail Systems, Inc.
P.O. Box 59-2027 AMF
Miami, Florida 33158-2027

(N) = Number of Webs = 1, 2 or 3
ALL JOINTS AT A SUPPORT MAY HAVE A BEARING PLATE (BR1)
This transparency device and the method of producing drawings and data sheets, using same, are covered by patents pending


PK4(N)
CHORD
PLATE LENGTH PARALLEL TO LEFT




PK5(N)
RIGHT CHORD
PLATE LENGTH PARALLEL TO




SP10




SP11
BLOCK




SP10 SP20



VC1(N)
FLUSH




ISO(N)
BR1
FLUSH
PLATE LENGTH PARALLEL TO CHORD




PB2(N)
90°
PLATE LENGTH PERPENDICULAR TO CHORD




PE4(N)
PLATE LENGTH PARALLEL TO LEFT CHORD




PK1(N)
PK00
PLATE LENGTH HORIZONTAL TO CUT




PK2(N)
90°
PLATE LENGTH PERPENDICULAR TO CUT




PK3(N)
PLATE LENGTH VERTICAL




HL78
HL51



HP1(N)
HP00
PLATE LENGTH PARALLEL TO SLOPE
SLOPE CHORD




HP2(N)
PLATE LENGTH PARALLEL TO STEEPER SLOPE CHORD




HP3(N)
PLATE LENGTH PARALLEL TO CHORD
SLOPE CHORD




INO(N)
BR01
FLUSH
PLATE LENGTH PARALLEL TO CHORD




IN11
BR01
FLUSH
PLATE LENGTH PARALLEL TO WEBS




HL21




HL24




HL31




HL41
HL00
HL51




HL48
HL51




HL71
HL51




HL05




HL11




HL13




HL14
BUTT CUT




HL15




HL16




EBO(N)




EB11




ETO(N)
ETO0




ET11




HL01
WEDGE
WEO1




HL04




BR02
BEARING DETAIL - PLAN VIEW
BR02




CL1(N)
FLUSH WHEN NOT GIVEN
90° ANGLE BETWEEN PLATE AND CUT




CL1(N) CL2(N)
FLUSH WHEN NOT GIVEN
90° ANGLE BETWEEN PLATE AND CUT




CR0(N)
SH11



CR0(N)
SH01



CR11
BR01
FLUSH



7 F3-18C
JT TYPE W LEN Y X (MEMBERS)

1 H1.01 GNA20 2.7X 4.7
2 H1.01 GNA20 2.0X 2.3
3 H1.01 GNA20 4.0X 7.0
4 H1.01 GNA20 3.0X 4.7
5 H1.01 GNA20 4.0X 3.9

DESIGN SPEC: FOR LIGHT METAL PLATE
CONNECTED WOOD TRUSSES, IPI, 1985

REFER TO GANG-NAIL TECHNICAL BULLETIN
164 FOR FRAMING PRODUCTS APPLICATION
GANG-NAIL "91C" RECOMMENDED FOR LATERAL
RESTRAINT OF NON-BEARING PARTITION WALLS


MEMBER	FORCE (LBS)	HOR DISP FT-IN-5X	SLOPE/12 DEPTH IN	LOAD (PLF)	MAXIMUM LENGTH	WEIR F FR-TO (LBS)	CONC LOAD LBS	CHORDS	SIZE	LUMBER DESCRIPTION
1-2	4176	4-3-12	4.000	80.0	0.0	2-4	4276	3	2X 4	NO. 2 KD15 SO. PINE
2-3	0	0-0-0	0.000	80.0	0.0	4-1	0	0	2X 4	NO. 2 KD15 SO. PINE
3-4	2361	0-0-0	0.000	80.0	0.0	4-1	0	0	2X 4	NO. 2 KD15 SO. PINE
4-1	3951	7-9-12	0.000	20.0	10.0	WEBS 2-4	0	0	2X 4	NO. 2 KD15 SO. PINE
						WEBS 3-4	0	0	2X 6	

DESIGN CRITERIA
TOP CH. LL= 30 PSF
DL= 10 PSF
90T CH. DL= 0 PSF
TOTAL LOAD= 50 PSF
SPACING= 24 IN. C/O
INPUT DEF. C/2+0
INCREASES (PER CENT)
LUMBER= 15 NAIL= 15
TCH LS= 15 BOH LS= 15
NAIL VALUES (PSI) NFI
CHORDS MAX MIN
GNA20 227 227 227 227
LEFT OVERHANG = 0-6-0

NOTE: LATERAL BRACES AND PURLINS INDICATED FOR TRUSS MEMBERS
ARE REQUIRED TO REDUCE BUCKLING LENGTH OF MEMBER, AND SHOULD
BE NAILED TO TRUSS MEMBERS WITH MINIMUM OF 2-10D COMMON WIRE
NAILS. PROVISIONS MUST BE MADE AT ENDS OR SPECIFIED INTERVALS
TO RESTRAIN OR ANCHOR LATERAL BRACING BY OTHERS.

Note: Verify all dimensions before fabrication.

GROSS BRG
JT REACT IN-SX
1 431 5-8
3 427 5-8
HEEL-L= 4/16
OWH-R=25-0 P



Handling & Erection

CARELESS HANDLING OF COMPONENTS SHALL NOT BE PERMITTED
UNLESS THE FOLLOWING PRECAUTIONS ARE TAKEN: ALL COMPONENTS
SHALL BE LIFTED BY THE LIFTING POINTS INDICATED BY THE
DRAWING. NO OTHER LIFTING POINTS SHALL BE USED. ALL
COMPONENTS SHALL BE LIFTED BY THE LIFTING POINTS INDICATED
BY THE DRAWING. NO OTHER LIFTING POINTS SHALL BE USED. ALL
COMPONENTS SHALL BE LIFTED BY THE LIFTING POINTS INDICATED
BY THE DRAWING. NO OTHER LIFTING POINTS SHALL BE USED.

Miscellaneous Information

THIS DATA SHEET AND THE INFORMATION THEREON IS THE PROPERTY OF
DIAMOND TRUSS CO. AND IS LOANED TO YOU FOR YOUR INFORMATION
ONLY. IT IS NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM
OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING
PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE
AND RETRIEVAL SYSTEM, WITHOUT THE WRITTEN PERMISSION OF
DIAMOND TRUSS CO.

Bracing Information

ALL LATERAL BRACING REQUIRED TO BE INSTALLED IN ACCORDANCE
WITH THE FOLLOWING: ALL LATERAL BRACING SHALL BE INSTALLED
IN ACCORDANCE WITH THE FOLLOWING: ALL LATERAL BRACING SHALL
BE INSTALLED IN ACCORDANCE WITH THE FOLLOWING: ALL LATERAL
BRACING SHALL BE INSTALLED IN ACCORDANCE WITH THE FOLLOWING:

Connector Hardware

CONNECTIONS SHALL BE MADE IN ACCORDANCE WITH THE
FOLLOWING: ALL CONNECTIONS SHALL BE MADE IN ACCORDANCE
WITH THE FOLLOWING: ALL CONNECTIONS SHALL BE MADE IN
ACCORDANCE WITH THE FOLLOWING: ALL CONNECTIONS SHALL BE
MADE IN ACCORDANCE WITH THE FOLLOWING:

Lumber

LUMBER MUST BE OF A GRADE APPROVED BY THE
DESIGNER. ALL LUMBER SHALL BE KILN DRIED TO A
MOISTURE CONTENT OF 19% OR LESS. ALL LUMBER SHALL
BE KILN DRIED TO A MOISTURE CONTENT OF 19% OR LESS.

Design Criteria

THE DESIGN AND CONSTRUCTION OF THIS TRUSS SHALL
BE IN ACCORDANCE WITH THE FOLLOWING: ALL DESIGN AND
CONSTRUCTION SHALL BE IN ACCORDANCE WITH THE FOLLOWING:

Gang-Nail Systems, Inc.
PO BOX 2007
1000 WATTS RD
HOLLYWOOD, FL 33027-2007


CHARTER MEMBER
FE18444
MAY 19, 1984
3 OF 6

AUTO TRUSS


Gang-Nail Systems, Inc.
P.O. Box 58, 2037 AMF
Miami, Florida 33169-2037

(N) = Number of Webs = 1, 2 or 3
ALL JOINTS AT A SUPPORT MAY HAVE A BEARING PLATE (BR01)
This transparency device and the method of producing drawings and data sheets, using same, are covered by patents pending


PK4(N)
PLATE LENGTH PARALLEL TO LEFT CHORD




PK5(N)
PLATE LENGTH PARALLEL TO RIGHT CHORD




SP10




SP11




SP10 SP20




VC1(N)




ISO(N)
PLATE LENGTH PARALLEL TO CHORD




PB2(N)
PLATE LENGTH PERPENDICULAR 90° DEGREE TO CUT



PE4(N)
PLATE LENGTH PARALLEL TO LEFT CHORD




PK1(N)
PLATE LENGTH HORIZONTAL




PK2(N)
PLATE LENGTH PERPENDICULAR 90° DEGREE TO CUT




PK3(N)
PLATE LENGTH VERTICAL




HL78



HP1(N)
PLATE LENGTH PARALLEL TO SHALLOWER SLOPED CHORD




HP2(N)
PLATE LENGTH PARALLEL TO STEEPER SLOPED CHORD




HP3(N)
PLATE LENGTH PARALLEL TO SHALLOWER SLOPED CHORD




INO(N)




IN11




HL21




HL24




HL31




HL41




HL48




HL71




HL05




HL11




HL13




HL14




HL15




HL16




EB0(N)




EB1




ET0(N)




ET1




HL01



HL04




BR02
BEARING DETAIL - PLAN VIEW




CL1(N)
FLUSH WHEN 90° ANGLE BETWEEN PLATE AND CUT




CL2(N)
FLUSH WHEN 90° ANGLE BETWEEN PLATE AND CUT




CR0(N)



CR0(N)



CR11



5/19/58

Gang-Mali Systems, Inc.
P.O. Box 36 2031 Adel, Maine 04010-0203
Tel: 207/368-2031 Fax: 207/368-2031
Holland Wtts: (800) 432-2808

MAILED
MAY 17, 1988

TP1

























FE18444

20F6

This transparency device and the method of producing drawings and data sheets, using same, are covered by patents pending.
 (N) = Number of Webs = 1, 2 or 3
 ALL JOINTS AT A SUPPORT MAY HAVE A BEARING PLATE (BR01)

AUTO TRUSS


Gang-Nail Systems, Inc.
 P.O. Box 59-2027
 Miami, Florida 33159-2027

 VC3(N)	 VC2(N)	 VC1(N)	 PK4(N) PLATE LENGTH PARALLEL TO LEFT CHORD	 PK5(N) PLATE LENGTH PARALLEL TO RIGHT CHORD	 SP10	 ISO(N) PLATE LENGTH PERPENDICULAR TO CHORD	 PK1(N) PLATE LENGTH HORIZONTAL	 PK2(N) PLATE LENGTH PERPENDICULAR TO CUT	 HP1(N) PLATE LENGTH PARALLEL TO SHALLOWER SLOPED CHORD	 HP2(N) PLATE LENGTH PARALLEL TO STEEPER SLOPED CHORD	 IN0(N) PLATE LENGTH PARALLEL TO CHORD	 HL21	 HL31	 HL41	 HL05	 HL13	 HL14	 EB0(N)	 ET0(N)	 HL04	 BR02 BEARING DETAIL - PLAN VIEW	 CL1(N) FLUSH WHEN NOT GIVEN AND CUT	 CR11
---	--	---	---	--	---	---	---	---	--	---	---	---	--	---	---	--	---	---	--	--	--	---	--

5/19/88

GANG-NAIL "GTC" RECOMMENDED FOR LATERAL
RESTRAINT OF NON-BEARING PARTITION WALLS

Caution: Connector plates are designed for forces shown only. Increase plate sizes as necessary for handling on joints, such as heel, hip, peak, splices, etc.



Note: Verify all dimensions before fabrication.

W
WIRELESS
WIRELESS
WIRELESS

Gang-Nail Systems, Inc.
P.O. Box 29 202 2nd Ave. - Miami, Florida 33109 202
Tel: (305) 586-0500 - National WATS: (800) 227-2061
Hawaii WATS: (800) 327-2009

DATE: 12/19/82

10E6

FE18444

791













































ME:MBR

CHARTEU

This transparency device and the method of producing drawings and data sheets, using same, are covered by patents pending.
(N) = Number of Webs = 1, 2 or 3
ALL JOINTS AT A SUPPORT MAY HAVE A BEARING PLATE (BR01)

AUTO TRUSS


Gang-Nail Systems, Inc.
P.O. Box 59, 2037 AMF
Miami, Florida 33159-2037

 VC3(N)	 VC2(N)				
 VC1(N)	 SP10 SP20	 SP11	 SP10	 PK5(N)	 PK4(N)
 PK3(N)	 PK2(N)	 PK1(N)	 PE4(N)	 PB2(N)	 ISO(N)
 IN11	 IN0(N)	 HP3(N)	 HP2(N)	 HP1(N)	 HL78
 HL71	 HL48	 HL41	 HL31	 HL24	 HL21
 HL16	 HL15	 HL14	 HL13	 HL11	 HL05
 HL04	 HL01	 ET11	 ET0(N)	 EB11	 EBO(N)
 CR11	 CRO(N)	 CRO(N)	 CL1(N) CL2(N)	 CL1(N)	 BR02

OCEAN COUNTY, NEW JERSEY
401 CHAMBERS BRIDGE ROAD, BRICK, N.J. 08723

Daniel F. Newman, Mayor

Members of Township Council
Mary Anne L. Butler, Council, President
Charles E. Anderson
Patrick L. Bonazzi
Edmund H. Hibbard
Joseph C. Scarpelli
Warren H. Wolf
David W. Wolfe



Division of Inspection

A.J. Cierzo,
Construction Official

(201) 477-3000, ext. 2

CHECK LIST

7-22-88
man called
JH

RE: Block 793-17 Lot 1-2 Address _____

Please be advised that your application for a construction permit for the subject property has been rejected due to deficiencies in the following areas:

Administrative _____

Zoning _____

Engineering _____

Building _____

Plumbing _____

Electric _____

Fire _____

6-21-88 SPAN ON BENTERS NOT SHOWN
MUST COME IN. JH

See attached review check list(s) for details as to the reason your submission has been rejected. Please revise your application accordingly and resubmit to this office.


There is a 20 working day time limit for review of all documents submitted with a construction permit application. This time limit ceases in the event of a rejection of any type, and starts over again when the rejection(s) have been corrected and the application resubmitted.

747-0853
called 6-21-88 JH

NO ANSWER.
JH

Arthur J. Cierzo,
Construction Official

Date _____



$$\begin{array}{r} 21 \\ 1 \\ \hline 31 \end{array}$$



Township of Brick

401 Chambers Bridge Road, Brick, N.J. 08723 (201) 477-3000

Office of
Inspections

UNIFORM CONSTRUCTION CODE Chapter 23, Title 5

Approval of Part
5.23-2.5 (7)

OWNER/AGENT Kennel Mall Assoc.
ADDRESS 241 Millburn Ave
TOWN Millburn N.J. ZIP 07041
BLOCK 670 LOT 4-5-8-23-25

- ☒ FOOTING
☒ FOUNDATION
☐ OTHER


OWNER/AGENT PROCEED AT OWN RISK ☒

OWNER/AGENT Wall Street

BUILDING SUB-CODE OFFICIAL Edward Dwyer

CONSTRUCTION OFFICIAL Arthur [Signature]

See letter dated 4-11-88
from Joseph F. Martone
Plng. Bd. Attorney
JH



Township of Brick

401 Chambers Bridge Road, Brick, N.J. 08723 (201) 477-3000

Office of
Division of Inspections

DATE

March 23, 1988

SUBJECT: LOT(S)

45-A-23-28

BLOCK

670

AFFIDAVIT

I SAL DAVINO hereby request a temporary building permit to proceed with construction of footings and foundation (only) on the subject property at my own risk. I understand and acknowledge that the issuance of the full building permit is subject to further approvals as normally required. I understand that adjustments in the foundation and first floor elevation may be necessary in order to comply with the approved plot plan grading. The below department approvals are required prior to issuance of a temporary building permit.

Applicant

Date

none
Twp. Engineer or Ass't. Engineer
Engineering Department

Date

3-23-88

John Krinsky
Zoning Officer
Zoning Department


Date

4-7-88

Edward Deppa
Building Inspector
Building Department

Date

4/5/88



Township of Brick

401 Chambers Bridge Road, Brick, N.J. 08723 (201) 477-3000

Office of
Division of Inspections

DATE

March 23, 1988

SUBJECT: LOT(S)

PS-8-23-28

BLOCK

670

AFFIDAVIT

I SAL DAVINO hereby request a temporary building permit to proceed with construction of footings and foundation (only) on the subject property at my own risk. I understand and acknowledge that the issuance of the full building permit is subject to further approvals as normally required. I understand that adjustments in the foundation and first floor elevation may be necessary in order to comply with the approved plot plan grading. The below department approvals are required prior to issuance of a temporary building permit.

[Signature]
Applicant

Date

[Signature]
Twp. Engineer or Ass't. Engineer
Engineering Department


3-23-88
Date

[Signature]
Zoning Officer
Zoning Department

4-7-88
Date

[Signature]
Building Inspector
Building Department

4/5/88
Date



Township of Brick

401 Chambers Bridge Road, Brick, N.J. 08723 (201) 477-3000

Office of
Inspections

UNIFORM CONSTRUCTION CODE Chapter 23, Title 5

Approval of Part
5.23-2.5 (7)

OWNER/AGENT Kennedy Mall Assoc.
ADDRESS 241 Millburn Ave
TOWN Millburn N.J. ZIP 07041
BLOCK 670 LOT 4-5-8-23-25

- ☒ FOOTING
☒ FOUNDATION
☐ OTHER

OWNER/AGENT PROCEED AT OWN RISK ☒

OWNER/AGENT Self

BUILDING SUB-CODE OFFICIAL Edward Dwyer

CONSTRUCTION OFFICIAL Arthur Wynn

~~HOLD UNTIL 5/15/88~~
~~RECEIVED~~
See letter dated 4-11-88
from Joseph F. Marton
Plngl Bl Attorney
JH

TOWNSHIP OF BRICK

OCEAN COUNTY, NEW JERSEY

401 CHAMBERS BRIDGE ROAD, BRICK, N.J. 08723

Daniel F. Newman, Mayor

Members of Township Council

Mary Anne L. Butler, Council President

Charles E. Anderson

Patrick L. Bottazzi

Edmund H. Hibbard

Joseph C. Scarpelli

Warren H. Wolf

David W. Wolfe



Division of Inspections

A.J. Cierzo,
Construction Official

(201) 477-3000, ext. 262

CHECK LIST

RE: Block _____ Lot _____ Address Kennedy Mall

Please be advised that your application for a construction permit for the subject property has been rejected due to deficiencies in the following areas:

Administrative Signed Site plan required
Zoning _____
Engineering _____
Building _____
Plumbing _____
Electric _____
Fire _____

See attached review check list(s) for details as to the reason your submission has been rejected. Please revise your application accordingly and resubmit to this office.

There is a 20 working day time limit for review of all documents submitted with a construction permit application. This time limit ceases in the event of a rejection of any type, and starts over again when the rejection(s) have been corrected and the application resubmitted.

Arthur J. Cierzo,
Construction Official

Date

3-30-88

CONTRACTOR'S MATERIAL & TEST CERTIFICATE FOR ABOVEGROUND PIPING

PROCEDURE

Upon completion of work, inspection and tests shall be made by the contractor's representative and witnessed by an owner's representative. All defects shall be corrected and system left in service before contractor's personnel finally leave the job.

A certificate shall be filled out and signed by both representatives. Copies shall be prepared for approving authorities, owners and contractor. It is understood the owner's representative's signature in no way prejudices any claim against contractor for faulty material, poor workmanship, or failure to comply with approving authority's requirements or local ordinances.

PROPERTY NAME

KENNEDY SHOPPING CENTER

DATE

12-28-88

PROPERTY ADDRESS

BRICKTOWN, N.J.

PLANS

ACCEPTED BY APPROVING AUTHORITY(S) NAMES

ISO COMMERCIAL RISK SERVICES, INC.

ADDRESS

90 PRESIDENTIAL PLAZA, SYRACUSE, N.Y. 13221

INSTALLATION CONFORMS TO ACCEPTED PLANS

EQUIPMENT USED IS APPROVED

IF NO, EXPLAIN DEVIATIONS

☒ YES ☐ NO

☒ YES ☐ NO

INSTRUCTIONS

HAS PERSON IN CHARGE OF FIRE EQUIPMENT BEEN INSTRUCTED AS TO LOCATION OF CONTROL VALVES AND CARE AND MAINTENANCE OF THIS NEW EQUIPMENT

☒ YES ☐ NO

IF NO, EXPLAIN

HAVE COPIES OF APPROPRIATE INSTRUCTIONS AND CARE AND MAINTENANCE CHARTS AND NFPA 13A BEEN LEFT ON PREMISES

☒ YES ☐ NO

IF NO, EXPLAIN

LOCATION OF SYSTEM

SUPPLIES BLDGS.

ENTIRE BLDG.

SPRINKLERS

MAKE

MODEL

YEAR OF MANUFACTURE

ORIFICE SIZE

QUANTITY

TEMPERATURE RATING

RELIABLE

G

1988

1/2

260

165°

"

"

"

"

325

212°

PIPE AND FITTINGS

PIPE CONFORMS TO NFPA #13 STANDARD

☒ YES ☐ NO

FITTINGS CONFORM TO NFPA #13 STANDARD

☒ YES ☐ NO

IF NO, EXPLAIN

N/A

ALARM VALVE OR FLOW INDICATOR

ALARM DEVICE

MAXIMUM TIME TO OPERATE THROUGH TEST PIPE

TYPE

MAKE

MODEL

MIN.

SEC.

DRY VALVE

Q.O.D.

MAKE

MODEL

SERIAL NO.

MAKE

MODEL

SERIAL NO.

RELIABLE

D

RELIABLE

B1

DRY PIPE OPERATING TEST

TIME TO TRIP THRU TEST PIPE

WATER PRESSURE

AIR PRESSURE

TRIP POINT AIR PRESSURE

TIME WATER REACHED TEST OUTLET

ALARM OPERATED PROPERLY

MIN.

SEC.

PSI

PSI

PSI

MIN.

SEC.

YES

NO

Without Q.O.D.

With Q.O.D.

IF NO, EXPLAIN

N/A

DELUGE & PREACTION VALVES	OPERATION ☐ PNEUMATIC ☐ ELECTRIC ☐ HYDRAULIC							
	PIPING SUPERVISED ☐ YES ☐ NO				DETECTING MEDIA SUPERVISED ☐ YES ☐ NO			
	DOES VALVE OPERATE FROM THE MANUAL TRIP AND/OR REMOTE CONTROL STATIONS ☐ YES ☐ NO							
	IS THERE AN ACCESSIBLE FACILITY IN EACH CIRCUIT FOR TESTING ☐ YES ☐ NO IF NO, EXPLAIN							
	MAKE	MODEL	DOES EACH CIRCUIT OPERATE SUPERVISION LOSS ALARM		DOES EACH CIRCUIT OPERATE VALVE RELEASE		MAXIMUM TIME TO OPERATE RELEASE	
			YES	NO	YES	NO	MIN.	SEC.
TEST DESCRIPTION	HYDROSTATIC: Hydrostatic tests shall be made at not less than 200 psi (13.6 bars) for two hours or 50 psi (3.4 bars) above static pressure in excess of 150 psi (10.2 bars) for two hours. Differential dry-pipe valve clappers shall be left open during test to prevent damage. All aboveground piping leakage shall be stopped. FLUSHING: Flow the required rate until water is clear as indicated by no collection of foreign material in burlap bags at outlets such as hydrants and blow-offs. Flush at flows not less than 400 GPM (1514 L/min) for 4-inch pipe, 600 GPM (2271 L/min) for 5-inch pipe, 750 GPM (2839 L/min) for 6-inch pipe, 1000 GPM (3785 L/min) for 8-inch pipe, 1500 GPM (5678 L/min) for 10-inch pipe and 2000 GPM (7570 L/min) for 12-inch pipe. When supply cannot produce stipulated flow rates, obtain maximum available. PNEUMATIC: Establish 40 psi (2.7 bars) air pressure and measure drop which shall not exceed 1-1/2 psi (0.1 bars) in 24 hours. Test pressure tanks at normal water level and air pressure and measure air pressure drop which shall not exceed 1-1/2 psi (0.1 bars) in 24 hours.							
TESTS	ALL PIPING HYDROSTATICALLY TESTED AT <u>200</u> PSI FOR <u>2</u> HRS. IF NO, STATE REASON							
	DRY PIPING PNEUMATICALLY TESTED ☐ YES ☐ NO							
	EQUIPMENT OPERATES PROPERLY ☒ YES ☐ NO							
	DRAIN TEST	READING OF GAGE LOCATED NEAR WATER SUPPLY TEST PIPE: STATIC PRESSURE: _____ PSI				RESIDUAL PRESSURE WITH VALVE IN TEST PIPE OPEN WIDE _____ PSI		
	Underground mains and lead in connections to system risers flushed before connection made to sprinkler piping.							
	VERIFIED BY COPY OF THE U FORM NO. 85B ☐ YES ☐ NO OTHER _____ EXPLAIN _____							
	FLUSHED BY INSTALLER OF UNDERGROUND SPRINKLER PIPING ☐ YES ☐ NO							
BLANK TESTING GASKETS	NUMBER USED	LOCATIONS						NUMBER REMOVED
WELDING	WELDED PIPING ☐ YES ☒ NO							
	IF YES ...							
	DO YOU CERTIFY AS THE SPRINKLER CONTRACTOR THAT WELDING PROCEDURES COMPLY WITH THE REQUIREMENTS OF AT LEAST AWS D10.9, LEVEL AR-3 ☐ YES ☐ NO							
	DO YOU CERTIFY THAT THE WELDING WAS PERFORMED BY WELDERS QUALIFIED IN COMPLIANCE WITH THE REQUIREMENTS OF AT LEAST AWS D10.9, LEVEL AR-3 ☐ YES ☐ NO							
	DO YOU CERTIFY THAT WELDING WAS CARRIED OUT IN COMPLIANCE WITH A DOCUMENTED QUALITY CONTROL PROCEDURE TO INSURE THAT ALL DISCS ARE RETRIEVED, THAT OPENINGS IN PIPING ARE SMOOTH, THAT SLAG AND OTHER WELDING RESIDUE ARE REMOVED, AND THAT THE INTERNAL DIAMETERS OF PIPING ARE NOT PENETRATED ☐ YES ☐ NO							
HYDRAULIC DATA NAMEPLATE	NAMEPLATE PROVIDED ☐ YES ☒ NO		IF NO, EXPLAIN					
REMARKS	DATE LEFT IN SERVICE WITH ALL CONTROL VALVES OPEN:							
SIGNATURES	NAME OF SPRINKLER CONTRACTOR <u>NATIONAL FIRE PROTECTION INC.</u>							
	TESTS WITNESSED BY							
	FOR PROPERTY OWNER (SIGNED)		TITLE		DATE			
FOR SPRINKLER CONTRACTOR (SIGNED)		TITLE		DATE				
ADDITIONAL EXPLANATION AND NOTES								

Attorney(s): Christopher Konzelmann, Esquire
Office Address & Tel. No.: 222 Haddon Avenue, Suite 300, Westmont, NJ 08108
(609)858-5300
Attorney(s) for Plaintiffs

SALVATOR DAVINO, FIDELITY
MANAGEMENT COMPANY, INC., AND
KENNEDY MALL ASSOCIATES

Plaintiff(s)

vs.

WEATHERVANE SERVICE, INC., AND
M&M ROOFING CO., INC.

Defendant(s)

SUPERIOR COURT OF NEW JERSEY
OCEAN COUNTY
LAW DIVISION

DOCKET NO. OCN L-5019-91

CIVIL ACTION

Subpoena
DUCES TECUM

The State of New Jersey, to: Brick Township Building Inspector
401 Chambersbridge Road
Brick Town, NJ 08723

You are hereby commanded to attend and give testimony before the above named Court at
WHITE AND WILLIAMS, 222 Haddon Avenue, Suite 300, Westmont, NJ

on Mon day, January 6, 1992, at 10:00 o'clock A. M., on the part of

Plaintiffs
in the above entitled action, and that you have and bring with you and produce at the same time and place,
the following:


A true and correct copy of your entire file which relates
to any and all work performed at the Loews Cinema Center 5, Kennedy
Mall, Brick Town, New Jersey between December 1, 1990 and March 4, 1991.

See attached sheet

Failure to appear according to the command of this Subpoena will subject you to a penalty, damages
in a Civil Suit and punishment for contempt of Court.

Dated: 12/3 1991


CHRISTOPHER KONZELMANN
Attorney for Plaintiffs


DONALD F. PHELAN
Clerk

PROOF OF SERVICE

On 19____, I, the undersigned, being over the age of 18, served the
within Subpoena by delivering a copy thereof to the person named therein, at

to such person the attendance fee of \$____ and mileage of \$____
and by tendering
as allowed by law.

I certify that the foregoing statements made by me are true. I am aware that if any of the foregoing
statements made by me are wilfully false, I am subject to punishment.

Dated: 19____

Address for Service:

ATTACHED SHEET

This request includes but is not limited to:

1. All building and construction permits that were issued by the township.

2. All permits for electrical contracting work that was to be performed at the building between the time periods indicated above.

3. All documentation which is in any way related to inspections performed on the electrical work that was performed on the building during the time periods indicated above.

NOTE: This subpoena requests production of documents only. No deposition testimony will be taken on the date and time indicated above. In lieu of personally appearing on the date and time set forth above, you may mail the requested documents to Christopher Konzelmann, Esquire, White and Williams, 222 Haddon Avenue, Suite 300, Westmont, New Jersey.

LAW OFFICES

WHITE AND WILLIAMS

SUITE 300

222 HADDON AVENUE

WESTMONT, NEW JERSEY 08108

609-858-5300

FAX: 609-858-0722

CHRISTOPHER P. LEISE

MANAGING PARTNER

CERTIFIED CIVIL TRIAL ATTORNEY

ONE LIBERTY PLACE

SUITE 1800

1650 MARKET STREET

PHILADELPHIA, PENNSYLVANIA 19103-7301

215-864-7000

FAX: 215-864-7123

AMERICUS CENTRE

SUITE 1006

6TH AND HAMILTON STREETS

ALLENTOWN, PENNSYLVANIA 18101

215-435-8414

FAX: 215-435-8420

SUITE 206

1500 LANCASTER AVENUE

PAOLI, PENNSYLVANIA 19301

215-251-0466

FAX: 215-296-4628

THREE CHRISTINA CENTRE

SUITE 1202

201 NORTH WALNUT STREET

WILMINGTON, DELAWARE 19801

302-654-0424

FAX: 302-654-0245

December 3, 1991

RECEIVED

DEC 5 1991

DIV. OF INSPECTION

Brick Township Building Inspector
401 Chambersbridge Road
Brick Town, NJ 08723

RE: Davino v. M&M Roofing Company, et al.

Dear Building Inspector:

Enclosed please find a subpoena requesting your appearance for a deposition on Monday, January 6, 1992 at 10:00 a.m. in my Westmont office. The subpoena specifically requests production of certain documentation. In lieu of personally appearing on the date and time set forth in the subpoena, you may simply mail the requested documents to me at the above address. If there is a photocopying charge for the documents, kindly advise.

Thank you.

Very truly yours,

WHITE AND WILLIAMS



By: Christopher Konzelmann

CK:tl

Enclosures

Attorney(s): Christopher Konzelmann, Esquire
Office Address & Tel. No.: 222 Haddon Avenue, Suite 300, Westmont, NJ 08108
(609)858-5300
Attorney(s) for Plaintiffs

SALVATOR DAVINO, FIDELITY
MANAGEMENT COMPANY, INC., AND
KENNEDY MALL ASSOCIATES

Plaintiff(s)

vs.

WEATHERVANE SERVICE, INC., AND
M&M ROOFING CO., INC.

Defendant(s)

SUPERIOR COURT OF NEW JERSEY

OCEAN COUNTY

LAW DIVISION

DOCKET NO. OCN L-5019-91

CIVIL ACTION

Subpoena
DUCES TECUM

The State of New Jersey, to: Brick Township Building Inspector
401 Chambersbridge Road
Brick Town, NJ 08723

You are hereby commanded to attend and give testimony before the above named Court at
WHITE AND WILLIAMS, 222 Haddon Avenue, Suite 300, Westmont, NJ

on Mon day, January 6, 1992, at 10:00 o'clock A. M., on the part of


Plaintiffs
in the above entitled action, and that you have and bring with you and produce at the same time and place,
the following:


A true and correct copy of your entire file which relates
to any and all work performed at the Loews Cinema Center 5, Kennedy
Mall, Brick Town, New Jersey between December 1, 1990 and March 4, 1991.

See attached sheet

Failure to appear according to the command of this Subpoena will subject you to a penalty, damages
in a Civil Suit and punishment for contempt of Court.

Dated: 12/3 1991


CHRISTOPHER KONZELMANN
Attorney for Plaintiffs


DONALD F. PHELAN
Clerk

PROOF OF SERVICE

On 19, I, the undersigned, being over the age of 18, served the
within Subpoena by delivering a copy thereof to the person named therein, at

to such person the attendance fee of \$ and mileage of \$ and by tendering
as allowed by law.

I certify that the foregoing statements made by me are true. I am aware that if any of the foregoing
statements made by me are wilfully false, I am subject to punishment.

Dated: 19

Address for Service:

ATTACHED SHEET

This request includes but is not limited to:

1. All building and construction permits that were issued by the township.
2. All permits for electrical contracting work that was to be performed at the building between the time periods indicated above.
3. All documentation which is in any way related to inspections performed on the electrical work that was performed on the building during the time periods indicated above.

NOTE: This subpoena requests production of documents only. No deposition testimony will be taken on the date and time indicated above. In lieu of personally appearing on the date and time set forth above, you may mail the requested documents to Christopher Konzelmann, Esquire, White and Williams, 222 Haddon Avenue, Suite 300, Westmont, New Jersey.

TOWNSHIP OF BRICK
OCEAN COUNTY, NEW JERSEY
401 CHAMBERS BRIDGE ROAD, BRICK, N. J. 08723

Stevan J. Zboyan, Mayor



Township Council:
Andrew R. Ciesla, President
Albert Chrobocinski
Helen Fayad
Lee Hartman
Thomas G. Maiorino
Warren H. Wolf
David W. Wolfe

Department of Administration & Finance

Division of Inspections
A.J. Cierzo
Construction Official
(201) 477-3000, Ext. 260
Fax: (201) 920-4850

December 12, 1991

Christopher Konzelmann, Esq.
Suite 300
222 Haddon Avenue
Westmont, New Jersey 08108

Re: Subpoena: Salvator Davino, Fidelity Management Inc. and Kennedy
Mall Associates. vs. Weathervane Service, Inc. and M &
M Roofing, Inc.

Dear Mr. Konzelmann,

Pursuant to your letter dated December 3rd, enclosed you will find
copies of documents produced in lieu of personally appearing, Monday,
January 6, 1992 for above related subpoena.

In brief I have chronologically given you all applications that have
been submitted and approved for various work to be done at the Theatre
between December 1, 1990 and March 4, 1991, and other permits needed to
restore the Theatre after the fire.

1. On 1/28/91 permit #72-91 was issued, replacing old roof with hot
& torch down system.
Contractor of record: M & M. Roofing, Millburn, N.J.
A Certificate of Approval was approved 11/19/91
2. 3/6/91 permit #237-91 was issued, to demolish partial portion due
to fire and to access fire damage.
Contractor of record: Point Construction Co. Inc. P.O. Box 288,
Succasunna, N.J.
A Certificate of Approval was approved 11/19/91
3. 10/18/91 permit #1957-91 was issued for fire sprinkler system.
Contractor of record: R/L. Dehn & Sons Fire Protection Inc., 60
W. Prospect St. Waldwick, N.J.
Final inspections were made, Plumbing 11/4/91 and Fire 11/22/91

Page 2


4. 10/18/91 permit #1956-91 was issued for fire restoration.
Contractor of record: Point Construction Co. Inc. 641 Shunpike
Rd., Chatham, N.J.
A Temporary C/O was issued 11/22/91 for cinema 3,4,& 5 only.
A Temporary C/O was issued 11/27/91 for cinema 1 & 2.

The Temporary C/O was issued pending final Building due to a pre-fab
steel stairway for the mezzanine that is on back order.

If any additional information is needed, please don't hesitate to call.
The Ocean County Electrical Bureau will be forwarding their letter to
you with their records.

The Inspectors of Record: Ray Korkowski, Building Sub-Code
 Joseph Evaristo, Fire Sub-Code
 Jim Hyers, Plumbing Inspector
 Bob Kochis, Electric Sub-Code
 Arthur J. Cierzo, Construction Official
 and Custodian of records

Very truly yours,


Arthur J. Cierzo
Construction Official

AJC/t1

NATIONAL FIRE PROTECTION INC.*Automatic Sprinkler Systems*

- ENGINEERING
- DESIGN/BUILD
- FABRICATION
- MAINTENANCE

• 215-647-7572

JANUARY 13, 1989

Date of Transmission

Time: 12:25 AM / PMNumber of Pages (including this one): 2MODULAR STRUCTURES

Company Transmitted To

Company Fax Number: (201) 725 - 5014Attention: JOE MORELLIRegarding: KENNEDY FLOW TEST

Transmission From: NATIONAL FIRE PROTECTION, INC.

Sender's Name: MELVIN LITTLE / Amey

If you have any questions or comments, please call (215) 647-7572

NFPI FAX Number: (215) 889-0428

Thank you.

**ORIGINAL
ILLEGIBLE**

NATIONAL FIRE PROTECTION INC.
SPECIFICATION SHEET

W A T E R F L O W T E S T R E S U L T S

KENNEDY SHOPPING CENTER

DATE OF TEST: January 3, 1989

TIME OF TEST: 12:05 PM

WITNESSES: Nicholas G. Amalfa OF

Brick Township Municipal Utilities Authority

Joseph T. Egan OF

National Fire Protection, Incorporated

Melvin S. Little OF

National Fire Protection, Incorporated

PRESSURE HYDRANT

Location: Southeast corner of Shopping Center

Static Pressure: 64

Residual Pressure: 48

Residual Pressure:

FLOW HYDRANT

Location: Southeast corner of Shopping Center

Flow: 1 2½ (No. & Size) Opening (s)

Flowed with a .90 coefficient at a
pitot pressure of 33

Flow: _____ (No. & Size) Opening (s)

Flowed with a _____ coefficient at a
pitot pressure of .

RESULTS

Static Pressure: 64 psi

Residual Pressure and Flow 48 psi @ 964 GPM

Residual Pressure and Flow	psi @	GPM
----------------------------	-------	-----

BRICK TOWNSHIP PLANNING BOARD

SITE PLAN APPROVAL WITH VARIANCE AND VARIOUS DESIGN WAIVERS

RESOLUTION R-119-87

September 9, 1987

CASE NO.: 1731-PSP-V-FSP-11/86

31,900
WHEREAS, Kennedy Mall Associates, owner of Lots 4, 5, 8, 23 and 25, Block 670, Brick Township Tax Map, have applied for site plan approval for the purpose of constructing a 29,650 sq. ft. building on "Kennedy Mall" together with a variance for insufficient rear setback and various design waivers and also includes an updating and improvement to parking and other appurtenances at the site; and

WHEREAS, proper service has been made upon all of the property owners within 200 feet of the premises in question and proper notice and publication has been made as required by New Jersey Statute and proper proof of service has been filed by the applicant with the Planning Board of the Township of Brick; and

WHEREAS, the Planning Board having considered the application and plans filed with its secretary and having heard the witnesses and evidence and examined the exhibits of the parties in interest and having heard and considered the comments of the public, if any, on the 22nd day of April, 1987; and

In conjunction with this resolution the Planning Board

Site-2
KMA
Dugle
MS/D
Mortone
Gauliano
Bldg
Eng-2
Zoning

has made the following findings of fact:

1. The applicant is the owner of the subject premises.
2. The subject premises are located in the B-3 zone.
3. The existing retail uses and the proposed uses at this site are permitted uses within the B-3 zone.

4. The application, as submitted, requests a variance for insufficient rear setback of 38 ft., 50 ft. required, and the Planning Board finds that this requested variance is reasonable and should be granted for the following reasons:

A. The proposed rear setback for the new building is generally in keeping with the existing setback for the existing building, encroaches on no adjoining premises, and provides a sufficient width for vehicular traffic and is accordingly determined to be an extension of a pre-existing situation or condition.

B. This variance can be granted without a substantial detriment to the surrounding area and the public good and without substantially impairing the intent and purpose of the Master Plan and Zoning Ordinance of the Township of Brick provided the conditions set forth hereinafter are complied with by the applicant.

5. The application, as submitted, requests the following design waivers:

<u>Item</u>	<u>Required</u>	<u>Provided</u>
A) Parking Stall Dimensions	10 ft. x 20 ft.	9 ft. x 18 ft.
B) Number of Parking Spaces	890	680

<u>Item</u>	<u>Required</u>	<u>Provided</u>
C) Soil Boring Logs	Yes	No
D) Drainage Calculations	Yes	No
E) Survey Bearings to Nearest Seconds	Yes	No
F) Site Lighting	Yes	No
G) Existing & Proposed Contours, Finished Grades, Spot Elevations Tied to NGVD	Yes	No

The Planning Board finds that the requested design waivers are reasonable and should be granted for the following reasons:

A. With regard to parking stall dimensions, the existing parking stalls at this site are presently 9 ft. x 18 ft. and to require that the applicant increase them to 10 ft x 20 ft. would cause the elimination of a substantial number of parking spaces and increase non-conformity as to number.

B. The requested design waiver for 680 parking spaces, 890 required, is determined to be reasonable based upon the testimony submitted by the applicant as to the usage of the site.

C. The remaining design waivers are determined to be reasonable since literal enforcement is impracticable and would exact undue hardship due to peculiar conditions pertaining to the subject premises.

6. As requested by the Planning Board during consideration of this application, the applicant has submitted a revised plan showing additional site improvements and landscaping, elimination of various entrances, a revised traffic flow pattern and circulation plan, clean up and renovation of various areas, etc. and as

RESOLUTION R-119-87

PAGE FOUR

CASE NO.: 1731-PSP-V-FSP-11/86

September 9, 1987

a result of this revised plan, the Planning Board finds that the applicant shall be granted site plan approval on a condition that the conditions and requirements set forth hereinafter are complied with by the applicant.

NOW, THEREFORE, BE IT RESOLVED, that the application of Kennedy Mall Associates, owners of Lots 4, 5, 8, 23 and 25, Block 670, Brick Township Tax Map, for an amended site plan approval to construct an additional retail building together with variance for insufficient rear setback for the proposed building and various design waivers is hereby APPROVED on this 9th day of September, 1987, subject to the following conditions:

A. The applicant shall comply with all standard Planning Board conditions for site plan approval as set forth in Attachment "A".

B. The applicant shall comply with all representations and agreements made by the applicant or applicant's representatives during the consideration of this application.

C. The applicant shall comply in all respects with the conditions and requirements set forth in the report of the Planning Board Engineer dated September 2, 1987 and the report of the Township Planner dated August 27, 1987.

D. In addition, the applicant shall comply with the following specific conditions as a condition of this approval:

1. The applicant has agreed to repair bulkheading where necessary.

2. The existing trash storage area and dumpster at the location of the florist shall be enclosed by a trash enclosure.

3. In accordance with the agreement of the applicant, the applicant shall install 2 trash compactors, 1 behind the existing building and 1 behind the proposed building to provide for the expected volume of trash.

4. Each trash enclosure shall be constructed of decorative block similar to that of the main building. Each trash enclosure shall have a chain link access gate with privacy slats and shall have structural steel reinforcement located therein to prevent trucks which are unloading the dumpster or compactor from causing damage to the enclosure.

5. In order to provide adequate vehicular and truck traffic circulation to the rear of the building and in particular for loading and unloading, the proposed building shall be squared off at its westerly side and ten (10) feet eliminated from the easterly side of the building in order to provide for a 30 foot distance between the existing building and the proposed building. In addition, the 7 parking spaces located to the rear of the proposed building shall be eliminated for the purpose of allowing adequate turning radius for truck traffic. The space between the buildings shall be for ingress only and the traffic flow at the rear of the building shall be one-way in an easterly direction. Stop signs shall be installed at these locations.

6. The plan shall be revised to show the acquisition of the triangular portion of property from Cedar Bridge Associates for the purpose of providing adequate access to the rear of the existing.

building.

7. Litter receptacles of the approved design shall be installed in front of all buildings at appropriate locations. In addition, benches for use by shoppers shall be installed at appropriate locations in front of all buildings.

8. All uses proposed at this location shall be permitted conforming uses. In the event there is a change of use and the new use requires additional parking, revised site plan approval shall be required.

9. In accordance with the agreement of the applicant, the applicant shall landscape the former sewerage treatment plant area with appropriate plantings.

10. In accordance with the agreement of the applicant, the applicant shall stabilize the stream bank.

11. There shall be included a note on the plan that facade signs will not exceed 15% of the facade area upon which it is erected.

12. The existing access point at the florist shall be revised to provide one way ingress only.

13. The plan shall be revised to eliminate all access points and the installation of landscaping along the property line south of the gasoline stations.

14. All dead shrubs previously planted shall be removed and shall be replanted as a condition of this approval.

15. In accordance with the agreement of the applicant, the applicant shall clean up and renovate the rear of the existing building.

16. The applicant shall re-stripe the entire parking lot in

accordance with the parking plan approved as part of this approval.

17. The middle driveway in the vicinity of the existing tavern shall be closed and eliminated.

18. The parking located at the rear of the building shall be designated as employee parking only.

19. The applicant shall install lighting in the vicinity of every door area. In addition, there shall be included a note on the plan that illumination intensity complying with ordinance requirements shall be provided throughout the site.

20. The light pole stantions shall be upgraded aesthetically so as to conform with existing standards.

21. The buffer areas and landscaping at the site shall be irrigated with an underground irrigation and sprinkler system using an on-site individual non-potable water source.

22. The applicant shall implement a litter abatement plan with the parking lot and public areas to be swept twice a week or more often if necessary.

23. Tree islands measuring 7 ft. x 7 ft. shall be curbed and wood chip mulch provided for the trees.

24. Foundation planters along the front of the building shall be required for the purpose of breaking up the front of the building.

25. Handicapped parking spaces shall be indicated on the plan.

26. Loading zones shall be provided at the rear of both the existing building and the proposed building and shall be delineated on the plan.

RESOLUTION R-119-87

PAGE EIGHT

CASE NO.: 1731-PSP-V/FSP-11/86

September 9, 1987

MOVED BY: Mr. Scherer

SECONDED BY: Mr. Cevascvo

VOTING IN THE AFFIRMATIVE: Mr. Cevasco Mr. Cierzo

Mr. Geller Mrs. Hartman Mr. Mangarelli Mr. Vespi

Mr. Kazawic Mr. Scherer

VOTING IN THE NEGATIVE: _____

ABSTAINING: _____

ABSENT: Mr. Gunther Mayor Newman Councilman Scarpelli

CERTIFICATION

I, E. JOAN KULL, Clerk to the Planning Board of the Township of Brick, County of Ocean, State of New Jersey, do hereby certify that the foregoing resolution was duly passed by the said Planning Board of the Township of Brick at a regular meeting held on the 9th day of September, 1987.

IN WITNESS WHEREOF, I have set my hand this 11th day of September, 1987.

E. Joan Kull

E. JOAN KULL, Clerk Planning Board
of the Township of Brick

ATTACHMENT "A"

STANDARD PLANNING BOARD CONDITIONS FOR SITE PLANS

RESOLUTION R-119-87

September 9, 1987

CASE NO. 1731-PSP-V/FSP-11/86

PAGE NINE

1. Applicant shall obtain certification by the Local Soil Conservation District of a plan for soil erosion and sediment control in accordance with Public Law 1975, Chapter 251, "Soil Erosion and Sediment Control Act."

2. All materials, methods of construction and details shall be in conformance with the current Township of Brick "Engineering Specifications and Construction Details", available at the office of the Township Engineer.

3. Applicant shall obtain any other approvals with respect to submission to any other Federal, State, County or Municipal agency having jurisdiction over same. Upon receipt of the approval, the applicant shall supply a copy of said permit or permits to the Board. In the event that any other jurisdictional agency requires a change in the applicant's plans, the applicant must reapply to the Brick Township Planning Board for approval of that change.

4. Applicant shall resubmit this entire proposal should there be any deviation from this Resolution or the submitted documents which are hereby made a part hereof and shall be binding on the applicant.

5. Applicant shall supply evidence by way of a statement from the Brick Township Tax Collector that all taxes are paid to date at the date of the fulfillment of the conditions of this resolution.

6. Applicant shall post an inspection fund with the Township Clerk in an amount to be determined by the Township Engineer.

7. Before the issuance of a building permit, the applicant shall furnish the Township Clerk with a performance bond in an amount to be determined by the Township Engineer.

8. No soil shall be removed from the site without the written approval of the Township Council.

Let Ceryo

STANZIONE, STANZIONE, MARTONE & ROSEN

A PROFESSIONAL ASSOCIATION

Attorneys at Law

STANZIONE BUILDING

200 MAIN STREET

TOMBS RIVER, NEW JERSEY 08763

(201) 240-1234

FAX: (201) 240-4948

April 11, 1988

ALFRED A. STANZIONE, JR.

RICHARD D. STANZIONE

CHARTERS IN THE SUPREME COURT OF
NEW JERSEY AS A CIVIL TRIAL ATTORNEY
LICENSED N.J. B.C. & P.A. #18

JOSEPH F. MARTONE

NATHAN S. ROSEN

EDMUND P. GLADIER

RECEIVED
APR 12 1988
DIV. OF INSPECTION

MAILING ADDRESS
P.O. Box 417
TOMBS RIVER, N.J. 08764

Kennedy Mall Associates
241 Millburn Avenue
Millburn, NJ 07041

Attention: Mr. Sal Davino

Re: Kennedy Mall Associates - Site Plan
Boxk 670, Lot 4, 5, 8, 23, & 25
Resolution R-119-87 adopted Sept. 9, 1987

Dear Mr. Davino:

The purpose of this letter is to confirm my telephone conversation with you regarding the above.

It appears clear from a reading of the Resolution that it is necessary to correct the first paragraph of the Resolution to reflect a building area of 31,980 square feet. The 29,650 square feet is not correct.

I intend to bring this error to the attention of the Planning Board and to recommend their adoption of a correction to this Resolution.

Very truly yours,

Joseph F. Martone

JOSEPH F. MARTONE

JFM:RLW

CC: E. Joan Kull, Secretary

RECEIVED

APR 11 1988

MUNICIPAL ENGINEER

Let Curyo

STANZIONE, STANZIONE, MARTONE & ROSEN

A PROFESSIONAL ASSOCIATION

Attorneys at Law

STANTONE BUILDING

200 MAIN STREET

TOMBS RIVER, NEW JERSEY 08763

(201) 240-1234

FAX: (201) 240-4948

RECEIVED

APR 12 1988

DIV. OF INSPECTION

P.O. Box 417
TOMBS RIVER, N.J. 08764

ALFRED A. STANTONE, JR.

RICHARD D. STANTONE

CHARTERED BY THE SUPREME COURT OF
NEW JERSEY AS A CERT. LEGAL ATTORNEY
NEW JERSEY, N.J. & N.Y. BAR

JOSEPH F. MARTONE

NAIL S. ROSEN

EDMUND P. GLADSTONE

April 11, 1988

Kennedy Mall Associates
241 Millburn Avenue
Millburn, NJ 07041

Attention: Mr. Sal Davino

Re: Kennedy Mall Associates - Site Plan
Box 670, Lot 4, 5, 8, 23, & 25
Resolution R-119-87 adopted Sept. 9, 1987

Dear Mr. Davino:

The purpose of this letter is to confirm my telephone conversation with you regarding the above.

It appears clear from a reading of the Resolution that it is necessary to correct the first paragraph of the Resolution to reflect a building area of 31,980 square feet. The 29,650 square feet is not correct.

I intend to bring this error to the attention of the Planning Board and to recommend their adoption of a correction to this Resolution.

Very truly yours,

Joseph F. Martone

JOSEPH F. MARTONE

JFM:RLW

cc: E. Joan Kull, Secretary

RECEIVED

APR 11 1988

MUNICIPAL ENGINEER

To Whom It May Concern;

A Final Certificate of Occupancy has not been issued for the addition to Kennedy Mall in Birch Town, as we're waiting for final engineering inspections and plumbing ^{units need} inspection to be made, as well as seven electrical finals. Nene had a final signed site plan.

There are seven vacant units of the fifteen intended, there were six temporary C/o's and two certificates of availability issued to date, we have final fire on the steel and sprinkles, final soil on the site, temp until complete by bldg. plng not complete on ten of the fifteen units. Also not finalized on the seven vacant units.