

Brick

Permit Without a Jacket

Permit Number B-964

Construction Permit # B-964

Aug. 2, 1982

Owner ... Vornado, Inc. (Foodarama Supermarkets, Inc.)

Location ... Rt. 70 & Chambers Bridge Rd.

Laurelton

Block 701 Lot 8

Contractor ... Charles C. Sorensen

Fee \$ 144.50 ck. Use Loading Dock

BUILDING SUB-CODE INSPECTIONS

Footing Trench

Foundation

Slab

Sheathing

Framing

Insulation

Sheet Rock

Plumbing

Fire Inspection

Final 12/20/82

C.O. Issued

PLUMBING SUB-CODE INSPECTIONS

Slab

Rough

Septic/Sewer

Water

Final

Electrical Final

VIOLATIONS

Use reverse side for additional remarks

Approved plans must be on job or assessed penalty under 5:23:2.5 (C5)
Finals for Certificates of Occupancy must be called for or assessed penalty under 5:23-27.

CONSTRUCTION PERMIT APPLICATION
BRICK TOWNSHIP, NEW JERSEY

IMPORTANT — Complete ALL items. Mark boxes where applicable

I. LOCATION OF BUILDING	Number and street	SHOPPING CENTER	Section	Lot	Block
	ROUTE 70 & CHAMBERS BRIDGE RD	Laurelton	8	701	
	N S E W side of STATE HWY 70	N S AT intersection of	CHAMBERS BRIDGE ROAD		
(Other local geographic, political, or legal subdivision identification)					

II. TYPE AND COST OF BUILDING — All applicants complete Parts A - D

A. TYPE OF IMPROVEMENT

- 1 ☐ New buildings
- 2 ☐ Addition (If residential, enter number of new housing units added, if any, in Part D, 13)
- 3 ☒ Alteration (See 2 above)
- 4 ☐ Repair, replacement
- 5 ☐ Demolition
- 6 ☐ Moving (relocation)
- 7 ☐ Garage
- ☐ Swim Pool ☐ in ☐ out
- ☐ Fence

D. PROPOSED USE — For "Wrecking" most recent use

Residential

- 12 ☐ One family
- 13 ☐ Two or more family — Enter number of units
- 14 ☐ Transient hotel, motel, or dormitory — Enter number of units
- 15 ☐ Garage
- 16 ☐ Carport
- 17 ☐ Other — Specify

Nonresidential

- 18 ☐ Amusement, recreational
- 19 ☐ Church, other religious
- 20 ☐ Industrial
- 21 ☐ Parking garage
- 22 ☐ Service station, repair garage
- 23 ☐ Hospital, institutional
- 24 ☐ Office, bank, professional
- 25 ☐ Public utility
- 26 ☐ School, library, other educational
- 27 ☒ Stores, mercantile
- 28 ☐ Tanks, towers
- 29 ☐ Other - Specify

B. OWNERSHIP

- 8 ☒ Private (individual, corporation, nonprofit institution, etc.)
- 9 ☐ Public (Federal, State, or local government)

C. COST

10. Cost of improvement \$35,000
- To be installed but not included in the above cost
- a. Electrical (# Fixtures, Outlets) 35,000
 - b. Plumbing (# of Fixtures) 4,500
 - c. Heating, air conditioning 20,000
 - d. Other (elevator, etc.)
11. TOTAL COST OF IMPROVEMENT \$94,500

Nonresidential — Describe in detail proposed use of buildings, e.g., food processing plant, machine shop, laundry building at hospital, elementary school, secondary school, college, parochial school, parking garage for department store, rental office building, office building at industrial plant. If use of existing building is being changed, enter proposed use.

SUPERMARKET

LOADING DOCK, 15000.00
CUBE.FE

III. SELECTED CHARACTERISTICS OF BUILDING —

For new buildings and additions, complete Parts E - I; for wrecking, complete only Part H, for all others skip to IV.

E. PRINCIPAL TYPE OF FRAME	H. DIMENSIONS	FEE COMPUTATIONS	
		LOADING DOCK 15,000.00	
☐ Masonry (wall bearing)	Number of stories 1	VOLUME OF BUILDING	105.00 ✓
☐ Wood frame	Total square feet of floor area, all floors, based on exterior dimensions 50,977	BUILDING SUB CODE	—
☒ Structural steel	Total land area, sq. ft. 867,280	ELECTRICAL CODE	—
☐ Reinforced concrete		PLUMBING CODE	10,50 ✓
☐ Other - Specify		PLAN REVIEW	20.00 ✓
F. TYPE OF HEATING SYSTEM	I. RESIDENTIAL BUILDING ONLY	CERTIFICATE OF OCCUPANCY	9.00 ✓
Specify GAS	Number of bedrooms	STATE TRAINING FUND	
Air Cond. Yes ☒ No ☐	Number of bathrooms { Full Partial	CONSTRUCTION	144.50 ✓
G. TYPE OF SEWERAGE DISPOSAL		PERMIT FEE	
☒ Public			
☐ Individual			

SEE REVERSE

B964

Chark

SUB CONTRACTORS

NAME	TRADE	ADDRESS	ZIP CODE	PHONE #
1.				
2.				
3.				
4.				
5.				
6.				
7.				
8.				

PERSON TO BE IN CHARGE OF CONSTRUCTION

NAME **CHARLES C. SORENSEN - DIRECTOR OF TECHNICAL SERVICES**
FOODARAMA SUPERMARKETS, INC.
 ADDRESS **303 W. MAIN ST., FREEHOLD, NJ 07728**


IV. IDENTIFICATION — To be completed by all applicants

Name	Mailing address — Number, street, city, and State	ZIP code	Tel. No.
1. Owner Agent	VORNADO, INC.	174 PASSAIC ST., GARFIELD, NJ	07026 201-773-4000
	FOODARAMA		
	SUPERMARKETS INC.	303 W. MAIN ST., FREEHOLD, NJ	07728 201-462-4700
2. Contractor			
3. Architects			


The owner of this building and the undersigned agree to conform to all applicable laws of Township of Brick and that all required state, county and local prior approvals have been given.

Signature of applicant **CHARLES C. SORENSEN** Address **303 W. MAIN ST.** Application date
FOODARAMA SUPERMARKETS, INC. **Freehold, NJ** **2/25/82**

DO NOT WRITE IN THIS SPACE — FOR OFFICE USE ONLY

Approved by  Date permit issued **2/2/82** Permit Number **B964**

I agree to construct said building in conformity with the plans and specifications filed with the Construction Official and in compliance with the provisions of the Building Code whether shown on plans or not.



Township of Brick

401 Chambers Bridge Road, Brick, N.J. 08723 (201) 477-3000

Office of
Division of Inspections

December 3, 1982

Foodarama Supermarkets, Incorporated
Box 592
Freehold, New Jersey 07728

Re: Shoprite #903, Brick, NJ

Dear Sirs:

You are hereby granted a temporary Certificate of Occupancy for Shoprite Store #903 for a period of thirty (30) days, beginning December 4, 1982 and ending January 4, 1983. During this time the following items will be corrected:

1. The steel welds will be painted.
2. There will be complete compliance with the Ocean County Electrical Bureau.
3. Clarification of interpretation #10 from the Department of Community Affairs. (Plumbing Code)
4. The stairs leading to the manager's office and the ceiling in the manager's office shall be altered to meet the codes for height.
5. There exists a physical cross connection between the rug cleaning equipment and the potable water supply system. The rug cleaning equipment must be disconnected immediately and not used until an approved back flow preventing device is installed on the hot and cold water supply of this equipment.
6. Parking spaces and fire zones have to be painted.
7. The heating system has to be completed.
8. The pump to the sprinkler system has to be hooked up.

Yours truly,

Arthur J. Cierzo
Arthur J. Cierzo
Construction Official

AJC/wp

cc: Tax Assessor
Division of Inspections

Wm. L. Lee

Signature of acknowledgement