

PERMIT NO. a Permit to Follow

Numerous Contradictions

Application Completes: Sections I, II, III (optional), IV, VI, and VII

VI. BUILDING/SITE CHARACTERISTICS		(office use only)
1. Number of Stories	_____	1
2. Height of Structure	_____ ft.	16
3. Area — Largest Floor	_____ sq. ft.	19258
4. New Building Area	_____ sq. ft.	5340
5. Volume of New Structure	_____ cu. ft.	42446
6. Construction Classification	_____	2C
7. Total Land Area Disturbed	_____ sq. ft.	5340
8. Flood Hazard Zone	_____	—
9. Base Flood Elevation	_____ ft.	—
10. Wetlands	yes _____ no _____	— —
11. Max. Live Load	_____	—
12. Max. Occupancy Load	_____	—

VII. DESCRIPTION OF BUILDING USE

A. RESIDENTIAL

1. ☐ Hotels (R-1)

2. ☐ Multi-Family (R-2)

3. ☐ Two-Family (R-3) BOCA

4. ☐ Two-Family (R-4) CABO

5. ☐ One-Family (R-3) BOCA

6. ☐ One-Family (R-4) CABO

No. of dwelling units:

Before Construction 1

After Construction 1

Net Gain or Loss

B. NON-RESIDENTIAL

1. State Specific Use:

IV. DOES OR WILL YOUR BUILDING CONTAIN ANY OF THE FOLLOWING?

1. ☐ Elevators/Escalators/Lifts/ Dumbwaiters/Moving Walks	5. ☐ Cross-Connections/Backflow Preventers
2. ☐ High Pressure Boilers	6. ☐ Hazardous Uses/Places of Assembly
3. ☐ Pressure Vessels	7. ☐ Sprinklers
4. ☐ Refrigeration Systems	8. ☐ Smoke Control Systems in Open Wells
	9. ☐ Underground Storage Tanks

2. Use Group: *E. Schaefer* *E/A*
3. Change in Use Group, Indicate Former:

LDS BR 10317672

CERTIFICATION IN LIEU OF OATH

I. OWNER SECTION (to be completed if the applicant is the owner in fee)

I hereby certify that I am the owner in fee of the property listed on Page 1.

Mark the following applicable boxes:

A. ☐ I further certify that a new home (private residence) will be constructed on this property for my own use and occupancy. This dwelling is to be occupied by myself and is not to be used for any purpose other than single family residential use. I attest that all construction, plumbing, or electrical work will be done, in whole or in part, by me or by subcontractors under my supervision, in accordance with all applicable laws; and, I further acknowledge that said new home is not covered under the New Home Warranty and Builders Registration Act (N.J.S.A. 46:3B-1 et seq.) and that such fact shall be disclosed to any person purchasing this property within ten years of the date of issuance of a certificate of occupancy.

I UNDERSTAND THAT IN MARKING BOX A, I ACKNOWLEDGE THAT I AM ASSUMING RESPONSIBILITY FOR THE WORK DONE ON SAID PROPERTY, THE CONDITION OF THE PROPERTY PRIOR TO, DURING, AND AFTER ANY WORK PERFORMED, AND FOR THE PERFORMANCE OF THE SUBCONTRACTORS I HIRE, EMPLOY, OR OTHERWISE CONTRACT OR WITH WHOM I MAKE AGREEMENTS TO PERFORM WORK. I AM VOLUNTARILY AND KNOWINGLY ASSUMING THIS RESPONSIBILITY.

B. ☐ I further certify the following as required by the New Jersey Uniform Construction Code, N.J.A.C. 5:23-2.15(e)1.vii:

I personally prepared the plans submitted for: 1) the new home referred to in A.; or, 2) an addition, alteration, renovation, or repair to an existing single family residence owned and occupied by myself and located on the property listed on Page 1; or, 3) a new structure that will be physically separate from, but that will be deemed part of, an existing single family residence that is owned and occupied by myself and located on the property listed on Page 1.

C. ☐ I further certify that I will perform or supervise the following work:

C.1. ☐ Building C.2. ☐ Fire Protection

I further certify that I will perform the following work:

C.3. ☐ Electrical C.4. ☐ Plumbing

D. ☐ I agree to advise all contractors on this project that they are required to be registered with the New Jersey Division of Taxation and to comply with all New Jersey tax laws.

I further certify the following as required by the Uniform Construction Code, N.J.A.C. 5:23-2.15(a)5: All required State, county, and local prior approvals have been given, including such certification as the construction official may require.

I understand that if any of the above statements are willfully false, I am subject to punishment.

Signature _____ Date _____

II. AGENT SECTION (to be completed if the applicant is not the owner in fee)

I hereby certify the following as required by the Uniform Construction Code, N.J.A.C. 5:32-2.15(d): the proposed work is authorized by the owner in fee; and I have been authorized by the owner in fee to make this application as his agent.

I further certify the following as required by the Uniform Construction Code, N.J.A.C. 5:23-2.15(a)5: All required State, county, and local prior approvals have been given, including such certification as the construction official may require.

I agree to advise all contractors on this project that they are required to be registered with the New Jersey Division of Taxation and to comply with all New Jersey tax laws.

I understand that if any of the above statements are willfully false, I am subject to punishment.

☒ Check if contractor.

Agent Name Wallace Bros., Inc.

Address 2222 Rt. 88

Brick, N.J.

Telephone (732) 295-9340

Signature [Signature]

III. ☐ LEAD HAZARD ABATEMENT: Include Homeowner or Building Owner Affidavit as per N.J.A.C. 5:17.

OFFICE DATE RECEIVED: _____

VIII. PRIOR APPROVALS CHECKLIST (office use only)	LOCAL APPROVAL		COUNTY APPROVAL		REGIONAL APPROVAL		STATE APPROVAL		COMMENTS
	Prelimin. Initial	Final Date	Prelimin. Initial	Final Date	Prelimin. Initial	Final Date	Prelimin. Initial	Final Date	
☐ Zoning Officer									
☐ Planning Board									
☐ Zoning Board									
☐ Sewer Authority									
☐ Water Authority									
☐ Police Department									
☐ Health Department									
☐ Soil Conservation									
☐ N.J. Department of Community Affairs									
☐ N.J. Department of Transportation									
☐ N.J. Department of Environmental Protection									
☐ Utility Dig No.									
☐									
☐									

IX. SUBCODES AND SPECIAL REGULATIONS APPLICABLE (office use only—optional)

Name of Code & Edition	Name of Code & Edition	Other
Building _____	Energy _____	_____
Electrical _____	Barrier Free _____	_____
Plumbing _____	Flood Hazard _____	_____
Fire Protection _____	As Built Elevation Cert. _____	_____
Mechanical _____	Other _____	_____

X. CERTIFICATES ISSUED (office use only)

	DATE ISSUED	DATE EXPIRED	DATE REISSUED	DATE EXPIRED
☐ Temporary Certificate of Occupancy	No. _____	_____	_____	_____
☐ Temporary Certificate of Compliance	No. _____	_____	_____	_____
☐ Continued Certificate of Occupancy	No. _____	_____	_____	_____
☐ Certificate of Compliance	No. _____	_____	_____	_____
☒ Certificate of Occupancy	No. <u>3887</u>	<u>9-18-98</u>	_____	_____
☐ Certificate of Approval	No. _____	_____	_____	_____
☐ Lead Abatement Clearance Certificate	No. _____	_____	_____	_____



CERTIFICATE

Date Issued 9-2-98
Control #
Permit # 97-3887

IDENTIFICATION

Block 1421 Lot 14
Work Site Location 2282 Tanes Mill Rd.
Owner in Fee Brick Board of Education
Address 101 Hendrickson Ave.
Brick, NJ
Tele. ()
Contractor Wallace Brothers, Inc.
Address 2222 Rt. 88
Brick, NJ
Tele. ()
Lic. No. or Bldrs. Reg. No.
Federal Emp. No.
or Social Security No.

Home Warranty No. N/A
Use Group F
Maximum Live Load
Description of Work/Use:

Outdoor stage addition to Herbertsville Elementary School

Type of Warranty Plan: [] State [] Private
Construction Classification
Maximum Occupancy Load

CERTIFICATE OF OCCUPANCY/APPROVAL

☐ CERTIFICATE OF OCCUPANCY

This serves notice that said building, structure, or equipment has been constructed or installed in accordance with the New Jersey Uniform Construction Code, and is approved for use and/or occupancy.

☐ CERTIFICATE OF APPROVAL

☐ CERTIFICATE OF CONTINUED OCCUPANCY

This serves notice that based on a general inspection of the visible parts of the building there are no imminent hazards and the building is approved for continued occupancy.

XXXXXX ☒ TEMPORARY CERTIFICATE OF OCCUPANCY

If this is a Temporary Certificate of Occupancy the following conditions must be met no later than September 16, 19 98 or the owner will be subject to a fine or order to vacate: Pending compliance with Engineering.

Fee \$
Paid [] Check No.
Collected by:

CONSTRUCTION OFFICIAL

[Signature]

TOWNSHIP OF BRICK
401 CHAMBERS BRIDGE RD
DIVISION OF INSPECTIONS

IDENTIFICATION

UCC NEW JERSEY
CERTIFICATE

Date Issued 09/18/98
Control #
Permit # 97-3887.2

Block 1421 Lot 14 Qual
Work Site Location 2282 LANES MILL RD
FOOTING & FOUNDATION
Owner in Fee/Occupant BRICK BD OF EDUCATION
Address 101 HENDRICKSON AVE.
BRICK, NJ 08723-
Telephone (908)785-3005
Contractor WALLACE BROTHERS INC.
Address 2222 RT. 88
BRICK, NJ 08723-
Telephone (908)295-9340 Fax ()
Lic. No. or Bldrs. Reg. No.
Federal Emp. No. 22-2775668

Home Warranty No.
Type of Warranty Plan: [] State [] Private
Use Group E
Maximum Live Load 0
Construction Classification
Maximum Occupancy Load 0
Description of Work/Use:
FOOTING & FOUNDATION ONLY 12/16/97

OUTDOOR STAGE ADDITION TO HERBERTSVILLE ELEMENTARY
SCHOOL

[X] CERTIFICATE OF OCCUPANCY

This serves notice that said building or structure has been constructed in accordance with the New Jersey Uniform Construction Code and is approved for occupancy.

[] CERTIFICATE OF APPROVAL

This serves notice that the work completed has been constructed or installed in accordance with the New Jersey Uniform Construction Code and is approved.

If the permit was issued for minor work, this certificate was based upon that was visible at the time of inspection.

[] TEMPORARY CERTIFICATE OF OCCUPANCY/COMPLIANCE

If this is a Temporary Certificate of Occupancy or Compliance, the following conditions must be met no later than _____, or the owner will be subject to fine or order to vacate:

[] CERTIFICATE OF CLEARANCE - LEAD ABATEMENT 5:17

This serves notice that based on written certification, lead abatement was performed as per NJAC 5:17, to the following extent:

[] Total removal of lead-based paint hazards in scope of work
[] Partial or limited time period (____ years); see file

[] CERTIFICATE OF CONTINUED OCCUPANCY

This serves notice that based on a general inspection of the visible parts of the building there are no imminent hazards and the building is approved for continued occupancy.

[] CERTIFICATE OF COMPLIANCE

This serves notice that said potentially hazardous equipment has been installed and/or maintained in accordance with the New Jersey Uniform Construction Code and is approved for use until _____.

CERTIFICATION OFFICIAL
N.J.C. 17:26 (rev. 3/96)

Fee \$ 0
Paid [] Check No. _____
Collected by: _____



CONSTRUCTION PERMIT

Date Issued

Control #

Permit #

12-16-97
3887-97

IDENTIFICATION Block

Lot

Work Site Location

Contractor

Address

Owner in Fee

Address

Tele. ()

Lic. No. or Bldrs. Reg. No.

Exp. Date

Tele. ()

Federal Emp. No.

or Social Security No.

Is hereby granted permission to perform the following work:

☒ BUILDING ☐ PLUMBING ☐ OTHER☒ ELECTRICAL ☐ FIRE PROTECTION☐ ELEVATOR DEVICES

DESCRIPTION OF WORK:

Footings -
Foundation
only

NOTE: If construction does not commence within one (1) year of date of issuance, or if construction ceases for a period of six (6) months, this permit is void.

Estimated Cost of Work \$

U.C.C. Form F-170C

CONSTRUCTION OFFICIAL

PAYMENTS (Office Use Only)

Building

Plumbing

Electrical

Fire Protection

Other

Other

DCA Training Fee

Cert. of Occ.

Other

Total

Check No.

Cash

Collected By:

Herbertsville
School

REC
4/16/98



PERMIT UPDATE

ZOK

Date Update Issued

Control #

Permit #

Date Permit Issued

4/16/98

97-3887+B

IDENTIFICATION Block

1421

Lot

14

Work Site Location

282 LONGMILL RD

Owner in Fee

TRILLIARD OF EDUCATION

Address

101 HEDDICKSON

Tele

(732) 745-3000

Contractor

LEONARD BROS., INC.

Address

2722 E. 28

Tele

(732) 245-5310

Lic. No. or Bldrs. Reg. No.

Federal Emp. No.

222-1756-68

or Social Security No.

is hereby granted permission to perform the following work:

☒ BUILDING

☐ PLUMBING

☐ OTHER

☐ ELECTRICAL

☐ FIRE PROTECTION

☐ ELEVATOR DEVICES

Ang OK 4-1598

DESCRIPTION OF WORK:

12' x 17'4" ADDITION (STAGE)

Estimated Cost of Work \$

25,000

J. Pichay
CONSTRUCTION OFFICIAL
WP

PAYMENTS (Office Use Only)

Building

Electrical

Plumbing

Fire Protection

Elevator Devices

Other

DCA Training Fee

Cert. of Occ.

Other

Total

Check No.

Cash

Collected By:

EXEMPT



**BUILDING
SUBCODE
TECHNICAL SECTION**



Date Received
Date Issued
Control #
Permit #

12-16-97
3887297

A. IDENTIFICATION—APPLICANT: COMPLETE ALL APPLICABLE INFORMATION, WHEN CHANGING

CONTRACTORS, NOTIFY THIS OFFICE. CALL UTILITY DIG NO. 1-800-272-1000.

Block 1412 Lot 12

Work Site Location HERBERT ISWICK ELEMENTARY SCHOOL

Owner in Fee REIN-RENNON CO. DEWITT

Address 111 HUNDRETT ROAD

Address REIN D.O.J. C6724

Tele. (732) 185-3600

Contractor W. MURPHY & SONS, INC.

Address 222 E. 8th

Address REIN, L.I. C6724

Tele. (732) 295-5340

Lic. No. or Bids. Reg. No. _____

Federal Emp. No. 222-775 668 or Social Security No. _____

JOB SUMMARY (Office Use Only)

PLAN REVIEW	Date	Initial	INSPECTIONS	Dates (Month/Day)	Initial
☐ No Plans Req.			Type:	Failure	Approval
☐ All			Footings		
☐ Footings			Foundation		
☐ Foundation			Slab		
☐ Frame			Frame		
☐ Other			Insulation		
Joint Plan Review Required:			Finishes:		
☐ Elec. ☐ Plumb. ☐ Fire			Energy		
SUBCODE APPROVAL			Mechanical		
☐ CO ☐ CCO ☐ CA			TCO		
Date: _____			Other		
Approved By: _____			Final		

B. BUILDING CHARACTERISTICS

Use Group Present A-3 Proposed _____

Constr. Class Present 2C Proposed _____

No. of Stories 1

Height of Structure 216 Ft.

Area—Largest Floor 17524 Sq. Ft.

New Bldg. Area/All Floors 52410 Sq. Ft.

Volume of New Structure 994140 Cu. Ft.

Total Land Area Disturbed 53410 Sq. Ft.

Est. Cost of Bldg. Work:

1. New Bldg. \$ 408,000

2. Alteration \$ _____

3. Total (1+2) \$ 408,000

NOTE: VARIANCE 1200S IS

E.C. CONY. PLUMBING
PERMIT CONTRACTORS

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner-of-record and am authorized to make this application.

Signature _____

D. TECHNICAL SITE DATA

DESCRIPTION OF WORK

WATER TREATMENT ADDITION

(Office Use Only)
FEE

TYPE OF WORK:	
☒ New Building	
☒ Addition	
☐ Alteration	
☐ Roofing	
☐ Siding	
☐ Fence	Height (6' or over)
☐ Sign	Sq. Ft.
☐ Pool	
☐ Asbestos Abatement	
☐ Other	
☐ Demolition	
Paid ☐ Check # _____	Administrative Surcharge \$ _____
Collected by: _____	Minimum Fee \$ _____
	DCA TRAINING FEE \$ _____
	TOTAL FEE \$ _____

TOWNSHIP OF BRICK
401 CHAMBERS BRIDGE RD
DIVISION OF INSPECTIONS

UCC NEW JERSEY
BUILDING
SUBCODE
TECHNICAL SECTION

Date Received 04/06/98
Date Issued 04/01/98
Control # 4-16-98
Permit # 97-3887+B

A. IDENTIFICATION-APPLICANT: COMPLETE ALL APPLICABLE INFORMATION. WHEN CHANG-
ING CONTRACTORS. NOTIFY THIS OFFICE. CALL UTILITY DIG NO: 1-800-272-1000

Block 1421 Lot 14
Work Site Location 2282 LANES MILL RD

ADDITION

Owner in fee BRICK RD OF EDUCATION
Address 101 HENDRICKSON AVE.

BRICK, NJ 08723-

Tele. (208) 785-3005

Contractor WALLACE BROTHERS INC.

Address 2222 RT. 88

BRICK, NJ 08723-

Tele. (208) 295-9340

Lic. No. or Bids. Reg. No.

Federal Emp. No. 22-275668

or Social Security No.

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner
of record and am authorized to make this application.

Signature

D. TECHNICAL SITE DATA
DESCRIPTION OF WORK

ADDITION

12' X 17' STAGE

JOB SUMMARY (Office Use Only)

PLAN REVIEW Date Initial INSPECTIONS

☒ No Plans Req. 4/14/98

☒ All 4/14/98

☐ Footing 5/8/98

☐ Foundation 5/8/98

☐ Frame 5/8/98

☐ Other 5/8/98

Joint Plan Review Required:

☐ Elect ☐ Plumb ☐ Fire

SUBCODE APPROVAL ☐ Elev

☐ CO ☐ CC0 ☐ CA

Date: 5/8/98

Approved By: [Signature] Final

Dates (Month/Day)

Failure Failure Approval Initial

5/8/98 5/8/98

5/8/98 5/8/98

5/8/98 5/8/98

5/8/98 5/8/98

5/8/98 5/8/98

5/8/98 5/8/98

5/8/98 5/8/98

5/8/98 5/8/98

5/8/98 5/8/98

5/8/98 5/8/98

5/8/98 5/8/98

5/8/98 5/8/98

5/8/98 5/8/98

5/8/98 5/8/98

5/8/98 5/8/98

5/8/98 5/8/98

5/8/98 5/8/98

5/8/98 5/8/98

5/8/98 5/8/98

5/8/98 5/8/98

5/8/98 5/8/98

5/8/98 5/8/98

TYPE OF WORK

☒ New Building

☐ Addition

☐ Alteration

☐ Roofing

☐ Siding

☐ Fence

☐ Sign

☐ Pool

☐ Asbestos Abatement

☐ Other

☐ Demolition

☐ Demolition

☐ Demolition

☐ Demolition

☐ Demolition

☐ Demolition

☐ Demolition

☐ Demolition

☐ Demolition

☐ Demolition

☐ Demolition

☐ Demolition

☐ Demolition

FEE (Office Use Only)

\$ 470

\$ 470

\$ 470

\$ 470

\$ 470

\$ 470

\$ 470

\$ 470

\$ 470

\$ 470

\$ 470

\$ 470

\$ 470

\$ 470

\$ 470

\$ 470

\$ 470

\$ 470

\$ 470

\$ 470

\$ 470

\$ 470

\$ 470

B. BUILDING CHARACTERISTICS
Use Group Present E Proposed E
Constr. Class Present Proposed
No. of Stories 1
Height of Structure 9 ft.
Area Largest Floor 209 Sq. ft.
New Bldg. Area/All Floors 209 Sq. ft.
Volume of New Structure 18,792 Cu. ft.
Total Land Area Disturbed 0 Sq. ft.

Est. Cost of Bldg. Work:
1. New Bldg. \$ 25,000
2. Alteration \$ 0
3. Total (1+2) \$ 25,000

Paid ☐ Check # Administrative Surcharge \$ 0
Collected by: Minimum Fee \$ 0
TOTAL FEE \$ 0
DCA Training Fee \$ 0



**BUILDING
SUBCODE
TECHNICAL SECTION**



Date Received
Date Issued
Control #
Permit #

12/10/97
3887-97

A. IDENTIFICATION - APPLICANT: COMPLETE ALL APPLICABLE INFORMATION, WHEN CHANGING

CONTRACTORS, NOTIFY THIS OFFICE, CALL UTILITY DIG NO: 1-800-272-1000.

Block 1421 of 12
Work Site Location HERBERT-JULIE ELEMENTARY SCHOOL
Owner in Fee LAOS MU B. - RLV
Address 101 HADDAMUSOON AVE.
Tel. 732, 785-3000
Contractor EDUARDO REOS, INC.
Address 222 E. 88
Tel. 732, 295-9340
Lic. No. of Bldgs. Reg. No. _____
Federal Emp. No. 222-775 668 or Social Security No. _____

JOB SUMMARY (Office Use Only)

PLAN REVIEW	Date	Initial	INSPECTIONS	Dates (Month/Day)
☐ No Plans Req.			Type:	Failure
☒ All <u>FF only</u>	<u>12/6/97</u>	<u>RM</u>	<u>Footings</u>	<u>12/10/97</u>
☐ Footing			<u>Foundation</u>	<u>12/10/97</u>
☐ Foundation			<u>Slab</u>	<u>12/10/97</u>
☐ Frame			<u>Frame</u>	<u>12/10/97</u>
☐ Other			<u>Insulation</u>	<u>12/10/97</u>
Joint Plan Review Required:			<u>Finishes:</u>	<u>12/10/97</u>
☐ Elec. ☐ Plumb. ☐ Fire			<u>Energy</u>	<u>12/10/97</u>
SUBCODE APPROVAL			<u>Mechanical</u>	<u>12/10/97</u>
☐ CO ☐ CCO ☐ CA			<u>Other</u>	<u>12/10/97</u>
Date: _____			<u>Final</u>	<u>12/10/97</u>
Approved By: _____				<u>12/10/97</u>

B. BUILDING CHARACTERISTICS

Use Group E Present 2C Proposed _____
Constr. Class _____
No. of Stories _____
Height of Structure _____ Ft.
Area - Largest Floor 19528 Sq. Ft.
New Bldg. Area/All Floors 5340 Sq. Ft.
Volume of New Structure 99440 Cu. Ft.
Total Land Area Disturbed 5340 Sq. Ft.

Est. Cost of Bldg. Work:
1. New Bldg. \$ 408,000
2. Alteration \$ _____
3. Total (1+2) \$ 408,000

Note: Change Bldg. IS
G.C. Copy - MULTIPLE
PRIME CONTRACTORS

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner of record and am authorized to make this application.

Signature _____

D. TECHNICAL SITE DATA

DESCRIPTION OF WORK

MULTI PURPOSE ROOM ADDITION

(Office Use Only)
FEE

\$ _____

\$ _____

\$ _____

\$ _____

\$ _____

\$ _____

\$ _____

\$ _____

\$ _____

\$ _____

\$ _____

\$ _____

\$ _____

\$ _____

\$ _____

\$ _____

\$ _____

\$ _____

\$ _____

\$ _____

\$ _____

\$ _____


\$ _____

1/12 - Found OK to backfill pending Arch letter.
on elimination of Keyway J.

8-19- Penetrations in fire wall - J

8/28 - Above OK - All purpose room OK for temp J
Kitchen not completed -

9/18/98 - Kitchen complete - J



ELECTRICAL SUBCODE TECHNICAL SECTION

A. IDENTIFICATION—APPLICANT: COMPLETE ALL APPLICABLE INFORMATION, WHEN CHANGING CONTRACTORS, NOTIFY THIS OFFICE. CALL UTILITY DIG NO: 1-800-272-1000.

Block 1421 Lot 14

Work Site Location HERBERTSVILLE ELEMENTARY SCHOOL
MULTI-PURPOSE ROOM ADDITION
Owner in Fee/Occupant BUCK BOARD OF EDUCATION (Loren Willard)
Address 101 HERBERTSVILLE AVENUE
BUCK, N.J. 08724

Tele. (732) 762-2000
Contractor DACY ELECTRIC INC.
Address 198 DRUM DELIST 604D
BUCK, N.J. 08723

Tele. (732) 920-6969 Fax (732) 920-5050
Lic. No. 10117
Federal Emp. No. 22-341244

B. ELECTRICAL CHARACTERISTICS

Use Group Present Proposed _____
☐ Pole/Pad # _____ ☐ Temporary ☐ Other _____
Building Occupied as Subcode Utility Co. BP&U
Est. Cost of Elec. Work \$ 55,000.-

JOB SUMMARY (Office Use Only)

PLAN REVIEW	Date	Initial	INSPECTIONS	Type:	Failure	Dates (Month/Day)	Approval	Initial
☐ No Plans Required								
Joint Plan Review Required:								
☐ Building ☐ Plumbing								
☐ Fire ☐ Elevator								
☒ Elec. Plans Approved								
Date: <u>8/7/2015</u>								
Approved by: <u>[Signature]</u>								
SUBCODE APPROVAL								
☐ CO ☐ CCO ☒ CA								
Date: <u>8/8/2015</u>								
Approved by: <u>LMW</u>								

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner of record and am authorized to make this application and perform the work listed on this application.

Applicant's Signature/Contractor's Seal and Signature
[Signature]

☒ Licensed Electrical Contractor ☐ Exempt Applicant



Date Received
Date Issued
Control #
Permit #

D. TECHNICAL SITE DATA

QTY.	SIZE	ITEMS	FEE (Office Use Only)
33		Lighting Fixtures	
21		Receptacles	
14		Switches	
1		Detectors	
3		Light Poles	
9		Motors—Fract. HP	
6		Emergency & Exit Lights	
10/1		Communications Points	
		Alarm Devices/F.A.C. Panel	
		TOTAL NUMBERS	\$ 55

Pool Permit/With UW Lights	
Storable Pool/Spa/Hot Tub	
KW Elec. Range/Receptacle	9
KW Oven/Surface Unit	
KW Elec. Water Heater	
KW Elec. Dryer/Receptacle	9
KW Dishwasher	
HP Garbage Disposal	
KW Central A/C Unit	57
HP/KW Space Heater/Air Handler	
KW Baseboard Heat	
HP Motors 1/+ HP	
KW Transformer/Generator	
AMP Service	
AMP Subpanels	40
AMP Motor Control Center	
KW Elec. Sign/Outline Light	

Administrative Surcharge	\$
Minimum Fee	\$ 202
DCA Training Fee	\$
TOTAL FEE	\$ 40.


PLAN REVIEW FEE ONLY.

2/3/98 m3208889

Inspection of conduit is approved
slab in slab - will need equipment & recording

Note - PVE conductor pulled in all conduits.

DEC 18 21 07 10 03



FIRE PROTECTION SUBCODE TECHNICAL SECTION



Date Received
Date Issued
Control #
Permit #

A. IDENTIFICATION—APPLICANT: COMPLETE ALL APPLICABLE INFORMATION. WHEN CHANGING CONTRACTORS, NOTIFY THIS OFFICE. CALL UTILITY DIG NO: 1-800-272-1000.

Block 1421 Lot 14
Work Site Location HEBERTVILLE ELEMENTARY SCHOOL
MULTIPURPOSE ROOM ADDITION
Owner In Fee BECCA BORD OF EDUCATION
Address 101 HEBERTVILLE AVENUE
BECCA, N.J. 08724
Tele. (732) 262-2500
Contractor DACEY ELECTRIC INC.
Address 198 DRUM POINT RD.
BECCA, N.J. 08723
Tele. (732) 920-6969
Lic. No. 10117 or Social Security No. _____
Federal Emp. No. 22-3141244

B. FIRE PROTECTION CHARACTERISTICS

Use Group _____ Present _____ Proposed _____
Constr. Class. _____ Present _____ Proposed _____
Heating Systems ☐ New ☐ Existing
Type: ☐ Gas ☐ Oil ☐ Electrical ☐ Solar
☐ Other _____
Location: _____

Total Est. Cost of Fire Prot. Work \$ 6,000.00 ☐ Other _____

JOB SUMMARY (Office Use Only)

PLAN REVIEW:	INSPECTIONS:	Dates (Month/Day)
☐ No Plans Required	Type: _____	Failure Failure Approval Initial
Joint Plan Review Required:	Suppression Test	<u>8/21/81</u> <u>1981</u> <u>9/25/81</u> <u>(initials)</u>
☐ Bldg. ☐ Plumb.	Fire Alarm Test	
☐ Elec. ☐ Elevator	Smoke Test	
☐ Fire Plans Approved	Mechanical	
Date: <u>3/31/93</u>	TCO	
Approved by: <u>[Signature]</u>	Other	
SUBCODE APPROVAL:	Other	
☐ CO ☐ CCO <u>1/24</u>	Other	
Date: <u>5-25-81</u> <u>Becca</u>	Other	
Approved by: <u>Becca only</u>	Other	

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner of record and am authorized to make this application.

[Signature]
SIGNATURE

D. TECHNICAL SITE DATA

Description of Work

Water Supply Source _____
Method of Valve Supervision _____
Local Alarm Supervision _____
Central Supervision _____
Proprietary Supervision _____
Flammable Liquid Storage Tanks _____
Combustible Liquid Storage Tanks _____
L.P.G. Storage Tanks _____
L.N.G. Storage Tanks _____
Number _____
FEE (Office Use Only) _____

Wet Sprinkler Heads _____
Dry Sprinkler Heads _____
TOTAL _____

Smoke Detectors _____
Heat Detectors _____
TOTAL _____

Stand Pipes _____
Kitchen Hood Exhaust Systems _____

Pre-Engineered Systems _____

CO₂ Suppression _____
Halon Suppression _____
Foam Suppression _____
Dry Chemical _____
Wet Chemical _____

Gas or Oil Fired Appliances _____
OTHER Strobe Lights & Bells _____

Paid ☐ Check # _____
Collected by: _____
Administrative Surcharge \$ _____
Minimum Fee \$ _____
DCA Training Fee \$ _____
TOTAL FEE \$ _____


8/5/84 @ 100
Seal penetration

- Alcan tests
- Duct Defects


C11/88 8/31 - Duct Def. NOT TIED IN

C1020 8/2 -

Herb
647842 HMC



PLUMBING SUBCODE TECHNICAL SECTION



Date Received
Date Issued
Control #
Permit #

4-6-08
12-16-97
98-07-15
92-3887
97-3887

A. IDENTIFICATION—APPLICANT: COMPLETE ALL APPLICABLE INFORMATION. WHEN CHANGING CONTRACTORS, NOTIFY THIS OFFICE. CALL UTILITY DIG NO: 1-800-272-1000.

Block 142 lot 24
Work Site Location Herbertsville Elem School
Owner in Fee Back Board of Education
Address 101 Hendrickson
Back RD
Tel: (732) 785-3000
Contractor Ames Mechanical Inc
Address 1889 Lakewood Rd, Unit 28
Tel: (732) 240 4893 Fax (732) 505 8315
Lic. No. 1079
Federal Emp. No. 22-2964462

B. PLUMBING CHARACTERISTICS

Use Group Present Proposed
Building Sewer Size 4" Public Sewer
Water Service Size 1 1/4" Public Water Private Well
Est. Cost of Plumbing Work \$ 29500-

JOB SUMMARY (Office Use Only)

PLAN REVIEW		INSPECTIONS		Dates (Month/Day)	
		Type:	Failure	Approval	Initial
☐ No Plans Required		Slab			
☐ Joint Plan Review Required:		Rough (Final)			
☐ Building ☐ Electric		Water			
☐ Fire ☐ Elevator		Sewer			
☐ Plumbing Plans Approved		Fixtures			
Date: <u>12/26/97</u>		Gas Equipment			
Approved by: <u>[Signature]</u>		Gas Piping			
		Solar			
		TCO			
SUBCODE APPROVAL					
☐ CO ☐ CCO ☐ CA					
Date: <u>8-21-98</u>					
Approved by: <u>[Signature]</u>					

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner of record and am authorized to make this application and perform the work listed on this application.

Signature — Contractor's Seal
[Signature]

☒ Licensed Plumbing Contractor ☐ Exempt Applicant

D. TECHNICAL SITE DATA (List of all fixtures.)

NO.	FIXTURE/EQUIPMENT
<u>2</u>	Water Closet
<u>2</u>	Urinal/Bidet
<u>4</u>	Bath Tub
<u>1</u>	Lavatory
<u>1</u>	Shower
<u>1</u>	Floor Drain
<u>1</u>	Sink mop
<u>1</u>	Dishwasher
<u>1</u>	Drinking Fountain
<u>1</u>	Washing Machine
<u>1</u>	Hose Bibb
<u>1</u>	Water Heater
<u>1</u>	Fuel Oil Piping
<u>1</u>	Gas Piping
<u>1</u>	Steam Boiler
<u>1</u>	Hot Water Boiler
<u>1</u>	Sewer Pump
<u>1</u>	Interceptor/Separator
<u>1</u>	Backflow Preventer
<u>1</u>	Greasetrap
<u>1</u>	Sewer Connection
<u>1</u>	Water Service Connection
<u>1</u>	Stacks
<u>1</u>	Other
<u>1</u>	Other
<u>1</u>	Other

Administrative Surcharge \$
Minimum Fee \$
DCA Training Fee \$
TOTAL FEE \$

TOWNSHIP OF BRICK

ZONING PERMIT

Date of Issue: April 8, 1998 1998 - 0378

Block 1421 Lot 14 Zone R-20

Property Address: 2282 Lanes Mill Road

Owner: Brick Township Board of Education (Phone): (732) 785-3000

Applicant: Steve Wallace (Phone): (732) 295-9340

Existing Use: Herbertsville Elementary School

Proposed Use: Herbertsville Elementary School

Proposed Construction (if any): 12' by 17'4" outdoor stage addition; 11'8" high.

Conditions: As approved by Planning Board Resolution.

Zoning Permit No. 1997-2859 approved December 9, 1997.

This permit shall be null, void and of no effect if any of the facts contained in the application upon the basis of which this permit was granted are false or untrue in any material respect. This permit shall expire one (1) year after the date of issuance if the use or substantial construction has not been commenced.


Michael P. Fowler, AICP/PP
Municipal Planner


Sean Kinnevy
Zoning Officer

TOWNSHIP OF BRICK

ZONING PERMIT

Date of Issue: December 9, 1997 1997 - 2859

Block 1421 Lot 14 Zone R-20

Property Address: 2282 Lanes Mill Road

Owner: Brick Township Board of Education (Phone): (732) 785-3000

Applicant: Steve Wallace (Phone): (732) 295-9340


Existing Use: Herbertsville Elementary School.


Proposed Use: Herbertsville Elementary School.

Proposed Construction (if any): Multi-purpose room and kitchen addition;
22' high; 5,340 square feet.

Conditions: As approved by Planning Board Resolution.

This permit shall be null, void and of no effect if any of the facts contained in the application upon the basis of which this permit was granted are false or untrue in any material respect. This permit shall expire one (1) year after the date of issuance if the use or substantial construction has not been commenced.


Michael P. Fowler, AICP/PP
Municipal Planner


Sean Kinnevy
Zoning Officer

INSPECTOR:

JOB:

WEATHER:

TEMPERATURE:

DATE:

TYPE OF WORK:

LOCATION:

BLOCK:

LOT:

ENGINEERING RECOMMENDATIONS FOR CERTIFICATE OF OCCUPANCY INSPECTION CHECK LIST

ITEMS TO BE COMPLETED	COMPLETED	DEFICIENT
1. Driveway	✓	
2. Grading	✓	
3. Sidewalk	✓	
4. Road Pavement	✓	
5. Landscaping & Sodding	✓	
6. Clean-up Procedures	✓	
7. Note on going construction in immediate area	✓	
8. Safety	✓	

COMMENTS REFERENCING ITEM NUMBER:

RECOMMENDATIONS:

☐ TEMP. C.O.☒ FINAL C.O.☐ DETAILED REINSPECTION☐ HOLD INSPECTION UNTIL LOT ELEVATION FIELD VERIFIED
 PLANNING BOARD ENGINEER

 MUNICIPAL ENGINEER

I _____, Authorized representative of _____, hereby acknowledge the above deficiencies, and further realize that the Certificate of Occupancy will be conditioned upon the acceptable resolution thereof within _____ days of the issuance of Certificate of Occupancy.

BLOCK 1421 LOT 14 SITE LOCATION Laces Mill Road Update - 99-388916

BUILDING INSPECTION

Contractor: DOUGLAS BROS., INC.
Address: 2222 E. 88 Phone: (732) 295-9340
Town: Egan, NJ State: NJ Zip: 08724
LIC #: FEDERAL EMP. NO. (or SSN#): 222775668

ESTIMATED COST OF BUILDING WORK

NEW BUILDING (1) \$ ALTERATION (2) \$
ADDITION (3) \$ 25,000 TOTAL (1+2+3) \$ 25,000

BUILDING CHARACTERISTICS

ADDITION or SINGLE FAMILY DWELLING
USE GROUP: E PRESENT PROPOSED
CONSTRUCTION CLASS: PRESENT PROPOSED
NO. OF STORIES: 1 HT. OF STRUCTURE: 9 FT.
AREA: LARGEST FLOOR: 208.8 SQ. FT.
TOTAL BLDG. AREA: ALL FLOORS: 208.8 SQ. FT.
VOLUME OF STRUCTURE: 18,792 CU. FT.
TOTAL LAND AREA DISTURBED: 228.8 SQ. FT.

TYPE OF WORK		TYPE OF WORK	
NEW BLDG.	COST	MISC.	COST
ADDITION	25,000	FENCE 4 ft.	
ALTERATION		SIGN 8 ft.	
ROOFING		POOL	
SIDING		ASBESTOS ABATEMENT	
DEMOLITION		DCA	
		TOTAL	25,000

DESCRIPTION OF WORK

COMMENTS: 12' x 17' 4" ADDITION
To Backside

CERTIFICATION IN LIEU OF OATH

I HEREBY CERTIFY THAT I AM THE (AGENT OF) OWNER OF RECORD AND AM AUTHORIZED TO MAKE THIS APPLICATION AND PERFORM THE WORK LISTED ON THIS APPLICATION.
SEAL & SIGNATURE

PLUMBING INSPECTION

Contractor: DOUGLAS BROS., INC.
Address: 2222 E. 88 Phone: (732) 295-9340
Town: Egan, NJ State: NJ Zip: 08724
LIC #: FEDERAL EMP. NO. (or SSN#): 222775668

ESTIMATED COST OF PLUMBING WORK:

Sewer Size: 1/4" Water Size: 1/4" \$

TECHNICAL SITE DATA (List all fixtures)

NO.	FIXTURE/EQUIPMENT	NO.	FIXTURE/EQUIPMENT
	Water Closet		Steam Boiler
	Urinal / Bidet		Hot Water Boiler
	Bath Tub		Sewer Pump
	Lavatory		Interceptor/Separator
	Shower		Backflow Preventer
	Floor Drain		Grease Trap
	Sink		Water Cooled A/C
	Dishwasher		or Refrigeration Unit
	Drinking Fountain		Sewer Connection
	Washing Machine		Water Service Connection
	Hose Bibb		Active Solar System
	Water Heater		Other
	Fuel Oil Piping		Other
	Gas Piping		Other

DESCRIPTION OF WORK

COMMENTS:

CERTIFICATION IN LIEU OF OATH

I HEREBY CERTIFY THAT I AM THE (AGENT OF) OWNER OF RECORD AND AM AUTHORIZED TO MAKE THIS APPLICATION AND PERFORM THE WORK LISTED ON THIS APPLICATION.
SEAL & SIGNATURE (Contractor's Seal)

FIRE INSPECTION

Contractor: DOUGLAS BROS., INC.
Address: 2222 E. 88 Phone: (732) 295-9340
Town: Egan, NJ State: NJ Zip: 08724
LIC #: FEDERAL EMP. NO. (or SSN#): 222775668

ESTIMATED COST OF FIRE PROT. WORK:

Heating Type: ☒ Gas ☐ Oil ☐ Electrical ☐ Solar
Heating System: ☐ New ☒ Existing
Location of Furnace / Boiler

TECHNICAL SITE DATA (Description of Work)

WATER SUPPLY SOURCE			
METHOD OF VALVE SUPERVISION: LOCAL ALARM SUPERVISION 12/1A 12/1A			
CENTRAL SUPERVISION			
PROPRIETARY SUPERVISION			
Flammable Liquid Storage Tanks	☐ Capacity	Fuel	
Combustible Liquid Storage Tanks	☐ Capacity	Fuel	
L.P.G. Storage Tanks	☐ Capacity	Fuel	
L.N.G. Storage Tanks	☐ Capacity	Fuel	
NO. ITEM	NO. ITEM		
Wet Sprinkler Heads	Pre-Engineered System		
Dry Sprinkler Heads	CO ₂ Suppression		
TOTAL	Halon Suppression		
	Foam Suppression		
Smoke Detectors	Dry Chemical		
Heat Detectors	Wet Chemical		
TOTAL	Gas or Oil Fired Appliance		
	Other		
Stand Pipes			
Kitchen Hood Exhaust System			

DESCRIPTION OF WORK

COMMENTS: 12' x 17' 4" Street
ADDITION To Multi Purpose Room

CERTIFICATION IN LIEU OF OATH

I HEREBY CERTIFY THAT I AM THE (AGENT OF) OWNER OF RECORD AND AM AUTHORIZED TO MAKE THIS APPLICATION AND PERFORM THE WORK LISTED ON THIS APPLICATION.
SEAL & SIGNATURE (Contractor's Seal)

Brick Township Board of Education



101 HENDRICKSON AVENUE
BRICK, NEW JERSEY 08724-2599
TELEPHONE (732) 785-3000

Administrative Offices

September 9, 1998

Mr. Kenny Schaeffer
Engineering Department
Brick Township Municipal Building
401 Chambers Bridge Road
Brick, NJ 08723

Dear Mr. Schaeffer:

As per your request, this is to advise you that the playground equipment will be reinstalled by the Brick Board of Education Maintenance Department and the ball field is scheduled to be regraded at a later date by the Brick Board of Education Grounds Department.

Please make final approval to the building department for final Certificate of Occupancy on completed school additions if the remainder of the site work meets with your approval.

Very truly yours,

Philip W. Nicastro, Ed.D.
Business Administrator/
Board Secretary

PWN:rp
EnginDpt. Ltr98

9/14/98
Memo to file
RJS



Township of Brick

401 Chambers Bridge Road, Brick, N.J. 08723 (201) 477-3000

Office of
Division of Inspections

Date: DECEMBER 11, 1997

Subject: HERBERTSVILLE ELEMENTARY SCHOOL

Block 1421 Lot 14

AFFIDAVIT:

I _____ hereby request a temporary building permit to proceed with construction of footings and foundation (only) on the subject property at my own risk. I understand and acknowledge that the issuance of the full building permit is subject to further approvals as normally required. I understand that adjustments in the foundation and first floor elevation may be necessary in order to comply with the approved plot plan grading. The below department approvals are required prior to issuance of a temporary building permit.

Applicant _____ Date _____

Twp. Engineer or Ass't. Engineer _____ Date _____

Zoning Officer _____ Date _____
Zoning Department

Building Inspector _____ Date _____
Building Department



Township of Brick

401 Chambers Bridge Road, Brick, N.J. 08723 (201) 477-3000

Office of
Division of Inspections

UNIFORM CONSTRUCTION CODE
Chapter 23, Title 5

Approval of Part
5.23-2.16 (g)

OWNER/AGENT BD OF ED.?HERBERTSVILLE ELEMENTARY SCHOOL

ADDRESS 2282 LANES MILL RD

TOWN BRICK

ZIP (08723

BLOCK 1421

LOT 14



FOOTING.



FOUNDATION



OTHER

OWNER/AGENT PROCEED AT OWN RISK



OWNER/AGENT _____

BUILDING SUB-CODE OFFICIAL _____

☒ CONSTRUCTION OFFICIAL

J. Carizza

YEZZI ASSOCIATES
ARCHITECTS PLANNERS

Please file

1421 14

November 21, 1997

Mr. Michael Clayton
Ocean County Fire Inspector
Ocean County Construction Inspection Dept.
P.O. Box 2191
Toms River, NJ 08754

REF: Herbertsville Elementary School Classroom Addition

Dear Mr. Clayton:

As per our telephone conversation, enclosed please find a sketch of the area between the existing and new classroom addition.


I would like to mention that we are providing a two hour rated wall at the new building (UL Des. #U418) facing existing classroom windows. Additionally, windows on the part of the existing building facing the new addition constitute only 17.4% of the wall area as calculated below:

Wall area = 844 s.f.
Window area = 147 s.f.

Window area equals 17.4% of the wall area.

I hope the information provided is adequate and if you have any other questions, please call this office.

Yours truly,



Bashir Hamid, R.A.

Enclosure: Sketch

Massimo Francis Yezzi, Jr., NCARB, RA, PP
18 Washington Street
P.O. Box 1638, Toms River, N.J. 08754

Tel: 732-240-3433
Fax: 732-240-3463
1-800-376-3433

ARCHITECTURE

PLANNING

INTERIOR DESIGN

BOCA® PLAN REVIEW RECORD

Valuation: _____

Fee: _____

NATIONAL BUILDING CODE
(All Articles except 24, 28, 29, 30, 31 and 32)

Plan Review # _____

Date _____

JURISDICTION Fire (City, County, Township, etc.)

BUILDING LOCATION Henbertsville Elementary (Street address)

BUILDING DESCRIPTION Multipurpose

REVIEWED BY G. L. H. R.

Numerals indicated in parenthesis are applicable code sections of the 1987 BOCA National Building Code.

SPOKE to 7222 office 1/27/90
document on separation wall

No.	DESCRIPTION	Code Section
1)	This A-3 use indicate same on plans See drawing AE	
2)	Indicate fire wall separation between A-3 and E classroom use plan indicate 2 hour but not SELF Supporting fire wall. Per Boca 707.	
3)	Indicate rating of doors Existing to addition of OK 1 1/2 hour GF.	
4)	fill out fire tech	
5)	Fire alarm shop drawing for approval by this office PRIOR to installation (cut and specs)	

OK

The plan review accomplished as indicated in this record is limited to those code sections specifically identified here. Copyright, 1987, Building Officials and Code Administrators International, Inc. Reproduction by any means is prohibited. BOCA® is a trademark of Building Officials and Code Administrators International, Inc., and is registered in the U.S. Patent and Trademark Office. NOTE: In order that we might develop other programs and provide additional services of benefit to the building administration profession, please re-order additional copies of this form from:



BUILDING OFFICIALS AND CODE ADMINISTRATORS INTERNATIONAL, INC.
4051 W. FLOSSMOOR ROAD COUNTRY CLUB HILLS, ILLINOIS 60477-1

**BOCA®
NATIONAL BUILDING CODE
PLAN REVIEW RECORD**

Valuation: _____

Plan Review # _____

Fee: _____

Date: 11-17-97

JURISDICTION Building

BUILDING LOCATION Herbertsville Elementary
(City, County, Township, etc.)

BUILDING DESCRIPTION Addition
(Street address)

REVIEWED BY I-M Block 1421
Lot 27 14

Numerals indicated in parenthesis are applicable code sections of the 1993 BOCA National Building Code. The organization of this Plan Review Record follows the common Building Code format implemented in the 1993 BOCA National Building Code. The plan review accomplished as indicated in this record is limited to those code sections specifically identified herein. This record references commonly applicable code sections. It does not reference all code provisions which may be applicable to specific buildings. This record is designed to be used only by those who are knowledgeable and capable of exercising competent judgement in evaluating construction documents for code compliance.




CORRECTION LIST

No.	DESCRIPTION	Code Section
①	DRAWINGS NOT SEALED	
②	NO STRUCTURAL DRAWINGS (SHOP DRAWINGS)	
③	What is % OF addition OF existing structure (To Comply with IUT 523-2.5) (To Address upgrades needed)	
④	Supply Compaction Data Before calling For Footing inspection	
⑤	Supply Shop Drawings For Re-Bar ↑ Review on Footing & Foundation	
	OK For Footing & Foundation only	



Copyright, 1993, Building Officials and Code Administrators International, Inc. Reproductions by any means is prohibited. BOCA® is the trademark of Building Officials and Code Administrators International, Inc., and is registered in the U.S. Patent and Trademark Office. NOTE: In order that we might develop other programs and provide additional services of benefit to the Code Administration profession, please re-order additional copies of this form from:

**BUILDING OFFICIALS AND CODE ADMINISTRATORS INTERNATIONAL, INC.
4051 W. FLOSSMOOR ROAD COUNTRY CLUB HILLS, ILLINOIS 60478-5795**



**FACSIMILE TRANSMISSION COVER SHEET**COMPANY : Brick Twp. Inspection DepartmentATTENTION : Frank ~~Walter~~ MizerFROM : WALTER NICLAUS - PROJECT COORDINATORREFERENCE: Herbertville Elem. Schl. Multipurpose Rm Phase II
Steel Weld and Connection InspectionFAX NUMBER : 262-8954NUMBER OF PAGES INCLUDING THIS ONE : 2 DATE: 3/31/98☒ FOR REVIEW AND COMMENT
☒ AS PER YOUR REQUEST☒ FOR APPROVAL
☒ FOR YOUR USE☐ HARD COPY MAILED
☐ HARD COPY FILEDFrank,As you requested, Please find the Testing
Agencies report on the field connections on
the steel frame work @ the above site.I'm hoping we can possibly set up
whatever is required for acceptance of this
work. Any Questions Please Call.THANKS,WALT**IF TRANSMISSION NOT PROPERLY RECEIVED PLEASE CALL: 908-295-9340**

THIS MESSAGE IS INTENDED ONLY FOR THE USE OF THE INDIVIDUAL OR ENTITY TO WHICH IT IS ADDRESSED
AND MAY CONTAIN INFORMATION THAT IS PRIVILEGED, CONFIDENTIAL AND EXEMPT FROM DISCLOSURE
UNDER APPLICABLE LAW. IF YOU HAVE RECEIVED THIS TRANSMISSION IN ERROR PLEASE NOTIFY US
IMMEDIATELY.



AMERICAN TESTING & TECHNICAL SERVICES

INC. MAR 30 1998
NON-DESTRUCTIVE WELD EXAMINATION
VISUAL INSPECTION REPORT MASTERCRAFT Iron, Inc.

Client: Mastercraft Iron works
Project: Herbertsville Ele. School
Location: Herbertsville, NJ

Date: March 20, 1998
Report No.: HS-01
Page: 1 of 1

An inspector was present at the above project site and location to perform visual weld inspections as per AWS D1.1-96, Section 6.9, Table 6.1. The following observations were made:

Performed visual inspection on A-325 high strength "TC" bolted connections and found them acceptable to AISC code standards, section 5.

The fillet welds on the steel joist to the top flanges of beams were inspected and accepted, as were the welds on the joist bridging.

The upper and lower roof deck puddle welds were found acceptable to AWS welding code requirements and the project drawings.

Respectively submitted,

American Testing & Technical Services, Inc.

Robert Morgan
Robert Morgan
Technician


FILE COPY

4 RICHARD AVENUE HOPELAWN, NEW JERSEY 08861
TEL. 908 826-1176 FAX 908 826-3615 BEEPER 908 827-4484

OFFICES IN NEW JERSEY AND FLORIDA

TOWNSHIP OF BRICK

OCEAN COUNTY, NEW JERSEY
401 CHAMBERS BRIDGE ROAD, BRICK, N.J. 08723



Joseph C. Scarpelli, Mayor

Township Council:

Victor Cantillo – President
Martin J. Anton
Helen Fayad
Gregory S. Kavanagh
Mary Lou Powner
Kathy M. Russell
Frederick J. Underwood, Sr.

Department of Engineering

Office of the Municipal Engineer

(732) 262-1038

Fax: (732) 262-8954

<http://www.gbshost.com/brick>

DATE 3.18.98

Municipal Engineer
401 Chambers Bridge Road
Brick, New Jersey 08723

RE: Block 1421 Lot 14

Dear Sir: DR. NILASTRO

1, BRICK BOARD OF EDUCATION of 101 HEDRICKSON AVE. - BRICK
(Name) (Address)

request to be exempted from the plot plan requirement as outlined in the Brick Land Use Book, Chapter 190.31, part B. The property (please circle one) is is not located in a flood zone.

Respectfully yours,

Applicant's Signature

732-785-3000
Phone #

1. Submit survey showing location of addition with proposed dimensions, grading. If driveway is being added, show type, width and length.
2. Proof that the property is not located in a Flood Hazard Area.

NOTE: Any excavations to be removed from the Township requires a mining permit.

OFFICE USE

Approved _____ Date _____ BY _____
Rejected _____ Date _____ BY _____

REMARKS: _____



Herbertsville School New Devices

New Addition Zone List

- 50 - Heat detector multi purpose room
- 51 - Heat detector multi purpose room
- 52 - Heat detector multi purpose room
- 53 - Heat detector multi purpose room
- 54 - Duct detector multi purpose room RTU-1
- 55 - Heat detector multi purpose room
- 56 - Heat detector multi purpose room
- 57 - Heat detector multi purpose room
- 58 - Heat detector multi purpose room
- 59 - Duct detector multi purpose room RTU-2
- 61 - Pull station multi purpose room north east
- 62 - Pull station multi purpose room North west
- 63 - Pull station multi purpose room south west
- 64 - Heat detector kitchen
- 65 - Heat detector faculty room
- 66 - Multi purpose room electric room
- 67 - Men's room multi purpose room
- 68 - Women's room multi purpose room
- 69 - Pull station kitchen
- 70 - Pull station multi purpose room south east

3117 Oceanic Drive • Toms River, NJ 08753
(732) 929-3792 • fax (732) 270-5821

NEW JERSEY STATE DEPARTMENT OF EDUCATION
Bureau of Facility Planning Services
Release Form for School Construction Plans


State Plan No. SP#97323 Municipality BRICK TOWNSHIP

County OCEAN

School District BRICK TOWNSHIP BOARD OF EDUCATION

Name of School HERBERTSVILLE SCHOOL

It is the request of the above named school district to have this project reviewed for U.C.C. compliance by a municipal code enforcing agency pursuant to P.L. 1990, c. 23.



Chief School Administrator

DR. BRUCE R. NORMANDIA, SUPERINTENDENT

6/15/97
Date

Name (print)

This project will be reviewed for UCC compliance by appropriately licensed code officials employed by _____ (Municipality)


Municipal Code Enforcing Agency Chief

J. Curia
Name (print)

6/9/97
Date

THIS AREA TRANSMITTED SUBMITTED BELOW:

Below this line to be completed by the Bureau of Facility Planning Services.

This plan has been approved for
conformance with N.J.A.C. 6:22

Approved as noted

As required

Approved for construction

For review and comment


Other

Director, Bureau of Facility Planning Services

FOR AND ON BEHALF OF:

Date

Plans and drawings received on behalf of the local school district by:


Signature

THOMAS MISERENDINO
Name (print)

Educational Specialist
Title

6/30/97
Date

RECEIVED BY:

SIGNED

If additional copies are required, please notify us at once.



NEW JERSEY STATE DEPARTMENT OF EDUCATION
Bureau of Facilities Planning Services
Release Form for School Construction Plans
State of New Jersey

DEPARTMENT OF EDUCATION
CN 500
TRENTON NJ 08625-0500

Municipality: BRICK TOWNSHIP

LEO KLAGHOLZ
Commissioner

July 1, 1997

CHRISTINE TODD WHITMAN

Governor

County: OCEAN

School District: BRICK TOWNSHIP BOARD OF EDUCATION

Mr. Massimo Yezzi

Name of: Yezzi Associates

18 Washington Street

Toms River, NJ 08753

It is the responsibility of the school district to have this project reviewed for U.S.C. 12-1. Release by the State Department of Education is not a guarantee of compliance with P.L. 1990, c. 12.

RE: Brick Township School District
Herbertsville Elementary School
Ocean County

SP#97323

FINAL EDUCATIONAL APPROVAL

DR. NORMANDIA SUPERINTENDENT

Dear Mr. Yezzi:

Final Educational Approval are given for the above project. Per your Affidavit of June 16, 1997, there are no changes to the educational program as previously submitted.

Per your request, the enclosed "Release Form for School Construction Plans" is also approved.

Sincerely,

Thomas Miserendino

THOMAS MISERENDINO

Educational Facilities Planning Services

Below this line to be completed by the Bureau of Facility Planning Services.

c. Superintendent
Business Administrator
Board President
Ocean County Superintendent

This plan has been
conforming to with

Director of Educational Facilities Planning Services

Plans and Drawings received on behalf of the school district by

Thomas Miserendino
Signature

Thomas Miserendino
6/16/97

BU I L D I N G S U B C O D E (1 of 2)

UCCARS

Permit #: 97-3887+A

Name: ERICK BD OF EDUC Loc: 2282 LANES MILL RD

CONTRACTOR -- Federal Emp ID: 22-2775668

Name: WALLACE BROTHERS INC.

Address: 2222 RT. 88

SS#:

Lic:

Tel: 908/295-9340

Est Cost of Bldg Work --

New Bldg: \$ 408,000

Alteration: \$ 0

Total: \$ 0

No. of Stories: 1

Height of Structure: 16 ft

Area - Largest Floor: 19,258 sq ft

New Bldg Area - All Floors: 5,340 sq ft

Volume of New Structure: 99,440 cu ft

Total Land Area Disturbed: 0 sq ft

Date Received: 04/03/98

State Appr

HUD

TECHNICAL SITE DATA (Description of work) --

BUILDING REVIEW ONLY FOOTING AND FOUNDATION ALREADY APPROVED ON 12-16-97

APPROVED

DATE 4-3-98

when done

UCCARS

(N/A No cooking appliances)

OK ~~✓~~ Shop draining hood and fire suppression system for approval prior to installation

7) Contractor to update permit for their work re fire alarm.

8) ~~Emergency lighting~~ provide? ~~how?~~
OK cel