

BLOCK 702LOT 5

QUALIFICATION CODE

C10-602258

ADDRESS (SITE)

PERMIT NO.

10-1857

FUDGE
Pond Golf
COURSE

CONSTRUCTION PERMIT APPLICATION

REC'D JUN 23 2010

Applicant Completes: Sections I, II, III (optional), IV, VI, and VII

I. IDENTIFICATION

1. Proposed Work Site at: 301 CHAMBERSBRIDGE ROAD

2. Name of Owner in Fee: COUNTY OF OCEAN
 Tel. (732) 920-4733 e-mail _____
 Address 301 CHAMBERSBRIDGE ROAD
street municipality zip code

3. Ownership in Fee: Public _____ Private _____

4. Principal Contractor: _____ Tel. (_____) _____
 Address _____ e-mail _____

License No. OR, if new home, Builder Reg. No. _____ Exp. Date _____

Home Improvement Contractor Registration No. or Exemption Reason (if applicable): _____

Federal Emp. ID No. _____ FAX: (_____) _____

5. Architect or Engineer N/A Contact _____
 Address _____ e-mail _____
 Tel. (_____) _____ FAX: (_____) _____

6. Responsible Person in Charge once Work has Begun SCOTT BINKLEY
 Tel. (732) 920-4733 FAX: (732) 477-1257

V. FEE SUMMARY (for office use only)

		Update	Update
1. Building	\$ <u>1</u>		
2. Electrical	\$ <u>1</u>		
3. Plumbing	\$ <u>1</u>		
4. Fire Protection	\$ <u>1</u>		
5. Elevator Devices	\$ <u>1</u>		
6. Subtotal	\$ <u>1</u>		
7. Less 20% for State Plan Review	\$ <u>1</u>		
8. Subtotal	\$ <u>1</u>		
9. State Permit Surcharge Fee	\$ <u>1</u>		
10. Subtotal	\$ <u>1</u>		
11. Cert. of Occupancy	\$ <u>1</u>		
12. Other	\$ <u>1</u>		
13. TOTAL	\$ <u>1</u>		

VI. BUILDING/SITE CHARACTERISTICS

1. Number of Stories	<u>1</u>	
2. Height of Structure	<u>8.5</u>	ft.
3. Area — Largest Floor	<u>208</u>	sq. ft.
4. New Building Area	<u>208</u>	sq. ft.
5. Volume of New Structure	<u>1768</u>	cu. ft.
6. Max. Live Load	<u>250 PSF</u>	
7. Max. Occupancy Load	<u>0</u>	
8. If Industrialized Building: State Approved	<u>HUD</u>	
9. Total Land Area Disturbed	<u>208</u>	sq. ft.
10. Flood Hazard Zone		
11. Base Flood Elevation		ft.
12. Wetlands	yes _____ no <u>x</u>	

(office use only)

IIa. PROPOSED WORK

- ☐ Minor Work ☒ New Building ☐ Addition ☐ Demolition
☐ Repair ☐ Alteration ☐ Renovation ☐ Reconstruction
☐ Asbestos Abat. -Subch. 8 ☐ Lead Hazard Abatement ☐ Radon Remediation ☐ Annual Permit

IIb. SUBCODES

(Check all that apply)

- ☒ Building
☒ Electrical
☐ Plumbing
☒ Fire Protection
☐ Elevator

FOR OFFICE USE ONLY (Optional)

Est. Cost	Plans Rec'd by	Date Rec'd	Rejection Date	Approval Date	Re-viewer	Resubmission Dates Approval	Rejection	Re-viewer
<u>30,000</u>				<u>7/2/10</u>	<u>KA</u>			
				<u>7-1-10</u>	<u>07</u>			
			<u>7-6-10</u>	<u>7-8-10</u>	<u>08</u>	<u>7-1-10</u>	<u>08</u>	<u>08</u>

TOTAL COST

VII. DESCRIPTION OF BUILDING USE

A. RESIDENTIAL (primary use)

1. State Specific Use: _____
2. Use Group, Proposed: _____
3. Change in Use Group, Indicate Present: _____
4. No. of dwelling units: Total Units Income restricted
- Gained, Sale _____
- Gained, Rental _____
- Lost, Sale _____
- Lost, Rental _____

B. NON-RESIDENTIAL (primary use)

1. State Specific Use: STORAGE
2. Use Group, Proposed: _____
3. Change in Use Group, Indicate Present: _____
- C. MIXED USE -List secondary use(s): _____
- D. Construct. Classification: Present _____ Proposed _____

III. PLAN REVIEW (optional)

DO YOU WANT:

- ☐ 1. Partial Releases
☐ 2. Prototype Processing

IV. DOES OR WILL YOUR BUILDING CONTAIN ANY OF THE FOLLOWING?

- ☐ 1. Elevators/Escalators/Lifts/Dumbwaiters/Moving Walks
☐ 2. High Pressure Boilers
☐ 3. Pressure Vessels
☐ 4. Refrigeration Systems
☐ 5. Cross-Connections/Backflow Preventers
☐ 6. Hazardous Uses/Places of Assembly
☐ 7. Sprinklers
☐ 8. Smoke Control Systems in Open Wells
☐ 9. Underground Storage Tanks
☐ 10. Swimming Pools, Spas and Hot Tubs
☐ 11. LPGas Tanks

COMMERCIAL

CERTIFICATION IN LIEU OF OATH

I. OWNER SECTION (to be completed if the applicant is the owner in fee)

I hereby certify that I am the owner in fee of the property listed on Page 1.

Mark the following applicable boxes:

- A. ☐ I further certify that a new home (private residence) will be constructed on this property for my own use and occupancy. This dwelling is to be occupied by myself and is not to be used for any purpose other than single family residential use. I attest that all construction, plumbing, or electrical work will be done, in whole or in part, by me or by subcontractors under my supervision, in accordance with all applicable laws; and, I further acknowledge that said new home is not covered under the New Home Warranty and Builders Registration Act (N.J.S.A. 46:3B-1 et seq.) and that such fact shall be disclosed to any person purchasing this property within ten years of the date of issuance of a certificate of occupancy.

I UNDERSTAND THAT IN MARKING BOX A, I ACKNOWLEDGE THAT I AM ASSUMING RESPONSIBILITY FOR THE WORK DONE ON SAID PROPERTY, THE CONDITION OF THE PROPERTY PRIOR TO, DURING, AND AFTER ANY WORK PERFORMED, AND FOR THE PERFORMANCE OF THE SUBCONTRACTORS I HIRE, EMPLOY, OR OTHERWISE CONTRACT OR WITH WHOM I MAKE AGREEMENTS TO PERFORM WORK. I AM VOLUNTARILY AND KNOWINGLY ASSUMING THIS RESPONSIBILITY.

- B. ☐ I further certify the following as required by the New Jersey Uniform Construction Code, N.J.A.C. 5:23-2.15(e)1.ix:

I personally prepared the plans submitted for: 1) the new home referred to in A.; or, 2) an addition, alteration, renovation, or repair to an existing single family residence owned and occupied by myself and located on the property listed on Page 1; or, 3) a new structure that will be physically separate from, but that will be deemed part of, an existing single family residence that is owned and occupied by myself and located on the property listed on Page 1.

- C. ☐ I further certify that I will perform or supervise the following work:

C.1. ☐ Building C.2. ☐ Fire Protection

I further certify that I will perform the following work:

C.3. ☐ Electrical C.4. ☐ Plumbing

- D. ☐ I agree to advise all contractors on this project that they are required to be registered with the New Jersey Division of Taxation and to comply with all New Jersey tax laws.

I further certify the following as required by the Uniform Construction Code, N.J.A.C. 5:23-2.15(a)5: All required State, county, and local prior approvals have been given, including such certification as the construction official may require.

I understand that if any of the above statements are willfully false, I am subject to punishment.

Signature _____ Date _____

II. AGENT SECTION (to be completed if the applicant is not the owner in fee)

I hereby certify the following as required by the Uniform Construction Code, N.J.A.C. 5:23-2.15(d): the proposed work is authorized by the owner in fee; and I have been authorized by the owner in fee to make this application as his agent.

I further certify the following as required by the Uniform Construction Code, N.J.A.C. 5:23-2.15(a)5: All required State, county, and local prior approvals have been given, including such certification as the construction official may require.

I agree to advise all contractors on this project that they are required to be registered with the New Jersey Division of Taxation and to comply with all New Jersey tax laws.

I understand that if any of the above statements are willfully false, I am subject to punishment.

☐ Check if contractor.

Agent Name SCOTT BINKLEY

Address 301 CHAMBERS BRIDGE RD BRICK

Telephone (732) 920-4733

Signature Scott Binkley

- III. ☐ LEAD HAZARD ABATEMENT: Include Homeowner or Building Owner Affidavit as per N.J.A.C. 5:17.

OFFICE DATE RECEIVED: _____

VIII. PRIOR APPROVALS CHECKLIST (office use only)	LOCAL APPROVAL		COUNTY APPROVAL		REGIONAL APPROVAL		STATE APPROVAL		COMMENTS
	Prelimin. Initial	Final Date	Prelimin. Initial	Final Date	Prelimin. Initial	Final Date	Prelimin. Initial	Final Date	
☐ Zoning Officer									
☐ Planning Board									
☐ Zoning Board									
☐ Sewer Authority									
☐ Water Authority									
☐ Police Department									
☐ Health Department									
☐ Soil Conservation									
☐ N.J. Department of Community Affairs									
☐ N.J. Department of Transportation									
☐ N.J. Department of Environmental Protection									
☐ Utility Dig No.									
☐									
☐									

IX. SUBCODES AND SPECIAL REGULATIONS APPLICABLE
Name of Code & Edition _____

Building _____
 Electrical _____
 Plumbing _____
 Fire Protection _____
 Mechanical _____

- X. CERTIFICATES ISSUED** (office use only)
- ☐ Temporary Certificate of Occupancy No. _____
 - ☐ Temporary Certificate of Compliance No. _____
 - ☐ Continued Certificate of Occupancy No. _____
 - ☐ Certificate of Compliance No. _____
 - ☐ Certificate of Occupancy No. _____
 - ☐ Certificate of Approval No. _____
 - ☐ Lead Abatement Clearance Certificate No. _____

Need journeyman's license for plumb for Golf course

Other _____

PREPARED _____ DATE REISSUED _____ DATE EXPIRED _____



Brick Township
401 Chambersbridge Rd
Brick, NJ 08723

Date Issued 06/15/2011
Control Number C-10-002258
Permit Number 10-1857
Permit Issue Date 07/16/2010
Certificate Number 10-1857

Certificate

Construction Code Division

(Certificate of Approval)

Identification

Work Site Location: 301 CHAMBERS BRIDGE RD. Brick Township, NJ Block: 702 Lot: 5 Qual: _____
Owner in Fee: OCEAN COUNTY
Owner Address: 101 HOOPER AVE TOMS RIVER NJ 08753
Telephone: (732) 920-4733
Contractor: OCEAN COUNTY
Address: 101 HOOPER AVE TOMS RIVER NJ 08753
Telephone: (732) 920-4733 Fax: _____
License Number or Builders Registration Number: _____ Federal Emp. Number: _____

Home Warranty Number: _____

Type of Warranty Plan: ☐ State ☐ Private

Use Group: B Construction Classification: _____

Maximum Live Load: 0 Maximum Occupancy Load: 0

Description of Work/Use: NEW COMMERCIAL STRUCTURE CONSTRUCTION OF SLAB FOR INSTALLATION OF PRE-FABRICATED PESTICIDE STORAGE BUILDING CONTAINING SELF-CONTAINED FIRE SUPPRESSION.

Certificate Comments:

☐ **Certificate of Occupancy**

This serves notice that said building or structure has been constructed in accordance with the New Jersey Uniform Construction Code and is approved for occupancy.

☒ **Certificate of Approval**

This serves notice that the work completed has been constructed or installed in accordance with the New Jersey Uniform Construction Code and is approved. If the permit was issued for minor work, this certificate was based upon what was visible at the time of inspection.

☐ **Certificate of Continued Occupancy**

This serves notice that based on a general inspection of the visible parts of the building there are no imminent hazards and the building is approved for continued occupancy.

☐ **Temporary Certificate of Compliance**

The following conditions must be met no later than or the owner will be subject to fine or order to vacate:

This certificate has an expiration date of:

Conditions to be met:

☐ **Certificate of Clearance - Lead Abatement 5:17**

This serves notice that based on written certification, lead abatement was performed as per NJAC5:17 to the following extent.

- ☐ Total removal of lead-based paint hazards in scope of work
☐ Partial or limited time period (years); see file

☐ **Certificate of Clearance - Asbestos Abatement**

This serves notice that based on written certification, asbestos abatement was performed to the following extent.

- ☐ Total removal of asbestos hazards in scope of work
☐ Partial or limited time period (years); see file

☐ **Certificate of Compliance**

This serves notice that said potentially hazardous equipment has been installed and/or maintained in accordance with the New Jersey Uniform Construction Code and is approved for use until

☐ **Temporary Certificate of Occupancy**

The following conditions must be met no later than: or the owner will be subject to fine or order to vacate:

This certificate has an expiration date of:

Conditions to be met:

Construction Official

Date Printed: 06/15/2011 U.C.C. F260 (rev. 08/05)

Fee: \$0.00

Check Number: _____

Collected By: _____

Page 1



CONSTRUCTION PERMIT

Date Issued
Control #
Permit #

7/16/10
C-10-002258
10-1857

IDENTIFICATION Block: 702 Lot: 5 Qualifier
Work Site Location: 301 CHAMBERS BRIDGE RD. Brick Township, NJ Contractor OCEAN COUNTY
Owner in Fee OCEAN COUNTY Address 101 HOOPER AVE TOMS RIVER NJ 08753
101 HOOPER AVE TOMS RIVER NJ 08753 Telephone: (732) 920-4733
Telephone: (732) 920-4733 Lic. No. or Bldrs. Reg. No.
Federal Employee No.

Is hereby granted permission to perform the following work:

- ☒ BUILDING ☐ PLUMBING ☐ LEAD HAZARD ABATEMENT
☒ ELECTRICAL ☒ FIRE PROTECTION ☐ DEMOLITION
☐ ELEVATOR DEVICES ☐ ASBESTOS ABATEMENT (Subchapter 8 only) ☐ OTHER

DESCRIPTION OF WORK:

NEW COMMERCIAL STRUCTURE CONSTRUCTION OF SLAB FOR INSTALLATION OF
PRE-FABRICATED PESTICIDE STORAGE BUILDING CONTAINING SELF-CONTAINED FIRE
SUPPRESSION.

Note: If construction does not commence within one (1) year of date of issuance, or if
construction ceases for a period of six (6) months, this permit is void.

Estimated Cost of Work \$31,001

Construction Official

Date

U.C.C. F170
equiv (rev 8/03)

1 WHITE - INSPECTOR

2 CANARY - OFFICE

3 PINK - TAX ASSESSOR

4 GOLD - APPLICANT

PAYMENTS (Office Use Only)

Building	\$0
Electrical	\$0
Plumbing	\$0
Fire Protection	\$0
Elevator Devices	\$0
Other	\$0.00
DCA Training Fee	\$0
CO Fee	
Other	\$0
Total	\$0
Check No.	
Cash	\$0
Credit	\$0
Collected By	

REQUIRED INSPECTIONS

Construction work must be inspected in accordance with the State Uniform Construction Code Regulations N.J.A.C. 5:23-2.18. This agency will carry out such periodic inspections during the progress of work as are necessary to insure that the work installed conforms with the requirements of the Uniform Construction Code.

The owner or other responsible person in charge of work must notify this agency when work is ready for any required inspections specified below. Requests for inspections must be made at least 24 hours prior to the time the inspection is desired. Inspections will be performed within three business days of the time for which they are requested. The work must not proceed in a manner which will preclude the inspection until it has been made and approval granted.

- ☐ Required inspections for all subcodes for one- and two-family dwellings are as follows:
1. The bottom of footing trenches before placement of footings, except that in cases of pile foundations, inspections shall be made in accordance with the requirements of the building subcode.
 2. Foundations and all walls up to grade level prior to back filling.
 3. All structural framing, connections, wall and roof sheathing and insulation; electrical rough wiring, panel and service installation; rough plumbing. The framing inspection shall take place after the rough electrical and plumbing inspections and after the installation of the heating, ventilation and /or air conditioning duct system. The insulation inspection shall be performed after all other subcode rough inspections and prior to the installation of any interior finish material.
 4. Installation of all finished materials, sealings of exterior joints, plumbing piping, trim and fixtures; electrical wiring, devices and fixtures; mechanical systems equipment.

Additional required inspections for all subcodes of construction, for other than one- and two-family dwellings, are fire suppression systems, heat producing devices and Barrier Free subcode accessibility, if applicable.

- ☐ Required special inspections. The applicant by accepting the permit will be deemed to have consented to these requirements:
- ☐ A final inspection is required for each applicable subcode area before a final Certificate of Occupancy or Approval may be issued. The final inspections include the installation of all interior and exterior finish materials, sealing of exterior joints, mechanical system and other required equipment; electrical wiring, devices and fixtures; plumbing pipes, trim and fixtures; tests required by any provision of the adopted subcodes, Barrier Free accessibility, if applicable; and verification of compliance with NJAC 5:23-3.5, "Posting structures".
- ☐ A complete copy of released plans must be kept on the job site.
- If you do not understand any of this information, please ask.



FIRE PROTECTION SUBCODE TECHNICAL SECTION

A. IDENTIFICATION—APPLICANT: COMPLETE ALL APPLICABLE INFORMATION, WHEN CHANGING CONTRACTORS, NOTIFY THIS OFFICE. CALL UTILITY DIG NO: 1-800-272-1000.

Block 102 Lot 5 Qualification Code 08133

Work Site Location 301 CHAMBERSBRIDGE ROAD

Owner in Fee DEAN COUNTY LIFE COURSE AT FOLGE FOUN

Address 301 CHAMBERSBRIDGE ROAD BRICK 08133

Tel (732) 930-4733 FAX (732) 938-8668

Contractor ALLEN FIRE & SAFETY 908-894110

Address 1600 N. 5TH ST. CHATELAIN (MAY 11) BRICK 08133

Tel (732) 922-3399 FAX (732) 922-3399

Fire Protection Equipment, NJ Div of Fire Safety Permit No. PA0146

Fire Alarm Contractor No. PA0146

Federal Emp. No. 22-869087

B. FIRE PROTECTION CHARACTERISTICS

Use Group: Present Proposed Fire Alarm System: [X] New or [] Existing

Const. Class: Present Proposed Location of Panel: PA0146

Heating System: [X] New or [] Existing [] HVAC Fire Suppression/Standpipe System: [X] New or [] Existing

Type: [] Gas [] Oil [X] Electric [] Solar Location of Main Control Valve: PA0146

Location: PA0146

Fuel Storage Tank: PA0146

Fuel Type: [] Flammable or [X] Combustible Capacity PA0146

Total Cost of Fire Protection Work \$ PA0146

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent or) owner of record and am authorized to make this application.

Applicant's Signature/Contractor's Signature PA0146

[] Exempt Applicant



Date Received 10-1857
Control # 610-002058
Date Issued 7/16/10
Permit # PA0146

D. TECHNICAL SITE DATA
DESCRIPTION OF WORK: PLATE FACTORY INSTALLATION BY MEAN.
INTO SEWERAGE.

Water Supply Source PA0146

Method of Alarm/Suppression System Supervision PA0146

Flammable/Combustible Tanks

Alarm Systems

[] System

[] 110v Interconnected

[] CO Detectors/110v

Alarm Devices (i.e., smoke, heat, pulls, water/flow)

Supervisory Devices (i.e., tamper, low/high air)

Signaling Devices (i.e., horn/strobes, bells)

Other Devices

TOTAL

Suppression Systems

Fire Pump GPM Type

Dry Pipe/Alarm Valves

Pre-action Valves

Sprinkler Heads (Dry and Wet)

Standpipes

Pre-engineered Systems

Wet Chemical

Dry Chemical

CO₂ Suppression

Foam Suppression

FM200 Suppression

Other Systems

Kitchen Hood Exhaust System

Smoke Control System

Fired Appliances [] Gas or [] Oil

Fireplace Venting/Metal Chimney

Other

Administrative Surcharge \$ PA0146


Minimum Fee \$ PA0146

State Permit Surcharge Fee \$ PA0146

TOTAL FEE \$ PA0146



ELECTRICAL SUBCODE



A. IDENTIFICATION—APPLICANT: COMPLETE ALL APPLICABLE INFORMATION. WHEN CHANGING CONTRACTORS, NOTIFY THIS OFFICE. CALL UTILITY DIG NO: 1-800-272-1000.

Block 103 Lot 5 Qualification Code _____

Work Site Location 301 CHAMBERSBROOK ROAD

Owner In Fee: CREAK COUNTY COURSE AT FOLGUE ROAD

Tel (732) 930-4733 e-mail SBINKLEY@Co.CREAK.NJ.US

Address 301 CHAMBERSBROOK ROAD BECK 08723

Contractor: _____ street _____ municipality _____ zip code _____

Address _____ e-mail _____ Tel. () _____

Contractor License No. _____ Exp. Date _____

Home Improvement Contractor Registration No. or Exemption Reason (if applicable): _____

Federal Emp. ID No. _____ FAX: () _____

B. ELECTRICAL CHARACTERISTICS

Use Group Present _____ Proposed _____

[] Pole/Pad # _____ [] Temporary [] Other _____

Building Occupied as STORAGE Utility Co. _____

Est. Cost of Elec. Work \$ _____

JOB SUMMARY (Office Use Only)

PLAN REVIEW

[] No Plans Required

[] Partial - Underslab Utilities Approved

Date: _____ Approved by: _____

[] Electric Plans Approved

Date: _____ Approved by: _____

Joint Plan Review Required:

[] Bldg. [] Plumb. [] Fire. [] Elev.

SUBCODE APPROVAL FOR PERMIT

Date: 5-1-10

Approved by: JS

SUBCODE APPROVAL FOR CERTIFICATE

[] CO [] CCO [] CA

Date: 5-12-11

Approved by: JS

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner of record and am authorized to make this application and perform the work listed on this application.

Applicant's Signature/Contractor's Seal and Signature

[] Licensed Elec. Contractor [] Certifd Landscape Irrigation Contr [] Exempt Applicant

D. TECHNICAL SITE DATA

DESCRIPTION OF WORK

CONNECT MAINTENANCE BUILDING TO
DEGRADED STORAGE BUILDING

Date Received
Control #
Date Issued
Permit #

10-1857
7/10/10

QTY. SIZE ITEMS

3 Lighting Fixtures

1 Receptacles

1 Switches

1 Detectors

1 Light Poles

1 Motors—Fract. HP

1 Emergency & Exit Lights

1 Communications Points

1 Alarm Devices/F.A.C. Panel

TOTAL NUMBERS

Pool Permitwith UW Lights

Storage Pool/Spa/Hot Tub

KW Elec. Range/Receptacle

KW Oven/Surface Unit

KW Elec. Water Heater

KW Elec. Dryer/Receptacle

KW Dishwasher

HP Garbage Disposal

KW Central A/C Unit

HP/KW Space Heater/Air Handler

KW Baseboard Heat

HP Motors 1/+ HP

KW Transformer/Generator

AMP Service

AMP Subpanels

AMP Motor Control Center

KW Elec. Sign/Outline Light

FEE (Office Use Only)

\$

Administrative Surcharge \$

Minimum Fee \$

State Permit Surcharge Fee \$

TOTAL FEE \$

April 2009



BUILDING SUBCODE TECHNICAL SECTION



A. IDENTIFICATION—APPLICANT: COMPLETE ALL APPLICABLE INFORMATION. WHEN CHANGING CONTRACTORS, NOTIFY THIS OFFICE. CALL UTILITY DIG NO. 1-800-272-1000.

Block 702 Lot 5 Qualification Code _____
Work Site Location 301 CHAMBERSBURG ROAD

Owner in Fee: County of Ocean

Tel. (732) 920-4733 e-mail SHUCKER@CO.OCEAN.NJ.US

Address _____ Municipality _____ Tel. (_____) Zip code _____

Contractor: Robert Pardo e-mail _____
Address 601P COVES

Contractor License No. or Builder Registration No. _____ Exp. Date _____

Home Improvement Contractor Registration No. or Exemption Reason (if applicable): _____
Federal Emp. ID No. _____ FAX: (_____) _____

JOB SUMMARY (Office Use Only)		PLAN REVIEW		Date		INSPECTIONS		Type		Failure		Dates (Month/Day)		Initial	
☐ No Plans Required						☐ All									
☐ Footings/Foundations						☐ Footing Bonding									
☐ Structural/Framework						☐ Foundation									
☐ Exterior						☐ Slab									
☒ Interior						☐ Frame									
☒ Plan Review Required						☐ Truss Sys./Bracing									
☐ Elec. ☐ Plumb. ☐ Fire ☐ Elevator						☐ Barrier-Free									
SUBCODE APPROVAL FOR PERMIT						☐ Insulation									
Date: _____						☐ Finishes -Base Layer									
SUBCODE APPROVAL FOR CERTIFICATE						☐ Finishes -Final									
Date: _____						☐ Energy									
☐ CO						☐ Mechanical									
☐ CA						☐ TCO									
Other _____						☐ Barrier-Free									
Approved by: <u>Shuck</u>						☐ Final									
Barrier-Free						☐ Barrier-Free									

B. BUILDING CHARACTERISTICS

Use Group Present	Proposed	Constr. Class Present	Proposed
No. of Stories <u>1</u>	<u>8.5</u>	If Industrialized Building:	
Height of Structure _____ ft.	<u>208</u>	State Approved _____	HUD _____
Area — Largest Floor _____ sq. ft.	<u>208</u>	Est. Cost of Bldg. Work: _____	
New Bldg. Area/All Floors _____ sq. ft.	<u>1768</u>	1. New Bldg. _____	
Volume of New Structure _____ cu. ft.	<u>25085</u>	2. Rehabilitation _____	
Max. Live Load _____	<u>150</u>	3. Total (1+2) \$ _____	
Max. Occupancy Load _____	<u>150</u>		

U.C.C. F110
(rev. 12/07)

C. CERTIFICATION IN LIEU OF OATH
I hereby certify that I am the (agent or) owner of record and am authorized to make this application.

Date Received _____
Control # _____
Date Issued _____
Permit # _____

7/16/10
10-657

D. TECHNICAL SITE DATA

DESCRIPTION OF WORK
CONSTRUCTION OF SUB FOR INSTALLATION OF PRE-FABRICATED PESTICIDE STORAGE BUILDING CONTAINING SELF CONTAINED FIRE SUPPRESSION.

TYPE OF WORK:	FEE (Office Use Only)
☒ New Building	\$ _____
☐ Addition	\$ _____
☐ Rehabilitation	\$ _____
☐ Roofing	\$ _____
☐ Siding	\$ _____
☐ Fence _____	Height (exceeds 6') \$ _____
☐ Sign _____	Sq. Ft. \$ _____
☐ Pool	\$ _____
☐ Retaining Wall _____	Sq. Ft. \$ _____
☐ Asbestos Abatement Subchapter 8	\$ _____
☐ Lead Haz. Abatement NJAC 5:17	\$ _____
☐ Radon Remediation	\$ _____
☐ Other _____	\$ _____
☐ Demolition	\$ _____

Administrative Surcharge \$ _____
Minimum Fee \$ _____
State Permit Surcharge Fee \$ _____
TOTAL FEE \$ _____

1 White = Inspector Copy
2 Canary = Office Copy
3 Pink = Office Copy
4 Gold = Applicant Copy



BUILDING SUBCODE TECHNICAL SECTION



A. IDENTIFICATION—APPLICANT: COMPLETE ALL APPLICABLE INFORMATION. WHEN CHANGING CONTRACTORS, NOTIFY THIS OFFICE. CALL UTILITY DIG NO: 1-800-272-1000.

Block 702 Lot 5 Qualification Code _____

Work Site Location 301 CHAMBERSBURG ROAD

Owner In Fee: PRICE NOT SET

Tel. (732) 920-4733 e-mail SHAWLEY@COASTAL.NJ.US

Address _____ Municipality _____ Zip Code _____

Contractor: _____ Tel. (_____) _____

Address _____ e-mail _____

Contractor License No. or Builder Registration No. _____ Exp. Date _____

Home Improvement Contractor Registration No. or Exemption Reason (if applicable): _____

Federal Emp. ID No. _____ FAX: (_____) _____

JOB SUMMARY (Office Use Only)

PLAN REVIEW	Date	Initial	INSPECTIONS	Failure	Dates (Month/Day)	Approval	Initial
☐ No Plans Required			Type:				
☐ All			Footings				
☐ Footings/Foundations			Foundation Bonding				
☐ Structural Framework			Foundation				
☐ Exterior			Slab				
☒ Interior			Frame				
Joint Plan Review Required:			Truss Sys./Bracing				
☐ Elec. ☐ Plumb. ☐ Fire ☐ Elevator			Barrier-Free				
SUBCODE APPROVAL FOR PERMIT			Insulation				
Date:			Finishes -Base Layer				
Approved by:			Finishes -Final				
SUBCODE APPROVAL FOR CERTIFICATE			Energy				
☐ CO ☐ CCO ☐ CA			Mechanical				
Date:			TCO				
Approved by:			Other				
			Final				
			Barrier-Free				

B. BUILDING CHARACTERISTICS

Use Group Present	Proposed	Const. Class Present	Proposed
No. of Stories	<u>1</u>	If Industrialized Building:	
Height of Structure	<u>8.5</u> ft.	State Approved	HUD
Area — Largest Floor	<u>708</u> sq. ft.	Est. Cost of Bldg. Work:	
New Bldg. Area/All Floors	<u>208</u> sq. ft.	1. New Bldg.	\$
Volume of New Structure	<u>1768</u> cu. ft.	2. Rehabilitation	\$
Max. Live Load	<u>250 PSF</u>	3. Total (1+2)	\$
Max. Occupancy Load	<u>0</u>		

U.C.C. F110
(rev. 12/07)

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner of record and am authorized to make this application.

Date Received
Control #
Date Issued
Permit #

7/16/10

D. TECHNICAL SITE DATA

Signature _____

DESCRIPTION OF WORK

CONSTRUCTION OF SUB FOR INSTALLATION OF PRE FABRICATED PESTICIDE STORAGE BUILDING EQUIPPED WITH SELF CONTAINED FIRE SUPPRESSION.

TYPE OF WORK:

- ☒ New Building
- ☐ Addition
- ☐ Rehabilitation
- ☐ Roofing
- ☐ Siding
- ☐ Fence _____ Height (exceeds 6') Sq. Ft.
- ☐ Sign _____ Sq. Ft.
- ☐ Pool
- ☐ Retaining Wall _____ Sq. Ft.
- ☐ Asbestos Abatement Subchapter 8
- ☐ Lead Haz. Abatement NJAC 5:17
- ☐ Radon Remediation
- ☐ Other _____
- ☐ Demolition

FEE (Office Use Only)

Administrative Surcharge \$
Minimum Fee \$
State Permit Surcharge Fee \$
TOTAL FEE \$

1 White = Inspector Copy
2 Canary = Office Copy
3 Pink = Office Copy
4 Gold = Applicant Copy



BUILDING SUBCODE TECHNICAL SECTION



A. IDENTIFICATION—APPLICANT: COMPLETE ALL APPLICABLE INFORMATION, WHEN CHANGING CONTRACTORS, NOTIFY THIS OFFICE. CALL UTILITY DIG NO. 1-800-272-1000.

Block 702 Lot 5 Qualification Code _____

Work Site Location 201 CHAMBERSBORO RD

Owner In Fee: OWNERS OF CHAMBERS

Tel. (732) 470-4733 e-mail SPARKY@CHAMBERSBORO.NJ.US

Address _____ street _____ municipality _____ zip code _____

Contractor: _____ Tel. (_____) _____

Address _____ e-mail _____

Contractor License No. or Builder Registration No. _____ Exp. Date _____

Home Improvement Contractor Registration No. or Exemption Reason (if applicable): _____

Federal Emp. ID No. _____ FAX: (_____) _____

JOB SUMMARY (Office Use Only)

PLAN REVIEW	Date	Initial	INSPECTIONS	Type	Failure	Dates (Month/Day)	Initial
						Failure	Approval
☐ No Plans Required			Footings				
☐ All			Footings/Bonding				
☐ Footings/Foundations			Foundation				
☐ Structural/Framework			Slab				
☒ Exterior			Frame				
☒ Interior			Truss Sys./Bracing				
Joint Plan Review Required:			Barrier-Free				
☐ Elec. ☐ Plumb. ☐ Fire ☐ Elevator			Insulation				
SUBCODE APPROVAL FOR PERMIT			Finishes -Base Layer				
Date:			Finishes -Final				
Approved by:			Energy				
SUBCODE APPROVAL FOR CERTIFICATE			Mechanical				
☐ CO ☐ CCO ☐ CA			TCO				
Date:			Other				
Approved by:			Final				
			Barrier-Free				

B. BUILDING CHARACTERISTICS

Use Group	Present	Proposed	Constr. Class	Present	Proposed
No. of Stories	<u>1</u>	<u>0.5</u>	If Industrialized Building:		
Height of Structure		<u>0.5</u> ft.	State Approved		HUD
Area — Largest Floor		<u>208</u> sq. ft.	Est. Cost of Bldg. Work:		
New Bldg. Area/All Floors		<u>208</u> sq. ft.	1. New Bldg.		
Volume of New Structure		<u>116.8</u> cu. ft.	2. Rehabilitation		
Max. Live Load		<u>150 PSF</u>	3. Total (1+2)		
Max. Occupancy Load		<u>0</u>			

U.C.C. F-110
(rev. 12/07)

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner of record and am authorized to make this application.

Signature _____

D. TECHNICAL SITE DATA

DESCRIPTION OF WORK

CONSTRUCTION OF SUB FEE INFORMATION OF ALL INFORMATION AS TO THE SUB FEE BUILDING CONSTRUCTION AND SUB FEE SUPPLEMENT.

TYPE OF WORK:

- ☒ New Building
- ☐ Addition
- ☐ Rehabilitation
- ☐ Roofing
- ☐ Siding
- ☐ Fence _____ Height (exceeds 6') Sq. Ft.
- ☐ Sign _____ Sq. Ft.
- ☐ Pool
- ☐ Retaining Wall _____ Sq. Ft.
- ☐ Asbestos Abatement Subchapter 8
- ☐ Lead Haz. Abatement NJAC 5:17
- ☐ Radon Remediation
- ☐ Other _____
- ☐ Demolition


FEE (Office Use Only)

Administrative Surcharge \$ _____
Minimum Fee \$ _____
State Permit Surcharge Fee \$ _____
TOTAL FEE \$ _____


1 White = Inspector Copy
3 Pink = Office Copy
2 Canary = Office Copy
4 Gold = Applicant Copy

Date Received
Control #
Date Issued
Permit #

7/16/10



ELECTRICAL SUBCODE TECHNICAL SECTION



A. IDENTIFICATION—APPLICANT: COMPLETE ALL APPLICABLE INFORMATION. WHEN CHANGING CONTRACTORS, NOTIFY THIS OFFICE. CALL UTILITY DIG NO: 1-800-272-1000.

Block 702 Lot 5 Qualification Code _____

Work Site Location 301 CHAMBERSBURG ROAD

BECK 08723

Owner in Fee: Ocean County Golf Course at Fodge Pond

Tel. (732) 920-4133 e-mail SBINKLEY@Co.Ocean.NJ.US

Address 301 CHAMBERSBURG ROAD BECK 08723

street

municipality

zip code

Contractor: _____ Tel. (____) _____ e-mail _____

Contractor License No. _____ Exp. Date _____

Home Improvement Contractor Registration No. or Exemption Reason (if applicable) _____

Federal Emp. ID No. _____ FAX: (____) _____

B. ELECTRICAL CHARACTERISTICS

Use Group _____ Present _____ Proposed _____

[] Pole/Pad # _____ [] Temporary [] Other _____

Building Occupied as STORAGE Utility Co. _____

Est. Cost of Elec. Work \$ _____

JOB SUMMARY (Office Use Only)

PLAN REVIEW

[] No Plans Required

[] Partial - Underslab Utilities Approved

Date: _____ Approved by: _____

[] Electric Plans Approved

Date: _____ Approved by: _____

Joint Plan Review Required:

[] Bldg. [] Plumb. [] Fire. [] Elev.

SUBCODE APPROVAL for PERMIT

Date: 7-7-10

Approved by: 97

SUBCODE APPROVAL for CERTIFICATE

[] CO [] CCO [] CA

Date: _____

Approved by: _____

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner of record and am authorized to make this application and perform the work listed on this application.

Applicant's Signature/Contractor's Seal and Signature

[] Licensed Elec. Contractor [] Certifd Landscape Irrigation Contr [] Exempt Applicant

D. TECHNICAL SITE DATA

Date Received

10-1857

Control #

Date Issued

Permit #

7/10/10

DESCRIPTION OF WORK

CONNECT MAINTENANCE BUILDING TO
PREFABRICATED STORAGE BUILDING

FEE (Office Use Only)

QTY

SIZE

ITEMS

Lighting Fixtures

Receptacles

Switches

Detectors

Light Poles

Motors—Fract. HP

Emergency & Exit Lights

Communications Points

Alarm Devices/F.A.C. Panel

TOTAL NUMBERS

Pool Permit/With UW Lights

Storable Pool/Spa/Hot Tub

KW Elec. Range/Receptacle

KW Over/Surface Unit

KW Elec. Water Heater

KW Elec. Dryer/Receptacle

KW Dishwasher

HP Garbage Disposal

KW Central A/C Unit

HP/KW Space Heater/Air Handler

KW Baseboard Heat

HP Motors 1/4 HP

KW Transformer/Generator

AMP Service

AMP Subpanels

AMP Motor Control Center

KW/Elec. Sign/Outline Light

Administrative Surcharge \$

Minimum Fee \$

State Permit Surcharge Fee \$

TOTAL FEE \$

April 2009

U.C.C. F120 (rev. 12/07)

1 White - Inspector Copy 2 Canary - Office Copy 3 Pink - Office Copy 4 Gold - Applicant Copy



ELECTRICAL SUBCODE



A. IDENTIFICATION—APPLICANT: COMPLETE ALL APPLICABLE INFORMATION. WHEN CHANGING CONTRACTORS, NOTIFY THIS OFFICE. CALL UTILITY DIG NO: 1-800-272-1000.

Block 102 Lot 5 Qualification Code _____

Work Site Location 301 COLUMBESBORO ROAD

Owner in Fee CELANO COUNTY (WEST AT ESTATE ROAD)

Tel. (723) 430-4733 e-mail SPINLEY@COUNTY.NJ.US

Address 201 CHAMBERSBORO ROAD PERK 08723

Contractor: _____ Tel. () _____

Address _____ e-mail _____

Contractor License No. _____ Exp. Date _____

Home Improvement Contractor Registration No. or Exemption Reason (if applicable): _____

Federal Emp. ID No. _____ FAX: () _____

B. ELECTRICAL CHARACTERISTICS

Use Group Present _____ Proposed _____

[] Pole/Pad # _____ [] Temporary [] Other _____

Building Occupied as STORAGE Utility Co. _____

Est. Cost of Elec. Work \$ _____

JOB SUMMARY (Office Use Only)

PLAN REVIEW

[] No Plans Required

[] Partial -Underslab Utilities Approved

Date: _____ Approved by: _____

[] Electric Plans Approved

DATE RECEIVED	CONTROL #	DATE ISSUED	PERMIT #
10-1857		7/10/10	

D. TECHNICAL SITE DATA	
DESCRIPTION OF WORK	
CONNECT ALTERNATE BUILDING TO	
REINFORCED STEEL BUILDING	

QTY	SIZE	ITEMS	FEE (Office Use Only)
1		Lighting Fixtures	
1		Receptacles	
1		Switches	
1		Detectors	
1		Light Poles	
1		Motors—Fract. HP	
1		Emergency & Exit Lights	
1		Communications Points	
1		Alarm Devices/F.A.C. Panel	
TOTAL NUMBERS			\$
Pool Permit/with UW Lights			
Storage Pool/Spa/Hot Tub			
KW Elec. Range/Receptacle			
KW Oven/Surface Unit			
KW Elec. Water Heater			
KW Elec. Dryer/Receptacle			
KW Dishwasher			
HP Garbage Disposal			
KW Central/A/C Unit			
HP/KW Space Heater/Air Handler			
KW Baseboard Heat			
HP Motors 1/4 HP			
KW Transformer/Generator			
AMP Service			
AMP Subpanels			
AMP Motor Control Center			
KW Elec. Sign/Outline Light			

Administrative Surcharge \$	
Minimum Fee \$	
State Permit Surcharge Fee \$	
TOTAL FEE \$	

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner of record and am authorized to make this application and perform the work listed on this application.

Applicant's Signature/Contractor's Seal and Signature

[] Licensed Elec. Contractor [] Certifd Landscape Irrigation Contr [] Exempt Applicant



FIRE PROTECTION SUBCODE TECHNICAL SECTION

A. IDENTIFICATION—APPLICANT: COMPLETE ALL APPLICABLE INFORMATION. WHEN CHANGING CONTRACTORS, NOTIFY THIS OFFICE. CALL UTILITY DIG NO: 1-800-272-1000.

Block 702 Lot 5 Qualification Code _____
Work Site Location 301 CHAMBERSBRIDGE ROAD BRK 08223

Owner In Fee DEAN LOUQUA (HOLE LOUSE AT FORD ROAD)
Address 301 CHAMBERSBRIDGE ROAD BRK 08223

Tel (732) 920-4733
Contractor ALLEN FIRE & SAFETY
Address ALLEN FIRE & SAFETY 517 CHILES DRIVE N

Tel (732) 922-3399 FAX (732) 928-8668
Fire Protection Equipment, NJ Div of Fire Safety Permit No. PO0116
Fire Protection Equipment, NJ Div of Fire Safety Installer No. PO0116
Fire Alarm Contractor No. PO0116
Federal Emp. No. 27-001087

B. FIRE PROTECTION CHARACTERISTICS

Use Group: Present _____ Proposed _____ Fire Alarm System: ☒ New or ☐ Existing
Constr. Class: Present _____ Proposed _____ Location of Panel: _____
Heating System: ☒ New or ☐ Existing ☐ HVAC Fire Suppression/Standpipe System:
Type: ☐ Gas ☐ Oil ☒ Electric ☐ Solar ☒ New or ☐ Existing
☐ Other _____ Location of Main Control Valve: _____

Location: _____

Fuel Storage Tank: _____
Fuel Type: ☐ Flammable or ☐ Combustible Capacity _____

Total Cost of Fire Protection Work \$ _____

JOB SUMMARY (Office Use Only)

PLAN REVIEW	INSPECTIONS	Dates (Month/Day)	Initial
☐ No Plans Required	Type: Alarm System	Failure	Approval
☐ Joint Plan Review Required:	Suppression Sys.	Failure	Approval
☐ Building ☐ Plumbing	Standpipe	Failure	Approval
☐ Electric ☐ Elevator	Fire Pump	Failure	Approval
☒ Fire Plans Approved	Pre-Eng. System	Failure	Approval
Date: <u>7-15-10</u>	Mechanical	Failure	Approval
Approved by: <u>[Signature]</u>	Smoke Control	Failure	Approval
SUBCODE APPROVAL	TCO	Failure	Approval
☐ CO ☐ CCO ☐ CA	Flam/Combust Tanks	Failure	Approval
Date: _____	Fireplace Venting	Failure	Approval
Approved by: _____	Final	Failure	Approval
	Other	Failure	Approval



C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent/d) owner of record and am authorized to make this application: _____

Applicant's Signature/Contractor's Signature _____
[] Exempt Applicant

D. TECHNICAL SITE DATA

DESCRIPTION OF WORK: PLATE PATTERN / INSTALLED BY M.W.
210 SERVICE
Water Supply Source _____
Method of Alarm/Suppression System Supervision _____

Flammable/Combustible Tanks

Alarm Systems ☐ System

☐ 110v Interconnected

☐ CO Detectors/110v

Alarm Devices (i.e., smoke, heat, pulls, water/flow)

Supervisory Devices (i.e., tamper, low/high air)

Signaling Devices (i.e., horn/strobes, bells)

Other Devices _____

TOTAL

Suppression Systems

Fire Pump _____ GPM Type _____

Dry Pipe/Alarm Valves

Pre-action Valves

Sprinkler Heads (Dry and Wet)

Standpipes

Pre-engineered Systems

Wet Chemical

Dry Chemical

CO₂ Suppression

Foam Suppression

FM200 Suppression

Other _____

Other Systems

Kitchen Hood Exhaust System

Smoke Control System

Fired Appliances ☐ Gas or ☐ Oil

Fireplace Venting/Metal Chimney

Other _____

Administrative Surcharge \$ _____

Minimum Fee \$ _____

State Permit Surcharge Fee \$ _____

TOTAL FEE \$ _____

Date Received _____
Control # _____

Date Issued _____
Permit # _____

10-1857
7/16/10



FIRE PROTECTION SUBCODE TECHNICAL SECTION

A. IDENTIFICATION—APPLICANT: COMPLETE ALL APPLICABLE INFORMATION. WHEN CHANGING CONTRACTORS, NOTIFY THIS OFFICE. CALL UTILITY DIG NO. 1-800-272-1000.

Block 703 Lot 5 Qualification Code 08723

Work Site Location 301 CAMBERSTONE ROAD ROCK 08723

Owner in Fee DEADWOOD HOUSE AT FOGUE BOND

Address 301 CAMBERSTONE ROAD ROCK 08723

Tel (732) 920-4723 FAX (732) 928-8118

Contractor ALLEN FIRE & SAFETY

Address 4101 N. 5TH AVE. ROCK 08723

Tel (732) 921-3339 FAX (732) 928-8118

Fire Protection Equipment, NJ Div of Fire Safety Permit No. 200116

Fire Protection Equipment, NJ Div of Fire Safety Installer No. 200116

Fire Alarm Contractor No. 200116

Federal Emp. No. 27-94067

B. FIRE PROTECTION CHARACTERISTICS

Use Group: Present _____ Proposed _____ Fire Alarm System: ☒ New or ☐ Existing

Constr. Class: Present _____ Proposed _____ Location of Panel: _____

Heating System: ☒ New or ☐ Existing ☐ HVAC Fire Suppression/Standpipe System: _____

Type: ☐ Gas ☐ Oil ☒ Electric ☐ Solar ☒ New or ☐ Existing

Location: _____ Location of Main Control Valve: _____

Fuel Storage Tank: _____

Fuel Type: ☐ Flammable or ☐ Combustible Capacity _____

Total Cost of Fire Protection Work \$ _____

JOB SUMMARY (Office Use Only)

PLAN REVIEW	INSPECTIONS	Dates (Month/Day)	Initial
☐ No Plans Required	Type: _____	Failure	Approval
Joint Plan Review Required:	Alarm System _____	Failure	Approval
☐ Building ☐ Plumbing	Suppression Sys. _____	Failure	Approval
☐ Electric ☐ Elevator	Standpipe _____	Failure	Approval
☒ Fire Plans Approved	Fire Pump _____	Failure	Approval
Date: <u>7-15-10</u>	Pre-Eng. System _____	Failure	Approval
Approved by: <u>[Signature]</u>	Mechanical _____	Failure	Approval
SUBCODE APPROVAL	Smoke Control _____	Failure	Approval
☐ CO ☐ CCO ☐ CA	TCO _____	Failure	Approval
Date: _____	Flam/Combust Tanks _____	Failure	Approval
Approved by: _____	Fireplace Venting _____	Failure	Approval
	Final _____	Failure	Approval
	Other _____	Failure	Approval



C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent) owner of record and am authorized to make this application.

Applicant's Signature/Contractor's Signature _____

[] Exempt Applicant

D. TECHNICAL SITE DATA

DESCRIPTION OF WORK: PLATE PARTIAL EXHAUSTS by owner.

Water Supply Source Two separate.

Method of Alarm/Suppression System Supervision _____

Flammable/Combustible Tanks

Alarm Systems

☐ System

☐ 110v Interconnected

☐ CO Detectors/110v

Alarm Devices (i.e., smoke, heat, pulls, water/flow)

Supervisory Devices (i.e., tamper, low/high air)

Signaling Devices (i.e., horn/strobes, bells)

Other Devices _____

TOTAL _____

Suppression Systems

Fire Pump _____ GPM Type _____

Dry Pipe/Alarm Valves _____

Pre-action Valves _____

Sprinkler Heads (Dry and Wet) _____

Standpipes _____

Pre-engineered Systems _____

Wet Chemical _____

Dry Chemical _____

CO₂ Suppression _____

Foam Suppression _____

FM200 Suppression _____

Other _____

Other Systems _____

Kitchen Hood Exhaust System _____

Smoke Control System _____

Fired Appliances ☐ Gas or ☐ Oil _____

Fireplace Venting/Metal Chimney _____

Other _____

Administrative Surcharge \$ _____

Minimum Fee \$ _____

State Permit Surcharge Fee \$ _____

TOTAL FEE \$ _____

U.C.C. F140
(rev. 1/04)

1 White = Inspector Copy
3 Pink = Office Copy

2 Canary = Office Copy
4 Gold = Applicant Copy

Date Received
Control #

Date Issued
Permit #

7/16/10

10-1857

ANSUL®
I-101™ INDUSTRIAL
GENERAL PURPOSE: TOTAL FLOODING/LOCAL APPLICATION
FIRE SUPPRESSION SYSTEM
TECHNICAL MANUAL
ANSUL PART NO. 435239

UNDERWRITERS LABORATORIES FILE NO. EX 1727

JULY 1, 2007

General Purpose: Total Flooding/Local Application

SECTION	PAGE NO.
I. GENERAL INFORMATION	1-1
Introduction	1-1
Temperature Limitations	1-1
UL Listing	1-1
II. COMPONENTS	2-1 – 2-12
Tanks and Valve	2-1 – 2-2
Nozzles	2-2
Tank Bracketing	2-2
MCH3 Control Head	2-3
ECH3 Control Head	2-3
NMCH3 Control Head	2-3
MB-P2 Mounting Bracket	2-3
PDA-D2 Adaptor	2-4
Pneumatic Actuating Tanks	2-4
PAC-10	2-4
PAC-200	2-4
Detection Equipment	2-4 – 2-5
FLK-1	2-4
FLK-1A	2-5
FLH-1	2-5
Fusible Links	2-5
Thermal Detectors	2-5
RPS-M Remote Pull Station	2-6
RPS-E2 Electric Pull Station	2-6
Electrical Gas Shut-Off Valve	2-6
Corner Pulleys	2-7
SBP-1	2-7
CBP-1	2-7
WBP-1	2-7
Tee Pulley	2-7
Swing Check Valve	2-7
Electrical Switches	2-8
Solenoid Monitor 120/24	2-8
Pipe and Fittings	2-8
Stainless Steel Actuation Hose	2-9
Pressure Switches	2-9
Pressure Bleed Down Adaptor	2-9
Flow Restrictor	2-9
Component List	2-10 – 2-11

Table of Contents

UL EX 1727 Page 2

7-1-07

SECTION	PAGE NO.
III. DESIGN	3-1 – 3-14
General	3-1
Choosing the Proper Agent	3-1
Choosing the Proper Type of System	3-1
System Types	3-1 – 3-2
Local Application – Tankside	3-1
Local Application— Overhead	3-1
Total Flooding	3-2
Guidelines	3-2
Total Flooding (0-5% Unclosable Opening)	3-2
Total Flooding (Greater than 5% Unclosable Opening)	3-2
Piping Limitations – A-25ABC w/2 Nozzle	3-3
Piping Limitations – A-50ABC/BC w/4 Nozzles	3-4
Local Application Overhead (Indoor Use Only)	3-5
Piping Limitations – A-25ABC/BC w/2 Nozzles	3-6
Piping Limitations – A-50ABC/BC w/4 Nozzles	3-7
Total Flooding with ABC	3-8
Total Flooding Nozzle Protection Chart	3-9
Piping Limitations – A-17ABC w/1 Nozzle	3-10
Piping Limitations – A-35ABC w/2 Nozzles	3-11
Piping Limitations – A-70ABC w/4 Nozzles	3-12
Piping Limitations – A-70ABC with 6 Nozzles	3-13
Detector Placement	3-14
IV. INSTALLATION	4-1 – 4-14
General	4-1
Tank Installation	4-1
Control Head Installation	4-1 – 4-3
Single Tank	4-1
Multiple Tanks	4-1 – 4-3
Multiple Tanks – PAC-10 or PAC-200	4-3
Multiple Tanks – Two Control Heads	4-3
Fusible Link Detector Installation	4-4 – 4-6
Fusible Links Without Hangers	4-4 – 4-5
Fusible Links With Hangers	4-5 – 4-6
Thermal Detector Installation	4-6
Setting The Control Head	4-6 – 4-7
MCH3/NMCH3 Control Head	4-6
ECH3 Control Head	4-6 – 4-7
Solenoid Monitor Installation	4-7
In A Detection Circuit	4-7
When Used as a Reset Relay	4-7

Table of Contents

UL EX 1727 Page 3

7-1-07

SECTION	PAGE NO.
IV. INSTALLATION (Continued)	
Remote Pull Station Installation	4-8 – 4-9
RPS-M	4-8
RPS-E2	4-9
Electrical Gas Shut-Off Valve Installation	4-9
Tee Pulley Installation	4-9
Micro Switch Installation	4-9 – 4-10
Pipe and Nozzle Installation	4-10 – 4-11
Tee Positioning	4-11
Hanger/Support Installation	4-11
Main/Reserve System	4-11
Pressure Switch Installation	4-12 – 4-13
System Checkout After Installation	4-12
Mechanical Control Head	4-12
Electrical Control Head	4-13
Testing Thermal Detectors	4-13
Testing Remote Pull Station	4-13
Completing System Checkout	4-13
V. RECHARGE/MAINTENANCE	5-1 – 5-2
General	5-1
Maintenance After Discharge	5-1 – 5-2
System Cleanup	5-1
System Tank Recharge	5-1 – 5-2
Piping and Nozzles	5-2
System Reset	5-2
Regular System Maintenance	5-2
6 Month Maintenance	5-2
Annual Maintenance	5-2
6 Year Maintenance	5-2
Hydrostatic Testing	5-2

Installation

CONTROL HEAD INSTALLATION (Continued)

Multiple Tank Installations (Continued)

MULTIPLE TANK ACTUATION USING MODEL PAC-10 OR PAC-200 PNEUMATIC ACTUATION TANK (Continued)

In order to actuate the agent tanks from a Model PAC-10/200 Pneumatic Actuation Tank, a 3/4 in. NPT x 1/4 in. NPT bushing must be screwed into the pneumatic tank's discharge port. A 1/4 in. NPT x 45° 1/4 in. flare type fitting (conforming to SAE J513c) must then be screwed into this bushing. The male straight connector (Part No. 32338) is used with stainless steel actuation hose. Also, a Model PDA-D2 Pneumatic Discharge Adaptor must be installed on the valve of each agent tank. Pneumatic tubing is then used to connect the PAC-10/200 pneumatic tank to the PDA-D2 of each agent tank valve. See Figure 5.




FIGURE 5
000375AC

NOTE

Pneumatic tubing used for remote tank actuation shall have an outside diameter of 1/4 in. with a minimum wall thickness of 1/32 in. This is commonly known as refrigeration-type copper tubing. All tubing fittings shall be of the 1/4 in., 45° flare type conforming to SAE J513c. Compression type fittings are not acceptable.

The Model PAC-10 pneumatic tank can actuate a maximum of ten (10) agent tanks with a maximum of 100 ft (30.5 m) of pneumatic tubing.

The Model PAC-200 pneumatic tank can actuate a maximum of twenty (20) agent tanks with a maximum of 200 ft (61 m) of pneumatic tubing.

MULTIPLE TANK ACTUATION USING TWO CONTROL HEADS

If the system design requires the use of two control heads for multiple tank actuation, a maximum of 25 ft (7.6 m) of tubing or stainless steel actuation hose is allowed between the two control heads and the PAC-10 tank. See Figure 6. If a PAC-10 tank is not utilized, there is a maximum of 25 ft (7.6 m) of tubing or stainless steel actuation hose for the two control heads and up to 4 tanks or a maximum of 18 ft (5.4 m) of tubing or stainless steel actuation hose for the two control heads and 5 tanks.




FIGURE 6
000350AN

SECTION IV

UL EX 1727 Page 4-2
7-1-07

Installation

CONTROL HEAD INSTALLATION (Continued)

Multiple Tank Installations (Continued)

MULTIPLE TANK ACTUATION USING MCH3/ECH3/NMCH3 CONTROL HEAD (Continued)

In order to actuate the agent tank(s) from a control head, a 1/4 in. NPT x 45° 1/4 in. flare type fitting (conforming to SAE J513c) or male straight connector (Part No. 32338) must be screwed into the base of the control head actuator. Also, a Model PDA-D2 Pneumatic Discharge Adaptor must be installed on the valve of each agent tank. Pneumatic tubing or stainless steel actuation hose is then used to connect the control head to the PDA-D2 of each agent tank valve. See Figure 3.

NOTE

Pneumatic tubing used for remote tank actuation shall have an outside diameter of 1/4 in. with a minimum wall thickness of 1/32 in. This is commonly known as refrigeration-type copper tubing. All tubing fittings shall be of the 1/4 in., 45° flare type conforming to SAE J513c. Compression type fittings are not acceptable.




FIGURE 3
002872PC

A single Model MCH3/ECH3/NMCH3 Control Head can actuate:

1. Up to four (4) tanks with a maximum of 25 ft (7.6 m) of copper or stainless steel pneumatic tubing or stainless steel actuation hose when using an O-ring (Part No. 55531) installed in place of the Teflon washer and the 16 gram CO₂ cartridge.
2. Up to five (5) tanks with a maximum of 18 ft (5.4 m) of copper or stainless steel pneumatic tubing or stainless steel actuation hose when using an O-ring (Part No. 55531) installed in place of the Teflon washer and the 16 gram CO₂ cartridge.

CAUTION

Confirm the Teflon washer in the control head actuator assembly has been replaced with the O-ring (Part No. 55531) and the 16 gram CO₂ cartridge is installed for 4 and 5 tank single control head actuation.

The actuation line must be tested for any leaks by using a hand held or electric vacuum pump. The pump should be used to draw a vacuum on the actuation line at the fitting closest to the control head. A vacuum should be pulled to 20 inches of mercury. Leaks exceeding 5 inches of mercury within 30 seconds are not allowed. If the gauge on the vacuum pump indicates a leak in the line, examine the actuation line for loose fittings or damage. Correct any leaks and retest.

MULTIPLE TANK ACTUATION USING MODEL PAC-10 OR PAC-200 PNEUMATIC ACTUATION TANK

The Model PAC-10 or PAC-200 Pneumatic Actuation Tank must be used if more than five (5) agent tanks require simultaneous actuation. The Model PAC-10/200 must be used in conjunction with a Model MCH3/ECH3/NMCH3 Control Head. The control head is mounted on the Model PAC-10/200 valve assembly.

The Model PAC-10/200 is shipped complete with a mounting bracket. The tank must be mounted vertically with the nameplate facing out. The bracket must be securely anchored to the wall using bolts or lag screws. The wall to which the bracket is attached must be sufficiently strong to support the pneumatic tank. The bracket should never be fastened to dry wall or similar material. If this type of wall is encountered, studs must be located and the bracket fastened to them. See Figure 4.




FIGURE 4
002874PC

General Purpose: Total Flooding/Local Application

Installation


This chapter will detail the basic information necessary for proper installation of the ANSUL[®] Industrial Fire Suppression System. However, before attempting any installation it is necessary to attend a Factory Certification Training Class and become Certified to install the ANSUL Industrial Fire Suppression System.

Pipe and fittings for the discharge piping, conduit (EMT), pipe straps, pipe hangers, mounting bolts, and other miscellaneous equipment are not furnished as part of the ANSUL Industrial Fire Suppression System. These items must be furnished by the installer.

Before attempting any installation, unpack the entire system and check that all necessary parts are on hand. Inspect parts for damage. Verify that tank pressure is within the acceptable range as shown on the gauge.

TANK INSTALLATION

The tank and valve assembly is shipped with an anti-recoil plug in the valve discharge port.



The tank must be mounted vertically with the discharge port facing either left or right. The Models A-17 and A-25 tanks must be mounted using a Model MB-15 Mounting Bracket Kit. The Model A-35, A-50, A-70, and tanks must be mounted using a Model MB-1 Mounting Bracket Kit.

The bracket must be securely anchored to the wall using bolts or lag screws. The wall to which the bracket is attached must be sufficiently strong to support the tank. The bracket should never be fastened to dry wall or similar material. If this type of wall is encountered, studs must be located and the bracket fastened to them. See Figure 1.




FIGURE 1
002971PG

CONTROL HEAD INSTALLATION

Single Tank Installations

For single tank system installations the Model MCH3/ECH3/NMCH3 Control Head can be installed directly onto the tank valve. When the control head is properly aligned in the desired position, tighten the knurled locking ring to secure the assembly. See Figure 2.





FIGURE 2
002932PG 003647PC

Multiple Tank Installations

MULTIPLE TANK ACTUATION USING MCH3/ECH3/NMCH3 CONTROL HEAD

The Model MCH3/ECH3/NMCH3 Control Head can be used to pneumatically actuate a maximum of five (5) agent tanks with a 16 gram CO₂ cartridge. When a control head is used for multiple tank actuation, it cannot be mounted directly onto a tank valve. The control head must be installed remotely using a Model MB-P2 Control Head Mounting Bracket. The bracket must be anchored to the wall using bolts or lag screws.



SECTION III

UL EX 1727 Page 3-14
7-1-07

Design

DETECTOR PLACEMENT.

Thermal detectors are required in all hazard areas protected by the ANSUL Industrial Fire Suppression Systems if automatic system operation is required. Either mechanical or electrical thermal detectors can be used for automatic system operation. Mechanical detectors (fusible links) are used in conjunction with the ANSUL Models MCH3 and NMCH3 control devices. Electrical detectors are used in conjunction with the ANSUL Models ECH3-24 and ECH3-120 Control Heads.

TOTAL FLOODING (DETECTOR SPACING) – THERMAL

Ceiling Height	Spacing
Up to 14 ft (4.2 m) Height	15 ft (4.5 m) maximum between detectors 7 ft 6 in (2.3 m) maximum from wall 225 ft ² (20.9 m ²) maximum coverage per detector
Greater than 14 ft (4.2 m) up to 20 ft (6.1 m) height	13 ft (3.9 m) maximum between detectors 6 ft 6 in (1.9 m) maximum from wall 169 ft ² (15.7 m ²) maximum coverage per detector
Greater than 20 ft (6.9 m) up to 24 ft (7.3 m)	11 ft (3.4 m) maximum between detectors 5 ft 6 in (1.7 m) maximum from wall 121 ft ² (11.2 m ²) maximum coverage per detector
Greater than 24 ft (7.3 m) up to 30 ft (9.1 m)	9 ft (2.7 m) maximum between detectors 4 ft 6 in (1.4 m) maximum from wall 81 ft ² (7.5 m ²) maximum coverage per detector

NOTE: For sloped ceiling (peaked type or shed type) installations, refer to NFPA-72, "National Fire Alarm Code" for detailed spacing requirements.

LOCAL APPLICATION – OVERHEAD (DETECTOR SPACING) – Maximum spacing per detector is 100 ft² (9.3 m²) or 5 ft (1.5 m) from edge of hazard and 10 ft (3.1 m) between detectors. When detectors are mounted below the ceiling in an open area, heat traps are recommended.

LOCAL APPLICATION – TANKSIDE (DETECTOR SPACING) – Detectors can be located either near the inner tank wall and flammable liquid surface or above the tank. If located above the tank, the rules for local application overhead would apply. If located on the tank wall, the detectors can be mounted horizontally or vertically in the freeboard area, but must be protected from damage during normal working operations. The maximum spacing per detector is 5 ft (1.5 m) from edge of hazard and 10 ft (3.1 m) between detectors.

A temperature survey must be performed to determine the maximum ambient temperature of the hazard survey. See Temperature Chart in Section II – Components.

TOTAL FLOODING (DETECTOR SPACING) – FUSIBLE LINKS

Ceiling Height	Spacing
Up to 14 ft (4.2 m) Height	10 ft (3.0 m) maximum detectors 5 ft (1.5 m) maximum from a wall* 100 ft ² (9.2 m ²) maximum coverage per detector
Greater than 14 ft (4.2 m) up to 20 ft (6.1 m) height	8 ft (2.4 m) maximum between detectors 4 ft (1.2 m) maximum from wall 64 ft ² (5.9 m ²) maximum coverage per detector

NOTE: For sloped ceiling (peaked type or shed type) installations, refer to NFPA-72, "National Fire Alarm Code" for detailed spacing requirements.

LOCAL APPLICATION – OVERHEAD (DETECTOR SPACING) – Maximum spacing per fusible link detector is 36 ft² (3.3 m²) or 3 ft (0.9 m) from edge of hazard and 6 ft (1.8 m) between fusible link detectors.

When a detector(s) is mounted more than 1 ft (0.3 m) below ceiling or in an open area, heat trap(s) is recommended. Detectors should be mounted overhead at nozzle height or as close to the hazard as possible without interference, not to exceed 10 ft (3 m).


Detectors should not be located where they will be susceptible to damage during the normal work operation.

LOCAL APPLICATION – TANKSIDE (DETECTOR SPACING) – Detectors can be located either near the inner tank wall and flammable liquid surface or above the tank. If located above the tank, the rules for local application overhead would apply. If located on the tank wall, the detectors can be mounted horizontally or vertically in the freeboard area but must be protected from damage during normal working operation. Detectors should be located at a maximum spacing per detector of 3 ft (0.9 m) from edge of hazard and 6 ft (1.8 m) between detectors on the long side of the tank.

*For 14 ft (4.3 m) wide booths with maximum height of 12 ft (3.7 m), the detector location off the side wall can be a maximum of 7 ft (2.1 m).

Design

A-70ABC WITH 6 NOZZLES



004537A/N

Tank Size	Maximum Nozzle Quantity	Nozzle Type	Piping Section	Size	Length Maximum	Elbows Maximum
A-70ABC	6	N-SCR, N-OTF	Tank to T1	1 in.	18 ft (5.5 m)	3
			T1 to T2 (4 Nozzle Side)	1 in.	14 ft (4.3 m)	1
			T2 to T3	3/4 in.	4 ft (1.2 m)	0
			T3 to Nozzle	3/4 in.	6 ft (1.8 m)	2
			T1 to T2 (2 Nozzle Side)	1 in.	14 ft (4.3 m)	2
			T2 to Nozzle	3/4 in.	6 ft (1.8 m)	2


NOTE:

1. These limitations apply to A-70ABC using six nozzles (2-N-SCR, 4 N-OTF, or 6 N-OTF).
2. System piping must be balanced. Balanced piping is that in which the difference between the shortest actual pipe length from T1 to nozzle and the longest actual pipe length from T1 to nozzle does not exceed 10% of the longest actual pipe length from T1 to nozzle. T2 to nozzle on the same branch must not exceed 10% of each other. The number and type of fittings for all last tee to nozzle sections must be equal.
3. A Main/Reserve Swing Check Valve, Part No. 417788, may be located between the tank and T1.
4. When using the 2-N-SCR, 4-N-OTF nozzle combination, the 2-N-SCRs must be located on the two nozzle side of the piping layout.

SECTION III

UL EX 1727 Page 3-12
7-1-07

Design



Total Flooding Piping Limits A-70ABC

Tank Size	Maximum Nozzle Quantity	Nozzle Type	Piping Section	Size	Length Maximum	Elbows Maximum
A-70ABC	4	NF-ABC	Tank to T1	1 in.	30 ft (9.1 m)	3
			T1 to T2	1 in.	14 ft (4.3 m)	2
			T2 to Nozzle	3/4 in.	9 ft (2.7 m)	2


NOTE:

1. A-70ABC must always use four (4) NF-ABC nozzles.
2. System piping must be balanced. Balanced piping is that in which the difference between the shortest actual pipe length from T1 to nozzle and the longest actual pipe length from T1 to nozzle does not exceed 10% of the longest actual pipe length from T1 to nozzle. T2 to nozzle on the same branch must not exceed 10% of each other. The number and type of fittings from all last tee to nozzle sections must be equal.
3. A Main/Reserve Swing Check Valve, Part No. 417788, may be located between the tank and T1.

SECTION III

UL EX 1727 Page 3-11
7-1-07

Design



062663PG

Total Flooding Piping Limits A-35ABC

Tank Size	Maximum Nozzle Quantity	Nozzle Type	Piping Section	Size	Length Maximum	Elbows Maximum
A-35ABC	2	NF-ABC	Tank to T1	3/4 in.	30 ft (9.1 m)	4
			T1 to Nozzle	3/4 in.	9 ft (2.7 m)	2

NOTE:


1. A-35ABC must always use two (2) NF-ABC nozzles.
2. System piping must be balanced. Balanced piping is that in which the difference between the shortest actual pipe length from T1 to nozzle and the longest actual pipe length from T1 to nozzle does not exceed 10% of the longest actual pipe length from T1 to nozzle. The number and type of fittings from all last tee to nozzle sections must be equal.
3. A Main/Reserve Swing Check Valve, Part No. 417788, may be located between the tank and T1.

SECTION III

UL EX 1727 Page 3-10
7-1-07

Design

A-17ABC WITH 1 NOZZLE



002864PC

Total Flooding Piping Limits A-17ABC

Tank Size	Nozzle Quantity	Nozzle Type	Piping Section	Size	Length Maximum	Elbows Maximum
A-17ABC	1	NF-ABC	Tank to Nozzle	3/4 in.	30 ft (9.1 m)	4

NOTE:

- 1. A-17ABC uses one (1) NF-ABC nozzle.
- 2. A Main/Reserve Swing Check Valve, Part No. 417788, may be located between the tank and T1.

Design

TABLE 1
TOTAL FLOODING NOZZLE PROTECTION CHART

Maximum Dimensions in feet/nozzle for one (1) Model NF-ABC

Side 1 ft (m)	Nozzle Height ft m	Maximum Side 2 ft m	Side 1 (feet)	Nozzle Height ft m	Maximum Side 2 ft m	Side 1 (feet)	Nozzle Height ft m	Maximum Side 2 ft m	Side 1 (feet)	Nozzle Height ft m	Maximum Side 2 ft m
3 (0.91)	8 (2.4)	16.70 (5.1)	7 (2.1)	8 (2.4)	15.46 (4.7)	11 (3.4)	8 (2.4)	12.92 (3.9)	15 (4.6)	8 (2.4)	7.94 (2.4)
	9 (2.7)	16.70 (5.1)		9 (2.7)	15.46 (4.7)		9 (2.7)	12.92 (3.9)		9 (2.7)	7.94 (2.4)
	10 (3.0)	16.70 (5.1)		10 (3.0)	15.46 (4.7)		10 (3.0)	11.78 (3.6)		10 (3.0)	7.94 (2.4)
	11 (3.4)	16.70 (5.1)		11 (3.4)	15.46 (4.7)		11 (3.4)	10.71 (3.3)		11 (3.4)	7.85 (2.4)
	12 (3.7)	16.70 (5.1)		12 (3.7)	15.43 (4.7)		12 (3.7)	9.62 (3.0)		12 (3.7)	7.20 (2.2)
	13 (4.0)	16.70 (5.1)		13 (4.0)	14.24 (4.3)		13 (4.0)	9.06 (2.8)		13 (4.0)	6.65 (2.0)
	14 (4.3)	16.70 (5.1)		14 (4.3)	13.22 (4.0)		14 (4.3)	8.42 (2.6)		14 (4.3)	6.17 (1.9)
	15 (4.6)	16.70 (5.1)		15 (4.6)	12.34 (3.7)		15 (4.6)	7.85 (2.4)		15 (4.6)	5.76 (1.8)
	16 (4.9)	16.70 (5.1)		16 (4.9)	11.57 (3.5)		16 (4.9)	7.36 (2.2)		16 (4.9)	5.40 (1.6)
	17 (5.2)	16.70 (5.1)		17 (5.2)	10.89 (3.3)		17 (5.2)	6.83 (2.1)		17 (5.2)	5.08 (1.5)
	18 (5.5)	16.70 (5.1)		18 (5.5)	10.29 (3.1)		18 (5.5)	6.55 (2.0)		18 (5.5)	4.80 (1.5)
	19 (5.8)	16.70 (5.1)		19 (5.8)	9.74 (3.0)		19 (5.8)	6.20 (1.9)		19 (5.8)	4.55 (1.4)
	20 (6.1)	16.70 (5.1)		20 (6.1)	9.26 (2.8)		20 (6.1)	5.89 (1.8)		20 (6.1)	4.32 (1.3)
4 (1.2)	8 (2.4)	16.49 (5.0)	8 (2.4)	8 (2.4)	14.97 (4.6)	12 (3.7)	8 (2.4)	12.00 (3.7)	16 (4.9)	8 (2.4)	5.66 (1.7)
	9 (2.7)	16.49 (5.0)		9 (2.7)	14.97 (4.6)		9 (2.7)	12.00 (3.7)		9 (2.7)	5.66 (1.7)
	10 (3.0)	16.49 (5.0)		10 (3.0)	14.97 (4.6)		10 (3.0)	10.80 (3.3)		10 (3.0)	5.66 (1.7)
	11 (3.4)	16.49 (5.0)		11 (3.4)	14.73 (4.5)		11 (3.4)	9.82 (3.0)		11 (3.4)	5.66 (1.7)
	12 (3.7)	16.49 (5.0)		12 (3.7)	13.50 (4.1)		12 (3.7)	9.00 (2.7)		12 (3.7)	5.66 (1.7)
	13 (4.0)	16.49 (5.0)		13 (4.0)	12.46 (3.8)		13 (4.0)	8.31 (2.5)		13 (4.0)	5.66 (1.7)
	14 (4.3)	16.49 (5.0)		14 (4.3)	11.57 (3.5)		14 (4.3)	7.71 (2.4)		14 (4.3)	5.66 (1.7)
	15 (4.6)	16.49 (5.0)		15 (4.6)	10.80 (3.3)		15 (4.6)	7.20 (2.2)		15 (4.6)	5.40 (1.6)
	16 (4.9)	16.49 (5.0)		16 (4.9)	10.13 (3.1)		16 (4.9)	6.75 (2.1)		16 (4.9)	5.06 (1.5)
	17 (5.2)	16.49 (5.0)		17 (5.2)	9.53 (2.9)		17 (5.2)	6.35 (1.9)		17 (5.2)	4.76 (1.4)
	18 (5.5)	16.49 (5.0)		18 (5.5)	9.00 (2.7)		18 (5.5)	6.00 (1.8)		18 (5.5)	4.50 (1.4)
	19 (5.8)	16.49 (5.0)		19 (5.8)	8.53 (2.6)		19 (5.8)	5.68 (1.7)		19 (5.8)	4.26 (1.3)
	20 (6.1)	16.20 (4.9)		20 (6.1)	8.10 (2.5)		20 (6.1)	5.40 (1.6)		20 (6.1)	4.05 (1.2)
5 (1.5)	8 (2.4)	16.22 (4.9)	9 (2.7)	8 (2.4)	14.39 (4.4)	13 (4.0)	8 (2.4)	10.91 (3.3)			
	9 (2.7)	16.22 (4.9)		9 (2.7)	14.39 (4.4)		9 (2.7)	10.91 (3.3)			
	10 (3.0)	16.22 (4.9)		10 (3.0)	14.39 (4.4)		10 (3.0)	9.97 (3.0)			
	11 (3.4)	16.22 (4.9)		11 (3.4)	13.09 (4.0)		11 (3.4)	9.06 (2.8)			
	12 (3.7)	16.22 (4.9)		12 (3.7)	12.00 (3.7)		12 (3.7)	8.31 (2.5)			
	13 (4.0)	16.22 (4.9)		13 (4.0)	11.08 (3.4)		13 (4.0)	7.67 (2.3)			
	14 (4.3)	16.22 (4.9)		14 (4.3)	10.29 (3.1)		14 (4.3)	7.12 (2.2)			
	15 (4.6)	16.22 (4.9)		15 (4.6)	9.60 (2.9)		15 (4.6)	6.65 (2.0)			
	16 (4.9)	16.20 (4.9)		16 (4.9)	9.00 (2.7)		16 (4.9)	6.23 (1.9)			
	17 (5.2)	15.25 (4.6)		17 (5.2)	8.47 (2.6)		17 (5.2)	5.86 (1.8)			
	18 (5.5)	14.40 (4.4)		18 (5.5)	8.00 (2.4)		18 (5.5)	5.54 (1.7)			
	19 (5.8)	13.64 (4.2)		19 (5.8)	7.58 (2.3)		19 (5.8)	5.25 (1.6)			
	20 (6.1)	12.96 (3.9)		20 (6.1)	7.20 (2.2)		20 (6.1)	4.98 (1.5)			
6 (1.8)	8 (2.4)	15.87 (4.8)	10 (3.0)	8 (2.4)	13.71 (4.2)	14 (4.3)	8 (2.4)	9.59 (2.9)			
	9 (2.7)	15.87 (4.8)		9 (2.7)	13.71 (4.2)		9 (2.7)	9.59 (2.9)			
	10 (3.0)	15.87 (4.8)		10 (3.0)	12.96 (4.0)		10 (3.0)	9.26 (2.8)			
	11 (3.4)	15.87 (4.8)		11 (3.4)	11.78 (3.6)		11 (3.4)	8.42 (2.6)			
	12 (3.7)	15.87 (4.8)		12 (3.7)	10.80 (3.3)		12 (3.7)	7.71 (2.4)			
	13 (4.0)	15.87 (4.8)		13 (4.0)	9.97 (3.0)		13 (4.0)	7.12 (2.2)			
	14 (4.3)	15.43 (4.7)		14 (4.3)	9.26 (2.8)		14 (4.3)	6.61 (2.0)			
	15 (4.6)	14.40 (4.4)		15 (4.6)	8.64 (2.6)		15 (4.6)	6.17 (1.9)			
	16 (4.9)	13.50 (4.1)		16 (4.9)	8.10 (2.5)		16 (4.9)	5.79 (1.8)			
	17 (5.2)	12.71 (3.9)		17 (5.2)	7.62 (2.3)		17 (5.2)	5.45 (1.7)			
	18 (5.5)	12.00 (3.7)		18 (5.5)	7.20 (2.2)		18 (5.5)	5.14 (1.6)			
	19 (5.8)	11.37 (3.5)		19 (5.8)	6.82 (2.1)		19 (5.8)	4.87 (1.5)			
	20 (6.1)	10.80 (3.3)		20 (6.1)	6.48 (2.0)		20 (6.1)	4.63 (1.4)			

SECTION III

UL EX 1727 Page 3-8
7-1-07

Design

GUIDELINES (Continued)

Total Flooding with ABC

Tanks: The Models A-17ABC, A-35ABC, and A-70ABC tanks can be used for ABC total flooding applications.

Nozzles: The Model NF-ABC is used for all ABC total flooding applications.

The Model A-17ABC can support one (1) Model NF-ABC nozzle.

The Model A-35ABC can support two (2) Model NF-ABC nozzles.

The Model A-70ABC can support four (4) Model NF-ABC nozzles.

Temperature Ranges: The operating temperature range for ABC total flooding applications is -20 °F to 120 °F (-28 °C to 48 °C).

Piping Requirements: Piping diagrams include limitations on pipe length and fittings.

Nozzle: The nozzle is to be mounted in the center of the protected area, with the discharge holes in the nozzle no greater than six (6) in (15.29 cm) from the ceiling. See Figure 4.





FIGURE 4
002860PC

Nozzle Coverages:

Protection	Nozzle	Specifications Maximum	Nozzle Location Within Protection Zone Length Width Height	Nozzle Offset	Nozzle Orientation
Flooding Area	NF-ABC	Volume – 1296 ft ³ (120.4 m ³) See Table 3-1	Length—Center Width—Center Height—20 ft (6.1 m) maximum	0 – 6 in. (0-15.29 cm)	Vertical
Flooding Area	N-OTF	Volume – 768 ft ³ (71.3 m ³) 8 x 8 x 12 ft (2.4 m x 2.4 m x 3.7 m)	Length—Center Width—Center Height—12 ft (3.7 m) maximum	0 – 6 in. (0-15.29 cm)	Vertical
Screen Area	N-SCR	8 x 12 ft (2.4 m x 3.7 m)	Length—Center Width—Center Height—12 ft (3.7 m) maximum	0 – 6 in. (0-15.29 cm)	Vertical

Design



00000CAN

Local Overhead Piping Limits A-50ABC

Tank Size	Maximum Nozzle Quantity	Nozzle Type	Piping Section	Size	Length Maximum	Elbows Maximum	Length Minimum	Elbows Minimum
A-50ABC	4	N-LA-ABC	Tank to T1	1 in.	25 ft (7.6 m)	4	5 ft (1.5 m)	1
			T1 to T2	3/4 in.	10 ft (3.1 m)	2	2.5 ft (0.8 m)	0
			T2 to Nozzle	3/4 in.	8 ft (2.4 m)	2	2.5 ft (0.8 m)	1
			Total Tank to Nozzle		43 ft (13.1 m)	8	20 ft (6.1 m)	3

Local Overhead Application Piping Limits A-50BC

Tank Size	Maximum Nozzle Quantity	Nozzle Type	Piping Section	Size	Length Maximum	Elbows Maximum	Length Minimum	Elbows Minimum
A-50BC	4	N-LA-BC	Tank to T1	1 in.	35 ft (10.7 m)	4	15.5 ft (4.7 m)	1
			T1 to T2	3/4 in.	12 ft (3.7 m)	2	2.5 ft (0.8 m)	0
			T2 to Nozzle	3/4 in.	12 ft (3.7 m)	3	2.5 ft (0.8 m)	1
			Total Tank to Nozzle		59 ft (18 m)	9	30 ft (9.1 m)	4

NOTE:


1. A-50ABC must always use four (4) N-LA-ABC nozzles.
2. A-50BC must always use four (4) N-LA-BC nozzles.
3. System piping must be balanced. Balanced piping is that in which the difference between the shortest actual pipe length from T1 to nozzle and the longest actual pipe length from T1 to nozzle does not exceed 10% of the longest actual pipe length from T1 to nozzle. T2 to nozzle on the same branch must not exceed 10% of each other. The number and type of fittings from all last tee to nozzle sections must be equal.
4. A Main/Reserve Swing Check Valve, Part No. 417788, may be located between the tank and T1.
5. Minimum requirements for piping and fittings do not apply to systems protecting hazards with no splashable hazard. A splashable hazard exists where liquid fuel in depth greater than 1/4 in. is present.

SECTION III

ULEX 1727 Page 3-6
7-1-07

Design

A-25ABC/BC WITH 2 NOZZLES



Local Overhead Application Piping Limits A-25ABC

Tank Size	Maximum Nozzle Quantity	Nozzle Type	Piping Section	Size	Length Maximum	Elbows Maximum	Length Minimum	Elbows Minimum
A-25ABC	2	N-LA-ABC	Tank to T1	3/4 in.	28 ft (8.5 m)	5	5 ft (1.5 m)	1
			T1 to Nozzle	3/4 in.	25 ft (7.6 m)	4	2.5 ft (0.8 m)	1
			Total Tank to Nozzle		53 ft (16.2 m)	9	25 ft (7.6 m)	4

Local Overhead Application Piping Limits A-25BC

Tank Size	Maximum Nozzle Quantity	Nozzle Type	Piping Section	Size	Length Maximum	Elbows Maximum	Length Minimum	Elbows Minimum
A-25BC	2	N-LA-BC	Tank to T1	3/4 in.	35 ft (10.7 m)	4	12.5 ft (3.8 m)	1
			T1 to Nozzle	3/4 in.	12 ft (3.7 m)	3	2.5 ft (0.8 m)	1
			Total Tank to Nozzle		47 ft (14.3 m)	7	24.5 ft (7.5 m)	4

NOTE:

1. A-25ABC must always use two (2) N-LA-ABC nozzles.
2. A-25BC must always use two (2) N-LA-BC nozzles.
3. System piping must be balanced. Balanced piping is that in which the difference between the shortest actual pipe length from T1 to nozzle and the longest actual pipe length from T1 to nozzle does not exceed 10% of the longest actual pipe length from T1 to nozzle. The number and type of fittings from all last tee to nozzle sections must be equal.
4. A Main/Reserve Swing Check Valve, Part No. 417788, may be located between the tank and T1.
5. Minimum requirements for piping and fittings do not apply to systems protecting hazards with no splashable hazard. A splashable hazard exists where liquid fuel in depth greater than 1/4 in. is present.

Design

GUIDELINES (Continued)

Local Application Overhead (Indoor Use Only)

Tanks: The Model A-25BC, A-25ABC, A-50BC, and A-50ABC can be used for local overhead applications.

Nozzles: The Model N-LA-ABC nozzle is used for both the A-25ABC and A-50ABC systems. The maximum nozzle height of the Model N-LA-ABC nozzle is 10 ft (3.0 m). The minimum nozzle height of the Model N-LA-ABC nozzle is 7.5 ft (2.3 m).

The Model N-LA-BC nozzle is used for both the A-25BC and A-50BC systems. The maximum nozzle height of the Model N-LA-BC nozzle is 11 ft (3.3 m). The minimum nozzle height of the Model N-LA-BC nozzle is 7.5 ft (2.3 m).

Note: Nozzle height is measured from the hazard surface to the closest point of the nozzle in the installed position.

Flow Restrictor: A Model FR-25sBC flow restrictor is required to be placed directly before each Model N-LA-BC nozzle when used with the A-25BC system for local overhead applications at any of the allowable nozzle heights. See Figure 2. No flow restrictors are required for A-25ABC, A-50ABC, or A-50BC systems.




FIGURE 2
003982PC

Temperature Range: The operating temperature range for the dry chemical tank assembly used for local overhead applications is 32 °F to 120 °F (0 °C to 48 °C).

Piping Requirements: Piping diagrams include limitations on pipe length and fittings.

Note: All listed piping diagrams represent maximum number of nozzles allowed. In applications that do not require the maximum number of nozzles, the quantity of nozzles can be reduced.

In applications of this type, along with the already listed limitations (notes included with each maximum layout), the following limitations apply:

- On the reduced nozzle side of the piping layout, the largest listed size pipe on the standard configuration layout must be utilized from T1 to nozzle.
- The maximum length of the reduced nozzle side must be the original combination from T1 to T2, and T2 to nozzle. **Note:** In systems utilizing a T3 split, the maximum length of the reduced nozzle side must be the original combination from T1 to T2, T2 to T3, and T3 to nozzle.
- The maximum number of elbows must be the original combination from T1 to T2, and T2 to nozzle. **Note:** In systems utilizing a T3 split, the maximum number of elbows must be the original combination from T1 to T2, T2 to T3, and T3 to nozzle.

Nozzle Placement and Coverage: The Models N-LA-ABC and N-LA-BC nozzles have been developed to provide local application of extinguishing agent from an overhead position. Both nozzles will protect a hazard area of 25 ft² (2.3 m²) with a 5 ft (1.5 m) maximum side. Proper nozzle placement is shown in Figure 3.





FIGURE 3
003929PC

Note: Minimum nozzle height of 7.5 ft (2.3 m) is only required when splashable liquid of 1/4 in. or greater is located in the hazard area.

SECTION III

UL EX 1727 Page 3-4
7-1-07

Design



Tankside Piping Limits A-50ABC

Tank Size	Maximum Nozzle Quantity	Nozzle Type	Piping Section	Size	Length Maximum	Elbows Maximum	Length Minimum	Elbows Minimum
A-50ABC	4	N-TS	Tank to T1	1 in.	53 ft (16.2 m)	6	6 ft (1.8 m)	1
			T1 to T2	3/4 in.	6 ft (1.8 m)	2	2 ft (0.6 m)	1
			T2 to Nozzle	3/4 in.	6 ft (1.8 m)	4	2 ft (0.6 m)	1
			Total Tank to Nozzle		65 ft (19.8 m)	10	16 ft (4.9 m)	4

Tankside Piping Limits A-50BC


Tank Size	Maximum Nozzle Quantity	Nozzle Type	Piping Section	Size	Length Maximum	Elbows Maximum	Length Minimum	Elbows Minimum
A-50BC	4	N-TS	Tank to T1	1 in.	65 ft (19.8 m)	8	5 ft (1.5 m)	2
			T1 to T2	3/4 in.	15 ft (4.6 m)	4	2 ft (0.6 m)	0
			T2 to Nozzle	3/4 in.	15 ft (4.6 m)	4	2 ft (0.6 m)	1
			Total Tank to Nozzle		95 ft (29 m)	14	16 ft (4.9 m)	3

NOTE:

- A-50ABC/BC must always use four (4) N-TS nozzles.
- System piping must be balanced. Balanced piping is that in which the difference between the shortest actual pipe length from T1 to nozzle and the longest actual pipe length from T1 to nozzle does not exceed 10% of the longest actual pipe length from T1 to nozzle. T2 to nozzle on the same branch must not exceed 10% of each other. The number and type of fittings from all last tee to nozzle sections must be equal.
- A Main/Reserve Swing Check Valve, Part No. 417788, may be located between the tank and T1.
- Minimum requirements for piping and fittings do not apply to systems protecting hazards with no splashable hazard. A splashable hazard exists where liquid fuel in depth greater than 1/4 in. is present.

Design

A-25ABC WITH 2 NOZZLES



Tankside Piping Limits A-25ABC

Tank Size	Maximum Nozzle Quantity	Nozzle Type	Piping Section	Size	Length Maximum	Elbows Maximum	Length Minimum	Elbows Minimum
A-25ABC	2	N-TS	Tank to T1	3/4 in.	31 ft (9.5 m)	6	5 ft (1.5 m)	1
			T1 to Nozzle	3/4 in.	16 ft (4.9 m)	4	3 ft (0.9 m)	1
			Total Tank to Nozzle		47 ft (14.3 m)	10	20 ft (6.1 m)	4

Tankside Piping Limits A-25BC

Tank Size	Maximum Nozzle Quantity	Nozzle Type	Piping Section	Size	Length Maximum	Elbows Maximum	Length Minimum	Elbows Minimum
A-25BC	2	N-TS	Tank to T1	3/4 in.	28 ft (8.5 m)	6	5 ft (1.5 m)	1
			T1 to Nozzle	3/4 in.	25 ft (7.6 m)	4	3 ft (0.9 m)	1
			Total Tank to Nozzle		53 ft (16.2 m)	10	25 ft (7.6 m)	4

NOTE:

1. A-25ABC/BC must always use two (2) N-TS nozzles.
2. System piping must be balanced. Balanced piping is that in which the difference between the shortest actual pipe length from T1 to nozzle and the longest actual pipe length from T1 to nozzle does not exceed 10% of the longest actual pipe length from T1 to nozzle. The number and type of fittings from all last tee to nozzle sections must be equal.
3. A Main/Reserve Swing Check Valve, Part No. 417788, may be located between the tank and T1.

SECTION III

UL EX 1727 Page 3-2
7-1-07

Design

SYSTEM TYPES (Continued)

Total Flooding: A supply of dry chemical agent is discharged into an enclosure surrounding the hazard by an arrangement of discharge nozzles. This type of system is used where there is a permanent enclosure surrounding the hazard that adequately enables the required concentration of agent to be built up. Typical applications include but are not limited to hazardous storage containers, computer rooms, generator rooms, and warehouses where sprinkler protection is unavailable. Total flooding systems require that an enclosure be present around the hazard area to allow the system to build up the proper concentration of agent within the hazard area. All total flooding systems utilize ABC (monoammonium phosphate-based) chemical only. ABC (monoammonium phosphate-based) chemical is utilized to suppress fires of "A" class combustible material (ordinary solid carbonaceous combustibles), "B" class combustible material (flammable liquids) and "C" class combustible material (electrical).

GUIDELINES

Where an enclosure is suitable for allowing total flooding protection depends on the unclosable opening percentage of the enclosure. Unclosable opening percentage is calculated as the area of the opening divided by the total surface area of the enclosure (area of the sides, top, and bottom of the enclosure).

Total Flooding (0-5% Unclosable Opening)

Total flooding protection is qualified for use on hazards whose enclosure has up to 5% unclosable opening. For enclosures that have greater than 5% unclosable opening, screening is required.

NFPA 17, "Dry Chemical Extinguishing Systems," makes an exception to the one pound of dry chemical per square foot of opening size not exceeding 15% of the total volume surface area which reads "a system that is listed by a testing laboratory for or including protection of unclosable openings may be used in lieu of the above."

Total Flooding (Greater than 5% Unclosable Opening)

This system can utilize the N-OTF total flood nozzle(s) and the N-SCR screening nozzle(s). The design is approved to a maximum hazard height of 12 ft (3.6 m) with no maximum unclosable opening.

Tanks: The Models A-15ABC, A-25ABC, A-35ABC, A-50ABC, and A-70ABC tanks can be used for total flood greater than 5% unclosable opening.

Nozzles: Four nozzles are available:

Nozzle	Application
N-SCR	Screening the opening
N-OTF	Work Area (Overhead Position)
N-PLU	Plenum Area (Overhead Position)
N-DCT	Duct

Temperature Range: The operating temperature range is 32 °F to 120 °F (0 °C to 48 °C).

Local Application Tankside (Indoor Use Only)

Tanks: The Models A-25BC, A-25ABC, A-50BC, and A-50ABC can be used for tankside applications.

Nozzles: The Model N-TS nozzle is used for all tankside applications.

Temperature Range: The operating temperature range for the dry chemical tank assembly used for tankside applications is -20 °F to 120 °F (-28 °C to 48 °C).

Piping Requirements: When using the Model A-25BC or A-50BC systems, each nozzle protects a maximum of 36 ft² (3.3 m²) with a maximum side dimension of 6 ft (1.8 m).

When using the Model A-25ABC or A-50ABC systems, each nozzle protects a maximum of 20.25 ft² (1.9 m²) with a maximum side dimension of 4 ft 6 in. (1.4 m).

The Model N-TS nozzle must be mounted 3-8 in. (7.6-20.3 cm) above the liquid surface, at least 1 in. (2.5 cm) below the lip of the pan. See Figure 1.

Piping Requirements: Piping diagrams below include limitations on pipe length and fittings.




FIGURE 1
00303MAN

General Purpose: Total Flooding/Local Application**Design****GENERAL**

ANSUL® Industrial Fire Suppression Systems may be used on a variety of hazards in many types of applications. The guidelines listed in this chapter deal with the limitations and parameters of various system configurations. It is the responsibility of the Certified installer to ensure that the proper system is being utilized, and that the system meets the limitations and parameters listed in this chapter. Before attempting to design any system it is necessary to attend a Factory Certification Training Class and become Certified to install ANSUL Industrial Fire Suppression Systems.

CHOOSING THE PROPER AGENT

It is necessary for the system designer to consider the combustible material found in the hazard area to ensure proper protection. The agent used in the system must be approved for the hazard class of the combustible material. The following are the hazard classes:

"A" Class: Ordinary solid carbonaceous combustibles. These include wood, paper, cloth, fiberglass, and plastics

"B" Class: Flammable liquids and gases. These include paints, solvents, gasoline, oils, and hydraulic fluids.

"C" Class: Electrical appliances. These include computers, power generators, and power transformers.

"D" Class: Combustible metals such as sodium, potassium, magnesium, titanium, and zirconium. The ANSUL Industrial Fire Suppression System is not intended to protect Class D hazards.

The following guidelines should be used for determining the proper agent:

ABC (monoammonium phosphate-based): for use with all "A," "B," and "C" Class hazards.

BC (sodium bicarbonate-based): for use with "B" and "C" Class hazards.

As per NFPA 17, pre-engineered dry chemical systems are not approved for deep-seated or burrowing fires (such as ordinary combustibles where the agent cannot reach the point of combustion), or on chemicals that contain their own oxygen supply (such as cellulose nitrate). Do not mix different types of agents, or agents from different manufacturers. Chemical reactions may occur when incompatible chemicals are mixed. Keep in mind that the agent used for each system must be acceptable to the Authority Having Jurisdiction.

CHOOSING THE PROPER TYPE OF SYSTEM

It is necessary for the system designer to consider the physical characteristics and layout of the hazard area to ensure proper protection. The hazard area must meet the criteria for a particular system for that system to be effective. The hazard area must be protected in accordance with NFPA 17 for proper protection. The following are lists of system types and the guidelines that are used to determine the proper type of system for that hazard:

SYSTEM TYPES

Local Application – Tankside: A supply of dry chemical agent is discharged directly onto a fire through an arrangement of discharge nozzles. This system is used for applying agent across a hazard area from the side of the area. Typical applications include but are not limited to dip tanks, quench tanks, and solvent tanks where overhead obstructions are present. Tankside applications require that the liquid tank have at least 4 in. of freeboard space above the liquid surface.

Tankside local application systems can utilize either BC (sodium bicarbonate-based) or ABC (monoammonium phosphate-based) suppression chemical.

BC (sodium bicarbonate-based) chemical is utilized to suppress fires of "B" class combustible material (flammable liquids). Class C protection only acceptable if total flooding.

ABC (monoammonium phosphate-based) chemical is utilized to suppress fires of "A" class combustible material (ordinary solid carbonaceous combustibles), "B" class combustible material (flammable liquids). Class C protection only acceptable if total flooding.

Local Application – Overhead – A supply of dry chemical agent is discharged directly onto a fire through an arrangement of discharge nozzles. This system is used for applying agent to an area from above the area. Typical applications include but are not limited to dip tanks, power generators, conveyors, belt driven machinery and transformers. The maximum nozzle height for overhead protection is 10.5 ft (3.2 m) for ABC coverage, and 11 ft (3.3 m) for BC coverage.

Overhead local application systems can utilize either BC (sodium bicarbonate-based) or ABC (monoammonium phosphate-based) suppression chemical.

BC (sodium bicarbonate-based) chemical is utilized to suppress fires of "B" class combustible material (flammable liquids).

ABC (monoammonium phosphate-based) chemical is utilized to suppress fires of "A" class combustible material (ordinary solid carbonaceous combustibles), "B" class combustible material (flammable liquids).

SECTION II

UL EX 1727 Page 2-12
7-1-07

Components

NOTES:

SECTION II

UL EX 1727 Page 2-11

7-1-07

Components**COMPONENT LIST – GENERAL PURPOSE: TOTAL FLOODING/LOCAL APPLICATION (Continued)**

<u>Model No.</u>	<u>Description</u>	<u>Part No.</u>
Solenoid Monitor 24	24VDC Solenoid Monitor	435264
Solenoid Monitor 120	120VAC Solenoid Monitor	435263
TD-140	140 °F (60 °C) Thermal Detector	550351
TD-190	190 °F (87.8 °C) Thermal Detector	550352
TD-225	225 °F (107.2 °C) Thermal Detector	550353
TD-325	325 °F (162.8 °C) Thermal Detector	550354
TD-450	450 °F (232.2 °C) Thermal Detector	550355
TD-600	600 °F (315.6 °C) Thermal Detector	550356
EGVSO-75	3/4 in. Electric Gas Valve	550358
EGVSO-100	1 in. Electric Gas Valve	550359
EGVSO-125	1 1/4 in. Electric Gas Valve	550360
EGVSO-150	1 1/2 in. Electric Gas Valve	550361
EGVSO-200	2 in. Electric Gas Valve	550362
EGVSO-250	2 1/2 in. Electric Gas Valve	550363
EGVSO-300	3 in. Electric Gas Valve	550385
MS-SPDT	Micro-Switch – Single Pole Double Throw	551154
MS-DPDT	Micro-Switch – Double Pole Double Throw	551155
MS-3PDT	Micro-Switch – 3 Pole Double Throw	551156
MS-4PDT	Micro-Switch – 4 Pole Double Throw	551157
- - -	Alarm Initiating Switch	550077
PS-SPDT-XP	Pressure Switch – Single Pole Double Throw	550052
CO2-6	6 x CO ₂ Cartridge	551059
CBP-1	Compression Bearing Corner Pulley	423250
SBP-1	Screw Bearing Corner Pulley	415670
WBP-10	Weather Proof Corner Pulley (10 Per Package)	550983
TP-1	Tee Pulley	550166
WC-100	Oval Sleeve Crimps (100 Per Package)	550122
- - -	Stop Sleeves (Pack of 10)	24919
- - -	Valve – Piston O-Ring	550636
- - -	Valve – Stem Washer	550284
- - -	Valve – Seat Washer	550021
- - -	Valve – Stem Head	550020
- - -	Valve – Body O-Ring	550029
- - -	Valve – Pressure Gauge	550025
- - -	Valve – Stem	550806
- - -	Valve – Stem O-Ring	550028
- - -	Valve – Conical Spring	550022
- - -	Valve – Piston	550805
FR-25sBC	Flow Restrictor	550235
- - -	Pressure Bleed Down Adaptor Assembly	551736
- - -	Dry Valve Rebuilding Kit	550037
- - -	Recharge Adaptor Kit (Dry)	550130
- - -	Dry Valve Hydrotest Kit	552182

SECTION II

UL EX 1727 Page 2-10
7-1-07

Components

COMPONENT LIST – GENERAL PURPOSE: TOTAL FLOODING/LOCAL APPLICATION

<u>Model No.</u>	<u>Description</u>	<u>Part No.</u>
A-15ABC	15 lb (6.8 kg) ABC Tank and Valve Assembly	435031
A-17ABC	17 lb (7.7 kg) ABC Tank and Valve Assembly	435028
A-25BC	25 lb (11.3 kg) BC Tank and Valve Assembly	435033
A-25ABC	25 lb (11.3 kg) ABC Tank and Valve Assembly	435032
A-35ABC	35 lb (15.9 kg) ABC Tank and Valve Assembly	435029
A-50BC	50 lb (22.7 kg) BC Tank and Valve Assembly	435035
A-50ABC	50 lb (22.7 kg) ABC Tank and Valve Assembly	435034
A-70ABC	70 lb (31.8 kg) ABC Tank and Valve Assembly	435030
RC-50ABC	50 lb (22.7 kg) Pail ABC Dry Chemical	435245
PAC-10	Pneumatic Actuating Tank	435267
PAC-200	Pneumatic Actuating Tank	435270
MB-P2	Control Head Mounting Bracket	550853
MB-15	Mounting Bracket (A-15,17,25 Tanks)	550054
MB-1	Mounting Bracket (A-35,70 Tanks)	550053
MB-U8	8 in. (20.3 cm) Unistrut Mounting Bracket	550324
MB-U10	10 in. (25.4 cm) Unistrut Mounting Bracket	550383
MB-U12	12 in. (30.5 cm) Unistrut Mounting Bracket	550638
MCH3	Mechanical Control Head	435016
NMCH3	Mechanical Control Head	435015
ECH3-24	24VDC Electrical Control Head	435017
ECH3-120	120VDC Electrical Control Head	435018
---	8 in. (20.3 cm) S.S. Actuation Hose	417582
---	16 in. (40.6 cm) S.S. Actuation Hose	31809
---	24 in. (60.9 cm) S.S. Actuation Hose	32336
---	42 in. (106.7 cm) S.S. Actuation Hose	430815
---	Male Elbow	31810
---	Male Tee	31811
---	Male Straight Connector	32338
PDA-D2	Pneumatic Actuating Adaptor	550829
---	Swing Check Valve	417788
NF-ABC	Nozzle Assembly	551678
N-LA-ABC	Nozzle Assembly	550646
N-LA-BC	Nozzle Assembly	550342
N-TS	Nozzle Assembly	550337
RPS-M	Remote Mechanical Pull Station	435257
RPS-E2	Remote Electric Pull Station	551166
FKL-1	10 in. (25.4 cm) Fusible Link Bracket	550131
FKL-1A	8 in. (20.3 cm) Fusible Link Bracket	550132
FLH-25	Fusible Link Hanger (25)	550876
FL-165	165 °F (73.9 °C) Fusible Link	550368
FL-212	212 °F (100 °C) Fusible Link	550365
FL-280	280 °F (137.8 °C) Fusible Link	550366
FL-360	360 °F (182.2 °C) Fusible Link	550009
FL-450	450 °F (232.2 °C) Fusible Link	550367
FL-500	500 °F (260 °C) Fusible Link	56816

Components

STAINLESS STEEL ACTUATION HOSE

The Stainless Steel Actuation Hose is used to connect the actuation line compression tees and can also be connected end to end. The hose has the same thread, 7/16-20, as the fittings. See Figure 27.

Hose Part No.	Length
417582	8 in. (20 cm)
31809	16 in. (41 cm)
32336	24 in. (61 cm)
430815	42 in. (107 cm)

Fitting Part No.	Description
31810	Male Elbow (7/16-20 x 1/4 in. NPT)
31811	Male Tee (7/16-20 x 7/16-20 x 1/4 in. NPT)
32338	Male Straight Connector (7/16-20 x 1/4 in. NPT)



FIGURE 27
300433

PRESSURE SWITCHES

Model PS-SPDT-XP

The Model PS-SPDT-XP is an explosion proof (NEMA 4; 7; 9) electrical pressure switch which can be field mounted in the discharge piping as shown in Figure 28. The switch is UL Listed (CCN: NOWT) and must be installed in accordance with the instructions contained with the switch and this manual. The switch provides one set of NO/NC dry contacts. It is intended for use with electric power shut-off devices (dealer supplied), electric gas valves, alarms, bells, lights, contactors, and other electrical devices designed to shut off or turn on upon system actuation. It is rated for 15 amps @ 125/250 VAC.




FIGURE 28
002625FC

PRESSURE BLEED DOWN ADAPTOR ASSEMBLY

The Pressure Bleed Down Adaptor Assembly, Part No. 551736, is required to open the valve stem on the tank when bleeding the tank down for six-year maintenance. See Figure 29.




FIGURE 29
404285

FLOW RESTRICTOR

A Model FR-25sBC flow restrictor is required to be placed directly before each Model N-LA-BC nozzle when used with the A-25BC system for local overhead applications at any of the allowable nozzle heights. See Figure 30.




FIGURE 30
002625FC

SECTION II

UL EX 1727 Page 2-8
7-1-07

Components

ELECTRICAL SWITCHES

The electrical switches are intended for use with electric gas valves, alarms, contactors, lights, contractor supplied electric power shut-off devices and other electrical devices that are designed to shut off or turn on when the system is actuated.

Switches are available in kits: One Switch Kit, Part No. 551154; Two Switch Kit, Part No. 551155; Three Switch Kit, Part No. 551156, and Four Switch Kit, Part No. 551157. Mounting hardware and 12 in. wire assemblies are provided with each kit. Each switch has a set of single-pole, double-throw contacts rated:

UL/cUL/CSA Rating

250 VAC, 21A Resistive
250 VAC, 2 HP
125 VAC, 1 HP

ENEC Rating

IE4T105μ Approved
250V, 21A Resistive
8A Motor Load




FIGURE 24
301812

The Alarm Initiating Switch Kit, Part No. 550077, can be field mounted within the control head. This switch must be used to close a supervised alarm circuit to the building main fire alarm panel when the control head actuates. This action will signal the fire alarm panel that there was a system actuation in the hazard area. The switch kit contains all necessary mounting components along with a mounting instruction sheet. The switch is rated 50 mA, 28 VDC.




FIGURE 25
004290

See NFPA 72, "National Fire Alarm Code," Initiating Devices section, for the correct method of wiring connection to the fire alarm panel.

SOLENOID MONITOR 120/24

The Solenoid Monitor 120/24 is used in conjunction with the Model ECH3 control head to supervise the actuation and detection circuits. In the event of a problem in the circuit, a light on the monitor goes out. The Solenoid Monitor 120 is used with the Model ECH3-120 control head. The Solenoid Monitor 24 is used with the Model ECH3-24 control head. Two sets of NO/NC dry contacts are provided. The unit mounts directly to a three gang wall outlet box. The Solenoid Monitor 120 acts as a reset relay when used with an electric gas valve. Electric gas valve wiring instructions are provided in the installation section of this manual. See Figure 26.




FIGURE 26
002680PC

PIPE AND FITTINGS

Pipe and fittings must be furnished by the installer. Schedule 40 black, galvanized, chrome plated, or stainless steel pipe must be used. Standard weight malleable, galvanized, chrome plated, or stainless steel fittings must also be used.

Components

CORNER PULLEYS

Model SBP-1

A corner pulley is used whenever a change in stainless steel cable direction is required. The Model SBP-1 corner pulley is equipped with a set screw fitting for connection to 1/2 in. EMT. See Figure 19.




FIGURE 19
000180

MODEL CBP-1

A corner pulley is used whenever a change in stainless cable direction is required. The Model CBP-1 is a grease-tight corner pulley designed for areas likely to experience excessive deposit build-up. It is equipped with a compression fitting for connection to 1/2 in. EMT. See Figure 20.

Note: The Model CBP-1 is not a liquid tight sealing device.




FIGURE 20
000181

Model WBP-1

A corner pulley is used whenever a change in stainless cable direction is required. The Model WBP-1 is a liquid-tight corner pulley designed for areas likely to experience excessive moisture build-up. It is equipped with a female pipe thread for connection to 1/2 in. rigid conduit. See Figure 21.




FIGURE 21
000194PC

TEE PULLEY

The Model TP-1 tee pulley is used to connect two remote mechanical pull stations to a single control head. The tee pulley replaces two standard 90° corner pulleys. See Figure 22.



CAUTION

The Tee Pulley must never be used to connect multiple fusible link lines to a single control head.




FIGURE 22
002857PC

SWING CHECK VALVE

The Swing Check Valve, Part No. 417788, is required when piping a main and reserve Monarch tank on the same distribution piping. It allows the dry chemical agent to discharge through the agent piping leading to the discharge nozzles, while preventing it from flowing into the piping from the other tank. The swing check valve body is constructed of brass with a 1 in. NPT female thread. See Figure 23.




FIGURE 23
000490

SECTION II

UL EX 1727 Page 2-6
7-1-07

Components

REMOTE MECHANICAL PULL STATION

Model RPS-M

Remote manual control for system releasing devices is provided by the Model RPS-M remote mechanical pull station. It is connected to the system releasing device by stainless steel cable. This cable is enclosed in 1/2 in. EMT with corner pulleys at each change in direction. The remote mechanical pull station shall be located at the point of egress from the hazard area. See Figure 16.







FIGURE 16
002652PC

Model RPS-E2

Remote manual actuation for the Model ECH control head is provided by the Model RPS-E2 remote electric pull station. Installation instructions are provided in the installation section of this manual. The remote electric pull station shall be located at the point of egress.



FRONT VIEW



SIDE VIEW

FIGURE 17
005667PC

Electric Gas Shut-Off Valve

A gas shut-off valve is required on all systems used to protect a gas fueled appliance to stop gas flow in the event of system actuation. A UL Listed electric gas valve can be used with either the Model MCH3, NMCH3 or ECH3 control head. The valves are rated for natural and LP gas. Valves are available in 120 VAC. Electric gas valves are available in the following sizes:

Model No.	Valve Size	Maximum Operating Pressure
EGVSO-75	3/4 in.	50 psi (3.4 bar)
EGVSO-100	1 in.	25 psi (1.7 bar)
EGVSO-125	1-1/4 in.	25 psi (1.7 bar)
EGVSO-150	1-1/2 in.	25 psi (1.7 bar)
EGVSO-200	2 in.	25 psi (1.7 bar)
EGVSO-250	2-1/2 in.	25 psi (1.7 bar)
EGVSO-300	3 in.	25 psi (1.7 bar)

Note: A UL Listed manual reset relay is required when using an electric gas valve. The ANSUL Model SM-120 solenoid monitor may be used for this purpose.




FIGURE 18
005646PC

Components

DETECTION EQUIPMENT (Continued)

Model FLK-1A

The Model FLK-1A fusible link kit includes an 8 in. (20.3 cm) steel bracket, two (2) 1/2 in. EMT connectors, two (2) cable crimps, and two (2) "S" hooks. Fusible links must be ordered separately.

Model FLH-1

The Model FLH-1 fusible link hanger is an accessory designed to simplify the installation of fusible links in the fusible link line. It can be used with the Model FLK-1/1A fusible link kits (kits must be ordered separately). The Fusible Link Hanger makes it possible to install fusible links without cutting and crimping loops in the fusible link line for each link. They are available in packages of 25 (FLH-25) only. See Figure 13.




FIGURE 13
002630PC

Fusible Links

The fusible link is designed to separate at a specific temperature, releasing tension from the fusible link line, causing system actuation. See Figure 14.




FIGURE 14
002651PC

After determining the maximum ambient temperature at the fusible link location, select the correct fusible link according to the temperature condition chart below:

Fusible Link Model No.	Maximum Ambient Temperature
FL-165	100 °F (38 °C)
FL-212	150 °F (66 °C)
FL-280	225 °F (107 °C)
FL-360	290 °F (143 °C)
FL-450	360 °F (182 °C)
FL-500	400 °F (204 °C)

Thermal Detectors

Rate compensated temperature thermal detectors are normally open, mechanical contact closure switches designed to operate at a factory preset temperature. They are available in six preset temperatures which meet NFPA standards and are UL Listed and FM Approved.




FIGURE 15
007254

After determining the maximum ambient temperature at the thermal detector location, select the correct thermal detector according to the temperature condition chart below:

Thermal Detector Model No.	Maximum Ambient Temperature
TD-140	100 °F (38 °C)
TD-190	150 °F (66 °C)
TD-225	185 °F (85 °C)
TD-325	285 °F (141 °C)
TD-450	410 °F (210 °C)
TD-600	560 °F (293 °C)

SECTION II

UL EX 1727 Page 2-4
7-1-07

Components

MODEL PDA-D2 PNEUMATIC ACTUATING ADAPTOR

The Model PDA-D2 Pneumatic Actuating Adaptor is used to open the tank valve when the system is actuated. It must be installed on the valve of each tank unless a control head has been mounted on the tank valve. See Figure 9.




FIGURE 9
002827PC

PNEUMATIC ACTUATING TANKS

Model PAC-10

The Model PAC-10 is a pneumatic actuating tank that can actuate a maximum of ten (10) agent tanks simultaneously. The Model PAC-10 includes a DOT 4BA350 tank pressurized with dry nitrogen to 350 psi (24.1 bar) @ 70 °F (21.1 °C), a brass valve with pressure gauge, and a wall mounting bracket. A Model MCH3, NMCH3 or ECH3 control head must be purchased separately and connected to the PAC-10 to open the valve. See Figure 10.




FIGURE 10
002847PC

Model PAC-200

The Model PAC-200 is a pneumatic actuating tank that can actuate a maximum of twenty (20) agent tanks simultaneously. The Model PAC-200 includes a DOT 4BA350 tank pressurized with dry nitrogen to 350 psi (24.1 bar) @ 70 °F (21.1 °C), a brass valve with pressure gauge, and a wall mounting bracket. A Model MCH3, NMCH3 or ECH3 control head must be purchased separately and connected to the PAC-200 to open the valve. See Figure 11.




FIGURE 11
002848PC

DETECTION EQUIPMENT

Model FLK-1

The Model FLK-1 fusible link kit includes a 10 in. (25.4 cm) steel bracket, two (2) 1/2 in. EMT connectors, two (2) cable crimps, and two (2) "S" hooks. Fusible links must be ordered separately. See Figure 12.




FIGURE 12
002849PC

Components

MODEL MCH3 – MECHANICAL CONTROL HEAD

The Model MCH3 mechanical control head is a fully mechanical control head which can be connected to the A-15/17/25/35/50/70 tank valve. This control head will support a fusible link detection system, a remote mechanical pull station (Model RPS-M), and an electric gas shut-off valve. A micro switch (Model MS-SPDT, MS-DPDT, MS-3PDT, or MS-4PDT) can be ordered separately and field installed. It is equipped with a local manual control handle that allows for mechanical system actuation. Operation of the local manual control requires removing the pull pin and rotating the handle clockwise. The Model MCH3 control head can actuate a maximum of five (5) tanks. See Figure 5.




FIGURE 5
004760PC

MODEL ECH3 – ELECTRIC CONTROL HEAD

The Model ECH3 electric control head is an electrically operated control head which can be connected to the A-15/17/25/35/50/70 tank valve. This control head will support an electric thermal detection system, a remote mechanical pull station (Model RPS-M), and an electric gas shut-off valve. It will not support a fusible link detection system. A micro switch (Model MS-DPDT) is included. The Model ECH3 control head is available in both 120 VAC (Model ECH3-120) and 24 VDC (Model ECH3-24). It is equipped with a local manual control handle that allows for mechanical system actuation. Operation of the local manual control requires removing the pull pin and rotating the handle clockwise. The Model ECH3 control head can actuate a maximum of five (5) tanks. See Figure 6.




FIGURE 6
004760PC

MODEL NMCH3 – MECHANICAL CONTROL HEAD

The Model NMCH3 Mechanical Control Head is a fully mechanical control head which can be connected to the A-15/17/25/35/50/70 tank valve. This control head will support a fusible link detection system, a remote mechanical pull station (Model RPS-M), and an electric shut-off valve. A micro switch (Model MS-SPDT, MS-DPDT, MS-3PDT, or MS-4PDT) can be ordered separately and field installed. There is no local manual actuation for the Model NMCH3. The Model NMCH3 control head can actuate a maximum of five (5) tanks. See Figure 7.




FIGURE 7
003845PC

MODEL MB-P2 – CONTROL HEAD MOUNTING BRACKET

The Model MB-P2 mounting bracket must be used to mount the Model MCH3, NMCH3 or ECH3 control head if the control head is not mounted directly on a tank valve. See Figure 8.





FIGURE 8
003846PC



SECTION II

UL EX 1727 Page 2-2
7-1-07

Components

TANKS AND VALVE (Continued)

A-50ABC: This system is charged with 50 lb (22.7 kg) of monoammonium phosphate based dry chemical, ANSUL Part No. 435245. It is Listed for use in local overhead and local tankside applications. It is rated to protect Class "A," "B," and "C" hazards.

A-70ABC: This system is charged with 70 lb (31.8 kg) of monoammonium phosphate based dry chemical, ANSUL Part No. 435245. It is Listed for use in total flooding applications. It is rated to protect Class "A," "B," and "C" hazards.

The dimensions of the A-15/17/25/35/50/70 tank and valve assemblies are shown in Figure 1. The tank is manufactured, tested, and marked in accordance with DOT specification 4BW350.

The valve shown in Figure 2 is a pressure sealed, poppet type valve. It is used on the A-15/17/25/35/50/70, PAC-10, and PAC-200 tanks. The valve discharge port is 3/4 in. NPT.

NOZZLES

Nozzles have been developed for total flooding, local application overhead, and local application tankside. The Model NF-ABC nozzle is used for total flooding protection. The Model N-SCR nozzle is used for screening the opening. The Model N-OTF nozzle is used for overhead total flooding application in the work area. The Model N-PLU nozzle is used for overhead application in the plenum area. The Model N-DCT nozzle is used for exhaust duct protection. The Models N-LA-ABC and N-LA-BC nozzles are used for local overhead application. The Model N-TS nozzle is used for local tankside application. See Figure 3.




FIGURE 3

TANK BRACKETING

Vertical wall mounting for the A-15ABC, A-17ABC, and A-25BC/ABC, is provided by the Model MB-15 mounting bracket kit. Vertical wall mounting for the A-35ABC, A-50BC/ABC and A-70ABC is provided by the Model MB-1 mounting bracket kit. See Figure 4.

For vertical floor mounting of the A-15ABC, A-17ABC, A-25BC and A-25ABC, an 8 in. (20.3 cm) unistrut type mounting bracket is available, the Model MB-U8.

For vertical floor mounting of the A-35ABC, A-50BC, and A-50ABC, a 10 in. (25.4 cm) unistrut type mounting bracket is available, the Model MB-U10.

For vertical floor mounting of the A-70ABC, a 12 in. (30.5 cm) unistrut type mounting bracket is available, the Model MB-U12.




FIGURE 4
0020843PC

General Purpose: Total Flooding/Local Application

Components

TANKS AND VALVE

ANSUL® automatic dry chemical systems are supplied in 17 lb (7.7 kg), 25 lb (11.3 kg), 35 lb (15.9 kg), 50 lb (22.7 kg), and 70 lb (31.8 kg) capacity tanks. They are the Models A-15ABC, A-17ABC, A-25BC, A-25ABC, A-35ABC, A-50BC, A-50ABC, and A-70ABC. Each tank must be separately piped to its own nozzles. All models are charged with dry nitrogen to 350 psi (24.1 bar) @ 70 °F (21.1 °C). These systems are for indoor hazard protection only. The particular models are as follows:

A-15ABC: This system is charged with 12.5 lb (5.7 kg) of monoammonium phosphate-based dry chemical, ANSUL Part No. 435245. It is Listed for use in total flooding applications. It is rated to protect Class "A," "B," and "C" hazards.

A-17ABC: This system is charged with 17 lb (7.7 kg) of monoammonium phosphate based dry chemical, ANSUL Part No. 435245. It is Listed for use in total flooding applications. It is rated to protect Class "A," "B," and "C" hazards.


A-25BC: This system is charged with 25 lb (11.3 kg) of regular sodium bicarbonate based dry chemical, ANSUL Part No. 435245. It is Listed for use in local overhead and local tankside applications. It is rated to protect only Class "B" and "C" hazards.

A-25ABC: This system is charged with 25 lb (11.3 kg) of monoammonium phosphate based dry chemical, ANSUL Part No. 435245. It is Listed for use in local overhead and local tankside applications. It is rated to protect Class "A," "B," and "C" hazards.

PCI-35ABC: This system is charged with 35 lb (15.9 kg) of monoammonium phosphate based dry chemical, ANSUL Part No. 435245. It is Listed for use in total flooding applications. It is rated to protect Class "A," "B," and "C" hazards.

A-50BC: This system is charged with 50 lb (22.7 kg) of regular sodium bicarbonate based dry chemical, ANSUL Part No. 435245. It is Listed for use in local overhead and local tankside applications. It is rated to protect only Class "B" and "C" hazards.


TANK AND VALVE ASSEMBLIES



MODEL NO.	A IN (cm)	B IN (cm)	C IN (cm)	D IN (kg)	LB (kg) WEIGHT	MOUNTING BRACKET USED
A-15ABC	6.00 (15.24)	21.44 (54.46)	27.19 (69.06)	18.69 (47.47)	30 (13.6)	MB-15
A-17ABC	8.00 (20.3)	24.81 (63.01)	30.56 (77.62)	22.06 (56.03)	50 (22.7)	MB-15
A-25ABC/BC	8.00 (20.3)	24.81 (63.01)	30.56 (77.62)	22.06 (56.03)	58 (26.3)	MB-15
A-35ABC	10.00 (25.4)	29.94 (76.05)	35.69 (90.65)	27.18 (69.04)	71 (32.2)	MB-1
A-50ABC/BC	10.00 (25.4)	29.94 (76.05)	35.69 (90.65)	27.18 (69.04)	86 (39.0)	MB-2
A-70ABC	12.00 (30.5)	35.31 (89.69)	41.06 (104.29)	32.56 (82.70)	130 (59.0)	MB-1

FIGURE 1
002841A1

VALVE CROSS SECTION



ITEM	PART NO.	DESCRIPTION
1	---	VALVE BODY
2	---	VALVE STEM & CAP ASSEMBLY
3	550022	CONICAL SPRING
4	550261	RETAINING WASHER
5	550024	E-RING
6	550025	PRESSURE GAUGE
7	550026	HIGH TEMPERATURE RELIEF PLUG
8	550029	VALVE BODY O-RING
9	550805	PISTON
10	550636	PISTON O-RING

FIGURE 2
002842PC



SECTION I

UL EX 1727 Page 1-1
7-1-07

General Purpose: Total Flooding/Local Application

General Information

INTRODUCTION

ANSUL® automatic dry chemical fire suppression systems are of the pre-engineered type as defined by the NFPA Standard for Dry Chemical Extinguishing Systems, NFPA-17. The extinguishing units described in this manual are intended to be installed, inspected, and maintained in accordance with NFPA-17. Limitations detailed in this manual have been established through extensive testing by Underwriters Laboratories, Inc. Installation and maintenance of the system must conform to the limitations detailed in this manual and be performed by an Authorized ANSUL dealer.

The ANSUL Industrial Fire Suppression System utilizes a either a sodium bicarbonate based dry chemical agent (specifically designed to suppress liquid, gas or electrical fires) or a monoammonium phosphate based dry chemical agent (specifically designed to suppress carbonaceous solid, liquid, gas or electrical fires). The system provides mechanical or electrical automatic actuation and can be manually actuated through a remote mechanical pull station. Upon actuation, the system discharges a pre-determined amount of agent to the hazard area.

The shutdown of fuel and power to the hazard area is required upon system actuation. Exhaust fan(s) in the ventilation system must be shut off during system discharge to allow the proper concentration of agent to build up in the hazard area.

TEMPERATURE LIMITATIONS

The operating temperature ranges of the ANSUL System are:

Monoammonium Phosphate (ABC) Total Flooding Systems: -20 °F (-28 °C) minimum to 120 °F (49 °C) maximum.

Local Application – Overhead Systems: 32 °F (0 °C) minimum to 120 °F (49 °C) maximum.

Local Application – Tankside Systems: -20 °F (-28 °C) minimum to 120 °F (49 °C) maximum.

UL LISTING

The ANSUL Industrial Fire Suppression System has been tested to the UL Standard for Pre-Engineered Dry Chemical Extinguishing System Units, UL1254 (Revised Sept. 29, 1998), and Listed by Underwriters Laboratories, Inc.

SECTION IV

UL EX 1727 Page 4-4
7-1-07

Installation

FUSIBLE LINK DETECTOR INSTALLATION

Fusible links are always used in conjunction with the Model MCH3 Mechanical Control Head. After mounting the tank and control head, the fusible link line can be installed. The first step to installing the fusible link line is to install the detector bracket(s). These brackets must be installed in the plenum area, hazard area, and in each duct. See Chapter III for detector placement guidelines.

Note: Only ML-style Fusible Links can be used.

Fusible Link Installation Without Hangers

Begin installing links at the terminal bracket. The link is connected to the far side of the terminal bracket using an "S" hook. The "S" hook must be crimped closed after the link is installed. A tight loop is then made in the cable and secured by the crimp provided. This loop is connected to the other side of the terminal link (see Figure 7) and the cable fed through the conduit to the next bracket. The cable

Installation

FUSIBLE LINK DETECTOR INSTALLATION (Continued)

Fusible Link Installation Without Hangers (Continued)

The fusible link line can now be put into a set position by applying tension to the fusible link line. This is accomplished by using a 1/2 in. hex wrench on the fusible link line ratchet wheel. The ratchet wheel will be ratcheted in a clockwise direction until the spring plate makes contact with the top of the control head box. The fusible link line is now in a set position. See Figure 9.




FIGURE 9
 002876PC

Fusible Link Installation Using Model FLH-1 Fusible Link Hangers

Beginning at the control head, feed the stainless steel cable through the conduit and brackets to the terminal bracket in one continuous length. Allow approximately 2.5 in. (6.4 cm) of slack at each bracket for the installation of the Fusible Link Hangers. At the terminal link, a tight loop is made in the cable and secured by the crimp provided. The cable is attached to the far side of the terminal bracket using an "S" hook. The "S" hook must be crimped closed after the cable is installed. See Figure 10.




FIGURE 10
 002877PC

Begin installing the Fusible Link Hangers at the terminal bracket and work toward the control head. Loop the cable through the oval opening in the hanger and hook the fusible link on the loop. See Figure 11.

Note: Only ML-style Fusible Links can be used




FIGURE 11
 002878PC

Hook the bottom of the link onto the bottom leg of the hanger. See Figure 12.




FIGURE 12
 002879PC

Center the hanger/link in the fusible link bracket by sliding it along the link line. This is easily accomplished before any tension is applied to the link line. Repeat this procedure for all fusible links.

After the last hanger/link in the series is connected, the cable should be fed through the hole in the fusible link ratchet wheel. The line must then be crimped, and the crimp positioned inside the center of the ratchet wheel.

NOTE

Crimps must always be used in conjunction with two (2) cable lengths. Loops are the accepted method of connecting the cable to mechanical components. The crimp must never be used on a single cable. Exception: Single cable crimp allowed in detection and gas valve ratchet wheel using stop sleeve, Part No. 26317 (packages of 10: Part No. 24919).

SECTION IV

UL EX 1727 Page 4-6
7-1-07

Installation

FUSIBLE LINK DETECTOR INSTALLATION (Continued)

Fusible Link Installation Using Model FLH-1 Fusible Link Hangers (Continued)

The fusible link line can now be put into a set position by applying tension to the fusible link line. This is accomplished by using a 1/2 in. hex wrench on the fusible link line ratchet wheel. The ratchet wheel will be ratcheted in a clockwise direction until the spring plate makes contact with the top of the control head box. The fusible link line is now in a set position. See Figure 9. Check to ensure that the fusible link hanger(s) remain centered in the bracket after the fusible link line is set. See Figure 13.

THERMAL DETECTOR INSTALLATION

Thermal detectors are always used in conjunction with the Model ECH3 Electrical Control Head. After mounting the tank and control head, the thermal detector(s) can be installed. See Section III for detector placement guidelines. Follow the instructions included with the detector for proper detector mounting procedures.




FIGURE 13
002850PC

SETTING THE CONTROL HEAD

Model MCH3/NMCH3 Mechanical Control Head

Once the fusible link line is set, the control head can be placed in the set position. To set the control head, the slide plate is moved from right to left, ensuring the bolt extending from the cam arm is in the slot provided in the slide plate. Continue moving the slide plate to the left until the latching arm is in the locked position. Insert the pull pin into the hole in the slide plate above the latching arm. This will lock the control head in the set position, eliminating accidental actuation during the rest of the installation procedure. See Figure 14.




FIGURE 14
002850PC

Model ECH3 Electrical Control Head

Once the thermal detectors have been installed, the control head can be placed in the set position. To set the control head, the slide plate is moved from right to left, ensuring the bolt extending from the cam arm is in the slot provided in the slide plate. Continue moving the slide plate to the left until the latching arm is in the locked position. Insert the pull pin into the hole in the slide plate above the latching arm. This will lock the control head in the set position, eliminating accidental actuation during the rest of the installation procedure.

Once the Model ECH Electrical Control Head is in the set position, it can be connected to the detection/actuation circuit.

NOTE

No electrical connections shall be made inside the control head. All electrical wiring shall exit the control head through the knock-out on the side of the box. All electrical connections must be made in an approved electrical box.

Connect one of the black wires on the solenoid in the control head to the red wire of the Model MS-SPDT Micro Switch. The brown wire from the micro switch is then connected to one side of the first thermal detector in series. Connect the other side of the first thermal detector in series and the remaining black wire on the solenoid in the control head to the appropriate power source after installing the Model SM-24/20 Solenoid Monitor.

CAUTION

The solenoid must never be wired "hot" (not through the micro-switch). If wired this way, the non-field replaceable solenoid will be damaged and the complete control head will require replacement.

Installation

SETTING THE CONTROL HEAD (Continued)

Model ECH3 Electrical Control Head (Continued)

NOTE

A Solenoid Monitor 120/24 must always be used with an Electrical Control Head to supervise the actuation/detection circuit.

The Model ECH3-24 Electrical Control Head requires a UL Listed 24VDC power supply with a minimum 2A rating. The Model ECH3-120 Electrical Control Head requires a 1A, 120VAC power supply.

SOLENOID MONITOR INSTALLATION

Solenoid Monitor Installation In Detection Circuit

After installing the thermal detectors and the control head, the Solenoid Monitor 120/24 can be installed. The Solenoid Monitor is connected to the wires leading from the last thermal detector. It should be mounted in a location where it can be readily observed.

The Solenoid Monitor is an end-of-line device that supervises the actuation/detection circuit. It is comprised of a push-type switch with a built-in indicator light, a plug-type relay, a relay socket, and a cover plate. The light, when illuminated, indicates that the detection/actuation circuit is in the normal condition. The Solenoid Monitor also provides two sets of dry contacts. The Solenoid Monitor's cover plate is used to mount the Solenoid Monitor in a standard 6 in. x 4 in. x 3 in. deep electrical box (See Figure 15).




FIGURE 15
032651A1

All wire for circuits using the Solenoid Monitor 24 shall be 18 gauge minimum, or as required by local code. All wire for circuits using the Solenoid Monitor 120 shall be 14 gauge minimum, or as required by local code. The basic wiring diagram for both Solenoid Monitors is shown in Figure 16.




FIGURE 16
032652PC

After the Solenoid Monitor has been installed, the detection/actuation circuit can be connected to the appropriate power source and energized. To energize the detector/actuation circuit, depress the switch on the Solenoid Monitor. The light will illuminate to indicate that the circuit is properly installed. If the light fails to illuminate, the wiring must be checked.

Solenoid Monitor When Used As A Reset Relay

The Model SM-24/120 can be used as a reset relay when required. A reset relay is required whenever an electrical gas shut-off valve is used in conjunction with the ANSUL Booth Industrial Fire Suppression System. For typical wiring connections, see Figure 17.




FIGURE 17
032653PC

SECTION IV

UL EX 1727 Page 4-8
7-1-07

Installation

REMOTE PULL STATION INSTALLATION

Model RPS-M

The Model RPS-M Remote Mechanical Pull Station is used for remote mechanical actuation of the Model MCH3/ECH3/NMCH3 Control Head. It is to be located near an exit in the path of egress from the hazard area no more than 4 ft (1.2 m) above the floor.

NOTE

A Model RPS-M Remote Mechanical Pull Station must be used for manual actuation of a Model NMCH3 Releasing Device.

The Pull Station can be surface mounted or recessed. It is connected to the control head using 1/16 in. diameter stainless steel cable. The cable enters the pull station box from the bottom, top, either side, or back. The cable enters the control head through the top-center knockout. The cable must be enclosed in 1/2 in. conduit with an ANSUL corner pulley at each change in conduit direction. Maximum limitations for the Model RPS-M Remote Mechanical Pull Station are as follows:

Model RPS-M Cable Run Limitations When Used With Model MCH3, ECH3, and NMCH3 Control Heads and Part No. 415670 and 423250 Pulley Elbows

Maximum length of cable: 150 ft (45.7 m)

Maximum # of pulleys: 40

After mounting the pull station box and conduit, feed the stainless steel cable from the control head, through the conduit, and into the pull station box. Insert the bushing into the pull station's cover plate and secure it with the locknut provided. Feed the cable through the bushing and into the pull handle ensuring that the cable fully crosses the set screw hole. Fasten the cable to the pull handle with the set screw (see Figure 18).




FIGURE 18
002684PC

NOTE

Crimps must always be used in conjunction with two (2) cable lengths. Loops are the accepted method of connecting the cable to mechanical components. The crimp must never be used on a single cable. Exception: Single cable crimp allowed in detection and gas valve ratchet wheel using stop sleeve, Part No. 26317 (packages of 10; Part No. 24919).

Cut and thread the cable through the hole in the latching arm of the control head and pull the cable tight. Crimp the cable 6 in. (15.2 cm) below the latching arm.

Pull the pull handle until the crimp touches the latching arm. Coil the excess cable in the pull box and attach the cover plate with the four screws provided. Insert the pull handle into the cover plate and insert the pull pin through the bushing and the pull handle. Secure the pull pin with the nylon tie provided. See Figure 19.




FIGURE 19

002685PC/003047PC

Installation

REMOTE PULL STATION INSTALLATION (Continued)

Model RPS-E2

The Model RPS-E2 remote electrical pull station is used for remote actuation of the Model ECH3 Control Head. It is to be located near an exit in the path of egress from the hazard area no more than 4 ft (1.2 m) above the floor. The Model RPS-E2 is installed in the detection/actuation circuit and wired in accordance with the instructions included. See Figure 16 for typical circuit wiring.

ELECTRICAL GAS SHUT-OFF VALVE INSTALLATION

The Model MCH3/ECH3/NMCH3 Control Head is used to operate the electrical gas shut-off valve. This valve is located in the fuel gas supply line. The valve body has an arrow which indicates direction of gas flow through the valve. A reset relay must always be used with an electrical gas shut-off valve. For proper wiring of the electrical gas shut-off valve, see Figure 17.

TEE PULLEY INSTALLATION

The Model TP-1 Tee Pulley is used to connect two (2) remote mechanical pull stations to a single control head. The cable proceeding from the control head must always enter the branch of the tee pulley. See Figure 20.




FIGURE 20
002040PC

MICRO SWITCH INSTALLATION

See NFPA 72, "National Fire Alarm Code," Initiating Devices section, for the correct method of wiring connection to the fire alarm panel.

The Model MS-SPDT, MS-DPDT, MS-3PDT, or MS-4PDT Micro Switch is available for use where an electrical output is required. These switches can be field installed in the control head. See Figure 21 and Figure 22 and refer to Instruction Sheet, Part No. 551159, included with switch shipping assembly, for detailed mounting instructions.




FIGURE 21
002039PC




FIGURE 22
003047PC

NOTE

The Model ECH3 Control Head is supplied with a Model MS-DPDT Micro Switch. This switch can be used in the actuation/detection circuit and for electrical output.

SECTION IV

UL EX 1727 Page 4-10
7-1-07

Installation

MICRO SWITCH INSTALLATION (Continued)

These switches may be used to provide an electrical signal to the main breaker and/or operate electrical accessories provided the rating of the switch is not exceeded. Wiring connections are shown in Figure 23. The contact ratings for the switches are as follows:

Contact Ratings For Micro Switches

21 amps, 1 HP, 125, 250, 277 VAC or 2 HP, 250, 277 VAC







FIGURE 23
002963PC

The Alarm Initiating Switch, Part No. 550077, must be used to close a supervised alarm circuit to the building main fire alarm panel when the control head actuates. This will signal the fire alarm panel that there was a system actuation in the hazard area. This switch can be field installed in the control head. Refer to Instruction Sheet, Part No. 550081, included with the switch shipping assembly, for detailed mounting instructions. Wiring connections are shown in Figure 24. The switch is rated at 50mA, 28VDC.



INCORRECT



CORRECT - SEPARATE INCOMING AND OUTGOING CONDUCTORS

FIGURE 24
004601/004605

PIPE AND NOZZLE INSTALLATION

General Piping Requirements

1. Use Schedule 40 black iron (if used in a relatively non-corrosive atmosphere), galvanized, chrome-plated, or stainless steel pipe conforming to ASTM A120, A53, or A106. Fittings must be a minimum of 150 lb Class. However, the A 35, 50, and 70 lb tanks must have a minimum of two (2) nozzles per tank to utilize the 150 lb Class fittings. If the A 35, 50, or 70 lb tank has one (1) nozzle, then a 300 lb Class fitting must be used. The remaining Monarch tanks have no limitations for the 150 lb Class fittings. Distribution pipe sizes are 3/4 in. or 1 in. depending on number of nozzles.
2. Pipe unions are acceptable.
3. Use reducing tees for all pipe splits.
4. Reducing bushings are not acceptable.
5. Cast iron pipe and fittings are not acceptable.
6. Pipe thread sealant or pipe joint compound is not allowed for distribution piping.
7. Bell Reducer or any non-restrictive fittings are allowed.
8. Before assembling the pipe and fittings, make certain all ends are carefully reamed and blown clear of chips and scale. Inside of pipe and fittings must be free of oil and dirt.
9. If Teflon tape is used on threaded ends, start at the second male thread and wrap the tape clockwise around the threads, away from the pipe opening.
10. All system piping must comply with Section A-5-9.1 of NFPA-17.





FIGURE 25
002963PC

Installation

PIPE AND NOZZLE INSTALLATION (Continued) General Piping Requirements (Continued)



TEE POSITIONING

In order to obtain equal distribution at a tee, the dry chemical must enter the side port of the tee and exit through the two end ports. See Figure 26.




FIGURE 26
003122

Hanger/Support Installation

The hanger/supports must be installed in conjunction with the pipe and fittings. The spacing requirements for hangers/supports depend on the pipe size being utilized; refer to the Spacing Guidelines Chart.

PIPE HANGER SPACING GUIDELINES CHART

Distribution Pipe Size	Maximum Spacing Distance Hanger to Hanger	
in.	ft	m
1/4	4	(1.2)
1/2	6	(1.8)
3/4	8	(2.4)
1	12	(3.6)

Other factors that influence hanger/support spacing are:

Hanger/Support must be placed within 1 ft (0.3 m) of the discharge nozzle.

Hanger/Support must be placed between elbows when distance is greater than 2 ft (0.6 m).




FIGURE 27

MAIN/RESERVE SYSTEM

When a reserve system is being utilized, two 1 in. swing check valves, Part No. 417788, must be installed in the distribution piping network. They should be positioned as close as possible to the "Y" fitting joining the piping from the main and reserve tanks to one common supply pipe. See Figure 28. **Note:** Make certain to install swing check valves in the direction of dry chemical flow as shown with an arrow stamped on the valve body.




FIGURE 28
003480

SECTION IV

UL EX 1727 Page 4-12

7-1-07

Installation

PRESSURE SWITCH INSTALLATION

The Model PS-SPDT-X Pressure Switch is available for use when an electrical output is required. It must be installed in the discharge piping within 12 in. (30.5 cm) of the valve discharge port as shown in Figure 29. An inline tee is used for the installation. The switch is isolated from the chemical by a 12 in. to 15 in. (30.5 to 38.1 cm) column of air in the form of a vertical pipe nipple. The switch is then mounted at the top of this nipple.

NOTE

Piping for pressure switch must be included in total tank to T1 piping limitations. The fitting used to connect the pressure switch to the distribution piping counts as one (1) elbow in that section.

As an alternate, the switch may be connected directly to the copper tubing of a remotely mounted control head or a PAC tank. The PS-SPDT-X counts as one tank in this section, and the limitations on copper tubing and/or pipe previously stated in this manual apply.




FIGURE 29
00J2SPC

SYSTEM CHECKOUT AFTER INSTALLATION

Model MCH3 Mechanical Control Head

Before putting the system into service, all components must be checked for proper operation. During this checkout, assure that the carbon dioxide pilot cartridge is not installed in the control head actuator. Remove the pull pin from the hole in the slide plate.

To check satisfactory operation of the control head, cut the terminal link or the "S" hook holding the link. This will relieve all tension on the fusible link line and operate the control head. The slide plate will move fully to the right. The gas valve cable will be released, causing the gas valve to close. Any auxiliary equipment connected to the dry contacts of the solenoid monitor and/or the Micro Switch in the control head will operate.

If any of these events fail to occur, the problem must be investigated and repaired.

Repair the terminal link and put the fusible link line back into the set position. This is accomplished by using a 1/2 in. hex wrench on the fusible link line ratchet wheel. The ratchet wheel will be ratcheted in a clockwise direction until the spring plate makes contact with the top of the control head box.

Once the fusible link line is set, the control head can be placed in the set position. To set the control head, the slide plate is moved from right to left, ensuring the bolt extending from the cam arm is in the slot provided in the slide plate. Continue moving the slide plate to the left until the latching arm is in the locked position.

Once the control head is set, pull the pull handle on the remote pull station to assure that the control head operates. If the control head operates normally, the control head can be reset as described above. Insert the pull pin into the hole in the slide plate above the latching arm. Replace the pull station handle, pull pin, and nylon tie.

Using a felt-tipped marker, write the date of installation on the carbon dioxide pilot cartridge. Screw the cartridge into the control head actuator until hand-tight. Never use a wrench to tighten the cartridge into the actuator.


Remove the pull pin from the hole in the slide plate and install the control head cover. Insert the pull pin through the local manual control handle and into the bushing. Secure the pull pin with the nylon tie provided.

Installation

SYSTEM CHECKOUT AFTER INSTALLATION (Continued)

Model ECH3-24/120 Electrical Control Head

Before putting the system into service, all components must be checked for proper operation. During this checkout, assure that the CO₂ pilot cartridge is not installed in the control head actuator. Remove the pull pin from the hole in the slide plate.



TESTING THERMAL DETECTORS

1. Remove the electric control head cover.
2. Test each detector individually and recock release mechanism after each test.
3. Using a heat gun positioned approximately 12 in. (30.5 cm) from the detector, apply heat to the detector for about one minute. Overheating will cause damage to the detector. Applying heat to the detector will cause the control head to operate. When the control head operates, the following will take place: a) The slide plate will move fully to the right; b) The indicator light on the solenoid monitor will go out; and c) Any auxiliary equipment connected to the dry contacts of the solenoid monitor and/or the micro switch in the control head will operate. If any of these events fail to occur, the problem must be investigated and repaired.
4. After all the thermal detectors have cooled, the control head can be placed in the set position. To set the control head, the slide plate must be moved from right to left, ensuring the bolt extending from the cam arm is in the slot provided in the slide plate. Continue moving the slide plate to the left until the latching arm is in the locked position.

TESTING REMOTE PULL STATION

1. Once the control head is set, pull the pull handle on the remote pull station to assure that the control head operates. If the control head operates normally, the control head can be reset as described in Step 4 above.
2. Insert the pull pin into the hole in the slide plate above the latching arm.
3. Replace the pull station handle, pull pin, and break rod.

COMPLETING SYSTEM CHECKOUT

1. Energize the actuation/detection circuit by depressing the push button on the solenoid monitor.
2. Using a felt-tipped marker, write the date of installation on the CO₂ pilot cartridge. Ensure that the actuator has an O-ring installed, and screw the cartridge into the control head actuator until hand tight. **Never use a wrench to tighten the cartridge into the actuator.**
3. Remove the pull pin from the hole in the slide plate and install the control head cover. Insert the pull pin through the local manual control handle and into the bushing. Secure the pull pin with the tie provided.

NOTE

Refer to NFPA-17 for additional inspection requirements.

SECTION IV

UL EX 1727 Page 4-14
7-1-07

Installation

NOTES:

General Purpose: Total Flooding/Local Application
Recharge/Maintenance
GENERAL

This chapter will detail the basic information necessary for proper maintenance of the ANSUL® Industrial Fire Suppression System. However, before attempting any system maintenance, it is necessary to attend a Factory Certification Training Class and become Certified to install and maintain the ANSUL Industrial Fire Suppression System.

MAINTENANCE AFTER SYSTEM DISCHARGE
System Cleanup

The hazard area cleanup after a system discharge is very basic. The dry chemical agent should be cleaned up by either sweeping or vacuuming. Residual dry chemical should be wiped off effected surfaces with a damp cloth.

System Tank Recharge


1. Remove the tank from the control head or pneumatic adaptors and inspect for visual damage. If there is any damage the tank must be hydrostatically tested before being refilled. If there is no damage, the tank can be recharged.
2. Reset all pneumatic actuators (Models PDA-D2) by depressing the check valve on top and relieving the pressure. Remove the pneumatic actuator or control head from the valve and use any 1/4-20 UN screw or bolt to screw into the top of the piston. Pull up on the piston until the piston is flush with the top of the valve body and remove the screw or bolt from the piston.
3. Remove the valve and siphon tube assembly from the tank and unscrew the siphon tube from the valve.
4. Inspect the valve to make sure no mechanical damage has occurred. If there is evidence of any damage to the seals, rebuild the valve using the Dry Valve Rebuilding Kit (ANSUL Part Number 550037).
5. Screw the siphon tube back into the valve.

6. Refill the tank with agent. Use the table below for easy reference.

Tank	Recharge
A-15ABC	12.5 lb ABC
A-17ABC	17 lb ABC
A-25BC	25 lb BC
A-25ABC	25 lb ABC
A-35ABC	35 lb ABC
A-50BC	50 lb BC
A-50ABC	50 lb ABC
A-70ABC	70 lb ABC


The Model RC-50ABC (Part No. 435245) is a 50 lb pail of ABC dry chemical recharge agent available from ANSUL. The Model RC-50BC (Part No. 435247) is a 50 lb pail of BC dry chemical recharge agent available from ANSUL.

7. Insert the siphon tube into the tank, and screw the valve onto the tank. Make sure that the valve is screwed completely into the tank.
8. Attach the Recharge Adaptor (ANSUL Part No. 550130) to the discharge port of the valve. The adaptor O-ring should be completely inside the discharge port. Attach a source of dry nitrogen to the adaptor.

Charge the tank with dry nitrogen to 350 psi at 70 °F.

NOTE

1. The pressure gauge attached to the tank valve should not be used to determine when the charging pressure has been reached. A pressure regulator should be used.
2. Higher pressure may be needed during the initial charging stage to blow the agent out of the siphon tube. Secure the tank during this stage, as it may jump as the agent is blown from the siphon tube.
9. Slowly disconnect the nitrogen source from the Recharge Adaptor. The tank valve will close when the Recharge Adaptor is depressurized. When the valve is closed and the nitrogen source is disconnected from the Recharge Adaptor, remove the recharge adaptor from the valve discharge port. Immediately screw the recoil preventer into the discharge port.



SECTION V

UL EX 1727 Page 5-2

7-1-07

Recharge/Maintenance

MAINTENANCE AFTER SYSTEM DISCHARGE (Continued)

System Tank Recharge (Continued)

10. Reinstall the tank to the piping network. Reattach the control head or pneumatic adaptor.
11. Install new CO₂ cartridge in control head.

Piping and Nozzles

Piping should be blown out with air or dry nitrogen. Nozzle blow off caps should be replaced.

System Reset

All fusible links should be replaced. The fusible link line can now be put into a set position by applying tension to the fusible link line. This is accomplished by using a 1/2 in. hex wrench on the fusible link line ratchet wheel. The ratchet wheel will be ratcheted in a clockwise direction until the spring plate makes contact with the top of the control head box. The fusible link line is now in a set position.

After setting the fusible link line, the system can be put back into service by following the SYSTEM CHECKOUT AFTER INSTALLATION Section of Section IV.

REGULAR SYSTEM MAINTENANCE

Six (6) Month Maintenance

1. Check that the hazard has not changed.
2. Check that all nylon ties are in place and the system has not been tampered with.
3. Check the entire system for mechanical damage.
4. Check the solenoid monitor.
5. Disconnect the control head or pneumatic tubing from each agent tank. Remove the carbon dioxide pilot cartridge and exercise the control head to ensure it is functioning properly. Make sure the gas shut-off valve and the remote pull station are functioning properly.

NOTE

Before continuing, remove the cover from the control head and insert the pull pin in the hole in the slide plate above the latching arm. This will secure the system, preventing accidental discharge.

6. Inspect fusible link detectors for excessive buildup. Clean or replace links if necessary. Visually inspect thermal detectors.

NOTE

Methods and frequency of inspection, testing and maintenance of detectors should be in accordance with NFPA-72.

7. Reinstall the carbon dioxide pilot cartridge and replace the control head cover and nylon tie.



Before screwing the carbon dioxide pilot cartridge into the actuator, ensure that the actuator has an O-ring installed.

8. Inspect the tank pressure. Tap the gauge lightly to ensure the needle is moving freely. If the gauge shows a loss in pressure indicated by the needle being below the green band, the tank should be removed and recharged per the SYSTEM TANK RECHARGE section of Section V (System Maintenance) in this manual.

Annual Maintenance

1. Inspect as per six (6) month maintenance instructions.
2. Disconnect and remove the discharge piping from the system. Using air or nitrogen, blow out the discharge piping. Replace all nozzle caps.
3. Fixed temperature sensing elements of the fusible alloy type shall be replaced at least annually or more frequently, if necessary, to assure proper operation of the system.
4. Test thermal detectors and remote pull station per SYSTEM CHECKOUT AFTER INSTALLATION section located in Chapter IV (System Installation) of this manual. Per NFPA 72, two (2) or more detectors per circuit should be tested. Note individual detector location and date of testing. Within 5 years, all detectors in system must be tested.
5. Replace the carbon dioxide pilot cartridge, recording the date of installation on the cartridge with a felt-tipped marker.



Before screwing the carbon dioxide pilot cartridge into the actuator, ensure that the actuator has an O-ring installed.

Six (6) Year Maintenance

1. Inspect as per annual maintenance instructions.
2. Examine the dry chemical. If there is evidence of caking, the dry chemical shall be discarded.

Hydrostatic Testing

The dry chemical agent tank(s) and pneumatic tank(s) shall be hydrostatically tested at least every twelve (12) years as per NFPA-17.

NOTE

Refer to NFPA-17 for additional maintenance requirements.



Brick Township
401 Chambersbridge Rd
Brick, NJ 08723
(732) 262-1027

Subcode Official Review

To: 101 HOOPER AVE TOMS RIVER, NJ 08753 CC:

RE: Fire Subcode
Block: 702 Lot: 5 Qual:
301 CHAMBERS BRIDGE RD.
Permit Number: Control Number: C-10-002258
Last Submit Date: Friday, July 02, 2010

Date: Tuesday, July 06, 2010

Dear OCEAN COUNTY,
Your request is hereby denied based upon the following infractions.
Need spec. guide on system being installed.

Sincerely,

Ron Pizar, Subcode Official

*** FAX TX REPORT ***

TRANSMISSION OK

JOB NO. 2322
DESTINATION ADDRESS 97324772757
PSWD/SUBADDRESS
DESTINATION ID
ST. TIME 07/06 08:16
USAGE T 00' 19
PGS. 1
RESULT OK



Brick Township
401 Chambersbridge Rd
Brick, NJ 08723
(732) 262-1027

Subcode Official Review

TO: 101 HOOPER AVE TOMS RIVER, NJ 08753 CC:


RE: Fire Subcode

Block: 702 Lot: 6 Quat:
301 CHAMBERS BRIDGE RD
Permit Number: Control Number: C-10-002298
Last Submit Date: Friday, July 02, 2010

Date: Tuesday, July 06, 2010

Dear OCEAN COUNTY,
Your request is hereby denied based upon the following infractions.
Need spec. guide on system being installed.

Sincerely,


Ron Pizarra, Subcode Official

REQUIREMENTS

drawings cover the following models: AG4800FR4

Building is of Non-combustible construction. Building walls, sump, and doors are of all steel construction.

Building is capable of withstanding, as a minimum, a 120 MPH Exposure D load and a downward vertical snow load of 30 PSF, plus its own weight.

Door support system shall be capable of supporting a load of 35F under dry conditions.

4-tight sump, capable of containing at least 25 percent of liquid storage capacity of the building shall be provided.

ing designed for natural or mechanical ventilation at a rate of ft./min./sq. ft. of floor area. Vent quantity and location vary based on option placement.

Chemical storage building shall be grounded. The individual containers shall be grounded while dispensing. Consult codes for grounding building. 5/16" ground bolts and weld are supplied on building. Order Securl's Part Number OPD023 3 ground rod & clamp, 10-#6 copper cable & terminal.

BUILDING DESIGN NOTES:

Ground weld nuts & bolts conveniently located.

2-Exterior
15-Interior

Finish is a two-part chemical resistant aliphatic polyurethane.

WATERIAL SPECIFICATIONS

Material stating CRS OC shall conform to ASTM A366
Tensile strength = 42-58 ksi, Yield Strength = 28-44 ksi
Elongation % in 2" = 28-44, Rockwell B Hardness 38-60

Material stating HRS OC shall conform to ASTM A569
Tensile strength = 45-60 ksi, Yield strength = 30-45 ksi
Elongation % in 2" = 23-41, Rockwell B Hardness 50-70

Material stating galvanized shall conform to ASTM A653,
Tensile strength = 42-58 ksi, yield strength = 28-48 ksi

1, R-11 glass fiber batt placed in wall and ceiling cavity areas.

5, 4 Hour fire rated wall has (4) layers of 3/4" thick Ultracode Gypsum on inside of 12 Ga. studs and 3 hour fire rated roof has (2) layers of 3/4" thick Ultracode Gypsum. Glass fiber or mineral wool batt material bearing UL Classification Marking to fill stud cavity.

5. Door and vent dampers are 3 hour fire protected.

SPECIAL CONDITIONS / LIMITATIONS

- Building is not a habitable structure

- Chemical storage in sealed or closed containers only and not opened during normal operations, suitable for storage of Class I, II and IIIA flammable or combustible liquids in sealed containers.

- Use group: H3

- Construction type: IIIB

- Complies with:

2006 International Mechanical Code w/ New Jersey amendments
2006 International Building Code w/ New Jersey amendments
2005 National Electrical Code w/ New Jersey amendments

- Setbacks: over 5' from rear, front, and both side elevations to the property line or mid way between two buildings on the same property.

- Manual emergency alarm system shall be provided outside and near the exit access door by others in the field if required.

- Handicapped accessibility by others in the field if required.

- Structure is capable of withstanding, as a minimum:

Ground Snow load: 30 psf

Wind Load: 120 mph (Exp. D)

Internal Pressure Coefficient: Gpfi = +/- .18

Enclosed Building / Wind Pressure: 33.5 psf

Seismic: Ss=0.2 & S1=0.04

WIRING NOTES

1. All wiring methods are in accordance to the latest NEC adopted by the state, including Article 500 & 501 and are subject to the Authority having jurisdiction.

2. Models BL and B200 thru B8000 wiring methods for the interior of the building are designed for Class I, Division I Hazardous Locations.

3. Location and quantity of devices, fixtures and conduit may vary based on customer's requirements, Authority having jurisdiction & Electrician's recommendations.

4. B/BL Models
Conductor: 12 - 10 - 8 AWG THHN

Reference Table 310-15 in National Electrical Code Handbook for allowable ampacities.

Conduit:

Type: Threaded rigid metal conduit

Sizes: 1/2", 3/4" & 1"

No. of Conductors in Conduit: Reference Table C8 in the National Electrical Code Handbook.

5. All devices are UL Listed.

6. Type of Circuit Protection Required:

Air Conditioner: Time-delayed UL Listed HACR circuit breaker

Exhaust: Standard UL Listed circuit breaker or fuse

Light: Standard UL Listed circuit breaker or fuse

Receptacle: Standard UL Listed circuit breaker or fuse

7. Electrical Service Panel Switch to be a maximum of 6"-7" from Grade.

Fire Suppression System is designed and installed in accordance with the National Fire Protection Association (NFPA 17) "Standard for Dry Chemical Extinguishing Systems".

SECURALL Storage Buildings provide ANSUL IND-X Industrial Fire Suppression Systems and are listed by Underwriter's Laboratories and approved by Factory Mutual Research Corporation.

Location of Dry Chemical Enclosure may vary based on number of building accessories.

Detectors may increase based on Manufacturer's recommendation and location of accessories.

Dry Chemical System is subject to the Authority having jurisdiction.

Fan automatically shuts down when Dry Chem activates.

General Piping Requirements:

1. Use schedule 40 Galvanized Pipe conforming to ASTM A120, A53, or A106. All Fittings must be 300 lb. Class minimum unless otherwise noted.

2. Before assembling, pipe ends and fittings shall be reamed, and inside blown clear of chips.

3. Inside of pipe and fittings shall be free of oil and dirt.

4. Minimum allowed nipple on tank outlet shall be 1" dia. X 3" long.

T. R. ARNOLD & ASSOCIATES, INC.

P. O. BOX 1081

ELKHART IN 46515

State(s) IN

Accredited Evaluation and Inspection Agency

This document is certified as being in conformance with State Building Codes

Date MAY 28 2009

Approval of this document does not authorize or approve any omission or deviation from the requirements of applicable State Laws.

INDEX

Pg. Description

10f10 Design Requirements

20f10 Suggested Foundation Plan

30f10 Building Layout

40f10 Building Elevations & Electrical Schematic

50f10 Sump Design

60f10 Bill of Materials

70f10 Welding - Sump

80f10 Welding - Walls & Roof

90f10 Electrical Load Calculations

100f10 Dry Chemical Calculations

Model AG4800FR4	
Exterior Dimensions	102Hx312Wx96D
55 gal Drum Capacity	48
Interior Dimensions	85Hx300Wx84D
Interior Area (sq.ft.)	175
Sump Capacity (gal)	763

This document and all information herein is proprietary and shall not be disclosed outside your organization, nor shall it be duplicated, used or disclosed for purposes other than as permitted under written agreement with Securl Products.

SPACE RESERVED FOR STAMPS OF APPROVAL

TOWNSHIP OF
RELEASED FOR PERMIT
Building Subcode 7/2/10
Plumbing Subcode
Fire Subcode
Electrical Subcode

FM APPROVAL
NO CHANGES ARE TO BE MADE WITHOUT NOTIFICATION TO AND APPROVAL FROM FACTORY MUTUAL-RESEARCH CORPORATION

5-27-09

SITE LOCATION:		DATE		DATE		DATE		DATE		DATE	
PARKS & RECREATION DEPT.		DATE		DATE		DATE		DATE		DATE	
FORCE POND GOLF COURSE		DATE		DATE		DATE		DATE		DATE	
301 CHAMBERSBRIDGE ROAD		DATE		DATE		DATE		DATE		DATE	
BRICK, NJ 08724		DATE		DATE		DATE		DATE		DATE	

A & A SHEET METAL PRODUCTS, INC.		11 POINT, INDIAN 46860		SUB-DIR.	
809004		SERIAL NO.		BUILDINGS	
CUSTOMER DRAWING		REVISION			
PART NUMBER AG4800FR4		SHEET NUMBER		1 OF 10	
SCALE Not To Scale					

T. R. ARNOLD & ASSOCIATES, INC.
P. O. BOX 1081
ELKHART, IN 46515


State(s) NJ-IL6C

Accredited Evaluation and
Inspection Agency

This document is certified as being in conformance
with State Building Codes

Date MAY 28 2009

Approval of this document does not authorize or approve
any omission or deviation from the requirements of
applicable State Laws.



SUGGESTED FOUNDATION

- Notes:
1. Concrete based on 3000 psi minimum
 2. Soil based on 2000 pfs minimum
 3. Foundation details are typical. Actual foundation is the responsibility of others and subject to inspection by the local building official.

FM

APPROVALS

FM APPROVALS
NO CHANGES ARE TO BE MADE WITHOUT
NOTIFICATION TO AND APPROVAL FROM
FACTORY MUTUAL RESEARCH
CORPORATION

SPACE RESERVED FOR STAMPS OF APPROVAL

5-27-09

SITE LOCATION:
PARKS & RECREATION DEPT.
FORGE POND GOLF COURSE
301 CHAMBERSBRIDGE ROAD
BRICK, NJ 08724

DATE	09/5/08	DATE	
MP		DATE	
CREATED		DATE	
DATE		DATE	
DATE		DATE	
DATE		DATE	

A & A SHEET METAL PRODUCTS, INC.
11 PORTL. BLDG. 4650

SE-CL-ALC CABINETS

SERIAL NO. 8090004

SUB-DIR. BUILDINGS

TITLE SUGGESTED FOUNDATION

PART NUMBER AG-400TR4

REVISION

SCALE Not To Scale

SHEET NUMBER 2 OF 10

Diagram illustrating the cross-section of a roof assembly, showing the following components and layers from top to bottom:

- (27) R-11 INSULATION
- (28) 20 GA INTERIOR PANEL
- (29) 2" INTERIOR FASTENERS, 10-32 x 1 1/2", SPACED EVERY 12" O.C. OR LESS, TYP.
- (30) 18 GA ROOF SUPPORT
- (31) 16" O.C., OR LESS, TYP.
- (32) LAYERS 3/4" ULTRACODE GYPSUM SHEETROCK

SEAM CAULKED BEFORE FASTENER INSTALLED

FR4 FIRE RATING:
WALLS: 4 HOUR FIRE RATING
ROOF: 3 HOUR FIRE RATING
OPENINGS: 3 HOUR FIRE RATING FOR CLOSURES
(DOORS, VENTS, EXHAUST OPENING)

23 4 LAYERS 3/4" ULTRACODE GYPSUM

27 2" 16 GA. STEEL STRAP

13 24" 12 GA. WALL SECTIONS

29 20 GA. INTERIOR PANELS

22 R-11 INSULATION

24.00 O.C. OR LESS, TYP.

1. FIRST LAYER #6-1.25" TYPE "F" FASTENERS SPACED APPROX. 24" O.C., OR LESS HORIZONTALLY ALONG STUDS.
2. SECOND LAYER #6-1.875" TYPE "F" FASTENERS STAGGERED & SPACED APPROX. 24" O.C., OR LESS HORIZONTALLY ALONG STUDS.
3. THIRD LAYER #6-1.875" TYPE "F" FASTENERS SPACED APPROX. 24" O.C., OR LESS, INTO 2" 16 GA. STEEL STRAPS.
4. FOURTH LAYER #8-2.575" TYPE "F" FASTENERS SPACED APPROX. 24" O.C. OR LESS, INTO 2" 16 GA. STEEL STRAPS AND SPACED EVERY 12" VERTICALLY ALONG STRAPS.

LONG

T. R. ARNOLD & ASSOCIATES, INC.
P. O. BOX 1081
ELKHART, IN 46515


State(s) ND-IBC

Accredited Evaluation and
Inspection Agency

This document is certified as being in conformance
with State Building Codes

Date MAY 28 2009

Approval of this document does not authorize or approve
any omission or deviation from the requirements of
applicable State Laws.



	FAN FORCED UNIT HEATER W/ THERMOSTAT 5kW, 24,000 BTU, 24 A, 208 V, 60Hz, 350 CFM		DRY CHEMICAL SYSTEM ALARM, .25 A
	DUST/VAPOR PROOF FLUORESCENT LIGHT FIXTURE .73 A, 120 V		TOTAL FLOODING NOZZLE, TTN 3/4"
	LOAD CENTER NEMA 3R, 120/240 V		FUSIBLE LINK DETECTOR, P/N 56838 CLIP-ON STYLE
	SWITCH IN WEATHER PROOF ENCLOSURE 15 A, 120 VAC		DRY CHEMICAL FIRE SUPPRESSION SYSTEM ENCLOSURE TANK ASSEMBLY BRACKET ASSEMBLY SAFETY RELIEF VALVE AUTOMATI MECHANICAL RELEASE
	EXPLOSION PROOF LIGHT FIXTURE W/PHOTOCELL 0.83 A, 120 V		CONTACTOR IN NEMA 3R ENCLOSURE 120 V INPUT, 240 V OUTPUT
	WEATHER PROOF RECEPTACLE 20 A, 125 V		

SPACE RESERVED FOR STAMPS OF APPROVAL

FM APPROVALS

FM APPROVALS
NO CHANGES ARE TO BE MADE WITHOUT
NOTIFICATION TO AND APPROVAL FROM
FACTORY MUTUAL RESEARCH
CORPORATION

R. M. Young

5-27-09

5-27-09

APPROVALS



**FM APPROVALS
NEEDS ARE TO BE MADE WITHOUT
ACTION TO AND APPROVAL FROM
CORY MUTUAL RESEARCH
CORPORATION**

SITE LOCATION:
PARKS & RECREATION DEPT.
FORGE POND GOLF COURSE
301 CHAMBERSBRIDGE ROAD
BRICK, NJ 08724

SUBMIT		DATE	
MP	08/19/08		
0-CHECKED	DATE		
DATE REC	DATE		
OK	DATE		
CONF. JOB	DATE		
APPROVED	DATE		

A & A SHEET METAL PRODUCTS, INC.

12 POVERT, BIRMINGHAM, AL 35203

45559

SE-001-A-L-F CABINETS

8090004

SERIAL NO. 45559

SUB-DIR. BUILDINGS

TITLE

BUILDING LAYOUT, WALL & ROOF DETAIL

PART NUMBER

AC4800FR4

REVISION


SCALE

Not To Scale


SHEET NUMBER

3 OF 10


NOTE:
ALL CONDUIT 1/2" UNLESS OTHERWISE NOTED.




LEFT ELEVATION



FRONT ELEVATION




REAR ELEVATION



RIGHT ELEVATION

T. R. ARNOLD & ASSOCIATES, INC.
P. O. BOX 1081
ELKHART, IN 46515
State(s) IN
Accredited Evaluation and
Inspection Agency
This document is certified as being in conformance
with State Building Codes
Date MAY 28 2009
Approval of this document does not authorize or approve
any omission or deviation from the requirements of
applicable State Laws.

ELECTRICAL SCHEMATIC





This document and all information herein is proprietary and shall not be disclosed outside your organization, nor shall it be duplicated, used or disclosed for purposes other than as permitted under written agreement with Securl Products.

SPACE RESERVED FOR STAMPS OF APPROVAL




FM APPROVALS
NO CHANGES ARE TO BE MADE WITHOUT
NOTIFICATION TO AND APPROVAL FROM
FACTORY MUTUAL RESEARCH
CORPORATION

5-27-09
[Signature]

SITE LOCATION: PARKS & RECREATION DEPT. FORGE POND GOLF COURSE 301 CHAMBERSBRIDGE ROAD BRICK, NJ 08724		DATE 06/05/08		A & A SEERT METAL PRODUCTS, INC.	
DESIGNED KX	DATE	SERIAL NO. 809004	SUB-DIR. BUILDINGS	TITLE EXTERIOR ELEVATIONS & ELECTRICAL SCHEMATIC	
DRAWN KX	DATE	PART NUMBER AG4800FFR4	REVISION	SCALE Not To Scale	
SHEET NUMBER 4 OF 10					



T. R. ARNOLD & ASSOCIATES, INC.
P. O. BOX 1081
ELKHART, IN 46515
State(s) NS-IND
Accredited Evaluation and
Inspection Agency
This document is certified as being in conformance
with State Building Codes
Date MAY 28 2009
Approval of this document does not authorize or approve
any omission or deviation from the requirements of
applicable State Laws.



This document and all information herein is proprietary and shall not be disclosed outside your organization, nor shall it be duplicated, used or disclosed for purposes other than as permitted under written agreement with Secural Products.

SPACE RESERVED FOR STAMPS OF APPROVAL

F M

FM APPROVALS
NO CHANGES ARE TO BE MADE WITHOUT
NOTIFICATION TO AND APPROVAL FROM
FACTORY MUTUAL RESEARCH
CORPORATION

537.09

R. Arnold

SITE LOCATION:
PARKS & RECREATION DEPT.
FORGE POND GOLF COURSE
301 CHAMBERSBRIDGE ROAD
BRICK, NJ 08724

DATE	09/15/08	A & A SHEET METAL PRODUCTS, INC.
BY	11 PATTI, INDIA 46580	
CHECKED	809004	SUB-DIR.
DESIGNED	809004	BUILDINGS
TITLE	SUMP LAYOUT	REVISION
PART NUMBER	AC4500FR4	
SCALE	Not To Scale	SHEET NUMBER 5 OF 10

WALL BOTTOM
ANGLE SIDES

SUMP WALL

1/8" $\perp$ TYP. NOTE A & D

1/8" $\perp$ 1-12" NOTE C

1/8" $\perp$ 1-12" NOTE C

1/8" $\perp$ NOTE A

1/8" $\perp$ TYP.

12 GA BASE SUPPORT

12 GA END SUPPORT

WALL BOTTOM ANGLE
FRONT & REAR

HOLD DOWN
BRACKET

T. R. ARNOLD & ASSOCIATES, INC.
P. O. BOX 1081
ELKHART, IN 46515
State(s) NT-ILC
Accredited Evaluation and
Inspection Agency
This document is certified as being in conformance
with State Building Codes
Date MAY 28 2009
Approval of this document does not authorize or approve
any omission or deviation from the requirements of
applicable State Laws.


SPACE RESERVED FOR STAMPS OF APPROVAL

NATIONAL Reference BOM		DATE 91-12-07	A & A SHEET METAL PRODUCTS, INC. LA PORTE, INDIANA 46350	
FROM		DATE	CAD DWG NO. 809004	SUB-DIR. BUILDINGS
PROJECT END		DATE	TITLE SUMP_WELD_NOTES	
CHECKED		DATE	PART NUMBER AC4800FRA	REVISION
APPROVED		DATE	SCALE Not To Scale	SHEET NUMBER 7 OF 10


REV.	DATE	BY	REVISION DESCRIPTION	ECN NO.

TOLERANCES
X
IN
IN
IN

John Arnold
5-27-09







WALL ASSEMBLY




ROOF ASSEMBLY


DOOR DETAIL
SECTION Y-Y



ROOF CUTTER
REAR



ROOF CUTTER
FRONT



DETAIL A
WALL SECTION WELDING

- WELDING NOTES
- MIG WELDING - 0.035Ø WIRE, WD-ER-70S-6 WELDING WIRE
- A. ALL SPICE WELDS FULL PENETRATION WITH BACKING, LEAVE BACK BAR.
 - B. 1 1/4" x Ø7/8" SLOT FOR PLUG WELD, FRONT & REAR WALL BOTTOM ANGLE, 26.5° OR LESS TYP. BETWEEN SLOTS.
 - C. WHEN FLOOR SPICE LANDS ON FORKLIFT CHANNEL, OR BASE SUPPORT, OMIT FILLET ON SEAM SIDE.
 - D. SEAL PASS AFTER WALL INSTALLED OR SLUMP LEVELED.
 - E. SEAL PASS CORNERS AND ROOF SEAMS AFTER ROOF INSTALLED.
 - F. EACH CONNECTION, ALL STUDS BOTH SIDES, BOTTOM.
 - G. ALL FLASHING TACK WELD ONLY AT EACH STUD OR 24".
 - H. WELD AT CORNER AND EACH HINGE AREA TYP.
 - I. SUB ASSEMBLY

T. R. ARNOLD & ASSOCIATES, INC.
P. O. BOX 1081
ELKHART, IN 46515



State(s) MS-IPBC

Accredited Evaluation and Inspection Agency

This document is certified as being in conformance with State Building Code or HEADER

Date MAY 28 2009

Approval of this document does not authorize or approve any omission or deviation from the requirements of applicable State Laws.



MATERIAL: ASTM 653 COMMERCIAL QUALITY

SPACE RESERVED FOR STAMPS OF APPROVAL

[Signature]

5.22.09

APPROVED				Factory Mutual Approved NO CHANGES ARE TO BE MADE WITHOUT NOTIFICATION TO AND APPROVAL FROM FACTORY MUTUAL RESEARCH CORPORATION			
FM				A & A STEEL METAL PRODUCTS, INC.			
DO NOT SCALE				CAD DWG NO. SUB-DIR.			
TOLERANCES				8090004 BUILDINGS			
PART NUMBER				BUILDING ASSEMBLY W/ WELDING JOINTS			
SCALE				REVISION			
Not To Scale				SHEET NUMBER			
				8 OF 10			

*WELDING PERFORMED TO AWS STANDARDS AND
INSPECTED BY CERTIFIED WELDERS. CERTIFICATION
INFORMATION CAN BE PROVIDED UPON REQUEST.*

CHEMICAL STORAGE BUILDING DRY CHEMICAL CALCULATION

General Information

Part Number: AG4800FR4

Building Dimensions (Inches): Height: 102, Width: 312, Depth: 96

Explosion Relief Panel Size (ft): 48 x 48

Calculations for Buildings up to 12' High and 10' Deep

Explosion Relief (Yes/No): NO

Fire Rating (NR, FR2, FR4): FR4

Interior Volume: 1395.95 cubic ft

Interior Area: 119.00 sq ft

Door Quantity: 1

Door: 18 x 80

By: MP

Date: 10/27/2008

Calculations:

HAZARD TYPE: Chemical Storage building suitable for storing agricultural chemicals.

HAZARD ATMOSPHERE: Exhaust shall shut down before dry chemical system activates. Exhaust opening protected with fire damper - 165°F Fusible Link. Vent opening protected with Fire Damper - 165°F Fusible Link.

DETERMINE PERCENT OF UNCLOSEABLE OPENINGS:

Building Surface area	(ft)	(ft)	
Ceiling	26	8	= 208.0 square feet
Floor	26	8	= 208.0 square feet
Wall Front & Rear	26	8.5	= 442.0 square feet
Wall Sides	8	8.5	= 136.0 square feet
Total Surface Area			= 994.0 square feet

Door Opening: Door design allows for automatic closing.

Door	6.7	x	5.0	(x1)	=	33.5 square feet
Calculation	33.5	/	994.0	x	100%	= 3.4

HAZARD VOL. UNIT: Building Volume = 1395.9 cubic ft

AREA OF COVERAGE: Building Area = 119.0 square ft

DETERMINE NUMBER OF TANKS REQUIRED:

A. Area of Coverage Method	Maximum Area per b Tank	Acceptable	=	288 square feet
B. Hazard Volume	Maximum Area per b Tank	Acceptable	=	1.396 cubic feet
C. Longest Side per Nozzle				

7 DETERMINE NUMBER OF DETECTORS REQUIRED:

Number of Detector(s) by Area Method	100 sq ft per Detector	2 Detectors
Spacing Between Detectors Method	10 ft Maximum Between Detectors	
Length (Width) Direction	6.5 ft	10 ft
Number of Detectors Required	4	Acceptable

Spacing from Wall Method	5 ft maximum from Wall	
Depth Direction	4 ft	Acceptable
Number of Detectors Required in Depth	1	

8 SYSTEM REQUIREMENTS:

Tank Size	50 lb using Foray
Nozzle(s)	TF-N-3/4 Total Flooding Nozzles
Detector(s)	3 Clip-on Style Detectors

T. R. ARNOLD & ASSOCIATES, INC.
P. O. BOX 1081
ELKHART, IN 46515
State(s) MS-IL-NC
Accredited Evaluation and
Inspection Agency
This document is certified as being in conformance
with State Building Codes
Date MAY 28 2009
Approval of this document does not authorize or approve
any omission or deviation from the requirements of
applicable State Laws.

This document and all information herein is proprietary and shall not be disclosed outside your organization, nor shall it be duplicated, used or disclosed for purposes other than as permitted under written agreement with Securall Products.

SPACE RESERVED FOR STAMPS OF APPROVAL

APPROVALS

FM APPROVALS
NO CHANGES ARE TO BE MADE WITHOUT
NOTIFICATION TO AND APPROVAL FROM
FACTORY MUTUAL RESEARCH
CORPORATION

SITE LOCATION:
PARKS & RECREATION DEPT.
FORGE POND GOLF COURSE
301 CHAMBERSBRIDGE ROAD
BRICK, NJ 08724

DATE	09/5/08	DATE	09/5/08
BY	MP	BY	MP
TITLE	DRY CHEMICAL CALCULATIONS	TITLE	DRY CHEMICAL CALCULATIONS
PART NUMBER	AG4800FR4	PART NUMBER	AG4800FR4
SCALE	Not To Scale	SCALE	Not To Scale
SHEET NUMBER	10 OF 10	SHEET NUMBER	10 OF 10

RECEIVING CLERK _____ PERMIT # 7/16/10
DATE REC'D _____ DATE ISSUED 29-00-516
BLOCK: 702 LOT: 5 QUALIFIER: _____ SITE ADDRESS: 301 Chambers Bridge Rd

IDENTIFICATION: _____
1. NAME OF OWNER IN FEE: County of Ocean
COMPLETE ADDRESS: 301 Chambers Bridge Rd
BRIERLY, NJ 08723
PHONE # 732-920-4733 EMAIL: _____

2. NAME OF APPLICANT: County of Ocean
APPLICANT ADDRESS: 301 Chambers Bridge Rd
BRIERLY, NJ 08723
PHONE # _____ EMAIL: _____

3. RESPONSIBLE PERSON FOR WORK: Scott Binkley
PHONE # 732-920-4733 FAX # 732-477-2757

4. SIGNATURE OF APPLICANT: _____

PROJECT DESCRIPTION: (PLEASE CHECK APPLICABLE WORK & DESCRIBE)
*NEW BUILDING: ☒ *ADDITION _____ *ALTERATION _____ *PORCH _____ *DECK _____

POOL: ABOVE GROUND _____ IN GROUND _____ FENCE: HEIGHT _____ TYPE _____
HEIGHT: 8.5' _____ (*IF APPLICABLE)

OTHER _____

DESCRIPTION: 2 lab for pre-fab pesticides storage building

ZONING REVIEW: 7/15/10 DATE DENIED: _____ DATE APPROVED: 7/15/10 INTLS: MMK
DATE REVIEWED: 7/15/10 (SEE BACK PAGE)

FOR OFFICE USE ONLY
FEE SUMMARY:
APPLICATION FEE: \$ Exempt
OTHER: \$ _____
TOTAL: \$ _____
REQUIRED BY APPLICANT
RESIDENTIAL: _____
COMMERCIAL: _____
EXISTING USE: _____
PROPOSED USE: _____
BOARD APPROVAL: _____ PB ZB
RESOLUTION#: _____
APPROVAL DATE: _____
COMMERCIAL

TOWNSHIP OF BRICK ZONING CHECKLIST

1) Two (2) copies of plot plan containing:

- All existing and proposed structures
- All dimensions of the lot and structures
- All setbacks from the structures to the property lines
- All adjacent streets and waterways
- If applicable, include a copy of the Zoning Board of Adjustment Resolution, the date that the map was signed, and/or the date that the subdivision map was filed with the Ocean County Clerk, along with the file map and number.

2) Two copies of the plans with dimensions and heights noted:

- Floor plans and elevations
- Signed site plans
- Property map
- Survey map

Choose which is applicable for submission

3) Plot plans and building plans must match for complete review

NOTE: NO PARTIAL, TAPED, FAXED, REDUCED OR ENLARGED COPIES CAN BE ACCEPTED

LAND USE

245 Attachment 5

Township of Brick

SCHEDULE OF AREA, YARD AND BUILDING REQUIREMENTS

Township of Brick
Ocean County, New Jersey

[Amended 6-26-1979 by Ord. No. 354-2B-79; 4-22-1980 by Ord. No. 354-2H-80; 10-14-1980 by Ord. No. 354-2N-80; 9-23-1980 by Ord. No. 354-1B-80; 8-25-83 by Ord. No. 354-2SS-83; 11-5-1984 by Ord. No. 354-2AAA-84; 11-5-1984 by Ord. No. 354-2CCC-84; 6-24-1986 by Ord. No. 354-2WWW-86; 5-13-1988 by Ord. No. 354-2TTTT-88; 9-12-1988 by Ord. No. 354-2XXX-88; 9-12-2000 by Ord. No. 354-2EE-00; 5-9-2000 by Ord. No. 354-2Z-00; 3-26-2002 by Ord. No. 354-2C-02; 11-26-2002 by Ord. No. 354-2L-02; 3-25-2003 by Ord. No. 354-2D-03; 6-13-2006 by Ord. No. 19-06]

Zone	Minimum Lot Size						Minimum Required Yard Depth						Maximum Lot Coverage by Building	Maximum Building Height			Minimum Floor/ Building Area (square feet) 2 stories/1 story	Maximum Allowable Impervious Coverage	
	Interior Lots			Corner Lots			Principal Building			Accessory Building				Stories	Eaves (feet)	Ridge (feet)			
	Area (square feet)	Width (feet)	Depth (feet)	Area (square feet)	Width (feet)	Depth (feet)	Front Yard (feet)	Side Yard, Each (feet)	Both Sides Combined (feet)	Rear Yard (feet)	Side Yard (feet)	Rear Yard ¹ (feet)							
R-R	40,000	150	150	40,000	150	150	50	25			50	25	25	25%	-	25		-	
RR-2																			
RR-3																			
R-20	20,000	100	125	25,000	100	125	40	15	-		40	10	10	25%	-	25	35	38.5	-
R-15	15,000	100	115	17,250	100	115	35	12	-		35	10	10	25%	-	25	35	38.5	-
R-10	10,000	90	100	10,500	100	100	30	6	20		20	5	5	30%	-	25	35	38.5	-
R-7.5	7,500	75	90	9,000	75	90	25	6	15		15	5	5	30%	-	25	35	38.5	-
R-5	5,000	50	75	6,000	50	75	20	5	12		15	5	5	35%	-	25	35	38.5	-
O-P	15,000	100	150	15,000	100	150	50	10	-		50	20	50	35% ²	2	-	35	38.5	1,500 70%
B-1	10,000	100	90	12,500	100	125	30	10	-		20	10	20	30% ²	2	-	35	38.5	1,000 60%
B-2	20,000	125	125	20,000	125	125	50	10	-		50	10	50	30% ²	2	-	35	38.5	2,000 65%
B-3	2 acres	200	200	2 acres	200	200	75	30	-		50	20	50	25% ²	-	-	35	38.5	2,000 65%
B-4	5 acres	300	300	-	-	-	100	50(150) ¹	-		100(150) ¹	20	50	25%	3	-	35	38.5	30,000 70%
M-1	5 acres	300	300	5 acres	300	300	100	50	-		150	75	150	30% ²	-	-	35	38.5	5,000 65%
R-M	25 acres	350	200	-	-	-	50	50	-		30	30	30	20%	-	25	35	38.5	- 65%
O-P-T	40,000	150	150	40,000	150	150	50	20	-		50	20	50	25% ²	2	-	35	38.5	2,000 50%
H-S																			70%

See § 245-90.

See § 245-103.

See § 245-261.

See § 245-103.

See § 245-90.

See § 245-261.

NOTES:

1. If adjacent to residential zone or use.
2. The maximum lot coverage shall refer only to that percentage of an affected lot which is suitable for building.
3. For rear yard setback requirements for accessory buildings on waterfront property, see § 245-100.

OFFICE USE ONLY



Brick Township
401 Chambers Bridge Rd.

Brick, NJ 08723
(732) 262-1027

Date Issued: _____
Application Number: ZA-10-00718
Application Date: 07/15/2010
Project Number: _____
Permit Number: _____
Fee: \$0

Zoning Permit

Worksite **301 CHAMBERS BRIDGE RD.**
Location: **Brick Township, NJ**

Block: **702**
Lot: **5**
Qualifier: _____
Zone: **R-R**

Owner: **OCEAN COUNTY**
Address: **101 HOOPER AVE**
TOMS RIVER, NJ 08753

Applicant: **County of Ocean - Forge Pond Golf Course**
Address: **301 Chambers Bridge Road**
Brick, NJ 08723

Application Approved Date: 07/15/2010



This Certifies that an application for the issuance of a Zoning Permit has been examined.

Use is: Public
Nonconforming Use is: _____

Work Description:
Shed - Construct 8' x 26' prefabricated shed for pesticide storage as per Capital Project Approval Resolution R-24-09, dated April 22, 2009.

Upon review it was determined that:

- ☒ Use is permitted by Ordinance
- ☐ Use is permitted by Variance approved on: _____
- ☐ Valid Nonconforming Use is established by
 - ☐ Zoning Board of Adjustment
 - ☐ Zoning Officer


Office of Zoning, Michael P. Fowler

Michael P. Fowler, Township Planner

07/15/2010

Date

7/15/10
Date



OCEAN COUNTY PARKS & RECREATION

*Ocean County Golf Course at Atlantis
Country Club Boulevard
Township of Little Egg Harbor, N.J. 08087
(609) 296-2444*

*Ocean County Golf Course at Forge Pond
301 Chambers Bridge Road
Brick, N.J. 08723
(732) 920-8899*

Ms. Nelson,

I have enclosed plans for our new chemical storage unit at the Forge Pond County Golf Course Maintenance Facility on Chambersbridge Road. They include an architectural drawing noting the location of the unit on the property, as well as specifications from the manufacturer. Our unit is the AG4800 model measuring 8'X26'. It is complete with self contained fire suppression, explosion proof lighting and many more safety features bringing us in line with DEP regulations for pesticide storage.

If you have any questions or need further information please do not hesitate to call me at 732-920-4733.

Regards,

Scott Binkley
Golf Superintendent
Forge Pond County Golf Course



SPECIAL ASSISTANCE/ACCOMMODATIONS available upon request.

BRICK TOWNSHIP PLANNING BOARD
CAPITAL PROJECT APPROVAL RESOLUTION

RESOLUTION R-24 -09

Page 1 of 2

April 22, 2009

WHEREAS, the **Forge Pond Golf Course Maintenance Facility**, **Ocean County Parks & Recreation**, intends to construct a chemical storage unit at the facility located on Block 702, Lot 5, necessitating the expenditure of public funds: and

WHEREAS, pursuant to N.J.S.A. 40:55D-31, this proposed action as described above was referred to the Planning Board for its recommendation; and

WHEREAS, Scott Binkley, Golf Superintendent, Forge Pond County Golf Course, presented to the Planning Board certain information and materials relating to the construction, installation and necessity of these improvements;

NOW, THEREFORE, the Board does, based upon the foregoing information, make the following findings:

1. The proposal is consistent with the Master Plan and in particular those aspects of the Master Plan relating to the development of public facilities and the location thereof.

File 2
OCP&R
Bus Ad
Council
Zoning

NOW, THEREFORE, be it resolved by the Brick Township Planning Board on this 22nd day of April, 2009 that it favorably recommends the undertaking and completion of this project by the Ocean County Parks and Recreation.

R-24-09

April 22, 2009

PAGE 2

MOVED BY: Ms. Tabor

Councilman Toth

SECONDED BY:

VOTING IN THE AFFIRMATIVE: Mr. Liloia, Mr. Marra, Ms. Tabor, Councilman Toth, Mr. Rappoccio, Mr. Palmieri, Mr. Coakley, Mr. Hahn, Mr. Catalano

VOTING IN THE NEGATIVE:


INELIGIBLE TO VOTE: Mr. Patterson

ABSTAINING:

ABSENT: Mr. Underwood

CERTIFICATION

I, JUDITH FOX NELSON, Clerk of the Planning Board of the Township of Brick, County of Ocean, State of New Jersey, do hereby certify that I am duly authorized to certify Resolutions. I certify that the forgoing Resolution was adopted by the Planning Board of the Township of Brick at a meeting held on the 22nd day of April, 2009.


JUDITH FOX NELSON
CLERK OF THE PLANNING BOARD



SECURALL®
Safety Storage Buildings
Phone: 888-326-7890

For safe storage of hazardous materials
You have come to the right place




EGSA
Home
Storage Cabinets
Get a Quote
Contact Us

- Building Specifications
- Hazmat Buildings
- Pesticide Buildings
- Custom Buildings
- Accessories
- Order Online
- Shipping Policy
- Frequently Asked Questions



Standard Features (Pesticide and Agri-Chemical Storage Buildings)

Models AG Buildings


Securall® Chemical Storage Buildings are designed with a wide variety of standard features to help our customers gain compliance with hazmat storage codes quickly and easily. Pesticide Storage Buildings are designed for outdoor storage of hazardous agricultural and turf-management chemicals.

Securall's quality cannot be beat with standard features such as corrosion-resistant, galvanized steel construction, tornado and hurricane resistant walls, and interlocking wall panels designed for superior strength and durability.


All models are FM approved, include UL listed electrical accessories, and are EPA and OSHA compliant.

Design Features

- R-11 Fiberglass Insulation in ceiling and walls
- Commercial grade lockset
- Vapor Resistant Exterior Light with Photocell
- GFCI Duplex receptacle with weatherproof cover
- Steel shelving (3 Tiers) with raised edges
- Chemical/corrosive/ultraviolet resistant paint
- Leak-tight continuously welded sump
- Heavy gauge aluminum threshold
- Warning labels
- Safety posters
- Dust Proof/Fluorescent Interior Light with Weatherproof Switch
- Forklift channels with anchoring brackets
- Natural convection air vents
- Removable Galvanized Steel Safety Flooring
- Reflective warning tape marking entryway




Pesticide and Agri-Chemical Storage Buildings

Natural Convection Air Vents (OSHA FM 5049, IBC) R-11 Fiberglass Insulation in Ceiling and Walls (IBC) Leak-tight, Continuously Welded Sump Meets EPA and OSHA Requirements for Secondary Containment (EPA, NFPA, OSHA, FM, IBC) Forklift Channels with Anchoring Brackets (EPA, to lift off ground to allow for visual inspection of sump area, IBC)		Dust-proof, Fluorescent Interior Light with Weatherproof Switch (UL, OSHA, IBC) Removable Galvanized Steel Safety Floor Planking (250-lb FM requirement OSHA 1910, IBC) Vapor-resistant Exterior Light with Photocell (UL, OSHA, IBC) Heavy Gauge Aluminum Threshold (IBC) Chemical/Corrosive/Ultraviolet Resistant Paint Reflective Warning Tape Marking Entry (OSHA 1910, IBC)
---	---	--


Exclusively Securall®

Tornado Resistant Walls

SECURALL Buildings have been tested to determine the amount of force they can withstand and were shown to withstand F-4 tornado force winds of 250 mph. The chart below demonstrates the wind speed that a particular length of wall will resist.



Interlocking Wall Structure



Securall Chemical Storage Buildings are designed using interlocking wall sections which provide superior strength and durability.

Exterior Wall Construction

SECURALL AG Buildings are all-welded using 12 gauge (AG1600X-AG8000X Models) and 16 gauge (AG200X-AG1200X Models) galvanneated steel outer walls and 20 gauge cold rolled steel inner walls provide maximum durability, weather resistance, and rigidity.

Fire Rating according to FM

2 Hour Fire Rated wall construction built with 1 hour fire rated roof construction, 1.5 hour fire rated door construction, and 1 layer of 5/8" gypsum ultracode wallboard. Air inlet vents with UL Listed and labeled fire damper with louvers. Dampers have a galvanized steel frame, curtain-type galvanized steel blades and a UL Listed 165° F fusible link.

4 Hour Fire Rated wall construction built with 3 hour fire rated roof construction, 3 hour fire rated door construction, and 2 layers of 5/8" gypsum ultracode wallboard. Air inlet vents with UL Listed and labeled fire damper with louvers. Dampers have a galvanized steel frame, curtain-type galvanized steel blades and a UL Listed 165° F fusible link.

Safety Floor Planking

Slip resistant planking 13" wide, 12 gauge galvanized steel with raised perforated buttons and debossed holes protruding down. Galvanized steel floor planking above sump area for maximum corrosion resistance. Floor planking designed to sustain a minimum uniformly distributed load of 250 pounds per square foot. Floor planking and supports are removable to facilitate sump cleaning in the event of a spill.



Door Style


Door for AG200-AG400 Provide one (42" wide x 62.5") and AG600-AG1200 Provide one (42" wide x 80") high door to facilitate the unloading and loading of hazardous material within the building. Installed with a UL Classified commercial grade keyed lockset. The door shall serve as personnel entrance and exit.

Door for AG1600-AG8000 Provide one 60" wide x 80" high double door to facilitate the unloading and loading of hazardous material within the building. Installed with a UL Classified commercial grade keyed lockset. The double door shall have one active leaf to serve as personnel entrance and exit. The active leaf must be equipped with a door closer. Available on B600-B1200 upgrade.

Explosion Relief Panels

Used in the construction of buildings designed to store Class IA and Class IB flammables. Explosion relief panels limit the damage within an enclosed hazardous location. When the panel(s) are subjected to an explosive force, the pressure relieving panel quickly vents the force before it causes major damage. The panels are designed to release at 20 psf.

Fire-Rated Buildings



Securall® Fire-Rated Storage Buildings (8'6"H X 42'W X 9'D Max Dimensions) carry the Factory Mutual System Approval label and are constructed based upon UL Fire Resistance Ratings classification criteria. In addition, all Fire-Rated Buildings come with hydraulic operated self-closing, fire-rated doors and fire damper protected vents.

Models AG Buildings

[Hazmat Buildings](#)
[Hurricane Rating](#)

[Chemical Buildings](#)
[Custom Buildings](#)

[Accessories](#)
[Order Now](#)

[Standard Features: Hazmat/Chemical](#)
[Get a Quote](#) [Contact us](#)

[Fire Rating](#)
[Home](#)

TOWNSHIP OF BRICK ZONING PERMIT APPLICATION

(Please Type or Print Neatly in Ink, Not Pencil)

Applications missing any of the following information
will delay processing and may be returned to you.

BLOCK 702 LOT 5 QUALIFIER _____

PROPERTY ADDRESS 301 CHAMBERSBRIDGE ROAD

PERSONAL NAME OF APPLICANT SCOTT BINKLEY

BUSINESS NAME OF APPLICANT COUNTY OF OCEAN, FORGE POND GOLF COURSE

MAILING ADDRESS OF APPLICANT 301 CHAMBERSBRIDGE ROAD

PROPERTY OWNER'S FULL NAME COUNTY OF OCEAN

PRESENT USE OF PROPERTY (check all that apply)

- ☐ Vacant Lot ☐ Single-family dwelling ☐ Multi-family dwelling
☒ Commercial (please describe) GOLF COURSE

PROPOSED USE OF PROPERTY (check all that apply)

- ☐ Vacant Lot ☐ Single-family dwelling ☐ Multi-dwelling
☒ Commercial (please describe) GOLF COURSE

PROPOSED CONSTRUCTION (check all that apply)

- ☐ New Building (please describe) _____ Height _____
☐ Addition - Height _____
☐ Alteration _____
☐ Porch or deck - Height _____
☐ Shed - Height _____
☐ Fence - Type _____ Height _____
☐ Swimming Pool ☐ in-ground ☐ above-ground
☒ Other (please describe) INSTALLATION OF PRE-FABRICATED STORAGE BUILDING

CHECKLIST

- ☐ All information completed above
☐ Two (2) copies of a plot plan containing:
☐ All existing and proposed structures
☐ All dimensions of the lot and structures
☐ All setbacks from the structures to the property lines
☐ All adjacent streets and waterways
☐ If applicable, include a copy of the Zoning Board of Adjustment Resolution, the date that the map was signed, and/or the date that the subdivision map was filed with the Ocean County Clerk, along with the file map and number.

Note: No partial, taped, faxed,
reduced or enlarged copies
can be accepted.

The applicant certifies that all statements and information made and provided as part of this application are true to the best of the applicant's knowledge, information and belief. The applicant further states that the applicant will comply with all other Municipal approvals and ordinances, and all County, State, and Federal Regulations.

SIGNATURE OF APPLICANT Scott Binkley Date _____

Reviewed by Zoning Office _____ Date _____ () Approved () Denied

March 2003

COMMERCIAL