

BRICK, TOWNSHIP
OF
(BUILDING DEPT.)

PERMIT WITHOUT
A JACKET

Book



**ELECTRICAL
SUBCODE
TECHNICAL SECTION**



Date Received
Date Issued
Control #
Permit #

424-4130

A. IDENTIFICATION—APPLICANT: COMPLETE ALL APPLICABLE INFORMATION, WHEN CHANGING CONTRACTORS, NOTIFY THIS OFFICE. CALL UTILITY DIG NO: 1-800-272-1000.

Block 701.25 Lot 220
Work Site Location BRIDGE RD
Owner in Fee VINCENT CASTALDO
Address 467 BOCA RATON RD
W. FLEMING AVE.
Tele. (305) 293-5461
Contractor Charles Neal Elect.
Address 39 Adams Ave.
W. Flemington Ave.
Tele. (305) 787-4447 CAC
Lic. No. 7663
Federal Emp. No. _____ or Social Security No. _____

B. ELECTRICAL CHARACTERISTICS

Use Group _____ Present _____ Proposed _____
[] Pole/Pad # _____ [] Temporary [] Other _____
Building Occupied as Laundromat Utility Co. _____
Est. Cost of Elec. Work \$ 5,000.00

JOB SUMMARY (Office Use Only)

PLAN REVIEW:
[] No Plans Required
Joint Plan Review Required:
[] Bldg. [] Plumb.
[] Fire [] Elevator
[] Elec. Plans Approved
Date: 5/2/2005
Approved by: MM
SUBCODE APPROVAL
[] CO [] CCO [X] CA
Date: 5/17/00
Approved By: MM

D. TECHNICAL SITE DATA

NO.	SIZE	ITEM
20		Fixtures (1)
20		Receptacles (2)
20		Switches (3)
79		Total 1 + 2 + 3
		Kw Range
		Kw Oven(s)
		Kw Surface Unit
		hp Dishwasher
		hp Garbage Disposal
		Kw Dryer
		Kw A/C Unit
		Burglar Alarms
		Intercoms Panels
		Smoke Detectors
		hp Whirlpool/spa
		Pool Bonding
		hp Pool Filter Motor
		Pool Lights
		1 kw Kw Water Heater(s) GAS FRED
		Kw Central heat:
		oil, gas or elec.
		Kw Baseboard Heat Units
		Thermostats
		hp Heat Pump
		1 hp Pump(s) Driller
		60A Amp Motor Control Center/Sub Panels
		Signs
		Light Standards
		1 1/2 hp Motors—Fractional H.P. Dryers
		23 1 hp Motors—All Others: WASHERS
		Kw Transformers
		Kw Generators
		Amp Service Entrance
		Other

FEE (Office Use Only)

Administrative Surcharge	\$ 25.5
Minimum Fee	\$ 4
DCA Training Fee	\$ 159
TOTAL FEE	\$ 188.5

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of) owner of _____ record and am authorized to make this application and perform the work listed on this application.

✓ Licensed Electrical Contractor [] Exempt Applicant

Signature—Contractor Seal

V. Coatsdale C.C. Form F-1208

1 White - Inspector Copy
2 Canary - Office Copy
3 Pink - Office Copy
4 Gold - Applicant Copy

4607 Boca Raton Dr. Farmington 08135

1/14/98 ① FILE FOR ALL WORK - SIGN, ETC

② LOCKED 1015 AM 5433

3/6/98 18" CONCRETE ON TOP OF PIPE.)

✓ ① MARK ALL PANELS & SWITCHES & EQUIPMENT

✓ ② INSTALL DISCONNECTING MEANS
ON BREAKER LOCKS

7/11/98 ① OLD EXISTING SIGN NOT CHANGED - ONLY PLASTIC
LETTERS

✓ ② STILL NEED BREAKER LOCKS - ORDERED

10-26-99 FINAL FAULTS -

✓ I D. BREAKERS, FOR SUB PANELS &
WASHERS

✓ SMOKE DETC DOWN

✓ TEMP CISHS STILL IN PART CRICK

✓ NO OUTLET BOILER ROOM

✓ WON VISIBLE HVAC

✓ NO EMC LIGHT OUTSIDE BLD.