

Brick

Permit Without a Jacket

Permit Number 5831.

LDS BR 10312620

Block 527-20

Lot 4-7

Location Cedarwood Park

Street Jackson Avenue

Proposed Use of Building Dwelling

Plumbing Permit No. **B-9544**

Building Permit No. **11004**

BRICK TOWNSHIP
OCEAN COUNTY, N. J.

DIVISION OF HEALTH
APPLICATION FOR
PLUMBING PERMIT

Location **CEDEWOOD PARK**

Street **JACKSON AVE**

Lot **4-7**

Block **527-20**

We hereby make application to install plumbing at the above location in accordance with the provisions of the Plumbing Code of the TOWNSHIP OF BRICK N. J. and following the plan drawn on the reverse side of this application.

Signed **MARYWELL BUILDERS**

Signed **Owner**

Date **9/9/76**

Fee **\$8.50**

\$7.00 for a fixture units
50c for each additional fixture unit

Septic 3

INSPECTION

Certificate of Approval **9/16/76**

Rough **9/15/76**

Final **9/15/76**

Septic or Sewer **5831508 9/15/76**

TYPE OF BUILDING

1 Family Dwelling ☒

Apartment House ☐

Store ☐

Office ☐

Factory ☐

New **RANCH**

Alteration ☐

No. of Fixtures	Fixtures	Units Per Fix.	Units
1	Water Closet	(4)	4
	Water Closet (Flush)	(8)	
1	Lavatories	(1)	1
1	Bath Tub	(2)	2
	Shower	(2)	
1	Kitchen Sink - 1 1/2 Trap	(2)	2
	Sink 2" Trap	(4)	
	Sink (Slop)	(3)	
	Laundry Tray	(2)	
	Dishwasher	(2)	
1	Washing Machine	(2)	2
	Urinals	(2)	
	Urinals (Flush)	(8)	
	Floor Drains	(1)	
	Other Fix.		
5	Total Fixtures		Total Units 11

NEEDS Hanger on 4

Plumbing Permit No. B-9234
Building Permit No. 11004

BRICK TOWNSHIP
OCEAN COUNTY, N. J.

DIVISION OF HEALTH
APPLICATION FOR
PLUMBING PERMIT

Location 330 Arkwood Ave
Street TACKSON AVE
Lot 4-7
Block 527-20

We hereby make application to install plumbing at the above location in accordance with the provisions of the Plumbing Code of the TOWNSHIP OF BRICK N. J. and following the plan drawn on the reverse side of this application.

Signed Mayor B. B. B.
SIGNED Plumber
Date 4/19/76
Fee \$8.50
\$7.00 for 8 fixture units
50c for each additional fixture unit

INSPECTION


Certificate of Approval
Rough 4/26/76 J.D.S.
Final
Septic or Sewer

TYPE OF BUILDING

1 Family Dwelling HOUSE

Apartment House
Store
Office
Factory
New RANCH
Alteration

No. of Fixtures	Fixtures	Units Per Fix.	Units
<u>1</u>	Water Closet	(4)	<u>4</u>
	Water Closet (Flush)	(8)	
<u>1</u>	Laboratories	(1)	<u>1</u>
<u>1</u>	Bath Tub	(2)	<u>2</u>
	Shower	(2)	
<u>1</u>	Kitchen Sink - 1 1/2 Trap	(2)	<u>2</u>
	Sink 2" Trap	(4)	
	Sink (Stop)	(3)	
	Laundry Tray	(2)	
	Dishwasher	(2)	
<u>1</u>	Washing Machine	(2)	<u>2</u>
	Urinals	(2)	
	Urinals (Flush)	(8)	
	Floor Drains	(1)	
	Other Fix.		
<u>5</u>	Total Fixtures		<u>11</u>



1:30 PM

DIVISION OF HEALTH OF THE TOWNSHIP OF BRICK
APPLICATION FOR PERMIT TO LOCATE AND CONSTRUCT AN INDIVIDUAL
SEWAGE DISPOSAL SYSTEM

Date Dec. 18, 1975

Jackson Avenue

Block No. 527-20 Lot No. 4, 5, 6 & 7

Street Location
Owner (print) Marywell Builders Inc. (George Weller)
If corporate owner or developer list names and position of individual applying for permit.
Present Address Shore Acres P.O. Box 137 Brick Town N.J.
Name and Address of Contractor (print) Marywell Builders Inc.
Type of Building to be served one family
Dwelling Unit - No. of Bedrooms 3 Expansion Attic Yes No x
Other Type of Building Gals. per person
Type of Facilities persons
Size of Lot 80 x 100 Area sq. ft. 8000
Septic Tank - Liquid Capacity 900 gal Shape Hexagonal Material Precast conc
Width 6' 1 1/2" Length 7' 1" Diameter
Liquid depth 4' 5 1/2" Distance from liquid to underside of top 8"
Liquid Disposal Disposal Trenches sq. ft. Disposal Bed sq. ft. Seepage Pits sq. ft.
Disposal Trenches - Width Depth Lin. Ft. of Pipe
Distance between lines Type of Pipe
Disposal Bed - Width 12' Length 33' Area sq. ft. 396
Lin. ft. of Pipe 132' Type of Pipe 4" perforated
Distance between lines 4'
Seepage Pits - Number Width Length Diameter
Depth below inlet Distance between pits
Shape of Pits Construction material
Depth of permeable material to be penetrated all

I certify that the proposed sewerage facilities for the proposed realty improvement are in compliance with the provisions of Chapter 199, P. L. 1959 Revised 1963 and these standards.

Robert B. Brown P.E.

Percolation Tests Results
(as performed according to specifications
set forth in P. L. 199, Sec. 9-B)

Dated December 18, 1975

4' up
1:45 PM
3/5/76
DM

10/21/75
Date

	Time in Min. per in.	Number of Tests to Determine Saturation	Depth	Type of Soil Encountered, Depth of Each Type
Ground Water at 4' 4' up 3/5/76 Source of Boring	Less than 5 min per inch 1:45 PM DM	1	1	Gray sand
			2	
			3	
			4	
			5 Water	Gray sand & small stone
			6	
			7	
			8	
			9	Sand
			10	
			11	
			12	
			13	
			14	
			15	
			16	
			17	
			18	
			19	
			20	
			21	
			22	
			23	
			24	
			25	
			26	
			27	
			28	
			29	
			30	

SEE ATTACHED DRAWING

Make an accurate sketch or attach plot plan showing the following - lot dimensions, location of house, location of each unit of disposal system, all buildings and large trees in disposal area. Include distances from house, side and rear lots lines, auxiliary buildings, large trees and sewerage units and water supply.

The undersigned agrees to construct the aforescribed individual sewage disposal system in accordance with the provisions of the Laws of the State of New Jersey and Standards adopted by the State Commissioner of Health pursuant thereto and applicable ordinances of the Township of Brick.

Owner George White

Contractor George White

Approved by J. McLaughlin Plumbing Inspector 3/8/76 Date

Engineer for the Board _____ Date


Remarks:

480

14.5
15.5
16.
16.5
17.5
18.5



MIDVALE AVENUE (33')



SURVEY OF
LOTS 4, 5, 6 & 7 BLOCK 527-20
TOWNSHIP OF BRICK
OCEAN COUNTY, NEW JERSEY

*Zoning ok.
1-7-76
Buttler*

NOTE:

ELEVATIONS BASED ON USCGS DATUM
14.4 = EXIST ELEV.
15.8 = PROPOSED ELEV
PUBLIC WATER AVAILABLE

A/K/A Lots 4, 5, 6 & 7, Block 20 on a map entitled "Cedarwood Park, Sub-division C - Annex, Ocean County, N.J." filed in the Ocean County Clerk's office as Map B-315

CENTRAL JERSEY ENGINEERS, INC.
1102 Ocean Avenue
Lakewood, N.J. 07001

SCALE: 1" = 20'
DRAWN BY: L.S. CH'D BY:
JOB NO. 876-23
DATE: DEC 8, 1975