



Township Archives
Township of Brick, NJ
401 Chambers Bridge Rd, Brick, NJ 08723

***This File Contains Personal Identifiable
Information of Private Citizen(s).***

Certain information contained in this file is ***Exempt from Release*** under the Open Public Records Act (OPRA) (Public Law 2001, CHAPTER 404 (N.J.S.A. 47:1A-1 et seq.)) and Executive Orders issued by the Governor of New Jersey. The following information ***MUST*** be redacted prior to release:

- Social Security Numbers
- Drivers' License Numbers
- Unlisted Phone Numbers
- Credit Card Numbers
- Bank Account Numbers and Balances

For further information, consult with the Township Clerk, Township Archivist or Township Attorney prior to release.

A handwritten signature in black ink, appearing to read "Bryan J. Dickerson", is written over a horizontal line.

Bryan J. Dickerson, CA, CMR
Township Archivist

Issued: 8 January 2020



CONSTRUCTION PERMIT APPLICATION

Applicant Completes: Sections I, II, III (optional), IV, VI, and VII

C21-000800

I. IDENTIFICATION

1. Proposed Work Site at: 197 CHAMBERS BRIDGE ROAD BRICK

2. Name of Owner in Fee: OCEAN ICE PALACE
 Tel. 732 4774411 e-mail RAVEN@OCEANHOCKEY.COM
 Address 197 CHAMBERS BRIDGE RD BRICK 08723
street municipality zip code

3. Ownership in Fee: Public _____ Private _____

4. Principal Contractor: WHITEWOOD ELECTRICAL Tel. 973 543 1994
 Address 31 PHOENIX DRIVE e-mail whitewoodelectric@yanco.com
Mendham NJ 07945
 License No. OR, if new home, Builder Reg. No. 14726 Exp. Date 3/2021
 Home Improvement Contractor Registration No. or Exemption Reason _____
 Federal Emp. ID No. 22 374 5167 FAX: 973 543 1994

5. Architect or Engineer _____ Contact _____
 Address _____ e-mail _____
 Tel. _____ FAX: _____

6. Responsible Person in Charge once Work has Begun Raven or Andrew
 Tel. 732-948-3487/732-948-3477 FAX: _____

V. FEE SUMMARY (for office use only)

		Update	Update
1. Building	\$ <u>460</u>		
2. Electrical			
3. Plumbing			
4. Fire Protection			
5. Elevator Devices			
6. Subtotal			
7. Less 20% for State Plan Review	\$		
8. Subtotal	\$		
9. State Permit Surcharge Fee	\$ <u>2</u>		
10. Subtotal	\$		
11. Cert. of Occupancy			
12. Other	\$ <u>402</u>		
13. TOTAL	\$		

VI. BUILDING/SITE CHARACTERISTICS

(office use only)

1. Number of Stories _____

2. Height of Structure _____ ft.

3. Area — Largest Floor _____ sq. ft.

4. New Building Area _____ sq. ft.

5. Volume of New Structure _____ cu. ft.

6. Max. Live Load _____

7. Max. Occupancy Load _____

8. If Industrialized Building: State Approved _____ HUD _____

9. Total Land Area Disturbed _____ sq. ft.

10. Flood Hazard Zone _____

11. Base Flood Elevation _____ ft.

12. Wetlands yes _____ no _____

IIa. PROPOSED WORK

- ☐ Minor Work ☐ New Building ☐ Addition ☐ Demolition
- ☐ Repair ☐ Alteration ☐ Renovation ☐ Reconstruction
- ☐ Asbestos Abat. -Subch. 8 ☐ Lead Hazard Abatement ☐ Radon Remediation ☐ Annual Permit

Electrical

IIb. SUBCODES

(Check all that apply)

- ☐ Building
- ☒ Electrical
- ☐ Plumbing
- ☐ Fire Protection
- ☐ Elevator

FOR OFFICE USE ONLY (Optional)

Est. Cost	Plans Rec'd by	Date Rec'd	Rejection Date	Approval Date	Re-viewer	Resubmission Dates Approval	Rejection	Re-viewer
	<u>CW</u>	<u>3/2/21</u>		<u>3-9-21</u>	<u>ML</u>			

TOTAL COST \$0

III. PLAN REVIEW (optional)

- DO YOU WANT:
1. ☐ Partial Releases
2. ☐ Prototype Processing

IV. DOES OR WILL YOUR BUILDING CONTAIN ANY OF THE FOLLOWING?

1. ☐ Elevators/Escalators/Lifts/ Dumbwaiters/Moving Walks
2. ☐ High Pressure Boilers
3. ☐ Pressure Vessels
4. ☐ Refrigeration Systems
5. ☐ Cross-Connections/Backflow Preventers
6. ☐ Hazardous Uses/Places of Assembly
7. ☐ Sprinklers/Standpipes
8. ☐ Smoke Control Systems in Open Wells
9. ☐ Underground Storage Tanks
10. ☐ Swimming Pools, Spas and Hot Tubs
11. ☐ LPGas Tanks
12. ☐ Fire Alarm

VII. DESCRIPTION OF BUILDING USE

A. RESIDENTIAL (primary use)

1. State Specific Use: _____
2. Use Group, Proposed: _____
3. Change in Use Group, Indicate Present: _____
4. No. of dwelling units: Total Units Income-restricted
- Gained, Sale _____
- Gained, Rental _____
- Lost, Sale _____
- Lost, Rental _____

B. NON-RESIDENTIAL (primary use)

1. State Specific Use: _____
2. Use Group, Proposed: _____
3. Change in Use Group, Indicate Present: _____
- C. MIXED USE -List secondary use(s): _____
- D. Construct. Classification: Present _____ Proposed _____



ELECTRICAL SUBCODE TECHNICAL SECTION



A. IDENTIFICATION—APPLICANT: COMPLETE ALL APPLICABLE INFORMATION. WHEN CHANGING CONTRACTORS, NOTIFY THIS OFFICE. CALL UTILITY DIG NO: 1-800-272-1000.

Block 702 Lot 9 Qualification Code _____

Work Site Location 197 Chambers bridge Rd Brick NJ
08123

Owner in Fee: Ocean Ice Palace

Tel. (732) 4774411 e-mail RAVEN@OCEANHOCKEY.COM

Address 197 CHAMBERS BRIDGE RD BRICK 08123
street municipality zip code

Contractor: Whitewood Electrical Contractors LLC Tel. (973) 543-1994

Address 31 Phoenix Drive e-mail whitewoodelectric@yahoo.com

Mendham, NJ 07945

Contractor License No. 14726 Exp. Date 3/2021

Home Improvement Contractor Registration No. or Exemption Reason (if applicable): _____

Federal Emp. ID No. 22-374-5167 FAX: (973) 543-1994

B. ELECTRICAL CHARACTERISTICS

Use Group Present _____ Proposed _____

[] Pole/Pad # _____ [] Temporary [] Other _____

Building Occupied as _____ Utility Co. _____

Est. Cost of Elec. Work \$ 1100.00

JOB SUMMARY (Office Use Only)

PLAN REVIEW

[] No Plans Required 3-9-21 Type _____ Failure _____ Failure _____ Approval _____ Initial _____

[] Partial Underslab Utilities Approved Rough _____

Date _____ Approved by _____ Barrier-Free _____

[] Electric Plans Approved Trench _____

Date _____ Approved by _____ Temp. Serv. _____

Joint Plan Review Required: Constr. Serv. _____

[] Bldg. [] Plumb. [] Fire. [] Elev. TCO _____

SUBCODE APPROVAL for PERMIT Other _____

Date _____ Service _____

Approved by _____ Final _____

SUBCODE APPROVAL for CERTIFICATE Barrier-Free _____

[] CO [] CGO [] CA Temp. Cut-in Card Date Issued _____

Date _____ Final Cut-in Card Date Issued _____

Approved by _____ Annual Pool Inspection _____

Date _____ Date of Grounding and Bonding _____

Approved by _____ Certification _____

C. CERTIFICATION IN LIEU OF OATH

I hereby certify that I am the (agent of owner of record and am authorized to make this application and perform the work listed on this application.

Applicant sign/Contractor sign and seal here: Leonardo DiGeronimo

Print name here: Leonardo DiGeronimo

[] Licensed Elec. Contractor [] Certif'd Landscape Irrigation Contr [] Exempt Applicant

D. TECHNICAL SITE DATA

DESCRIPTION OF WORK: 4 new circuits for bumper car chargers - refeed existing chargers

QTY. SIZE ITEMS FEE (Office Use Only)

4 60 Lighting Fixtures

Receptacles

Switches

Detectors

Light Poles

Motors—Fract. HP

Emergency & Exit Lights

Communications Points

Alarm Devices/F.A.C. Panel

TOTAL NUMBERS \$

Pool Permit/with UW Lights

Storable Pool/Spa/Hot Tub

KW Elec. Range/Receptacle

KW Oven/Surface Unit

KW Elec. Water Heater

KW Elec. Dryer/Receptacle

KW Dishwasher

HP Garbage Disposal

KW Central A/C Unit

HP/KW Space Heater/Air Handler

KW Baseboard Heat

HP Motors 1+ HP

KW Transformer/Generator

AMP Service

AMP Subpanels

AMP Motor Control Center

KW Elec. Sign/Outline Light

4 20A Dedicated Circuits


120V

Administrative Surcharge \$

Minimum Fee \$

State Permit Surcharge Fee \$

TOTAL FEE \$



Brick Township
401 Chambersbridge Rd
Brick, NJ 08723

Date Issued 03/25/2021
Control Number C-21-000800
Permit Number 21-0588
Permit Issue Date 03/09/2021
Certificate Number 21-0588

Certificate
Construction Code Division
(Certificate of Approval)

Identification

Work Site Location: 197 CHAMBERS BRIDGE RD. Brick Township, NJ Block: 702 Lot: 9 Qual: _____
Owner in Fee: OCEAN ICE PALACE, INC.
Owner Address: 197 CHAMBERS BRIDGE RD BRICK NJ 08723
Telephone: (732) 477-4411
Contractor: WHITEWOOD ELECTRICAL CONTRACTR
Address: 31 PHOENIX DRIVE MENDHAM NJ 07945
Telephone: (973) 543-1994 Fax: _____ Federal Emp. Number: 22-3745167
License Number or Builders Registration Number: _____

Home Warranty Number: _____ Type of Warranty Plan: ☐ State ☐ Private

Use Group: R-5 Construction Classification: _____

Maximum Live Load: 0 Maximum Occupancy Load: 0

Description of Work/Use: ELECTRICAL ALTERATIONS - - OCEAN ICE PALACE ...OUTLETS FOR BUMPER CAR CHARGERS

Certificate Comments:

☐ **Certificate of Occupancy**

This serves notice that said building or structure has been constructed in accordance with the New Jersey Uniform Construction Code and is approved for occupancy.

☒ **Certificate of Approval**

This serves notice that the work completed has been constructed or installed in accordance with the New Jersey Uniform Construction Code and is approved. If the permit was issued for minor work, this certificate was based upon what was visible at the time of inspection.

☐ **Certificate of Continued Occupancy**

This serves notice that based on a general inspection of the visible parts of the building there are no imminent hazards and the building is approved for continued occupancy.

☐ **Temporary Certificate of Compliance**

The following conditions must be met no later than or the owner will be subject to fine or order to vacate:

This certificate has an expiration date of:

Conditions to be met:

☐ **Certificate of Clearance - Lead Abatement 5:17**

This serves notice that based on written certification, lead abatement was performed as per NJAC5:17 to the following extent.

- ☐ Total removal of lead-based paint hazards in scope of work
☐ Partial or limited time period (years); see file

☐ **Certificate of Clearance - Asbestos Abatement**

This serves notice that based on written certification, asbestos abatement was performed to the following extent.

- ☐ Total removal of asbestos hazards in scope of work
☐ Partial or limited time period (years); see file

☐ **Certificate of Compliance**

This serves notice that said potentially hazardous equipment has been installed and/or maintained in accordance with the New Jersey Uniform Construction Code and is approved for use until

☐ **Temporary Certificate of Occupancy**

The following conditions must be met no later than: or the owner will be subject to fine or order to vacate: This certificate has an expiration date of:

Conditions to be met:

Daniel Newman Jr

Construction Official

Date Printed: 03/25/2021

U.C.C. F260 (rev. 08/05)

Fee: \$0.00

Check Number: _____

Collected By: _____



CONSTRUCTION PERMIT

Date Issued 3/9/21
Control # C-21-000800
Permit # 21-0588

IDENTIFICATION Block: 702 Lot: 9 Qualifier _____
Work Site Location: 197 CHAMBERS BRIDGE RD. Brick Township, NJ Contractor WHITEWOOD ELECTRICAL CONTRACTR
Address 31 PHOENIX DRIVE MENDHAM NJ 07945
Owner in Fee OCEAN ICE PALACE, INC.
197 CHAMBERS BRIDGE RD BRICK NJ 08723 Telephone: (973) 543-1994
Telephone: (732) 477-4411 Lic. No. or Bldrs. Reg. No. 14726
Federal Employee No. 22-3745167

Is hereby granted permission to perform the following work:

- ☐ BUILDING ☐ PLUMBING ☐ LEAD HAZARD ABATEMENT
☒ ELECTRICAL ☐ FIRE PROTECTION ☐ DEMOLITION
☐ ELEVATOR DEVICES ☐ ASBESTOS ABATEMENT (Subchapter 8 only) ☐ OTHER

DESCRIPTION OF WORK:

ELECTRICAL ALTERATIONS - OCEAN ICE PALACE ...OUTLETS FOR BUMPER CAR CHARGERS

Note: If construction does not commence within one (1) year of date of issuance, or if construction ceases for a period of six (6) months, this permit is void.

Estimated Cost of Work \$1,100

D. Newman
Construction Official

3/9/21
Date

U.C.C. F170
equiv. (rev 1/04)

1 WHITE - INSPECTOR

2 CANARY - OFFICE

3 PINK - TAX ASSESSOR

4 GOLD - APPLICANT

PAYMENTS (Office Use Only)

Building _____ \$0
Electrical _____ \$400
Plumbing _____ \$0
Fire Protection _____ \$0
Elevator Devices _____ \$0
Other _____ \$0.00
DCA Training Fee _____ \$2
CO Fee _____
Other _____ \$0
Total _____ \$402

Check No. _____
Cash _____ \$0
Credit _____ \$0
Collected By _____ \$0

REQUIRED INSPECTIONS

Construction work must be inspected in accordance with the State Uniform Construction Code Regulations N.J.A.C. 5:23-2.18. This agency will carry out such periodic inspections during the progress of work as are necessary to insure that the work installed conforms with the requirements of the Uniform Construction Code.

The owner or other responsible person in charge of work must notify this agency when work is ready for any required inspections specified below. Requests for inspections must be made at least 24 hours prior to the time the inspection is desired. Inspections will be performed within three business days of the time for which they are requested. The work must not proceed in a manner which will preclude the inspection until it has been made and approval granted.

☐ Required inspections for all subcodes for one- and two-family dwellings are as follows:

1. The bottom of footing trenches before placement of footings, except that in cases of pile foundations, inspections shall be made in accordance with the requirements of the building subcode.
2. Foundations and all walls up to grade level prior to back filling.
3. All structural framing, connections, wall and roof sheathing and insulation; electrical rough wiring, panel and service installation; rough plumbing. The framing inspection shall take place after the rough electrical and plumbing inspections and after the installation of the heating, ventilation and /or air conditioning duct system. The insulation inspection shall be performed after all other subcode rough inspections and prior to the installation of any interior finish material.
4. Installation of all finished materials, sealings of exterior joints, plumbing piping, trim and fixtures; electrical wiring, devices and fixtures; mechanical systems equipment.


Additional required inspections for all subcodes of construction, for other than one- and two-family dwellings, are fire suppression systems, heat producing devices and Barrier Free subcode accessibility, if applicable.

☐ Required special inspections. The applicant by accepting the permit will be deemed to have consented to these requirements:

☒ A final inspection is required for each applicable subcode area before a final Certificate of Occupancy or Approval may be issued. The final inspections include the installation of all interior and exterior finish materials, sealing of exterior joints, mechanical system and other required equipment; electrical wiring, devices and fixtures; plumbing pipes, trim and fixtures; tests required by any provision of the adopted subcodes, Barrier Free accessibility, if applicable; and verification of compliance with NJAC 5:23-3.5, "Posting structures".

☐ A complete copy of released plans must be kept on the job site.

If you do not understand any of this information, please ask.



Mechanical characteristics

Shell material: Aluminum
Outline dimension: L*W*H=185×150×72mm
Input socket: meets IEC standard
AC wires: 1.5m length
DC wires: 1.0m length
Net Weight: 1.5Kg

Main parameter

Max. OutputPower	480W
Input Voltage	179-265Vac & 88-132Vac & 88-265Vac
Output Voltage	24V+/-0.5Vdc
Output Voltage Tolerance	±0.5
Output Current	15A
Output Current Tolerance	±1
Certification	CE

Environmental condition

Humidity	5~95%
Altitude	≤3000m

Smart design , Higher efficiency

- 1 Fully automatic, pref-charge, constant current, constant voltage, a trickle, Automatic power off once full of power.
- 2 high precision current voltage locking, ensure full, no over charge.
- 3 Over current, over voltage, short circuit, over temperature, reverse connect protection, safe and reliable.
- 4 80% ~ 90% conversion efficiency, power factor>=0.9, efficient environmental protection.
- 5 Digital & light display, all aluminum shell, strong & durable.
- 6 European CE, safety certification, export quality.
- 7 Patent technology, quality assurance.

Multy protection

- | | | |
|-------------------------------|---|---|
| 1 Over Voltage Protection | √ | |
| 2 Voltage-limiting protection | √ | The charger software limits the maximum output voltage to a level suitable for the connected battery system. |
| 3 Thermal Protection | √ | |
| 4 Current-limiting Protection | √ | |
| 5 Short-circuit Protection | √ | Short circuit protection should be automatically recovery after remove the condition. |
| 6 Reverse Polarity Protection | √ | When output wires are reversely connected to the battery the charger will not operate and will work normally when DC wires are correctly connected. |
| 7 Temperature Compensation | √ | |

Optional input lead wire/plug

√ Optional output connector √

Application

Forklift truck
Electric cars
Battery car
Automatic carrier
Sweeping machine

