

BLOCK 1170 LOT 5 ADDRESS (SITE) _____ PERMIT NO. 1638-92 ^{update}

RECEIVED

AUG 14 1992



CONSTRUCTION PERMIT APPLICATION

Applicant Completes: Subparts I, II, III (optional), IV, VI and VII

I. IDENTIFICATION

1. Proposed Work-site at: Rte 70 & 98

2. Name of Owner in Fee: Price Club Tel. (____) _____

Address _____ street _____ municipality _____ zip code _____

3. Ownership in Fee: Public _____ Private _____ A.J. Carnegie Inc.

4. Principal Contractor: Seacoast Builders Tel. (908) 299-3930

Address Frederick, N.J. NO Brunswick, N.J. 08902

License No. OR, if new home, Builder Reg. No. _____ Exp. Date _____

Federal Emp. No. 21-1994436 Social Security No. _____

5. Architect or Engineer _____ Tel. (____) _____

Address _____

6. Responsible Person In Charge of Work A.J. Carnegie Tel. (908) 299-3930

II. PROPOSED WORK

1. ☐ Minor Work (single trade)
2. ☐ Small Job (\$5,000 and no prior approvals)
3. ☐ New Building
4. ☐ Addition
5. ☐ Alteration
6. ☒ Fire Protection
7. ☐ Plumbing
8. ☐ Electrical
9. ☐ Asbestos Abatement
10. ☐ Demolition

TOTAL COSTS

Est. Cost

165,000

OPTIONAL (for office use only)

Plans Rec'd By	Date Rec'd	Rejection Date	Approval Date	Re-viewer	Resubmission Dates	Re-viewer
<u>ye</u>	<u>8/14/92</u>				<u>11/20/92</u>	<u>ye</u>

III. DO YOU WANT: (optional) 1. ☐ Partial Releases 2. ☐ Prototype Processing

IV. DOES OR WILL YOUR BUILDING CONTAIN ANY OF THE FOLLOWING?

1. ☐ Elevators/Escalators/Lifts/Dumbwaiters/Moving Walks
2. ☐ High Pressure Boilers
3. ☐ Pressure Vessels
4. ☐ Refrigeration Systems
5. ☐ Cross-Connections/Backflow Preventers
6. ☐ Hazardous Uses/Places of Assembly
7. ☐ Sprinklers
8. ☐ Smoke Control Systems in Open Wells
9. ☐ Underground Storage Tanks

V. FEE SUMMARY (for office use only)

		Update	Update
1. Building	\$		
2. Electrical			
3. Plumbing			
4. Fire Protection			
5. Other <u>Sprinklers</u>			
6. Subtotal	\$		
7. Less 20% for State Plan Review			
8. Subtotal <u>Other</u>	\$		
9. DCA Training Fee			
10. Subtotal	\$		
11. Cert. of Occupancy			
12. Other <u>15</u>			
13. TOTAL	\$	<u>916-936</u>	

VI. BUILDING/SITE CHARACTERISTICS

1. Number of Stories _____
2. Height of Structure _____ ft.
3. Area—Largest Floor _____ sq. ft.
4. Building Area—All Floors _____ sq. ft.
5. Volume of Structure _____ cu. ft.
6. Construction Classification _____
7. Total Land Area Disturbed _____ sq. ft.
8. Flood Hazard Zone _____
9. Base Flood Elevation _____ ft.
10. Wetlands yes _____ sq. ft.
no _____
11. Fire Grading _____
12. Max. Live Load _____
13. Max. Occupancy Load _____

VII. DESCRIPTION OF BUILDING USE

A. RESIDENTIAL

1. ☐ Hotels (R-1)
2. ☐ Multi-Family (R-2)
3. ☐ Two-Family (R-3) BOCA
4. ☐ Two-Family (R-4) CABO
5. ☐ One-Family (R-3) BOCA
6. ☐ One-Family (R-4) CABO
- No of dwelling units: _____
- Before Construction _____
- After Construction _____
- Net gain or loss _____

B. NON-RESIDENTIAL

1. State Specific Use: _____
2. Use Group: _____
3. Change in Use Group. Indicate Former: _____

CERTIFICATION IN LIEU OF OATH

I. OWNER SECTION (to be completed if the applicant is the owner in fee)

I hereby certify that I am the owner in fee of the property listed on Page 1.

Mark the following applicable boxes:

- A. ☐ I further certify that a new home (private residence) will be constructed on this property for my own use and occupancy. This dwelling is to be occupied by myself and is not to be used for any purpose other than single family residential use. I attest that all construction, plumbing, or electrical work will be done, in whole or in part, by me or by subcontractors under my supervision, in accordance with all applicable laws; and, I further acknowledge that said new home is not covered under the New Home Warranty and Builders Registration Act (N.J.S.A. 46:3B-1 et seq.) and that such fact shall be disclosed to any person purchasing this property within ten years of the date of issuance of a certificate of occupancy.

I UNDERSTAND THAT IN MARKING BOX A, I ACKNOWLEDGE THAT I AM ASSUMING RESPONSIBILITY FOR THE WORK DONE ON SAID PROPERTY, THE CONDITION OF THE PROPERTY PRIOR TO, DURING, AND AFTER ANY WORK PERFORMED, AND FOR THE PERFORMANCE OF THE SUBCONTRACTORS I HIRE, EMPLOY, OR OTHERWISE CONTRACT OR WITH WHOM I MAKE AGREEMENTS TO PERFORM WORK. I AM VOLUNTARILY AND KNOWINGLY ASSUMING THIS RESPONSIBILITY.

- B. ☐ I further certify the following as required by the New Jersey Uniform Construction Code, N.J.A.C. 5:23-2.15(e)1.vii:

I personally prepared the plans submitted for: 1) the new home referred to in A.; or, 2) an addition, alteration, renovation, or repair to an existing single family residence owned and occupied by myself and located on the property listed on Page 1; or, 3) a new structure that will be physically separate from, but that will be deemed part of, an existing single family residence that is owned and occupied by myself and located on the property listed on Page 1.

- C. ☐ I further certify that I will perform or supervise the following work:

C.1. ☐ Building C.2. ☐ Fire Protection

I further certify that I will perform the following work:

C.3. ☐ Electrical C.4. ☐ Plumbing

- D. ☐ I agree to advise all contractors on this project that they are required to be registered with the New Jersey Division of Taxation and to comply with all New Jersey tax laws.

I further certify the following as required by the Uniform Construction Code, N.J.A.C. 5:23-2.15(a)5: All required State, county, and local prior approvals have been given, including such certification as the construction official may require.

I understand that if any of the above statements are willfully false, I am subject to punishment.

Signature _____ Date _____

II. AGENT SECTION

(to be completed if the applicant is not the owner in fee)

I hereby certify the following as required by the New Jersey Uniform Construction Code, N.J.A.C. 5:32-2.15(d): the proposed work is authorized by the owner in fee; and I have been authorized by the owner in fee to make this application as his agent.

I further certify the following as required by the Uniform Construction Code, N.J.A.C. 5:23-2.15(a)5: All required State, county, and local prior approvals have been given, including such certification as the construction official may require.

I agree to advise all contractors on this project that they are required to be registered with the New Jersey Division of Taxation and to comply with all New Jersey tax laws.

I understand that if any of the above statements are willfully false, I am subject to punishment.

☐ Check if contractor.

Agent Name _____

Address _____

Telephone (____) _____

Signature _____ Date _____

OFFICE DATE RECEIVED: _____

VIII. PRIOR APPROVALS CHECKLIST (office use only)	LOCAL APPROVAL		COUNTY APPROVAL		REGIONAL APPROVAL		STATE APPROVAL		COMMENTS
	Prelim. Initial	Final Date	Prelim. Initial	Final Date	Prelim. Initial	Final Date	Prelim. Initial	Final Date	
☐ Planning Board									
☐ Zoning Board									
☐ Sewer Authority									
☐ Water Authority									
☐ Fire Department									
☐ Police Department									
☐ Health Department									
☐ Soil Conservation									
☐ N.J. Dept. of Community Affairs									
☐ N.J. Department of Transportation									
☐ N.J. Dept. of Environmental Protect.									
☐ Utility Dig No.									
☐ Other									
☐									
☐									

IX. SUBCODES AND SPECIAL REGULATIONS APPLICABLE (office use only—optional)

Name of Code & Edition	Name of Code & Edition	Other
Building _____	Energy _____	
Electrical _____	Barrier Free _____	
Plumbing _____	Flood Hazard _____	
Fire Protection _____	As Built Elevation Cert. _____	
Mechanical _____	Other _____	

X. CERTIFICATES ISSUED (office use only)

☐ Temporary Certificate of Occupancy	No. _____	DATE EXPIRED _____
☐ Temporary Certificate of Occupancy	No. _____	
☐ Continued Certificate of Occupancy	No. _____	
☐ Certificate of Occupancy	No. _____	
☐ Certificate of Approval	No. _____	



PERMIT UPDATE

Date Update Issued
Control #
Permit #
Date Permit Issued

8/25/92
1638-92

IDENTIFICATION Block 1170 Lot 5, 6, 6.01 x 6.02
Work Site Location Rt 20 x 88 Contractor Sea Coast Beds Corp.
Owner in Fee The Price Co. Address _____
Address _____ Tele. (____) _____
Lic. No. or Bldrs. Reg. No. _____
Tele. (____) _____ Federal Emp. No. _____ 1638**
or Social Security No. _____ B10CK 0.00

is hereby granted permission to perform the following work:

☐ BUILDING ☐ PLUMBING ☐ Other _____

☐ ELECTRICAL ☒ FIRE PROTECTION

DESCRIPTION OF WORK:

Sprinkler Syst

Estimated Cost of Work \$ _____

[Signature]
CONSTRUCTION OFFICIAL

PAYMENTS (Office Use Only)		1170 #
Building	LOT	0.00
Plumbing	LOT	0.00
Electrical	J #	
Fire Protection	FIRE	1.00
Other <u>Fire Protection</u>	BUILDING	0.00
Other	TREES	15.00
Other	TOTAL	16.00
DCA Training Fee	CHECK	16.00
Cert. of Occ.	CHARGE	0.00
Other <u>Trees</u>		
Total		32.00
Check No.		756 12/14/92
Cash		
Collected By:		<u>[Signature]</u>

Submittal Data For FIRE PUMPS

NO. OF PRINTS	
10	For Approval
	Final
	Reproducible

SALES OFFICE: New Jersey PO#: _____
 Factory Order #: _____ Service: _____
 Job: Price Club
 Engineer: _____
 Contractor: A.S. Carnegie
 Sold To: _____ PO#: _____
 Reference: Main Fire Pump

PUMP	MOTOR	OPTIONS
Number of Units <u>1</u>	HP: <u>100</u>	Base:
Model <u>5-481-11C</u>	Phase: <u>3</u>	☐ Steel Drip Rim
Size <u>5X6X11C</u>	Hertz: <u>60</u>	☒ Steel Form
GPM <u>1000</u>	Volts: <u>460</u>	☐ Fabricated Steel
TDH <u>289' (125psi)</u>	RPM: <u>3560</u>	☐ Cast Iron Ring Type
RPM _____	Frame: <u>365TS</u>	
Connections:	Enclosure:	Coupling:
☐ Threaded	☒ ODP	Mfg: <u>Lovejoy</u>
☒ Flanged	☐ TEFC	Size: _____
☐ 125#	☐ X Proof	☐ Spacer
☐ 250#	☐ Vertical	☒ Guard
Lubrication:	☒ Horizontal	Test:
☒ Grease	☐ Part Winding	☒ Certified Performance
☐ Oil	☐ Hi Efficiency	☐ Wit. Certified Performance
Stuffing Box:	☒ Aurora To Furnish	☐ Hydro
☒ Packing	☐ Others To Furnish	☐ _____
☐ Lantern Ring	☒ Factory Choice	
Case _____	Mfg: _____	
Imp. _____		
Shaft _____		
Sleeve _____		
Case Ring _____		
Imp. Ring _____		

NOTE: Motor not mounted at factory on vertical units.

SPECIAL REQUIREMENTS

CERTIFIED PRINT: Section: 912 Page: 407 Curve Number: PC-123056
 Special: _____ Maintenance Sent: _____
 By: B. Casey Date: 8/10/92 Office: NJSO


This order will not be processed for manufacturing until approval is received. Prints are not to scale and are certified correct only for this order. All orders are subject to acceptance at Aurora Pump, North Aurora, Illinois.

AURORA MODEL 481 PUMPS

ON STANDARD STEEL BASE

SECTION 912 PAGE 251

DATED JANUARY 1992



RIGHT HAND ROTATION

LEFT HAND ROTATION

NOTES

1. All dimensions are in inches.
2. Dimensions may vary $\pm 3/8$ ".
3. Not for construction purposes unless certified.
4. Coupling gap may vary $1/8$ " to $2-1/16$ ".
5. Conduit box is shown in approximate location. Dimensions are not specified as they vary with each motor manufacturer.
6. Suction and discharge flanges are American Standard flat face.


* 0 is 10-1/2" when using frames 324TS - 365TS.

* 0 is 12 when using frames 404TS - 445TS.


PUMP SIZE			SERIES	OPTIONAL 1250 SECTION FLANGES.										OPTIONAL 2500 SECTION FLANGES										MOTOR FRAME																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																								
DISCH	MODEL	CASE BORE		0	S	W	X	Z	CP	HY	YY	ZZ	2500 DISCHARGE FLANGES	2500 DISCHARGE FLANGES	2500 DISCHARGE FLANGES	2500 DISCHARGE FLANGES																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																
2-1/2	481	10	3	2	8	4	13-1/2	9-3/4	4	24	5	10	3/4	APPROX	18	12	23	22	24	24	25	26	26	28	28	30	30	32	32	35	34	36	36	40	4457																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																													
3	481	10	4	3	9 m	4-1/2	13-1/2	10	4-1/2	24	5	11		BASE	5	7	9	-	9	-	10	-	10	-	-	-	-	-	-	-	-	-	-	-	4457																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																													
4	481	11	5		10	5	14-1/2	11-1/4	5	26	6	12-3/4		BASE	5	7	9	9	11	11	11	11	11	11	11	11	11	15	15	15	-	-	-	-	4457																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																													
4	481	16	6	3	11	6-1/2	14-1/2	11	6-1/2	36	6	14		BASE	7	9	9	9	11	11	11	11	11	11	11	11	11	16	16	16	-	-	-	-	4457																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																													
5	481	11	6		11 mm	5-1/2	16	11-1/4	5-1/2	28-1/2	6	13-1/4		BASE	7	9	10	11	11	11	11	11	11	11	11	11	12	12	15	-	15	-	-	-	4457																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																													
5	481	15	6	4	12-1/2	6-1/4	16	13-1/4	6-1/4	28-1/2	6	15		BASE	7	9	10	11	11	11	11	11	11	11	11	11	12	12	12	15	15	15	15	15	15	4457																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																												
5	481	17	6		12-1/2	6-1/4	16	14	6-1/4	28-1/2	6	15		BASE	7	9	10	11	11	11	11	11	11	11	11	11	12	12	12	15	-	15	-	-	4457																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																													
6	481	11	6		12-1/2	6-1/4	16	11-3/4	6-1/4	28-1/2	6	14-1/2	1-1/4	BASE	7	9	10	11	11	11	11	11	11	11	11	11	12	12	12	15	-	15	-	-	4457																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																													
6	481	15	6		13-1/2	6-3/4	16	14-1/4	6-3/4	32	7	16-3/4		BASE	-	11	12	12	12	12	12	12	12	12	12	12	12	12	12	-	15	-	15	-	4457																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																													
6	481	18	6		14-3/4	8	18	16	8	32	7	18		BASE	10	11	12	12	12	12	12	12	12	12	12	12	12	12	12	13	13	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	15	1

1000 G.P.M. SERIES 912 ELECTRIC MOTOR DRIVE

SECTION 912 PAGE 407
DATED NOVEMBER 1990



120
TO
200
PSI.



90
TO
160
PSI.


FIRE PUMP ACCESSORIES LIST

- ☒ ECCENTRIC SUCTION REDUCER
SIZE 8X6
☒ 125•
☐ 250•
- ☒ CONCENTRIC DISCHARGE INCREASER
SIZE 5X6
☒ 125•
☐ 250•
- ☐ OUTSIDE HOSE MANIFOLD
SIZE 8"
☒ 125•
☐ 250•
- ☒ HOSE VALVE 2-1/2" W/CAPS AND CHAINS
☐ TEE (REDUCING)
SIZE _____
☐ 125•
☐ 250•
- ☐ BALL DRIP VALVE
SIZE _____
- ☒ SUCTION AND DISCHARGE GAUGES, SIZE 1/4 NPT
- ☒ AIR RELEASE VALVE
SIZE 1/2"
- ☒ MAIN RELIEF VALVE
SIZE 4X4
☐ KUNKLE
☒ CLAYTON
☒ 125•
☐ 250•
- ☒ CASING RELIEF VALVE, SIZE 3/4 NPT
- ☒ WASTE CONE
SIZE _____
☐ OPEN
☒ ENCLOSED
- ☐ SPLASH SHIELD
☐ HORIZONTAL
☐ VERTICAL
- ☐ FLOW METER
☐ PRESSURE RECORDER
-
-

GS AURORA PUMP

A UNIT OF GENERAL SIGNAL
800 AIRPORT ROAD, NORTH AURORA, ILLINOIS 60542

FLOAT OPERATED AIR RELEASE VALVE




PRESSURE RATING		A	B	C
☒	UP TO 175 PSI	$5 \frac{7}{8}$	$3 \frac{3}{4}$	$2 \frac{1}{2}$
☐	UP TO 300 PSI	$6 \frac{11}{16}$	$5 \frac{5}{8}$	$4 \frac{1}{4}$


SUCTION & DISCHARGE GAUGES

SUCTION GAUGE	
☒	30"-0-150 PSI
☐	30"-0-300 PSI
DISCHARGE GAUGE	
☒	0-300 PSI
☐	0-600 PSI

ACCURACY: 2% OVER
CENTER THIRD OF RANGE.
3% OVER REMAINING
TWO-THIRDS OF RANGE.



RELIEF VALVE




SIZE	A	B	C	D
1/2	6	1 5/8	2	1/2
3/4	6	1 5/8	2	3/4
1	6 7/8	1 7/8	2 1/4	1

ECCENTRIC SUCTION REDUCER

125 • ☒
 250 • ☐


	A	B	L
	4	3	7
	5	4	8
	6	5	9
☒	8	6	11
	10	8	12
	14	12	16



CONCENTRIC DISCHARGE INCREASER

125 • ☒
 250 • ☐


	A	B	L
	3	2-1/2	7
	5	3	8
	5	4	8
	6	4	9
☒	6	5	9
	8	5	11
	8	6	11
	10	6	12
	10	8	12
	12	10	14




OUTSIDE HOSE MANIFOLD

125# □


250# □




6" FLANGE
2 VALVE CONNECTIONS



8" FLANGE
4 VALVE CONNECTIONS




10" FLANGE
6 VALVE CONNECTIONS



12" FLANGE
8 VALVE CONNECTIONS

HOSE VALVES WITH CAPS & CHAINS




PSLRTG	A	B	C	D
175	2 1/4	2 7/8	10 1/4	6
300	2 5/8	2 5/8	11	6

NOTE: ALL DIM. ARE BY VENDOR STD.

GS AURORA PUMP


A UNIT OF GENERAL SIGNAL
800 AIRPORT ROAD, NORTH AURORA, ILLINOIS 60542

MAIN RELIEF VALVE - KUNKLE



125° OR 250° INLET, 125° OUTLET				
SIZE	GPM	A	B	C
3	280, 500	21-1/4	5-7/8	6-1/8
4	750, 1000	22-5/8	6-7/16	6-5/8
6	1250-2500	29-1/4	8-1/2	9-3/8

MAIN RELIEF VALVE - CLA-VAL



125° INLET, 125° OUTLET				
SIZE	GPM	A	B	C
3	250, 500	6	4	18-3/4
4	750, 1000	7-1/2	5-1/16	17-7/16
6	1250-2500	10	6	20-1/2
8	3000-4000	12-3/4	8	24-1/4


250° INLET, 125° OUTLET				
SIZE	GPM	A	B	C
3	250, 500	8-1/2	4-3/8	16-3/8
4	750, 1000	9-7/8	5-1/4	17-1/4
6	1250-2500	10-1/2	6-1/2	19
8	3000-4000	13-1/4	8-1/2	24-1/4

GS AURORA PUMP

A UNIT OF GENERAL SIGNAL
800 AIRPORT ROAD, NORTH AURORA, ILLINOIS 60042

OPEN WASTE CONE

GPM	A	B	C
250			
500	3	5	10
750			
1000	4	8	11
1250			
1500			
2000	6	10	14
2500			
3000			
3500	8	14	16
4000			




NOTES

1. FLANGES A & B ARE ASA 125# RATING.
2. WASTE CONES FOR 250 THROUGH 2500 GPM SYSTEMS ARE CAST IRON.
3. WASTE CONES FOR 3000 THROUGH 4000 GPM SYSTEMS ARE FABRICATED STEEL.

ENCLOSED WASTE CONE

GPM	A	B	C
250			
500	3	5	10
750			
1000	4	8	11
1250			
1500			
2000	6	10	14
2500			
3000			
3500	8	14	16
4000			



NOTES

1. FLANGES A & B ARE ASA 125# RATING.
2. WASTE CONES FOR 250 THROUGH 2500 GPM SYSTEMS ARE CAST IRON.
3. WASTE CONES FOR 3000 THROUGH 4000 GPM SYSTEMS ARE FABRICATED STEEL.

FIRE PUMP CONTROLLER

☒ CLARK ☐ MASTER ☐ FIRETROL ☐ METRON ☐ FURNAS

☒ COMBINATION MANUAL-AUTOMATIC

☐ PRIMARY RESISTOR TYPE

☐ PART WINDING TYPE

☐ LIMITED SERVICE TYPE

☐ WITH RUNNING PERIOD TIMER

☐ WITHOUT RUNNING PERIOD TIMER

☒ WYE-DELTA START

☒ OPEN TRANSITION

☐ CLOSED TRANSITION

30,000 AMPS C.B. INTERRUPT CAPACITY

0-300 P.S.I. RANGE PRESSURE SWITCH

50 P.S.I. SUCTION PRESSURE

FOR 100 H.P., 3500 R.P.M., 3 PHASE, 60 HZ., 460 V. MOTOR

SPECIAL OPTIONS:

Wye-Delta Type-Open Transition



GENERAL

Joslyn Clark Fire Pump Controllers, fully comply with the National Fire Protection Association Standard NFPA-20, are listed by Underwriters' Laboratories, Inc. and are approved by Factory Mutual.


Wye-Delta type reduced-current starting is selected to meet local power utility limitations on inrush current or to minimize the size of a stand-by engine generator.

Bulletin C10690 are open transition starters in which the motor circuit is opened during the transition from start to run. Under a normal automatic start mode, the start contactors close connecting the motor to the line in a wye connection. After approximately 3 second time delay the start contactors open and the run contactor closes reconnecting the motor in a Delta connection.

Starting line current is 33.3% of across-the-line starting inrush (approximately 200% rated motor full load amperes) and starting torque is approximately 33.3% of normal starting torque.


STANDARD EQUIPMENT & PERFORMANCE

- Automatic start responsive to water pressure, with Running Period Timer. Terminal board jumper provided for manual stop operation.
- Deluge valve start or start from other fire protection equipment control having a normally closed contact which opens to start.
- Emergency start, by simply lifting the mechanical start handle. (Will energize delta contactors only)
- Choice of circuit breaker interrupting capacity ratings.
- Joslyn Clark Controls Locked Rotor Protector for drive motor protection. Factory set for the horsepower ordered. No field adjustment.
- Contacts for remote alarm of:
 1. Controller in "pump running" condition.
 2. Loss of line power in any phase.
 3. Phase reversal.
- Heavy gauge formed steel, NEMA 2 enclosure with top drip hood.
- Neutral grounding lug - "Suitable for use as service equipment".
- Voltage surge protection.



LISTED MODIFICATIONS





- Sequence start, addition of independent Sequence Timer.
- Lockout for low suction or for dual engine drive.
- Automatic transfer switch, modification "T"



U_L FM

ENCLOSURE B

FRONT VIEW



SPACE AVAILABLE FOR
ELECTRICAL CONDUIT
ENTRY.

DWG "B"

WYE DELTA CONTROLLER Motor Connections A10-10680-4	TYPE CIR. BKR. (See Table 1)	HORSEPOWER RANGE					DIM. INCHES 2					
		200-208V	220-240V	440-480V	550-600V	380/50HZ	A	B	C	D	E	ENC. STYLE
WITHOUT TRANSFER SWITCH												
SCHEMATIC DIAGRAM A10-10690-1	B&C	15-75	15-100	15-200	15-200	15-150	19	24	—	22	18 1/2	A
FIELD CONNECTIONS A10-10680-2	B&C	100-150	125-200	250-450	250-500	200-350	19	39	—	37	33 1/2	A
OPERATING INFORMATION B10-10600-1	D	75-150	100-200	200-400	—	150-350	19	39	—	37	33 1/2	A
WITH TRANSFER SWITCH												
SCHEMATIC DIAGRAM A10-10690-1T	B&C	15-75	15-100	15-200	—	15-150	24	22	48	—	18 1/2	B
FIELD CONNECTIONS A10-10680-2T	B&C	100-150	125-200	250-450	—	200-350	39	37	63	—	33 1/2	B
OPERATING INFORMATION B10-10600-1T	D	75-200	100-250	200-400	—	150-350	39	37	63	—	33 1/2	B

NOTE:

¹For 550-600V Controllers "C" Type Circuit Breakers are available from 15 through 125 Hp only.

²Dimensions are for Type 2, 3R & 12 enclosures.

JOB: Price club

MOTOR HORSEPOWER 100

LINE VOLTAGE / PHASE / FREQUENCY

460 , 3 , 60

CONTROLLER WITHSTAND RATING

30,000 SYMMETRICAL AMPERES

TABLE 1
CONTROLLER WITHSTAND RATING
CIRCUIT BREAKER INTERRUPTING CAPACITY SYMMETRICAL AMPERES



C.B. DESIGNATION	200-208V	220-240V	440-480V	550-600V	380/50/12
B	42K	42K	30K	22K	30K
C	100K	100K	100K	100K	100K
D	150K	150K	150K	150K	150K

Joslyn Clark Controls, INC.
P.O. Box 945
Lancaster, SC 29720
(803) 286-8491

1-06901-01A

SUITABLE FOR USE AS SERVICE EQUIPMENT SCHEMATIC DIAGRAM



REVISED PER
EON 5434, JND
12/14/90
REVISED RPT
CIRCUIT, EON
5027, JND



CONTROL TRANSFORMER PRIMARY CONNECTIONS		
LINE VOLTAGE	CONNECT TO	CONNECT JUMPER
200 - 208	H1 H2	- - -
220 - 240	H1 H2	H1 TO H3 H2 TO H4
380	H1 H2	- - -
440 - 480	H1 H2	H2 TO H3
550 - 600	H1 H2	- - -

SEE TABLE FOR
PRIMARY CONN.

- NOTE 1: REMOVE JUMPER "A" IF REMOTE START IS USED.
- NOTE 2: REMOVE JUMPER "B" IF DELUGE IS USED.
- NOTE 3: REMOVE JUMPER "C" IF MANUAL STOP IS REQUIRED WHEN RPT TIMER IS SUPPLIED.
- NOTE 4: MANUAL STOP (MOD. A) IS SPECIFIED. ST TIMER IS FURNISHED WHEN SEQUENCE START (MOD. B) IS SPECIFIED. SET AT 5 SECONDS.
- NOTE 5:



- FIELD TERMINAL BOARD CONNECTIONS
- TO ALARM CIRCUIT (IF USED) 240 VOLTS, 5 AMP AC MAX.
- INTERNAL DEVICE TERMINAL IDENTIFICATION
- () TERMINAL NUMBER ON DEVICE

REFER TO 810-10690-1
FOR OPERATING INSTRUCTIONS.

TITLE BL. C10690 FIRE PUMP CONTROLLER
WYE-DELTA OPEN TRANSITION STARTING.

MADE BY M.S. App'd BY SRK
DATE 08/17/90

JOSLYN CLARK CONTROLS, INC.
LANCASTER, S.C. 29721-0945

A10-10690-1



SHEET 1 OF 1 SHEET

2-08901-01A

FIELD CONNECTIONS

REVISIONS
RELEASED PER
ECN 5434. JMD

CONTROLLER TERMINAL BOARDS



LINE TERMINAL LUG SIZE PER PHASE

HORSE POWER					LUG SIZE - CU
200 V.	230 V.	380 V.	460 V.	575 V.	
15	15	15-30	15-40	15-50	(1) #14-2 AWG
20-25	20-30	40-50	50-60	60-75	(1) #14-1/0 AWG
30-50	40-60	60-100	75-125	100-125	(1) #6 AWG-250 MCM
60	75	125	150	150-200	(1) #6 AWG-350 MCM
75-150	100-200	150-350	200-400	250-500	(2) 3/0-500 MCM
---	---	---	450	---	(2) 1AWG-500 MCM
MOTOR TERMINAL LUG SIZE PER LEAD					
15-50	15-50	15-75	15-100	15-125	(1) #8-2/0 AWG
60-75	60-100	100-150	125-200	150-200	(1) #6 AWG-250 MCM
100-150	125-200	200-350	250-450	250-500	(1) #4 AWG-500 MCM

NOTE: THERE ARE (6) MOTOR LEADS. EACH MOTOR LEAD CARRIES 0.578 x FLA.

FOR POWER WIRE SIZING REFER TO THE NATIONAL ELECTRICAL CODE, NFPA 70.

JUMPER NOTES

- JUMPER A - REMOVE IF REMOTE START IS USED.
JUMPER B - REMOVE IF DELUGE IS USED.
JUMPER C - REMOVE IF MANUAL STOP IS REQUIRED WHEN RPT TIMER IS SUPPLIED.

NOTE 1: ALL ALARM CONTACTS SHOWN IN ALARM STATE AND RATED 5A 240 VOLTS.

TITLE BUL. 10680 & 10690 FIRE PUMP CONTROL

WYE-DELTA STARTING OPEN OR CLOSED TRANSITION

MADE BY MLS
APP'D BY EFK
DATE 09-5-90



JOSLYN CLARK CONTROLS, INC.

LANCASTER, S.C. 29721-0945

A10-10680-2

SHEET 1 OF 1 SHEET

A10-10680-4
SHEET 1 OF 1 SHEET



This drawing is for general information only. Refer to motor connection diagram for motor manufacture's specific wiring arrangement. Joslyn Clark Controls, Inc. assumes no liability for incorrect wiring of the motor to the controller.

A 10-17580-4

REVISIONS

RELEASED PER
EON 5434. JMD

11/8/90
ADDED DUAL VOL.
TO HEADING &
WARNING. JMD
ECN 5496.

MADE BY _____ MLS _____

APP'D BY _____
EEX

DATE 06-25-90

TITLE BUL. 10680 & 10690 FIRE PUMP CONTROL WITH DR

WITHOUT AUTOMATIC TRANSFER SWITCH -

WYE-DELTA STARTING OPEN OR CLOSED TRANSITION



JOCKEY PUMP CONTROLLER

☒ CLARK ☐ MASTER ☐ FIRETROL

☐ WITH RUNNING PERIOD TIMER

☒ WITHOUT RUNNING PERIOD TIMER

☐ WITH CONTROL TRANSFORMER

☒ WITHOUT CONTROL TRANSFORMER

_____ P.S.I. RANGE PRESSURE SWITCH
2 HP 30 RPM 3 PHASE, 60hz, 460 V. MOTOR

ALARM PANEL

☐ TYPE A

☐ TYPE B

☐ TYPE D

FIRE PUMP P.O. # _____

JOCKEY PUMP P.O. # _____

BY: _____

DATE: _____

NEW JERSEY BRANCH
433 N. MIDLAND AVE.
SADDLE BROOK, N.J. 07662
FAX: 201-791-3003
PHONE: 201-791-0200
NYC: 212-736-4146

JOCKEY PUMP CONTROLLERS-TYPE HPJ

Across The Line - Full Voltage - Automatic Type


DESCRIPTION

JOSLYN CLARK™ Type HPJ Jockey Pump Controllers are Listed by Underwriters Laboratories, Inc. in compliance with Standard UL-508 and meet NEMA Industrial Control Standards. These controllers are fusible switch combination, across the line, full voltage, automatic type in a TYPE 1 wall mounting enclosure.

STANDARD EQUIPMENT

- Full Voltage, Across The Line
- Suitable for application on 600 Volt maximum circuits capable of delivering 150,000 Amperes RMS symmetrical when equipped with Type J or Type R fuses.
- Fusible Disconnect Switch Combination
- Disconnect switch external operator mechanically interlocked with enclosure door and equipped for padlocking in "off" position.
- Pressure switch externally mounted to minimize electrical parts exposure to water and provide easy installation.
- Independent "high" (stop) and "low" (start) adjustment points on pressure switch; sealable for lamp-resistance.
- Automatic start, manual electric start and stop from front-mounted "Hand-Off-Auto" selector switch.
- JOSLYN CLARK™ Type HP NEMA rated magnetic motor starter with built-in overload protection-adjustable $\pm 15\%$ of heater element rating.
- TYPE 1 formed steel wall mounting enclosure. UL listed for withstand ratings up to 150,000 Amperes RMS symmetrical on 600 Volt circuits when equipped with Type J or Type R fuses.

Wall Mounting TYPE 1 Enclosure




LISTED MODIFICATIONS

- Neutral Grounding Lug to make controller "Suitable for use as Service Equipment" - SUSE
- Class R rejection fuse clips
- Running Period Timer (recommended to prevent excessive cycling)
- Control Transformer for 120 volt control voltage
- Pressure Switch Range: 6-232 psi (standard)
12-464 psi (optional)
58-870 psi (optional)
- "Motor Running" red pilot light
- Auxiliary contacts on motor starter

FUSING DATA


LINE VOLTS	FUSE CLIP MAX. RATING		THREE PHASE MAX. H.P.		SINGLE PHASE MAX. H.P.	
	AMPS	VOLTS	NON-TIME DELAY	DUAL ELEMENT	NON-TIME DELAY	DUAL ELEMENT
115	30	250	—	—	1/2	1 1/2
120	60	250	—	—	1 1/2	3
200	30	250	3	5	—	—
208	60	250	7 1/2	10	—	—
270	30	250	3	7 1/2	1 1/2	3
240	60	250	7 1/2	15	3	7 1/2
380	30	600	5	10	—	—
	60	600	10	25	—	—
440	30	600	7 1/2	15	—	—
480	60	600	15	25	—	—
550	30	600	7 1/2	15	—	—
600	60	600	20	25	—	—



DATED JULY 1986

SUPERSEDES PAGE 202

DATED OCTOBER 1983



MODEL	SUCTION	DISCH.	DF	DG
934	1	1	2	1-11/16
935	2	1-1/2	2-1/4	2-1/4

HP	RPM	FRAME
1/2-1-1/2	3500	56
1/2-1-1/2	1750	56
3	3500	145T
5	3500	182T
7-1/2	3500	184T
10	3500	213T

FRAME	A	B	D	E	F	H	AG	BA
56	6-3/4	4	3-1/2	2-7/16	1-1/2	11/32 SLOT	11	2-9/16
145T	7	6	3-1/2	2-3/4	2-1/2	11/32 SLOT	11	2-7/8
182T	9	6-1/2	4-1/2	3-3/4	2-1/4	13/32	11	3-5/8
184T	9	7-1/2	4-1/2	3-3/4	2-3/4	13/32	12	3-5/8
213T	9-1/2	8	5-1/4	4-1/4	2-3/4	7/16	14	4-1/2

PUMP	MODEL	934		935						
		SIZE	A04	D04	F05	G05	H05	I05	J05	K05

MODEL	V	J	YY	W	X	Z
934	1/2	10-15/16	3-3/4	3-3/16	6-3/8	7-3/4
	1-1/4	12-1/8		3-1/4	7-1/8	7-1/2
	1/2	11-1/4		4-5/16	7-5/8	8-1/16
935	3/4	13-3/16	4-1/2	4-7/16	7-7/8	10
	1-1/4	12-3/8		4-7/16	8-1/2	7-3/4

G.P.M.	P.S.I.	RELIEF VALVE SIZE INCHES
2.5	45-100	1/2
5	45-130	1/2
	135-215	1/2
7.5	45-130	1/2
	135-210	1/2
10	45-130	1/2
	135-205	1/2
15	45-130	1/2
	135-170	1/2
20	70-130	1/2
	135-155	1/2
25	80-130	3/4
	135	3/4
30	105-155	3/4
35	105-155	3/4
40	105-155	1
45	105-155	1

NOTES:

1. ALL DIMENSIONS IN INCHES.
2. NOT FOR CONSTRUCTION PURPOSES UNLESS CERTIFIED.
3. CAPACITOR WHEN FURNISHED NORMALLY APPEARS ON TOP OF MOTOR. DIMENSIONS ARE NOT SPECIFIED AS THEY VARY WITH EACH MOTOR MANUFACTURER.
4. DIMENSIONS MAY VARY $\pm 1/4"$.

GS AURORA PUMP
A UNIT OF GENERAL SIGNAL
600 AIRPORT ROAD • NORTH AURORA, ILLINOIS 60142

A.J. CARNEGIE, INC.
1600 Jersey Avenue

Automatic Fire Protection Systems

Box 3024

North Brunswick, N.J. 08902

908-249-3930
FAX 908-246-3631

HYDRAULIC DESIGN INFORMATION SHEET

DATE: August 7, 1992
NAME: Price Club
LOCATION: Brick Township
CONSTRUCTION: Non-combustible
OCCUPANCY: Auto Center

SYSTEM DESIGN

NFPA #13:
LIGHT HAZ.: _____ ORD. HAZ. GROUP: #1 _____ #2 _____ #3 _____ EX. HAZ.: _____

NFPA #231:
NFPA #231C: _____ FIGURE: _____ CURVE: _____

OTHER: (specify) FM Standard .30 gpm/sf over 3000 sf _____

AREA OF SPRINKLER OPERATION: 3000
DENSITY: .30
AREA PER SPRINKLER: 99.7
HOSE ALLOWANCE GPM: (inside)
HOSE ALLOWANCE GPM: (outside) 500
RACK SPRINKLER ALLOWANCE: -0-

SYSTEM TYPE

WET: ☒ DRY: _____ DELUGE: _____ PRE - ACTION: _____

SPRINKLER OR NOZZLE

MAKE: Central MODEL: A SIZE: 17/32 TEMP: 165 K: 8.1

CALCULATION SUMMARY

GPM REQUIRED: 1449 PSI REQUIRED: 65.7
"C" FACTOR USED: OVERHEAD: 120 UNDERGROUND: 140

WATER SUPPLY

WATER FLOW TEST

DATE:
STATIC PSI: 55
RESIDUAL PSI: 48
GPM FLOWING: 1734
ELEVATION: same

PUMP DATA

RATED CAPACITY: 1000
AT PSI: 125lbs
ELEVATION: same

LOCATION: Route 70 & 88
SOURCE: Water Department

Serial Number 1012122 Run Number 03235

CAFE

August 3, 1992

HYDRAULIC SYSTEM DESIGN REPORT

PRICE CLUB
RT. # 88
BRICKTOWN, N.J.

A.J. CARNEGIE, INC.
P.O. BOX 3024
NORTH BRUNSWICK, N.J.

AUTO CENTER SYSTEM CALCULATED TO PRODUCE
.30/3000 PLUS 500 GPM HOSE. 17/32" OREF.
K=8.1 SPRINKLERS.

Design Engineer

A.J.C., INC.

PROJECT NAME: PRICE CLUB AUTO CENTER

PROJECT NUMBER: AJC

-----UNITS TABLE-----

LENGTHS AND ELEVATIONS IN FEET PIPE DIAMETERS IN INCHES
PRESSURES IN POUNDS PER SQUARE INCH VOLUMES IN U.S. GALLONS
FLOWS IN U.S. GALLONS PER MINUTE VELOCITIES IN FEET PER SECOND

DENSITY REQUIREMENT: .300 GPM/SQ.FT. OVER MOST REMOTE 3000. SQ.FT.

THE SYSTEM HAS 13 LOOPS

-----WATER SUPPLY WSI ASSIGNED AT NODE 0-----

STATIC PRESSURE = 205.0 PSI 177.0 PSI FLOWING 1000.0 GPM
130.00 PSI FLOWING 1500.0 GPM

-----SPRINKLER ASSIGNMENT TO MAIN OR LOOP NODES-----

S1 = 8.10 K-FACTOR SPRINKLER ASSIGNED TO COVER 112.5 SQ.FT.

AT NODES: 56 57 58 69 70 71 72 73 74 75 76 82 83 84 85 86 87 88 89 95 96 97 98 99 100 101 102

-----FITTING TABLE-----

S = TF = 1 TURNING FLOW TEE FITTING
T2 = 2 TURNING FLOW TEE FITTINGS
L3 = 3 LONG TURN 90 DEGREE ELBOWS
L6 = 6 LONG TURN 90 DEGREE ELBOWS
17 = COMBINATION OF T2
18 = COMBINATION OF GV CV LE
19 = COMBINATION OF TF GV AV
20 = COMBINATION OF L3
21 = COMBINATION OF L6 TF

MAIN AND LOOP PIPES

PIPE CONFIG	H&W COEF	PIPE DIAM	FIT COMB	PIPE LGT	FIT E LGT	TOTAL LGT	ELEV CHANGE	ELEV FRIC PRES PRES	PRES LOSS	PIPE ID	TOTAL PRES	PIPE FLOW	VEL VEL	VEL PRES	NORMAL PRES	IN/OUT FLOW
WSI																<1449.3>
0																
1	120.	8.00		.0		.0		.00	.00	8.2490	65.78	1449.3	8.70			500.0
2	120.	8.00	18	10.0	28.0	38.0	2.0	.87	.27	1.14	8.2490	64.64	949.3	5.70		
3	120.	6.00	19	4.0	78.0	82.0	4.0	1.73	2.08	3.82	6.3570	60.82	949.3	9.60		
L1	4	120.	6.00	20	305.0	27.0	332.0	15.0	6.49	8.44	14.93	6.3570	45.89	949.3	9.60	
-----LOOP 1-----																
5																
6	120.	2.00	5	2.0	10.0	12.0	2.0	.87	.25	1.12	2.1570	44.77	50.1	4.40		
7	120.	2.00	17	209.0	20.0	229.0		4.87	4.87	2.1570	39.91	50.1	4.40			

12<	8	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.25	-.61	2.1570	40.52	50.1	4.40
	9	120.	4.00		11.6		11.6			.01	.01	4.2600	40.51	50.1	1.13
	10	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.24	.62	2.1570	39.89	-48.8	4.28
	11	120.	2.00	17	209.0	20.0	229.0			-4.63	-4.63	2.1570	44.52	-48.8	4.28
12>	12	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.24	-1.11	2.1570	45.63	-48.8	4.28
4<	(13)	120.	6.00		11.6		11.6			-.27	-.27	6.3570	45.89	-899.2	9.09

LOOP 2

13<	14	120.	4.00		11.6		11.6			.03	.03	4.2600	40.48	98.9	2.23
	15	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.23	.63	2.1570	39.84	-47.7	4.19
	16	120.	2.00	17	209.0	20.0	229.0			-4.44	-4.44	2.1570	44.29	-47.7	4.19
13>	17	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.23	-1.10	2.1570	45.39	-47.7	4.19
12<	(18)	120.	6.00		11.6		11.6			-.24	-.24	6.3570	45.63	-850.4	8.60

LOOP 3

14<	19	120.	4.00		11.6		11.6			.07	.07	4.2600	40.41	146.5	3.30
	20	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.23	.64	2.1570	39.77	-46.9	4.12
	21	120.	2.00	17	209.0	20.0	229.0			-4.31	-4.31	2.1570	44.08	-46.9	4.12
14>	22	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.23	-1.09	2.1570	45.17	-46.9	4.12
17<	(23)	120.	6.00		11.6		11.6			-.22	-.22	6.3570	45.39	-802.8	8.11

LOOP 4

19>	24	120.	4.00		11.6		11.6			.11	.11	4.2600	40.30	193.4	4.35
15<	25	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.22	.64	2.1570	39.66	-46.4	4.08
	26	120.	2.00	17	209.0	20.0	229.0			-4.23	-4.23	2.1570	43.89	-46.4	4.08
15>	27	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.22	-1.09	2.1570	44.98	-46.4	4.08
22<	(28)	120.	6.00		11.6		11.6			-.19	-.19	6.3570	45.17	-755.9	7.64

LOOP 5

24>	29	120.	4.00		11.6		11.6			.16	.16	4.2600	40.14	239.9	5.40
16<	30	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.22	.64	2.1570	39.50	-46.4	4.07
	31	120.	2.00	17	209.0	20.0	229.0			-4.22	-4.22	2.1570	43.72	-46.4	4.07
16>	32	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.22	-1.09	2.1570	44.80	-46.4	4.07
27<	(33)	120.	6.00		11.6		11.6			-.17	-.17	6.3570	44.98	-709.4	7.17

LOOP 6

29>	34	120.	4.00		11.6		11.6			.23	.23	4.2600	39.92	286.3	6.44
17<	35	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.22	.64	2.1570	39.27	-46.8	4.11
	36	120.	2.00	17	209.0	20.0	229.0			-4.29	-4.29	2.1570	43.56	-46.8	4.11
17>	37	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.22	-1.09	2.1570	44.65	-46.8	4.11
32<	(38)	120.	6.00		11.6		11.6			-.15	-.15	6.3570	44.80	-663.0	6.70

LOOP 7

34>	39	120.	4.00		11.6		11.6			.30	.30	4.2600	39.62	333.0	7.50
18<	40	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.23	.63	2.1570	38.98	-47.7	4.18
	41	120.	2.00	17	209.0	20.0	229.0			-4.44	-4.44	2.1570	43.42	-47.7	4.18
18>	42	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.23	-1.10	2.1570	44.52	-47.7	4.18
37<	(43)	120.	6.00		11.6		11.6			-.13	-.13	6.3570	44.65	-616.3	6.23

LOOP 8

39>	44	120.	4.00		11.6		11.6			.38	.38	4.2600	39.24	380.7	8.57
19<	45	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.25	.62	2.1570	38.61	-49.0	4.31
	46	120.	2.00	17	209.0	20.0	229.0			-4.68	-4.68	2.1570	43.30	-49.0	4.31
19>	47	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.25	-1.11	2.1570	44.41	-49.0	4.31
42<	(48)	120.	6.00		11.6		11.6			-.11	-.11	6.3570	44.52	-568.6	5.75

LOOP 9

44>	49	120.	4.00		11.6		11.6			.48	.48	4.2600	38.76	429.8	9.67
110<	50	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.26	.60	2.1570	38.15	-51.0	4.48
	51	120.	2.00	17	209.0	20.0	229.0			-5.03	-5.03	2.1570	43.18	-51.0	4.48

L10<	52	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.26	-1.13	2.1570	44.20	-50.9	4.47
47<	(53)	120.	6.00		11.6		11.6			-.10	-.10	6.3570	44.30	-519.3	5.25

LOOP 10

L11<	54	120.	4.00	21	150.0	56.0	206.0			10.43	10.43	4.2600	28.22	480.5	10.82
	55	120.	1.50	5	2.0	8.0	10.0	2.0	.87	1.04	1.91	1.6820	26.31	61.6	8.89
SI	* 56	120.	1.50		.0		.0			.00	.00	1.6820	26.31	61.6	8.89
SI	* 57	120.	1.50		9.7		9.7			.13	.13	1.6820	26.18	20.4	2.95
SI	* 58	120.	1.50		9.7		9.7			-.14	-.14	1.6820	26.31	-21.0	3.03
	59	120.	1.50		9.7		9.7			-1.03	-1.03	1.6820	27.34	-62.1	8.97
	60	120.	1.50		9.7		9.7			-1.03	-1.03	1.6820	28.38	-62.1	8.97
	61	120.	1.50		9.7		9.7			-1.03	-1.03	1.6820	29.41	-62.1	8.97
	62	120.	1.50		9.7		9.7			-1.03	-1.03	1.6820	30.44	-62.1	8.97
	63	120.	1.50		9.7		9.7			-1.03	-1.03	1.6820	31.47	-62.1	8.97
	64	120.	1.50	5	9.1	8.0	17.1			-1.82	-1.82	1.6820	33.29	-62.1	8.97
L11>	65	120.	1.50	5	2.0	8.0	10.0	-2.0	-.87	-1.06	-1.93	1.6820	35.21	-62.1	8.97
52<	(66)	120.	4.00	20	168.0	18.0	186.0			-8.99	-8.99	4.2600	44.20	-468.4	10.54

LOOP 11

L12<	67	120.	4.00		10.0		10.0			.39	.39	4.2600	27.83	419.0	9.43
	68	120.	1.50	5	2.0	8.0	10.0	2.0	.87	4.78	5.65	1.6820	22.18	140.1	20.23
SI	* 69	120.	1.50		.0		.0			.00	.00	1.6820	22.18	140.1	20.23
SI	* 70	120.	1.50		9.7		9.7			2.69	2.69	1.6820	19.48	104.4	15.07
SI	* 71	120.	1.50		9.7		9.7			1.29	1.29	1.6820	18.20	70.1	10.12
SI	* 72	120.	1.50		9.7		9.7			.38	.38	1.6820	17.82	36.2	5.22
SI	* 73	120.	1.50		9.7		9.7			.00	.00	1.6820	17.82	2.2	.31
SI	* 74	120.	1.50		9.7		9.7			-.30	-.30	1.6820	18.12	-32.0	4.63
SI	* 75	120.	1.50		9.7		9.7			-1.15	-1.15	1.6820	19.27	-65.9	9.52
SI	* 76	120.	1.50		9.7		9.7			-2.49	-2.49	1.6820	21.76	-100.2	14.46
	77	120.	1.50	5	9.1	8.0	17.1			-7.71	-7.71	1.6820	29.47	-135.6	19.59
L12>	78	120.	1.50	5	2.0	8.0	10.0	-2.0	-.87	-4.51	-5.37	1.6820	34.84	-135.6	19.59
65<	(79)	120.	4.00		10.0		10.0			-.37	-.37	4.2600	35.21	-406.2	9.14

LOOP 12

L13<	80	120.	4.00		10.0		10.0			.19	.19	4.2600	27.64	278.9	6.28
	81	120.	1.50	5	2.0	8.0	10.0	2.0	.87	4.75	5.61	1.6820	22.03	139.5	20.14
SI	* 82	120.	1.50		.0		.0			.00	.00	1.6820	22.03	139.5	20.14
SI	* 83	120.	1.50		9.7		9.7			2.67	2.67	1.6820	19.36	103.9	15.01
SI	* 84	120.	1.50		9.7		9.7			1.28	1.28	1.6820	18.08	69.7	10.07
SI	* 85	120.	1.50		9.7		9.7			.37	.37	1.6820	17.71	35.9	5.19
SI	* 86	120.	1.50		9.7		9.7			.00	.00	1.6820	17.70	2.0	.29
SI	* 87	120.	1.50		9.7		9.7			-.30	-.30	1.6820	18.01	-32.1	4.63
SI	* 88	120.	1.50		9.7		9.7			-1.15	-1.15	1.6820	19.15	-65.8	9.51
SI	* 89	120.	1.50		9.7		9.7			-2.49	-2.49	1.6820	21.64	-100.0	14.43
	90	120.	1.50	5	9.1	8.0	17.1			-7.67	-7.67	1.6820	29.31	-135.3	19.54
L13>	91	120.	1.50	5	2.0	8.0	10.0	-2.0	-.87	-4.49	-5.35	1.6820	34.67	-135.3	19.54
78<	(92)	120.	4.00		10.0		10.0			-.18	-.18	4.2600	34.84	-270.6	6.09

LOOP 13

80>	93	120.	4.00		10.0		10.0			.05	.05	4.2600	27.59	139.4	3.14
	94	120.	1.50	5	2.0	8.0	10.0	2.0	.87	4.74	5.60	1.6820	21.99	139.4	20.12
SI	* 95	120.	1.50		.0		.0			.00	.00	1.6820	21.99	139.4	20.12
SI	* 96	120.	1.50		9.7		9.7			2.66	2.66	1.6820	19.32	103.8	14.99
SI	* 97	120.	1.50		9.7		9.7			1.27	1.27	1.6820	18.05	69.6	10.05
SI	* 98	120.	1.50		9.7		9.7			.37	.37	1.6820	17.67	35.9	5.18
SI	* 99	120.	1.50		9.7		9.7			.00	.00	1.6820	17.67	2.0	.29
SI	* 100	120.	1.50		9.7		9.7			-.30	-.30	1.6820	17.98	-32.1	4.63
SI	* 101	120.	1.50		9.7		9.7			-1.15	-1.15	1.6820	19.12	-65.8	9.50
SI	* 102	120.	1.50		9.7		9.7			-2.48	-2.48	1.6820	21.61	-99.9	14.43
	103	120.	1.50	5	9.1	8.0	17.1			-7.67	-7.67	1.6820	29.27	-135.3	19.53

104	120.	1.50	5	2.0	8.0	10.0	-2.0	-.87	-4.48	-5.35	1.6820	34.62	-135.3	19.53
(105)	120.	4.00		10.0		10.0			-.05	-.05	4.2600	34.67	-135.3	3.04

135.4 PSI PRESSURE AVAILABLE AND 65.7 PSI PRESSURE REQUIRED AT THE WATER SUPPLY WHEN FLOWING 1448.9 GPM

900.0 GPM MINIMUM DESIGN FLOW REQUIREMENT

500.0 GPM REQUIRED ADDITIONAL FLOW

1867.6 GPM MAXIMUM FLOW


PRICE CLUB

Price Club
Auto Center

CONTRACT NAME:

NO:

PRESSURE (PSI) $\times 2$



A.J. CARNEGIE, INC.
1600 Jersey Avenue

Automatic Fire Protection Systems

Box 3024
North Brunswick, N.J. 08902

908-249-3930
FAX 908-246-3631

HYDRAULIC DESIGN INFORMATION SHEET

DATE: August 7, 1992
NAME: Price Club
LOCATION: Brick Township
CONSTRUCTION: Non-combustible
OCCUPANCY: Auto Center

SYSTEM DESIGN

NFPA #13:
LIGHT HAZ.: _____ ORD.HAZ.GROUP: #1 _____ #2 _____ #3 _____ EX.HAZ.: _____

NFPA #231:
NFPA #231C: _____ FIGURE: _____ CURVE: _____

OTHER: (specify) FM Standard .30 gpm/sf over 3000 sf _____

AREA OF SPRINKLER OPERATION: 3000
DENSITY: .30
AREA PER SPRINKLER: 99.7
HOSE ALLOWANCE GPM: (inside) _____
HOSE ALLOWANCE GPM: (outside) 500
RACK SPRINKLER ALLOWANCE: -0-

SYSTEM TYPE

WET: ☒ DRY: _____ DELUGE: _____ PRE - ACTION: _____

SPRINKLER OR NOZZLE

MAKE: Central MODEL: A SIZE: 17/32 TEMP: 165 K: 8.1

CALCULATION SUMMARY

GPM REQUIRED: 1449 PSI REQUIRED: 65.7
"C" FACTOR USED: OVERHEAD: 120 UNDERGROUND: 140

WATER SUPPLY

WATER FLOW TEST

DATE:
STATIC PSI: 55
RESIDUAL PSI: 48
GPM FLOWING: 1734
ELEVATION: same

PUMP DATA

RATED CAPACITY: 1000
AT PSI: 125lbs
ELEVATION: same

LOCATION: Route 70 & 88
SOURCE: Water Department

HYDRAULIC SYSTEM DESIGN REPORT

PRICE CLUB

RT. # 88

BRICKTOWN, N.J.

A.J. CARNEGIE, INC.

P.O. BOX 3024

NORTH BRUNSWICK, N.J.

Design Engineer

A.J.C., INC.

AUTO CENTER SYSTEM, CALCULATED TO PRODUCE
 .30/3000 PLUS 500 GPM HOSE. 17/32" OREF.
 K=8.1 SPRINKLERS.

PROJECT NAME: PRICE CLUB AUTO CENTER

PROJECT NUMBER: AJC

AUTO CENTER

-----UNITS TABLE-----

LENGTHS AND ELEVATIONS IN FEET PIPE DIAMETERS IN INCHES
 PRESSURES IN POUNDS PER SQUARE INCH VOLUMES IN U.S. GALLONS
 FLOWS IN U.S. GALLONS PER MINUTE VELOCITIES IN FEET PER SECOND

DENSITY REQUIREMENT: .300 GPM/SQ. FT. OVER MOST REMOTE 3000. SQ. FT.

THE SYSTEM HAS 13 LOOPS

-----WATER SUPPLY WSI ASSIGNED AT NODE 0-----

STATIC PRESSURE = 205.0 PSI 177.0 PSI FLOWING 1000.0 GPM
 130.00 PSI FLOWING 1500.0 GPM

-----SPRINKLER ASSIGNMENT TO MAIN OR LOOP NODES-----

S1 = 8.10 K-FACTOR SPRINKLER ASSIGNED TO COVER 112.5 SQ. FT.

----- AT NODES: 56 57 58 69 70 71 72 73 74 75 76 82 83 84 85 86 87 88 89 95 96 97 98 99 100 101 102

-----FITTING TABLE-----

5 = TF : 1 TURNING FLOW TEE FITTING
 T2 = 2 TURNING FLOW TEE FITTINGS
 L3 = 3 LONG TURN 90 DEGREE ELBOWS
 L6 = 6 LONG TURN 90 DEGREE ELBOWS
 17 = COMBINATION OF T2
 18 = COMBINATION OF GV CV LE
 19 = COMBINATION OF TF GV AV
 20 = COMBINATION OF L3
 21 = COMBINATION OF L6 TF

MAIN AND LOOP PIPES

PIPE CONFIG	H&W COEF	PIPE DIAM	FIT COMB	PIPE LGT	FIT E LGT	TOTAL LGT	ELEV CHANGE	ELEV PRES	FRIC PRES	PRES LOSS	PIPE ID	TOTAL PRES	PIPE FLOW	PIPE VEL	VEL PRES	NORMAL PRES	IN/OUT FLOW
WS1																	<1449.3>
0:																	
1	120.	8.00		.0		.0		.00	.00	8.2490	65.78	1449.3	8.70				500.0
2	120.	8.00	18	10.0	28.0	38.0	2.0	.87	.27	1.14	8.2490	64.64	949.3	5.70			
3	120.	6.00	19	4.0	78.0	82.0	4.0	1.73	2.08	3.82	6.3570	60.82	949.3	9.60			
L1	4	120.	6.00	20	305.0	27.0	332.0	15.0	6.49	8.44	14.93	6.3570	45.89	949.3	9.60		
-----LOOP 1-----																	
5																	
6	120.	2.00	5	2.0	10.0	12.0	2.0	.87	.25	1.12	2.1570	44.77	50.1	4.40			
7	120.	2.00	17	209.0	20.0	229.0			4.87	4.87	2.1570	39.91	50.1	4.40			

8	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	.25	-.61	2.1570	40.52	50.1	4.40
9	120.	4.00		11.6		11.6			.01	.01	4.2600	40.51	50.1	1.13
10	120.	2.00	5	2.0	10.0	12.0	2.0	.97	-.24	.62	2.1570	39.89	-48.8	4.28
11	120.	2.00	17	209.0	20.0	229.0			-4.63	-4.63	2.1570	44.52	-48.8	4.28
12	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.24	-1.11	2.1570	45.63	-48.8	4.28
(13)	120.	6.00		11.6		11.6			-.27	-.27	6.3570	45.89	-899.2	9.09

LOOP 2

14	120.	4.00		11.6		11.6			.03	.03	4.2600	40.48	98.9	2.23
15	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.23	.63	2.1570	39.84	-47.7	4.19
16	120.	2.00	17	209.0	20.0	229.0			-4.44	-4.44	2.1570	44.29	-47.7	4.19
17	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.23	-1.10	2.1570	45.39	-47.7	4.19
(18)	120.	6.00		11.6		11.6			-.24	-.24	6.3570	45.63	-850.4	8.60

LOOP 3

19	120.	4.00		11.6		11.6			.07	.07	4.2600	40.41	146.5	3.30
20	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.23	.64	2.1570	39.77	-46.9	4.12
21	120.	2.00	17	209.0	20.0	229.0			-4.31	-4.31	2.1570	44.08	-46.9	4.12
22	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.23	-1.09	2.1570	45.17	-46.9	4.12
(23)	120.	6.00		11.6		11.6			-.22	-.22	6.3570	45.39	-802.8	8.11

LOOP 4

24	120.	4.00		11.6		11.6			.11	.11	4.2600	40.30	193.4	4.35
25	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.22	.64	2.1570	39.66	-46.4	4.08
26	120.	2.00	17	209.0	20.0	229.0			-4.23	-4.23	2.1570	43.89	-46.4	4.08
27	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.22	-1.09	2.1570	44.98	-46.4	4.08
(28)	120.	6.00		11.6		11.6			-.19	-.19	6.3570	45.17	-755.9	7.64

LOOP 5

29	120.	4.00		11.6		11.6			.16	.16	4.2600	40.14	239.9	5.40
30	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.22	.64	2.1570	39.50	-46.4	4.07
31	120.	2.00	17	209.0	20.0	229.0			-4.22	-4.22	2.1570	43.72	-46.4	4.07
32	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.22	-1.09	2.1570	44.80	-46.4	4.07
(33)	120.	6.00		11.6		11.6			-.17	-.17	6.3570	44.98	-709.4	7.17

LOOP 6

34	120.	4.00		11.6		11.6			.23	.23	4.2600	39.92	286.3	6.44
35	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.22	.64	2.1570	39.27	-46.8	4.11
36	120.	2.00	17	209.0	20.0	229.0			-4.29	-4.29	2.1570	43.56	-46.8	4.11
37	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.22	-1.09	2.1570	44.65	-46.8	4.11
(38)	120.	6.00		11.6		11.6			-.15	-.15	6.3570	44.80	-663.0	6.70

LOOP 7

39	120.	4.00		11.6		11.6			.30	.30	4.2600	39.62	333.0	7.50
40	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.23	.63	2.1570	38.98	-47.7	4.18
41	120.	2.00	17	209.0	20.0	229.0			-4.44	-4.44	2.1570	43.42	-47.7	4.18
42	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.23	-1.10	2.1570	44.52	-47.7	4.18
(43)	120.	6.00		11.6		11.6			-.13	-.13	6.3570	44.65	-616.3	6.23

LOOP 8

44	120.	4.00		11.6		11.6			.38	.38	4.2600	39.24	380.7	8.57
45	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.25	.62	2.1570	38.61	-49.0	4.31
46	120.	2.00	17	209.0	20.0	229.0			-4.68	-4.68	2.1570	43.30	-49.0	4.31
47	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.25	-1.11	2.1570	44.41	-49.0	4.31
(48)	120.	6.00		11.6		11.6			-.11	-.11	6.3570	44.52	-568.6	5.75

LOOP 9

49	120.	4.00		11.6		11.6			.48	.48	4.2600	38.76	429.8	9.67
50	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.26	.60	2.1570	38.15	-51.0	4.48
51	120.	2.00	17	209.0	20.0	229.0			-5.03	-5.03	2.1570	43.18	-51.0	4.48

L10>	52	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-1.26	-1.13	2.1570	44.20	-50.9	4.47
47<	(53)	120.	6.00		11.6		11.6			-1.10	-1.10	6.3570	44.30	-519.3	5.25

LOOP 10

L11<	54	120.	4.00	21	150.0	56.0	206.0			10.43	10.43	4.2600	28.22	480.5	10.82
	55	120.	1.50	5	2.0	8.0	10.0	2.0	.87	1.04	1.91	1.6820	26.31	61.6	8.89
S1	* 56	120.	1.50		.0		.0			.00	.00	1.6820	26.31	61.6	8.89
S1	* 57	120.	1.50		9.7		9.7			.13	.13	1.6820	26.18	20.4	2.95
S1	* 58	120.	1.50		9.7		9.7			-1.14	-1.14	1.6820	26.31	-21.0	3.03
	59	120.	1.50		9.7		9.7			-1.03	-1.03	1.6820	27.34	-62.1	8.97
	60	120.	1.50		9.7		9.7			-1.03	-1.03	1.6820	28.38	-62.1	8.97
	61	120.	1.50		9.7		9.7			-1.03	-1.03	1.6820	29.41	-62.1	8.97
	62	120.	1.50		9.7		9.7			-1.03	-1.03	1.6820	30.44	-62.1	8.97
	63	120.	1.50		9.7		9.7			-1.03	-1.03	1.6820	31.47	-62.1	8.97
	64	120.	1.50	5	9.1	8.0	17.1			-1.82	-1.82	1.6820	33.29	-62.1	8.97
L11>	65	120.	1.50	5	2.0	8.0	10.0	-2.0	-.87	-1.06	-1.93	1.6820	35.21	-62.1	8.97
52<	(66)	120.	4.00	20	168.0	18.0	186.0			-8.99	-8.99	4.2600	44.20	-468.4	10.54

LOOP 11

L12<	67	120.	4.00		10.0		10.0			.39	.39	4.2600	27.83	419.0	9.43
	68	120.	1.50	5	2.0	8.0	10.0	2.0	.87	4.78	5.65	1.6820	22.18	140.1	20.23
S1	* 69	120.	1.50		.0		.0			.00	.00	1.6820	22.18	140.1	20.23
S1	* 70	120.	1.50		9.7		9.7			2.69	2.69	1.6820	19.48	104.4	15.07
S1	* 71	120.	1.50		9.7		9.7			1.29	1.29	1.6820	18.20	70.1	10.12
S1	* 72	120.	1.50		9.7		9.7			.38	.38	1.6820	17.82	36.2	5.22
S1	* 73	120.	1.50		9.7		9.7			.00	.00	1.6820	17.82	2.2	.31
S1	* 74	120.	1.50		9.7		9.7			-1.30	-1.30	1.6820	18.12	-32.0	4.63
S1	* 75	120.	1.50		9.7		9.7			-1.15	-1.15	1.6820	19.27	-65.9	9.52
S1	* 76	120.	1.50		9.7		9.7			-2.49	-2.49	1.6820	21.76	-100.2	14.46
	77	120.	1.50	5	9.1	8.0	17.1			-7.71	-7.71	1.6820	29.47	-135.6	19.59
L12>	78	120.	1.50	5	2.0	8.0	10.0	-2.0	-.87	-4.51	-5.37	1.6820	34.84	-135.6	19.59
65<	(79)	120.	4.00		10.0		10.0			-.37	-.37	4.2600	35.21	-406.2	9.14

LOOP 12

L13<	80	120.	4.00		10.0		10.0			.19	.19	4.2600	27.64	278.9	6.28
	81	120.	1.50	5	2.0	8.0	10.0	2.0	.87	4.75	5.61	1.6820	22.03	139.5	20.14
S1	* 82	120.	1.50		.0		.0			.00	.00	1.6820	22.03	139.5	20.14
S1	* 83	120.	1.50		9.7		9.7			2.67	2.67	1.6820	19.36	103.9	15.01
S1	* 84	120.	1.50		9.7		9.7			1.28	1.28	1.6820	18.08	69.7	10.07
S1	* 85	120.	1.50		9.7		9.7			.37	.37	1.6820	17.71	35.9	5.19
S1	* 86	120.	1.50		9.7		9.7			.00	.00	1.6820	17.70	2.0	.29
S1	* 87	120.	1.50		9.7		9.7			-1.30	-1.30	1.6820	18.01	-32.1	4.63
S1	* 88	120.	1.50		9.7		9.7			-1.15	-1.15	1.6820	19.15	-65.8	9.51
S1	* 89	120.	1.50		9.7		9.7			-2.49	-2.49	1.6820	21.64	-100.0	14.43
	90	120.	1.50	5	9.1	8.0	17.1			-7.67	-7.67	1.6820	29.31	-135.3	19.54
L13>	91	120.	1.50	5	2.0	8.0	10.0	-2.0	-.87	-4.49	-5.35	1.6820	34.67	-135.3	19.54
78<	(92)	120.	4.00		10.0		10.0			-.18	-.18	4.2600	34.84	-270.6	6.09

LOOP 13

80>	93	120.	4.00		10.0		10.0			.05	.05	4.2600	27.59	139.4	3.14
	94	120.	1.50	5	2.0	8.0	10.0	2.0	.87	4.74	5.60	1.6820	21.99	139.4	20.12
S1	* 95	120.	1.50		.0		.0			.00	.00	1.6820	21.99	139.4	20.12
S1	* 96	120.	1.50		9.7		9.7			2.66	2.66	1.6820	19.32	103.8	14.99
S1	* 97	120.	1.50		9.7		9.7			1.27	1.27	1.6820	18.05	69.6	10.05
S1	* 98	120.	1.50		9.7		9.7			.37	.37	1.6820	17.67	35.9	5.18
S1	* 99	120.	1.50		9.7		9.7			.00	.00	1.6820	17.67	2.0	.29
S1	* 100	120.	1.50		9.7		9.7			-1.30	-1.30	1.6820	17.98	-32.1	4.63
S1	* 101	120.	1.50		9.7		9.7			-1.15	-1.15	1.6820	19.12	-65.8	9.50
S1	* 102	120.	1.50		9.7		9.7			-2.48	-2.48	1.6820	21.61	-99.9	14.43
	103	120.	1.50	5	9.1	8.0	17.1			-7.67	-7.67	1.6820	29.27	-135.3	19.53

104	120.	1.50	5	2.0	8.0	10.0	-2.0	-.87	-4.48	-5.35	1.6820	34.62	-135.3	19.53
105	120.	4.00		10.0		10.0			-.05	-.05	4.2600	34.67	-135.3	3.04

135.4 PSI PRESSURE AVAILABLE AND 65.7 PSI PRESSURE REQUIRED AT THE WATER SUPPLY WHEN FLOWING 1448.9 GPM

900.0 GPM MINIMUM DESIGN FLOW REQUIREMENT

500.0 GPM REQUIRED ADDITIONAL FLOW

1867.6 GPM MAXIMUM FLOW


PRICE SCHEDULE

Price Club
Auto Center

CONTRACT NAME:

NO:

PRESSURE (PSI) $\times 2$



A.J. CARNEGIE, INC.
1600 Jersey Avenue

Automatic Fire Protection Systems

Box 3024
North Brunswick, N.J. 08902

908-249-3930
FAX 908-246-3631

HYDRAULIC DESIGN INFORMATION SHEET

DATE: August 7, 1992
NAME: Price Club
LOCATION: Brick Township
CONSTRUCTION: Non-combustible
OCCUPANCY: Auto Center

SYSTEM DESIGN

NFPA #13:
LIGHT HAZ.: _____ ORD.HAZ.GROUP: #1 _____ #2 _____ #3 _____ EX.HAZ.: _____

NFPA #231:
NFPA #231C: _____ FIGURE: _____ CURVE: _____

OTHER: (specify) FM Standard .30 gpm/sf over 3000 sf _____

AREA OF SPRINKLER OPERATION: 3000
DENSITY: .30
AREA PER SPRINKLER: 99.7
HOSE ALLOWANCE GPM: (inside)
HOSE ALLOWANCE GPM: (outside) 500
RACK SPRINKLER ALLOWANCE: -0-

SYSTEM TYPE

WET: ☒ DRY: _____ DELUGE: _____ PRE - ACTION: _____

SPRINKLER OR NOZZLE

MAKE: Central MODEL: A SIZE: 17/32 TEMP: 165 K: 8.1

CALCULATION SUMMARY

GPM REQUIRED: 1449 PSI REQUIRED: 65.7
"C" FACTOR USED: OVERHEAD: 120 UNDERGROUND: 140

WATER SUPPLY

WATER FLOW TEST

DATE:
STATIC PSI: 55
RESIDUAL PSI: 48
GPM FLOWING: 1734
ELEVATION: same

PUMP DATA

RATED CAPACITY: 1000
AT PSI: 125 lbs
ELEVATION: same

LOCATION: Route 70 & 88
SOURCE: Water Department

Serial Number 1012122 Run Number 03235

CAFE

August 3, 1992

HYDRAULIC SYSTEM DESIGN REPORT

PRICE CLUB
RT. # 39
BRICKTOWN, N.J.A.J. CARNEGIE, INC.
P.O. BOX 3024
NORTH BRUNSWICK, N.J.AUTO CENTER SYSTEM CALCULATED TO PRODUCE
.30/3000 PLUS 500 GPM HOSE. 17/32" OREF.
K=8.1 SPRINKLERS.

Design Engineer

A.J.C., INC.

PROJECT NAME: PRICE CLUB AUTO CENTER

PROJECT NUMBER: AJC

-----UNITS TABLE-----

LENGTHS AND ELEVATIONS IN FEET PIPE DIAMETERS IN INCHES
 PRESSURES IN POUNDS PER SQUARE INCH VOLUMES IN U.S. GALLONS
 FLOWS IN U.S. GALLONS PER MINUTE VELOCITIES IN FEET PER SECOND

DENSITY REQUIREMENT: .300 GPM/SQ.FT. OVER MOST REMOTE 3000. SQ.FT.

THE SYSTEM HAS 13 LOOPS

-----WATER SUPPLY WSI ASSIGNED AT NODE 0-----

STATIC PRESSURE = 205.0 PSI 177.0 PSI FLOWING 1000.0 GPM
 130.00 PSI FLOWING 1500.0 GPM

-----SPRINKLER ASSIGNMENT TO MAIN OR LOOP NODES-----

S1 : 8.10 K-FACTOR SPRINKLER ASSIGNED TO COVER 112.5 SQ.FT.

----- AT NODES: 56 57 58 69 70 71 72 73 74 75 76 82 83 84 85 86 87 88 89 95 96 97 98 99 100 101 102

-----FITTING TABLE-----

5 : TF : 1 TURNING FLOW TEE FITTING
 T2 : 2 TURNING FLOW TEE FITTINGS
 L3 : 3 LONG TURN 90 DEGREE ELBOWS
 L6 : 6 LONG TURN 90 DEGREE ELBOWS
 17 : COMBINATION OF T2
 18 : COMBINATION OF GV CV LE
 19 : COMBINATION OF TF GV AV
 20 : COMBINATION OF L3
 21 : COMBINATION OF L6 TF

MAIN AND LOOP PIPES

PIPE CONFIG	H&W COEF	PIPE DIAM	FIT COMB	PIPE LGT	FIT E LGT	TOTAL LGT	ELEV CHANGE	ELEV FRIC PRES PRES	PRES LOSS	PIPE ID	TOTAL PRES	PIPE FLOW	PIPE VEL	VEL PRES	NORMAL PRES	IN/OUT FLOW
WSI																<1449.3>
0																
1	120	8.00		.0		.0		.00	.00	8.2490	65.78	1449.3	8.70			500.0
2	120	8.00	18	10.0	28.0	38.0	2.0	.87	.27	1.14	8.2490	64.64	949.3	5.70		
3	120	6.00	19	4.0	78.0	82.0	4.0	1.73	2.08	3.82	6.3570	60.82	949.3	9.60		
4	120	6.00	20	305.0	27.0	332.0	15.0	6.49	8.44	14.93	6.3570	45.89	949.3	9.60		
----- LOOP 1 -----																
5																
6	120	2.00	5	2.0	10.0	12.0	2.0	.87	.25	1.12	2.1570	44.77	50.1	4.40		
7	120	2.00	17	209.0	20.0	229.0		4.87	4.87	2.1570	39.91	50.1	4.40			

8	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	.25	-.61	2.1570	40.52	50.1	4.40	
12 <	9	120.	4.00		11.6				.01	.01	4.2600	40.51	50.1	1.13	
	10	120.	2.00	5	2.0	10.0	2.0	.87	-.24	.62	2.1570	39.89	-48.8	4.28	
	11	120.	2.00	17	209.0	20.0	229.0		-4.63	-4.63	2.1570	44.52	-48.8	4.28	
12 >	12	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.24	-1.11	2.1570	45.63	-48.8	4.28
4 <	(13)	120.	6.00		11.6		11.6		-.27	-.27	6.3570	45.89	-899.2	9.09	

LOOP 2

13 <	14	120.	4.00		11.6		11.6		.03	.03	4.2600	40.48	98.9	2.23	
	15	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.23	.63	2.1570	39.84	-47.7	4.19
	16	120.	2.00	17	209.0	20.0	229.0		-4.44	-4.44	2.1570	44.29	-47.7	4.19	
13 >	17	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.23	-1.10	2.1570	45.39	-47.7	4.19
12 <	(18)	120.	6.00		11.6		11.6		-.24	-.24	6.3570	45.63	-850.4	8.60	

LOOP 3

14 <	19	120.	4.00		11.6		11.6		.07	.07	4.2600	40.41	146.5	3.30	
	20	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.23	.64	2.1570	39.77	-46.9	4.12
	21	120.	2.00	17	209.0	20.0	229.0		-4.31	-4.31	2.1570	44.08	-46.9	4.12	
14 >	22	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.23	-1.09	2.1570	45.17	-46.9	4.12
17 <	(23)	120.	6.00		11.6		11.6		-.22	-.22	6.3570	45.39	-802.8	8.11	

LOOP 4

19 <	24	120.	4.00		11.6		11.6		.11	.11	4.2600	40.30	193.4	4.35	
	25	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.22	.64	2.1570	39.66	-46.4	4.08
	26	120.	2.00	17	209.0	20.0	229.0		-4.23	-4.23	2.1570	43.89	-46.4	4.08	
15 >	27	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.22	-1.09	2.1570	44.98	-46.4	4.08
22 <	(28)	120.	6.00		11.6		11.6		-.19	-.19	6.3570	45.17	-755.9	7.64	

LOOP 5

24 <	29	120.	4.00		11.6		11.6		.16	.16	4.2600	40.14	239.9	5.40	
	30	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.22	.64	2.1570	39.50	-46.4	4.07
	31	120.	2.00	17	209.0	20.0	229.0		-4.22	-4.22	2.1570	43.72	-46.4	4.07	
16 >	32	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.22	-1.09	2.1570	44.80	-46.4	4.07
27 <	(33)	120.	6.00		11.6		11.6		-.17	-.17	6.3570	44.98	-709.4	7.17	

LOOP 6

29 <	34	120.	4.00		11.6		11.6		.23	.23	4.2600	39.92	286.3	6.44	
	35	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.22	.64	2.1570	39.27	-46.8	4.11
	36	120.	2.00	17	209.0	20.0	229.0		-4.29	-4.29	2.1570	43.56	-46.8	4.11	
17 >	37	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.22	-1.09	2.1570	44.65	-46.8	4.11
32 <	(38)	120.	6.00		11.6		11.6		-.15	-.15	6.3570	44.80	-663.0	6.70	

LOOP 7

34 <	39	120.	4.00		11.6		11.6		.30	.30	4.2600	39.62	333.0	7.50	
	40	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.23	.63	2.1570	38.98	-47.7	4.18
	41	120.	2.00	17	209.0	20.0	229.0		-4.44	-4.44	2.1570	43.42	-47.7	4.18	
18 >	42	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.23	-1.10	2.1570	44.52	-47.7	4.18
37 <	(43)	120.	6.00		11.6		11.6		-.13	-.13	6.3570	44.65	-616.3	6.23	

LOOP 8

39 <	44	120.	4.00		11.6		11.6		.38	.38	4.2600	39.24	380.7	8.57	
	45	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.25	.62	2.1570	38.61	-49.0	4.31
	46	120.	2.00	17	209.0	20.0	229.0		-4.68	-4.68	2.1570	43.30	-49.0	4.31	
19 >	47	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.25	-1.11	2.1570	44.41	-49.0	4.31
42 <	(48)	120.	6.00		11.6		11.6		-.11	-.11	6.3570	44.52	-568.6	5.75	

LOOP 9

44 <	49	120.	4.00		11.6		11.6		.48	.48	4.2600	38.76	429.8	9.67	
	50	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.26	.60	2.1570	38.15	-51.0	4.48
	51	120.	2.00	17	209.0	20.0	229.0		-5.03	-5.03	2.1570	43.18	-51.0	4.48	

L10>	52	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.26	-1.13	2.1570	44.20	-50.9	4.47
47<	(53)	120.	6.00		11.6		11.6			-.10	-.10	6.3570	44.30	-519.3	5.25

LOOP 10

49>															
L11>	54	120.	4.00	21	150.0	56.0	206.0			10.43	10.43	4.2600	28.22	480.5	10.82
	55	120.	1.50	5	2.0	8.0	10.0	2.0	.87	1.04	1.91	1.6820	26.31	61.6	8.89
S1	56	120.	1.50		.0		.0			.00	.00	1.6820	26.31	61.6	8.89
S1	57	120.	1.50		9.7		9.7			.13	.13	1.6820	26.18	20.4	2.95
S1	58	120.	1.50		9.7		9.7			-.14	-.14	1.6820	26.31	-21.0	3.03
	59	120.	1.50		9.7		9.7			-1.03	-1.03	1.6820	27.34	-62.1	8.97
	60	120.	1.50		9.7		9.7			-1.03	-1.03	1.6820	28.38	-62.1	8.97
	61	120.	1.50		9.7		9.7			-1.03	-1.03	1.6820	29.41	-62.1	8.97
	62	120.	1.50		9.7		9.7			-1.03	-1.03	1.6820	30.44	-62.1	8.97
	63	120.	1.50		9.7		9.7			-1.03	-1.03	1.6820	31.47	-62.1	8.97
	64	120.	1.50	5	9.1	8.0	17.1			-1.82	-1.82	1.6820	33.29	-62.1	8.97
L11>	65	120.	1.50	5	2.0	8.0	10.0	-2.0	-.87	-1.06	-1.93	1.6820	35.21	-62.1	8.97
52<	(66)	120.	4.00	20	168.0	18.0	186.0			-8.99	-8.99	4.2600	44.20	-468.4	10.54

LOOP 11

54>															
L12>	67	120.	4.00		10.0		10.0			.39	.39	4.2600	27.83	419.0	9.43
	68	120.	1.50	5	2.0	8.0	10.0	2.0	.87	4.78	5.65	1.6820	22.18	140.1	20.23
S1	69	120.	1.50		.0		.0			.00	.00	1.6820	22.18	140.1	20.23
S1	70	120.	1.50		9.7		9.7			2.69	2.69	1.6820	19.48	104.4	15.07
S1	71	120.	1.50		9.7		9.7			1.29	1.29	1.6820	18.20	70.1	10.12
S1	72	120.	1.50		9.7		9.7			.38	.38	1.6820	17.82	36.2	5.22
S1	73	120.	1.50		9.7		9.7			.00	.00	1.6820	17.82	2.2	.31
S1	74	120.	1.50		9.7		9.7			-.30	-.30	1.6820	18.12	-32.0	4.63
S1	75	120.	1.50		9.7		9.7			-1.15	-1.15	1.6820	19.27	-65.9	9.52
S1	76	120.	1.50		9.7		9.7			-2.49	-2.49	1.6820	21.76	-100.2	14.46
	77	120.	1.50	5	9.1	8.0	17.1			-7.71	-7.71	1.6820	29.47	-135.6	19.59
L12>	78	120.	1.50	5	2.0	8.0	10.0	-2.0	-.87	-4.51	-5.37	1.6820	34.84	-135.6	19.59
65<	(79)	120.	4.00		10.0		10.0			-.37	-.37	4.2600	35.21	-406.2	9.14

LOOP 12

67>															
L13>	80	120.	4.00		10.0		10.0			.19	.19	4.2600	27.64	278.9	6.28
	81	120.	1.50	5	2.0	8.0	10.0	2.0	.87	4.75	5.61	1.6820	22.03	139.5	20.14
S1	82	120.	1.50		.0		.0			.00	.00	1.6820	22.03	139.5	20.14
S1	83	120.	1.50		9.7		9.7			2.67	2.67	1.6820	19.36	103.9	15.01
S1	84	120.	1.50		9.7		9.7			1.28	1.28	1.6820	18.08	69.7	10.07
S1	85	120.	1.50		9.7		9.7			.37	.37	1.6820	17.71	35.9	5.19
S1	86	120.	1.50		9.7		9.7			.00	.00	1.6820	17.70	2.0	.29
S1	87	120.	1.50		9.7		9.7			-.30	-.30	1.6820	18.01	-32.1	4.63
S1	88	120.	1.50		9.7		9.7			-1.15	-1.15	1.6820	19.15	-65.8	9.51
S1	89	120.	1.50		9.7		9.7			-2.49	-2.49	1.6820	21.64	-100.0	14.43
	90	120.	1.50	5	9.1	8.0	17.1			-7.67	-7.67	1.6820	29.31	-135.3	19.54
L13>	91	120.	1.50	5	2.0	8.0	10.0	-2.0	-.87	-4.49	-5.35	1.6820	34.67	-135.3	19.54
78<	(92)	120.	4.00		10.0		10.0			-.18	-.18	4.2600	34.84	-270.6	6.09

LOOP 13


80>															
	93	120.	4.00		10.0		10.0			.05	.05	4.2600	27.59	139.4	3.14
	94	120.	1.50	5	2.0	8.0	10.0	2.0	.87	4.74	5.60	1.6820	21.99	139.4	20.12
S1	95	120.	1.50		.0		.0			.00	.00	1.6820	21.99	139.4	20.12
S1	96	120.	1.50		9.7		9.7			2.66	2.66	1.6820	19.32	103.8	14.99
S1	97	120.	1.50		9.7		9.7			1.27	1.27	1.6820	18.05	69.6	10.05
S1	98	120.	1.50		9.7		9.7			.37	.37	1.6820	17.67	35.9	5.18
S1	99	120.	1.50		9.7		9.7			.00	.00	1.6820	17.67	2.0	.29
S1	100	120.	1.50		9.7		9.7			-.30	-.30	1.6820	17.98	-32.1	4.63
S1	101	120.	1.50		9.7		9.7			-1.15	-1.15	1.6820	19.12	-65.8	9.50
S1	102	120.	1.50		9.7		9.7			-2.48	-2.48	1.6820	21.61	-99.9	14.43
	103	120.	1.50	5	9.1	8.0	17.1			-7.67	-7.67	1.6820	29.27	-135.3	19.53

104	120.	1.50	5	2.0	8.0	10.0	-2.0	-.87	-4.48	-5.35	1.6820	34.62	-135.3	19.53
105	120.	4.00		10.0		10.0			-.05	-.05	4.2600	34.67	-135.3	3.04

136.4 PSI PRESSURE AVAILABLE AND 65.7 PSI PRESSURE REQUIRED AT THE WATER SUPPLY WHEN FLOWING 1448.9 GPM
 900.0 GPM MINIMUM DESIGN FLOW REQUIREMENT
 500.0 GPM REQUIRED ADDITIONAL FLOW 1867.6 GPM MAXIMUM FLOW

3354

CONTRACT NAME:



✓X (USD) 38755383

BRICK TOWNSHIP		BY
Plan Review	Class	Date
zoning		
plumbing		
Building		8/14/92
Fire		
Energy		
Electrical		

A.J. CARNEGIE, INC.
1600 Jersey Avenue

Automatic Fire Protection Systems

Box 3024
North Brunswick, N.J. 08902

908-249-3930
FAX 908-246-3631

HYDRAULIC DESIGN INFORMATION SHEET

DATE: August 7, 1992
NAME: Price Club
LOCATION: Brick Township
CONSTRUCTION: Non-combustible
OCCUPANCY: Warehouse - Outflow only

SYSTEM DESIGN

NEPA #13:
LIGHT HAZ.: _____ ORD.HAZ.GROUP: #1 _____ #2 _____ #3 _____ EX.HAZ.: _____

NEPA #231:
NEPA #231C: _____ FIGURE: _____ CURVE: _____

OTHER: (specify) Outflow @ most remote for canopy & racks

AREA OF SPRINKLER OPERATION:
DENSITY:
AREA PER SPRINKLER:
HOSE ALLOWANCE GPM: (inside)
HOSE ALLOWANCE GPM: (outside)
RACK SPRINKLER ALLOWANCE:

SYSTEM TYPE

WET: ☒ DRY: _____ DELUGE: _____ PRE - ACTION: _____

SPRINKLER OR NOZZLE

MAKE: _____ MODEL: _____ SIZE: _____ TEMP: _____ K: _____

CALCULATION SUMMARY

GPM REQUIRED: _____ PSI REQUIRED: _____
"C" FACTOR USED: _____ OVERHEAD: 120 UNDERGROUND: 140

WATER SUPPLY

WATER FLOW TEST

DATE: _____
STATIC PSI: 55
RESIDUAL PSI: 48
GPM FLOWING: 1734
ELEVATION: same

PUMP DATA

RATED CAPACITY: 1000
AT PSI: 125lbs
ELEVATION: same

LOCATION: Route 70 & 88
SOURCE: Water Department

Serial Number 1012122 Run Number 03243

CAFE

January 1, 1980

PRICE CLUB
RT. # 88
BRICKTOWN, N.J.

HYDRAULIC SYSTEM DESIGN REPORT

A.J. CARNEGIE, INC.
P.O. BOX 3024
NORTH BRUNSWICK, N.J.Design Engineer
A.J.C., INC.GRID SYSTEM USED AS SUPPLY MAIN TO 500 GPM
OUTFLOW AT REAR OF GRID FOR CALCULATION
OF SYSTEMS OFF REAR GRID CROSS-MAIN. 500
GPM HOSE ALLOWANCE AT PUMP.

PROJECT NAME: PRICE CLUB GRID SUPPLY TO REAR

PROJECT NUMBER: AJC

-----UNITS TABLE-----

LENGTHS AND ELEVATIONS IN FEET	PIPE DIAMETERS IN INCHES
PRESSURES IN POUNDS PER SQUARE INCH	VOLUMES IN U.S. GALLONS
FLOWS IN U.S. GALLONS PER MINUTE	VELOCITIES IN FEET PER SECOND

OUTFLOW

THE SYSTEM HAS 9 LOOPS

-----WATER SUPPLY WS1 ASSIGNED AT NODE 0-----

STATIC PRESSURE = 205.0 PSI 177.0 PSI FLOWING 1000.0 GPM
130.00 PSI FLOWING 1500.0 GPM


-----FITTING TABLE-----

T2 = 2 TURNING FLOW TEE FITTINGS
L3 = 3 LONG TURN 90 DEGREE ELBOWS
17 = COMBINATION OF GV CV LE
18 = COMBINATION OF IF GV AV
19 = COMBINATION OF L3
20 = COMBINATION OF T2

MAIN AND LOOP PIPES

PIPE CONFIG	H&W COEF	PIPE DIAM	FIT COMB	PIPE LGT	FIT E LGT	TOTAL LGT	ELEV CHANGE	ELEV PRES	FRIC PRES	PRES LOSS	PIPE ID	TOTAL PRES	PIPE FLOW	PIPE VEL	VEL PRES	NORMAL PRES	IN/OUT FLOW
WS1																	<1000.0>
0>																	
1	120.	8.00		.0		.0			.00	.00	8.2490	177.00	1000.0	6.00			500.0
2	120.	8.00	17	10.0	28.0	38.0	2.0	.87	.08	.95	8.2490	176.05	500.0	3.00			
3	120.	6.00	18	4.0	78.0	82.0	4.0	1.73	.64	2.37	6.3570	173.68	500.0	5.05			
L1 >	4	120.	6.00	19	303.0	27.0	332.0	17.0	7.36	2.58	9.94	6.3570	163.75	500.0	5.05		
LOOP 1																	
L2 <	5	120.	6.00		11.6		11.6		.07	.07	6.3570	163.67	451.8	4.57			
L2 >	6	120.	2.00	20	213.0	20.0	233.0		4.54	4.54	2.1570	159.13	47.8	4.20			
	7	120.	4.00		11.6		11.6		-1.01	-1.01	4.2600	159.14	-48.2	1.08			
4<	(8)	120.	2.00	20	213.0	20.0	233.0		-4.61	-4.61	2.1570	163.75	-48.2	4.23			
LOOP 2																	
L3 <	9	120.	6.00		11.6		11.6		.06	.06	6.3570	163.61	404.0	4.08			
L3 >	10	120.	2.00	20	213.0	20.0	233.0		4.51	4.51	2.1570	159.10	47.6	4.18			
6<	(11)	120.	4.00		11.6		11.6		-1.03	-1.03	4.2600	159.13	-96.0	2.16			
LOOP 3																	
L4 <	12	120.	6.00		11.6		11.6		.05	.05	6.3570	163.56	356.4	3.60			
L4 >	13	120.	2.00	20	213.0	20.0	233.0		4.53	4.53	2.1570	159.03	47.7	4.19			

6" Main



Loop Nos. for Outflow for Rack System + Canopy

Assumes Most hydraulically remote area of building -
So. West Corner of System #3 Grid - to give flow for
each system -

PRICE SCHEDULE


Price Club

Outflow for canopy + shade
at West Remote Area of Bldg - Newcom

CONTRACT NAME:

NO:

PRESSURE (PSI) X 2



A.J. CARNEGIE, INC.

1600 Jersey Avenue

Automatic Fire Protection Systems

Box 3024

North Brunswick, N.J. 08902

908-249-3930

FAX 908-246-3631

HYDRAULIC DESIGN INFORMATION SHEET

DATE: August 7, 1992
NAME: Price Club
LOCATION: Brick Township
CONSTRUCTION: Non-combustible
OCCUPANCY: Warehouse - Outflow only

SYSTEM DESIGN

NFPA #13:
LIGHT HAZ.: _____ ORD. HAZ. GROUP: #1 _____ #2 _____ #3 _____ EX. HAZ.: _____

NFPA #231:
NFPA #231C: _____ FIGURE: _____ CURVE: _____

OTHER: (specify) Outflow @ most remote for canopy & racks

AREA OF SPRINKLER OPERATION:
DENSITY:
AREA PER SPRINKLER:
HOSE ALLOWANCE GPM: (inside)
HOSE ALLOWANCE GPM: (outside)
RACK SPRINKLER ALLOWANCE:

SYSTEM TYPE

WET: x DRY: _____ DELUGE: _____ PRE - ACTION: _____

SPRINKLER OR NOZZLE

MAKE: _____ MODEL: _____ SIZE: _____ TEMP: _____ K: _____

CALCULATION SUMMARY

GPM REQUIRED: _____ PSI REQUIRED: _____
"C" FACTOR USED: _____ OVERHEAD: 120 UNDERGROUND: 140

WATER SUPPLY

WATER FLOW TEST

DATE: _____
STATIC PSI: 55
RESIDUAL PSI: 48
GPM FLOWING: 1734
ELEVATION: same

PUMP DATA

RATED CAPACITY: 1000
AT PSI: 125lbs
ELEVATION: same

LOCATION: Route 70 & 88
SOURCE: Water Department

Serial Number 1012122 Run Number 03243

January 1, 1980

HYDRAULIC SYSTEM DESIGN REPORT

PRICE CLUB
RT. # 88
BRICKTOWN, N.J.

A.J. CARNEGIE, INC.
P.O. BOX 3024
NORTH BRUNSWICK, N.J.

Design Engineer
A.J.C., INC.

GRID SYSTEM USED AS SUPPLY MAIN TO 500 GPM
OUTFLOW AT REAR OF GRID FOR CALCULATION
OF SYSTEMS OFF REAR GRID CROSS-MAIN. 500
GPM HOSE ALLOWANCE AT PUMP.

PROJECT NAME: PRICE CLUB GRID SUPPLY TO REAR

PROJECT NUMBER: AJC

-----UNITS TABLE-----
LENGTHS AND ELEVATIONS IN FEET PIPE DIAMETERS IN INCHES
PRESSURES IN POUNDS PER SQUARE INCH VOLUMES IN U.S. GALLONS
FLOWS IN U.S. GALLONS PER MINUTE VELOCITIES IN FEET PER SECOND

THE SYSTEM HAS 9 LOOPS

-----WATER SUPPLY WSI ASSIGNED AT NODE 0-----
STATIC PRESSURE = 205.0 PSI 177.0 PSI FLOWING 1000.0 GPM
130.00 PSI FLOWING 1500.0 GPM


-----FITTING TABLE-----
T2 = 2 TURNING FLOW TEE FITTINGS
L3 = 3 LONG TURN 90 DEGREE ELBOWS
17 = COMBINATION OF GV CV LE
18 = COMBINATION OF TF GV AV
19 = COMBINATION OF L3
20 = COMBINATION OF T2

MAIN AND LOOP PIPES

PIPE CONFIG	H&W COEF	PIPE DIAM	FIT COMB	PIPE LGT	FIT E LGT	TOTAL LGT	ELEV CHANGE	ELEV PRES	FRIC PRES	PRES LOSS	PIPE ID	TOTAL PRES	PIPE FLOW	PIPE VEL	VEL PRES	NORMAL PRES	IN/OUT FLOW
WSI																	<1000.0>
0																	
1	120.	8.00		.0		.0			.00	.00	8.2490	177.00	1000.0	6.00			500.0
2	120.	8.00	17	10.0	28.0	38.0	2.0	.87	.08	.95	8.2490	176.05	500.0	3.00			
3	120.	6.00	18	4.0	78.0	82.0	4.0	1.73	.64	2.37	6.3570	173.68	500.0	5.05			
4	120.	6.00	19	305.0	27.0	332.0	17.0	7.36	2.58	9.94	6.3570	163.75	500.0	5.05			
----- LOOP 1 -----																	
5	120.	6.00		11.6		11.6			.07	.07	6.3570	163.67	451.8	4.57			
6	120.	2.00	20	213.0	20.0	233.0			4.54	4.54	2.1570	159.13	47.8	4.20			
7	120.	4.00		11.6		11.6			-.01	-.01	4.2600	159.14	-48.2	1.08			
4	(8)	120.	2.00	20	213.0	20.0	233.0		-4.61	-4.61	2.1570	163.75	-48.2	4.23			
----- LOOP 2 -----																	
9	120.	6.00		11.6		11.6			.06	.06	6.3570	163.61	404.0	4.08			
10	120.	2.00	20	213.0	20.0	233.0			4.51	4.51	2.1570	159.10	47.6	4.18			
6	(11)	120.	4.00	11.6		11.6			-.03	-.03	4.2600	159.13	-96.0	2.16			
----- LOOP 3 -----																	
12	120.	6.00		11.6		11.6			.05	.05	6.3570	163.56	356.4	3.60			
13	120.	2.00	20	213.0	20.0	233.0			4.53	4.53	2.1570	159.03	47.7	4.19			

Outflow

6" Main




Loop Nos. for Outflow for Rack System + Canopy

Assumes Most hydraulically remote area of building -
So, West Corner of System #3 Grid - to give flow for
each system -

Price Club

Price L100
Outflow for canopy + Rade
Remote Area of Bldg - Nucoms

 ZnO 

A.J. CARNEGIE, INC.
1600 Jersey Avenue

Automatic Fire Protection Systems

Box 3024

North Brunswick, N.J. 08902

908-249-3930
FAX 908-246-3631

HYDRAULIC DESIGN INFORMATION SHEET

DATE: August 7, 1992
NAME: Price Club
LOCATION: Brick Township
CONSTRUCTION: Non-combustible
OCCUPANCY: Warehouse - Outflow only

SYSTEM DESIGN

NFPA #13:
LIGHT HAZ.: _____ ORD. HAZ. GROUP: #1 _____ #2 _____ #3 _____ EX. HAZ.: _____

NFPA #231:
NFPA #231C: _____ FIGURE: _____ CURVE: _____

OTHER: (specify) Outflow @ most remote for canopy & racks

AREA OF SPRINKLER OPERATION:
DENSITY:
AREA PER SPRINKLER:
HOSE ALLOWANCE GPM: (inside)
HOSE ALLOWANCE GPM: (outside)
RACK SPRINKLER ALLOWANCE:

SYSTEM TYPE

WET: ☒ DRY: _____ DELUGE: _____ PRE - ACTION: _____

SPRINKLER OR NOZZLE

MAKE: _____ MODEL: _____ SIZE: _____ TEMP: _____ K: _____

CALCULATION SUMMARY

GPM REQUIRED: _____ PSI REQUIRED: _____
"C" FACTOR USED: _____ OVERHEAD: 120 UNDERGROUND: 140

WATER SUPPLY

WATER FLOW TEST

DATE: _____
STATIC PSI: 55
RESIDUAL PSI: 48
GPM FLOWING: 1734
ELEVATION: same

PUMP DATA

RATED CAPACITY: 1000
AT PSI: 125lbs
ELEVATION: same

LOCATION: Route 70 & 88
SOURCE: Water Department

Serial Number 1012122 Run Number 03243

January 1, 1980

PRICE CLUB RT. # 88 BRICKTOWN, N.J.		HYDRAULIC SYSTEM DESIGN REPORT A.J. CARNEGIE, INC. P.O. BOX 3024 NORTH BRUNSWICK, N.J. Design Engineer A.J.C., INC.	GRID SYSTEM USED AS SUPPLY MAIN TO 500 GPM OUTFLOW AT REAR OF GRID FOR CALCULATION OF SYSTEMS OFF REAR GRID CROSS-MAIN. 500 GPM HOSE ALLOWANCE AT PUMP.
--	--	--	--

PROJECT NAME: PRICE CLUB GRID SUPPLY TO REAR

PROJECT NUMBER: AJC

-----UNITS TABLE-----
 LENGTHS AND ELEVATIONS IN FEET PIPE DIAMETERS IN INCHES
 PRESSURES IN POUNDS PER SQUARE INCH VOLUMES IN U.S. GALLONS
 FLOWS IN U.S. GALLONS PER MINUTE VELOCITIES IN FEET PER SECOND

OUTFLOW

THE SYSTEM HAS 9 LOOPS

-----WATER SUPPLY WS1 ASSIGNED AT NODE 0-----
 STATIC PRESSURE = 205.0 PSI 177.0 PSI FLOWING 1000.0 GPM
 150.00 PSI FLOWING 1500.0 GPM

-----FITTING TABLE-----
 T2 = 2 TURNING FLOW TEE FITTINGS
 L3 = 3 LONG TURN 90 DEGREE ELBOWS
 L7 = COMBINATION OF GV CV LE
 L8 = COMBINATION OF TF GV AV
 L9 = COMBINATION OF L3
 L20 = COMBINATION OF T2


MAIN AND LOOP PIPES

PIPE CONFIG	H&W (COEF	PIPE DIAM	FIT COMB	PIPE LGT	FIT E LGT	TOTAL LGT	ELEV CHANGE	ELEV PRES	FRIC PRES	PRES LOSS	PIPE ID	TOTAL PRES	PIPE FLOW	PIPE VEL	VEL PRES	NORMAL PRES	IN/OUT FLOW
WS1																	<1000.0>
0																	
1	120.	8.00		10.0	28.0	38.0	2.0	.87	.08	.95	8.2490	177.00	1000.0	6.00			500.0
2	120.	8.00	17	10.0	28.0	38.0	2.0	.87	.08	.95	8.2490	176.05	500.0	3.00			
3	120.	6.00	18	4.0	78.0	82.0	4.0	1.73	.64	2.37	6.3570	173.68	500.0	5.05			
L1	4	120.	6.00	19	365.0	27.0	332.0	17.0	7.36	2.58	9.94	6.3570	163.75	500.0	5.05		
-----LOOP 1-----																	
L2	5	120.	6.00		11.6	11.6			.07	.07	6.3570	163.67	451.8	4.57			
L2	6	120.	2.00	20	213.0	20.0	233.0		4.54	4.54	2.1570	159.13	47.8	4.20			
	7	120.	4.00		11.6	11.6			-.01	-.01	4.2600	159.14	-48.2	1.08			
4	(9)	120.	2.00	20	213.0	20.0	233.0		-4.61	-4.61	2.1570	163.75	-48.2	4.23			
-----LOOP 2-----																	
L3	9	120.	6.00		11.6	11.6			.06	.06	6.3570	163.61	404.0	4.08			
L3	10	120.	2.00	20	213.0	20.0	233.0		4.51	4.51	2.1570	159.10	47.6	4.18			
6	(11)	120.	4.00		11.6	11.6			-.03	-.03	4.2600	159.13	-96.0	2.16			
-----LOOP 3-----																	
L4	12	120.	6.00		11.6	11.6			.05	.05	6.3570	163.56	356.4	3.60			
L4	13	120.	2.00	20	213.0	20.0	233.0		4.53	4.53	2.1570	159.03	47.7	4.19			

10	(14)	120.	4.00	11.6	11.6	-0.06	-0.06	4.2600	159.10	-143.6	3.23	
LOOP 4												
12												
15	15	120.	6.00	11.6	11.6	.04	.04	6.3570	163.52	308.6	3.12	
15	16	120.	2.00	20	213.0	20.0	233.0	4.60	4.60	2.1570	158.93	48.1
13	(17)	120.	4.00	11.6	11.6	-1.11	-1.11	4.2600	159.03	-191.4	4.31	
LOOP 5												
15												
16	18	120.	6.00	11.6	11.6	.03	.03	6.3570	163.50	260.5	2.63	
16	19	120.	2.00	20	213.0	20.0	233.0	4.73	4.73	2.1570	158.77	48.9
16	(20)	120.	4.00	11.6	11.6	-1.16	-1.16	4.2600	158.93	-239.5	5.39	
LOOP 6												
17												
17	21	120.	6.00	11.6	11.6	.02	.02	6.3570	163.48	211.6	2.14	
17	22	120.	2.00	20	213.0	20.0	233.0	4.94	4.94	2.1570	158.54	50.0
19	(23)	120.	4.00	11.6	11.6	-1.23	-1.23	4.2600	158.77	-288.4	6.49	
LOOP 7												
21												
18	24	120.	6.00	11.6	11.6	.01	.01	6.3570	163.47	161.6	1.63	
18	25	120.	2.00	20	213.0	20.0	233.0	5.24	5.24	2.1570	158.23	51.6
22	(26)	120.	4.00	11.6	11.6	-1.31	-1.31	4.2600	158.54	-338.4	7.62	
LOOP 8												
24												
19	27	120.	6.00	11.6	11.6	.01	.01	6.3570	163.46	110.0	1.11	
19	28	120.	2.00	20	213.0	20.0	233.0	5.63	5.63	2.1570	157.83	53.7
25	(29)	120.	4.00	11.6	11.6	-1.40	-1.40	4.2600	158.23	-390.0	8.78	
LOOP 9												
27												
	30	120.	6.00	11.6	11.6	.00	.00	6.3570	163.46	56.3	.57	
	31	120.	2.00	20	213.0	20.0	233.0	6.14	6.14	2.1570	157.32	56.3
28	(32)	120.	4.00	11.6	11.6	-1.51	-1.51	4.2600	157.83	-443.7	9.99	500.0

177.0 PSI PRESSURE AVAILABLE AND 177.0 PSI PRESSURE REQUIRED AT THE WATER SUPPLY WHEN FLOWING 1000.0 GPM

6" Main



Loop Nos. for Outflow for Rack System + Canopy

Assumes Most hydraulically remote area of building -
So, West Corner of System #3 Grid - to give flow for
each system -

PRICE SCHEDULE


Price Club

CONTRACT NAME:

NO:

Outflow for canopy + shade
East Remote Area of Bldg - Newcom

PRESSURE (PSI) X 2



BRICK TOWNSHIP
Plan Review Class Date By

Zoning _____
Plumbing _____
Building _____
Fire 8/14/92 _____
Energy _____
Electrical _____

A.J. CARNEGIE, INC.

1600 Jersey Avenue

Automatic Fire Protection Systems

Box 3024

North Brunswick, N.J. 08902

908-249-3930

FAX 908-246-3631

HYDRAULIC DESIGN INFORMATION SHEET

DATE: August 7, 1992
NAME: Price Club
LOCATION: Brick Township
CONSTRUCTION: Non-combustible
OCCUPANCY: Canopy System

SYSTEM DESIGN

NFPA #13:
LIGHT HAZ.: _____ ORD.HAZ.GROUP: #1 _____ #2 _____ #3 _____ EX.HAZ.: _____

NFPA #231:
NFPA #231C: _____ FIGURE: _____ CURVE: _____

OTHER: (specify) FM Standard .19gpm/sf over 1950 sf

AREA OF SPRINKLER OPERATION: 1950
DENSITY: .19
AREA PER SPRINKLER: 127.5
HOSE ALLOWANCE GPM: (inside) > 250
HOSE ALLOWANCE GPM: (outside)
RACK SPRINKLER ALLOWANCE: -0-

SYSTEM TYPE

WET: _____ DRY: x _____ DELUGE: _____ PRE - ACTION: _____

SPRINKLER OR NOZZLE

MAKE: Central MODEL: A SIZE: 1/2 TEMP: 165 K: 5.7

CALCULATION SUMMARY

GPM REQUIRED: 584.4 PSI REQUIRED: 87
"C" FACTOR USED: OVERHEAD: 120 UNDERGROUND: 140

WATER SUPPLY

WATER FLOW TEST

DATE:
STATIC PSI: 55
RESIDUAL PSI: 48
GPM FLOWING: 1734
ELEVATION: same

PUMP DATA

RATED CAPACITY: 1000
AT PSI: 125lbs
ELEVATION: same

LOCATION: Route 70 & 88
SOURCE: Water Department

PRICE CLUB
RT.# 88
BRICKTOWN, N.J.

HYDRAULIC SYSTEM DESIGN REPORT

A.J.CARNEGIE, INC.
P.O. BOX 3024
NORTH BRUNSWICK, N.J.

Design Engineer

A.J.C., INC.

GRID SYSTEM USED AS SUPPLY MAIN TO 500 GPM
OUTFLOW AT REAR OF GRID FOR CALCULATION
OF SYSTEMS OFF REAR GRID CROSS-MAIN. 500
GPM HOSE ALLOWANCE AT PUMP.
CANOPY DRY-PIPE SYSTEM CALCULATED TO
PRODUCE .19/1950 USING 17/32", K=8.1 SPRK.
C-120 FOR GALV. PIPE

PROJECT NAME: PRICE CLUB CANOPY SYST.

PROJECT NUMBER: AJC

-----UNITS TABLE-----

LENGTHS AND ELEVATIONS IN FEET PIPE DIAMETERS IN INCHES
PRESSURES IN POUNDS PER SQUARE INCH VOLUMES IN U.S. GALLONS
FLOWS IN U.S. GALLONS PER MINUTE VELOCITIES IN FEET PER SECOND

DENSITY REQUIREMENT: .190 GPM/SQ.FT. OVER MOST REMOTE 1950. SQ.FT.

-----WATER SUPPLY WSI ASSIGNED AT NODE 0-----

STATIC PRESSURE = 205.0 PSI 157.0 PSI FLOWING 500.0 GPM

CANOPY SYST

LINE 81	PIPE LGT	FIT COMB	FIT E LGT	TOTAL LGT	PIPE DIAM	ELEV CHANGE	H&W COEF	AREA COVER	K FACTOR	PIPE ID	ELEV PRES	FRIC PRES	NORMAL PRES	VEL PRES	TOTAL PRES	HEAD FLOW	PIPE FLOW	VEL
5	9.00			9.00	1.50		120.	127.5	8.10	1.610		.49	22.78	.00	22.78	38.66	38.66	6.09
6	9.00			9.00	1.50		120.	127.5	8.10	1.610		1.76	22.28	.99	23.27	38.23	76.89	12.12
7	9.00			9.00	2.00		120.	127.5	8.10	2.067		1.13	24.19	.84	25.02	39.84	116.73	11.16
8	9.00			9.00	2.00		120.	127.5	8.10	2.067		1.95	24.64	1.52	26.15	40.20	156.93	15.00
9	9.00			9.00	2.00		120.	127.5	8.10	2.067		2.99	25.69	2.41	28.10	41.05	197.98	18.93
10	2.00	5	10.00	12.00	2.00		120.	127.5	8.10	2.067		5.72	27.53	3.56	31.09	42.50	240.48	22.99
11	.01	5	15.00	15.01	3.00		120.	.0	.00	3.260		4.02	36.80	.00	36.80		584.37	22.46
12	7.00	5	12.00	19.00	2.50		120.	127.5	8.10	2.635		5.38	28.67	2.75	31.43	43.37	343.88	20.23
13	9.00			9.00	2.50		120.	127.5	8.10	2.635		1.98	27.34	2.10	29.44	42.35	300.51	17.68
14	9.00	19	30.00	39.00	2.50		120.	127.5	8.10	2.635		6.49	21.39	1.55	22.95	37.47	258.16	15.19
15	9.00			9.00	2.00		120.	127.5	8.10	2.067		3.66	16.29	3.00	19.29	32.70	220.69	21.10
16	9.00			9.00	2.00		120.	127.5	8.10	2.067		2.72	14.40	2.17	16.57	30.75	186.00	17.97
17	9.00			9.00	2.00		120.	127.5	8.10	2.067		1.95	13.10	1.52	14.62	29.31	157.26	15.04
18	9.00			9.00	2.00		120.	127.5	8.10	2.067		1.33	12.28	1.01	13.28	28.38	127.95	12.23
19	9.00	19	20.00	29.00	2.00		120.	127.5	8.10	2.067		2.70	9.97	.61	10.58	25.58	99.57	9.52
20	9.00			9.00	2.00		120.	127.5	8.10	2.067		.48	9.76	.34	10.10	25.30	74.00	7.07
21	9.00			9.00	1.50		120.	127.5	8.10	1.610		.75	8.94	.40	9.34	24.23	48.69	7.67
22	9.00			9.00	1.50		120.	127.5	8.10	1.610		.21	9.13	.00	9.13	24.47	24.47	3.86

40.82 PSI PRESSURE REQUIRED FLOWING 584.4 GPM

411.82 GPM = MIN REQUIRED FLOW 41.9% EXCESS FLOW

-----LINE ASSIGNMENT TO MAIN NODES-----

LINE 81 JOINS AT NODE: 4

-----FITTING TABLE-----

5 = LE : 1 LONG TURN 90 DEGREE ELBOW
5 = TF : 1 TURNING FLOW TEE FITTING
T2 : 2 TURNING FLOW TEE FITTINGS
L4 : 4 LONG TURN 90 DEGREE ELBOWS

B1 = 10 45 DEGREE ELBOWS
 17 = COMBINATION OF T2 L4
 18 = COMBINATION OF GV DV
 19 = COMBINATION OF B1

PIPE CONFIG	H&W COEF	PIPE DIAM	FIT COMB	PIPE LGT	FIT E LGT	TOTAL LGT	ELEV CHANGE	MAIN PIPES			PIPE ID	TOTAL PRES	PIPE FLOW	VEL	VEL PRES	NORMAL PRES	IN/OUT FLOW
								ELEV PRES	FRIC PRES	PRES LOSS							
WS1																	<584.4>
0.1																	
1	120.	3.00		.0		.0			.00	.00	3.2600	87.01	584.4	22.46			
2	120.	3.00	17	44.0	50.0	94.0	-19.0	-8.23	25.16	16.94	3.2600	70.07	584.4	22.46			
3	120.	3.00	18	.0	60.0	60.0	2.0	.87	16.06	16.93	3.2600	53.14	584.4	22.46			
B1	4	120.	3.00	3	20.0	5.0	25.0	13.0	5.63	6.69	12.32	3.2600	40.82	584.4	22.46	.00	40.82 584.4

141.0 PSI PRESSURE AVAILABLE AND 87.0 PSI PRESSURE REQUIRED AT THE WATER SUPPLY WHEN FLOWING 584.4 GPM
 370.5 GPM MINIMUM DESIGN FLOW REQUIREMENT
 .0 GPM REQUIRED ADDITIONAL FLOW 743.7 GPM MAXIMUM FLOW


PRICE CLUB

Price Club
Canopy System

CONTRACT NAME:

NO:

PRESSURE (PSI)



FLOW - GPM

A.J. CARNEGIE, INC.
1600 Jersey Avenue

Automatic Fire Protection Systems

Box 3024

North Brunswick, N.J. 08902

908-249-3930
FAX 908-246-3631

HYDRAULIC DESIGN INFORMATION SHEET

DATE: August 7, 1992
NAME: Price Club
LOCATION: Brick Township
CONSTRUCTION: Non-combustible
OCCUPANCY: Canopy System

SYSTEM DESIGN

NFPA #13:
LIGHT HAZ.: _____ ORD. HAZ. GROUP: #1 _____ #2 _____ #3 _____ EX. HAZ.: _____

NFPA #231:
NFPA #231C: _____ FIGURE: _____ CURVE: _____

OTHER: (specify) FM Standard .19gpm/sf over 1950 sf

AREA OF SPRINKLER OPERATION: 1950
DENSITY: .19
AREA PER SPRINKLER: 127.5
HOSE ALLOWANCE GPM: (inside) > 250
HOSE ALLOWANCE GPM: (outside)
RACK SPRINKLER ALLOWANCE: -0-

SYSTEM TYPE

WET: _____ DRY: x DELUGE: _____ PRE - ACTION: _____

SPRINKLER OR NOZZLE

MAKE: Central MODEL: A SIZE: 1/2 TEMP: 165 K: 5.7

CALCULATION SUMMARY

GPM REQUIRED: 584.4 PSI REQUIRED: 87
"C" FACTOR USED: OVERHEAD: 120 UNDERGROUND: 140

WATER SUPPLY

WATER FLOW TEST

DATE:
STATIC PSI: 55
RESIDUAL PSI: 48
GPM FLOWING: 1734
ELEVATION: same

PUMP DATA

RATED CAPACITY: 1000
AT PSI: 125lbs
ELEVATION: same

LOCATION: Route 70 & 88
SOURCE: Water Department

PRICE CLUB
RT. # 38
BRICKTOWN, N.J.

HYDRAULIC SYSTEM DESIGN REPORT

A.J. CARNEGIE, INC.
P.O. BOX 3024
NORTH BRUNSWICK, N.J.

Design Engineer
A.J.C., INC.

GRID SYSTEM USED AS SUPPLY MAIN TO 500 GPM
OUTFLOW AT REAR OF GRID FOR CALCULATION
OF SYSTEMS OFF REAR GRID CROSS-MAIN. 500
GPM HOSE ALLOWANCE AT PUMP.
CANOPY DRY-PIPE SYSTEM CALCULATED TO
PRODUCE .19/1950 USING 17/32", K=8.1 SPRK.
C-120 FOR GALV. PIPE

PROJECT NAME: PRICE CLUB CANOPY SYST.

PROJECT NUMBER: AJC

-----UNITS TABLE-----

LENGTHS AND ELEVATIONS IN FEET PIPE DIAMETERS IN INCHES
PRESSURES IN POUNDS PER SQUARE INCH VOLUMES IN U.S. GALLONS
FLOWS IN U.S. GALLONS PER MINUTE VELOCITIES IN FEET PER SECOND

DENSITY REQUIREMENT: .190 GPM/SQ.FT. OVER MOST REMOTE 1950. SQ.FT.

-----WATER SUPPLY WSI ASSIGNED AT NODE 0-----
STATIC PRESSURE = 205.0 PSI 157.0 PSI FLOWING 500.0 GPM

LINE BI	PIPE LGT	FIT COMB	FIT E LGT	TOTAL LGT	PIPE DIAM	ELEV CHANGE	H&W COEF	AREA COVER	K FACTOR	PIPE ID	ELEV PRES	FRIC PRES	NORMAL PRES	VEL PRES	TOTAL PRES	HEAD FLOW	PIPE FLOW	VEL
5	9.00			9.00	1.50			120.	127.5	8.10	1.610	.49	22.78	.00	22.78	38.66	38.66	6.09
6	9.00			9.00	1.50			120.	127.5	8.10	1.610	1.76	22.28	.99	23.27	38.23	76.89	12.12
7	9.00			9.00	2.00			120.	127.5	8.10	2.067	1.13	24.19	.84	25.02	39.84	116.73	11.16
8	9.00			9.00	2.00			120.	127.5	8.10	2.067	1.95	24.64	1.52	26.15	40.20	156.93	15.00
9	9.00			9.00	2.00			120.	127.5	8.10	2.067	2.99	25.69	2.41	28.10	41.05	197.98	18.93
10	2.00	5	10.00	12.00	2.00			120.	127.5	8.10	2.067	5.72	27.53	3.56	31.09	42.50	240.48	22.99
11	.01	5	15.00	15.01	3.00			120.	.0	.00	3.260	4.02	36.80	.00	36.80		584.37	22.46
12	7.00	5	12.00	19.00	2.50			120.	127.5	8.10	2.635	5.38	28.67	2.75	31.43	43.37	343.88	20.23
13	9.00			9.00	2.50			120.	127.5	8.10	2.635	1.98	27.34	2.10	29.44	42.35	300.51	17.68
14	9.00	19	30.00	39.00	2.50			120.	127.5	8.10	2.635	6.49	21.39	1.55	22.95	37.47	258.16	15.19
15	9.00			9.00	2.00			120.	127.5	8.10	2.067	3.66	16.29	3.00	19.29	32.70	220.69	21.10
16	9.00			9.00	2.00			120.	127.5	8.10	2.067	2.72	14.40	2.17	16.57	30.73	188.00	17.97
17	9.00			9.00	2.00			120.	127.5	8.10	2.067	1.95	13.10	1.52	14.62	29.31	157.26	15.04
18	9.00			9.00	2.00			120.	127.5	8.10	2.067	1.33	12.28	1.01	13.28	28.38	127.95	12.23
19	9.00	19	20.00	29.00	2.00			120.	127.5	8.10	2.067	2.70	9.97	.61	10.58	25.58	99.57	9.52
20	9.00			9.00	2.00			120.	127.5	8.10	2.067	.48	9.76	.34	10.10	25.30	74.00	7.07
21	9.00			9.00	1.50			120.	127.5	8.10	1.610	.75	8.94	.40	9.34	24.23	48.69	7.67
22	9.00			9.00	1.50			120.	127.5	8.10	1.610	.21	9.13	.00	9.13	24.47	24.47	3.86

40.82 PSI PRESSURE REQUIRED FLOWING 584.4 GPM

411.82 GPM = MIN REQUIRED FLOW 41.9% EXCESS FLOW

-----LINE ASSIGNMENT TO MAIN NODES-----

LINE BI JOINS AT NODE: 4

-----FITTING TABLE-----

3 = LE = 1 LONG TURN 90 DEGREE ELBOW
5 = TF = 1 TURNING FLOW TEE FITTING
T2 = 2 TURNING FLOW TEE FITTINGS
L4 = 4 LONG TURN 90 DEGREE ELBOWS

2 B1 = 10 45 DEGREE ELBOWS
 17 = COMBINATION OF T2 L4
 18 = COMBINATION OF GV DV
 19 = COMBINATION OF B1

PIPE CONFIG	H&W COEF	PIPE DIAM	FIT COMB	PIPE LGT	FIT E LGT	TOTAL LGT	ELEV CHANGE	MAIN PIPES			PIPE ID	TOTAL PRES	PIPE FLOW	VEL	VEL NORMAL		IN/OUT FLOW
								ELEV PRES	FRIC PRES	PRES LOSS					PRES	PRES	
WS1																	<584.4>
0																	
1	120.	3.00		.0		.0			.00	.00	3.2600	97.01	584.4	22.46			
2	120.	3.00	17	44.0	50.0	94.0	-19.0	-8.23	25.16	16.94	3.2600	70.07	584.4	22.46			
3	120.	3.00	18	.0	60.0	60.0	2.0	.87	16.06	16.93	3.2600	53.14	584.4	22.46			
B1	4	120.	3.00	3	20.0	5.0	25.0	13.0	5.63	6.69	12.32	3.2600	40.82	584.4	22.46	.00	40.82 584.4


141.0 PSI PRESSURE AVAILABLE AND 87.0 PSI PRESSURE REQUIRED AT THE WATER SUPPLY WHEN FLOWING 584.4 GPM
 370.5 GPM MINIMUM DESIGN FLOW REQUIREMENT
 .0 GPM REQUIRED ADDITIONAL FLOW 743.7 GPM MAXIMUM FLOW

PRICE CLUB

Price Club
Canopy System

CONTRACT NAME:

NO:



BRICK TOWNSHIP

Plan Review : Class Date BY

Zoning _____

Plumbing _____

Building _____

Fire 8/14/92 _____

Energy [Signature] _____

Electrical _____

A.J. CARNEGIE, INC.
1600 Jersey Avenue

Automatic Fire Protection Systems

Box 3024
North Brunswick, N.J. 08902

908-249-3930
FAX 908-246-3631

HYDRAULIC DESIGN INFORMATION SHEET

DATE: August 7, 1992
NAME: Price Club
LOCATION: Brick Township
CONSTRUCTION: Non-combustible
OCCUPANCY: Roof - Sales Area

SYSTEM DESIGN

NFPA #13:
LIGHT HAZ.: _____ ORD. HAZ. GROUP: #1 _____ #2 _____ #3 _____ EX. HAZ.: _____

NFPA #231:
NFPA #231C: _____ FIGURE: _____ CURVE: _____

OTHER: (specify) FM Standard EFSR Heads .99 gpm/sf over 1200

AREA OF SPRINKLER OPERATION: 1200
DENSITY: .99
AREA PER SPRINKLER: 100
HOSE ALLOWANCE GPM: (inside) >
HOSE ALLOWANCE GPM: (outside) > 250
RACK SPRINKLER ALLOWANCE: -0-

SYSTEM TYPE

WET: x DRY: _____ DELUGE: _____ PRE - ACTION: _____

SPRINKLER OR NOZZLE

MAKE: ASCO MODEL: K1 SIZE: 17/32 TEMP: 165 K: 14

CALCULATION SUMMARY

GPM REQUIRED: 1445.2 PSI REQUIRED: 120
"C" FACTOR USED: OVERHEAD: 120 UNDERGROUND: 140

WATER SUPPLY

WATER FLOW TEST

DATE:
STATIC PSI: 55
RESIDUAL PSI: 48
GPM FLOWING: 1734
ELEVATION: same

PUMP DATA

RATED CAPACITY: 1000
AT PSI: 125lbs
ELEVATION: same

LOCATION: Route 70 & 88
SOURCE: Water Department

PRICE CLUB		HYDRAULIC SYSTEM DESIGN REPORT		ROOF SPRINKLER SYSTEM CALCULATED TO FLOW (12) ESFR SPRINKLERS, (4) EACH ON (3) MOST REMOTE LINES AT MIN. 50 PSI EACH. K=14.0 250 GPM HOSE ALLOWANCE AT PUMP.	
RT. # 88		A.J. CARNEGIE, INC.			
BRICKTOWN, N.J.		P.O. BOX 3024			
		NORTH BRUNSWICK, N.J.			
		Design Engineer			
		A.J.C., INC.			

PROJECT NAME: PRICE CLUB ROOF ESFR SYSTEM #1(MOST REMOTE)

PROJECT NUMBER: AJC

ESFR System

-----UNITS TABLE-----

LENGTHS AND ELEVATIONS IN FEET	PIPE DIAMETERS IN INCHES
PRESSURES IN POUNDS PER SQUARE INCH	VOLUMES IN U.S. GALLONS
FLOWS IN U.S. GALLONS PER MINUTE	VELOCITIES IN FEET PER SECOND

DENSITY REQUIREMENT: .990 GPM/SQ.FT. OVER MOST REMOTE 1200. SQ.FT.

THE SYSTEM HAS 9 LOOPS

-----WATER SUPPLY WS1 ASSIGNED AT NODE 0-----

STATIC PRESSURE : 205.0 PSI 177.0 PSI FLOWING 1000.0 GPM
150.00 PSI FLOWING 1500.0 GPM

-----SPRINKLER ASSIGNMENT TO MAIN OR LOOP NODES-----

S1 : 14.00 X-FACTOR SPRINKLER ASSIGNED TO COVER 100.0 SQ.FT.

----- AT NODES: 41 42 43 44 50 51 52 53 59 60 61 62 -----

-----FITTING TABLE-----

5 = TF = 1 TURNING FLOW TEE FITTING
T2 = 2 TURNING FLOW TEE FITTINGS
L4 = 4 LONG TURN 90 DEGREE ELBOWS
17 = COMBINATION OF T2
18 = COMBINATION OF GV CV LE
19 = COMBINATION OF TF GV AV
20 = COMBINATION OF L4

MAIN AND LOOP PIPES

PIPE CONFIG	H&W COEF	PIPE DIAM	FIT COMB	PIPE LGT	FIT E LGT	TOTAL LGT	ELEV CHANGE	ELEV PRES	FRIC PRES	PRES LOSS	PIPE ID	TOTAL PRES	PIPE FLOW	PIPE VEL	VEL PRES	NORMAL PRES	IN/OUT FLOW
WS1																	<1445.2>
0																	
1	120.	8.00		.0		.0			.00	.00	8.2490	119.96	1445.2	8.68			
2	120.	8.00	18	10.0	28.0	38.0			.59	.59	8.2490	119.37	1445.2	8.68			250.0
3	120.	6.00	19	6.0	78.0	84.0	6.0	2.60	3.27	5.87	6.3570	113.50	1195.2	12.08			
4	120.	6.00	20	305.0	36.0	341.0	17.0	7.36	13.27	20.63	6.3570	92.88	1195.2	12.08			
----- LOOP 1 -----																	
5																	
6	120.	2.00	5	2.0	10.0	12.0	2.0	.87	.71	1.58	2.1570	91.30	87.2	7.66			
7	120.	2.00	17	209.0	20.0	229.0			13.57	13.57	2.1570	77.73	87.2	7.66			
8	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	.71	-.15	2.1570	77.88	87.2	7.66			
9	120.	4.00		10.0		10.0			.02	.02	4.2600	77.86	87.2	1.96			

10	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.70	.17	2.1570	77.69	-86.2	7.57
11	120.	2.00	17	209.0	20.0	229.0			-13.29	-13.29	2.1570	90.98	-86.2	7.57
12	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.70	-1.56	2.1570	92.54	-86.2	7.57
(13)	120.	6.00		10.0		10.0			-.34	-.34	6.3570	92.88	-1107.9	11.20

LOOP 2

14	120.	4.00		10.0		10.0			.08	.08	4.2600	77.78	173.4	3.90
15	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.69	.18	2.1570	77.60	-85.5	7.51
16	120.	2.00	17	209.0	20.0	229.0			-13.09	-13.09	2.1570	90.70	-85.5	7.51
17	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.69	-1.55	2.1570	92.25	-85.5	7.51
(18)	120.	6.00		10.0		10.0			-.29	-.29	6.3570	92.54	-1021.7	10.33

LOOP 3

19	120.	4.00		10.0		10.0			.16	.16	4.2600	77.62	258.9	5.83
20	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.68	.18	2.1570	77.44	-85.3	7.48
21	120.	2.00	17	209.0	20.0	229.0			-13.01	-13.01	2.1570	90.45	-85.3	7.48
22	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.68	-1.55	2.1570	92.00	-85.3	7.48
(23)	120.	6.00		10.0		10.0			-.25	-.25	6.3570	92.25	-936.2	9.46

LOOP 4

24	120.	4.00		10.0		10.0			.27	.27	4.2600	77.35	344.2	7.75
25	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.69	.18	2.1570	77.17	-85.5	7.50
26	120.	2.00	17	209.0	20.0	229.0			-13.07	-13.07	2.1570	90.24	-85.5	7.50
27	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.69	-1.55	2.1570	91.79	-85.5	7.50
(28)	120.	6.00		10.0		10.0			-.21	-.21	6.3570	92.00	-851.0	8.60

LOOP 5

29	120.	4.00		10.0		10.0			.41	.41	4.2600	76.94	429.7	9.67
30	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.70	.17	2.1570	76.77	-86.2	7.57
31	120.	2.00	17	209.0	20.0	229.0			-13.29	-13.29	2.1570	90.06	-86.2	7.57
32	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.70	-1.56	2.1570	91.62	-86.2	7.57
(33)	120.	6.00		10.0		10.0			-.17	-.17	6.3570	91.79	-765.5	7.74

LOOP 6

34	120.	4.00		10.0		10.0			.58	.58	4.2600	76.36	515.9	11.61
35	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.72	.15	2.1570	76.21	-87.6	7.69
36	120.	2.00	17	209.0	20.0	229.0			-13.69	-13.69	2.1570	89.90	-87.6	7.69
37	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.72	-1.58	2.1570	91.49	-87.6	7.69
(38)	120.	6.00		10.0		10.0			-.14	-.14	6.3570	91.62	-679.3	6.87

LOOP 7

39	120.	4.00		10.0		10.0			.77	.77	4.2600	75.59	603.5	13.58
40	120.	2.00	5	2.0	10.0	12.0	2.0	.87	3.36	4.23	2.1570	71.36	201.9	17.72
41	120.	2.00	5	58.0	10.0	68.0			19.04	19.04	2.1570	52.32	201.9	17.72
42	120.	2.00		10.0		10.0			.80	.80	2.1570	51.52	102.7	9.02
43	120.	2.00		10.0		10.0			.00	.00	2.1570	51.51	2.7	.24
44	120.	2.00		10.0		10.0			-.73	-.73	2.1570	52.25	-97.8	8.58
45	120.	2.00	5	121.0	10.0	131.0			-35.06	-35.06	2.1570	87.30	-197.0	17.29
46	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-3.21	-4.08	2.1570	91.38	-197.0	17.29
(47)	120.	6.00		10.0		10.0			-.11	-.11	6.3570	91.49	-591.6	5.98

LOOP 8

48	120.	4.00		10.0		10.0			.36	.36	4.2600	75.22	401.6	9.04
49	120.	2.00	5	2.0	10.0	12.0	2.0	.87	3.33	4.20	2.1570	71.03	200.9	17.64
50	120.	2.00	5	55.0	10.0	68.0			18.88	18.88	2.1570	52.15	200.9	17.64
51	120.	2.00		10.0		10.0			.79	.79	2.1570	51.36	101.9	8.95
52	120.	2.00		10.0		10.0			.00	.00	2.1570	51.36	2.1	.18
53	120.	2.00		10.0		10.0			-.74	-.74	2.1570	52.09	-98.2	8.63
54	120.	2.00	5	121.0	10.0	131.0			-35.15	-35.15	2.1570	87.24	-197.3	17.32
55	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-3.22	-4.09	2.1570	91.33	-197.3	17.32

46 (56) 120. 6.00 10.0 10.0 -0.05 -0.05 6.3570 91.38 -394.7 3.99

LOOP 9

48
 57 120. 4.00 10.0 10.0 .10 .10 4.2600 75.12 200.7 4.52
 58 120. 2.00 5 2.0 10.0 12.0 2.0 .87 3.32 4.19 2.1570 70.93 200.7 17.62
 S1 59 120. 2.00 5 58.0 10.0 68.0 18.84 18.84 2.1570 52.09 200.7 17.62 2.09 50.01 99.0
 S1 60 120. 2.00 10.0 10.0 .79 .79 2.1570 51.31 101.7 8.93 .54 50.77 99.8
 S1 61 120. 2.00 10.0 10.0 .00 .00 2.1570 51.31 1.9 .17 .00 51.31 100.3
 S1 62 120. 2.00 10.0 10.0 -.74 -.74 2.1570 52.05 -98.3 8.63 2.02 50.03 99.0
 63 120. 2.00 5 121.9 10.0 131.0 -35.18 -35.18 2.1570 87.23 -197.4 17.33
 64 120. 2.00 5 2.0 10.0 12.0 -2.0 -.87 -3.22 -4.09 2.1570 91.32 -197.4 17.33
 55 (65) 120. 6.00 10.0 10.0 -.01 -.01 6.3570 91.33 -197.4 1.99

136.8 PSI PRESSURE AVAILABLE AND 120.0 PSI PRESSURE REQUIRED AT THE WATER SUPPLY WHEN FLOWING 1445.2 GPM

1188.0 GPM MINIMUM DESIGN FLOW REQUIREMENT

250.0 GPM REQUIRED ADDITIONAL FLOW

1526.5 GPM MAXIMUM FLOW

TRACK 111.00 FT. (FORWARD POSITION) 68.00 FT. TRACK

120.24 PSI FLOWING 1445.06 GPM REQUIRED

FRONT TRACK 131.00 FT. (BACK POSITION) 48.00 FT. BACK TRACK

120.20 PSI FLOWING 1445.27 GPM REQUIRED

FRONT TRACK 121.00 FT. (MOST REMOTE POSITION) 58.00 FT. BACK TRACK

120.30 PSI FLOWING 1444.91 GPM REQUIRED

136.87 PSI FLOWING 1444.91 GPM AVAILABLE

MAIN PIPE DIAMETERS = 8.00 8.00 6.00 6.00

GRID FRONT TRACK DIAMETER = 6.00

GRID BACK TRACK DIAMETER = 4.00

CROSS TIE RISER DIAMETER = 2.00

GRID CROSS TIE DIAMETER = 2.00

SPRINKLER K-FACTOR = 14.0000

Proceed to prepare data for FULL GRID (Y/N) ?


PRICE CLUB

Price Club
RooF EFSR System

CONTRACT NAME:

NO:

PRESSURE (PSI) X 2



A.J. CARNEGIE, INC.

1600 Jersey Avenue

Automatic Fire Protection Systems

Box 3024

North Brunswick, N.J. 08902

908-249-3930

FAX 908-246-3631

HYDRAULIC DESIGN INFORMATION SHEET

DATE: August 7, 1992
NAME: Price Club
LOCATION: Brick Township
CONSTRUCTION: Non-combustible
OCCUPANCY: Roof - Sales Area

SYSTEM DESIGN

NFPA #13:
LIGHT HAZ.: _____ ORD. HAZ. GROUP: #1 _____ #2 _____ #3 _____ EX. HAZ.: _____

NFPA #231:
NFPA #231C: _____ FIGURE: _____ CURVE: _____

OTHER: (specify) FM Standard EFSR Heads .99 gpm/sf over 1200

AREA OF SPRINKLER OPERATION: 1200
DENSITY: .99
AREA PER SPRINKLER: 100
HOSE ALLOWANCE GPM: (inside) >
HOSE ALLOWANCE GPM: (outside) > 250
RACK SPRINKLER ALLOWANCE: -0-

SYSTEM TYPE

WET: ☒ DRY: _____ DELUGE: _____ PRE - ACTION: _____

SPRINKLER OR NOZZLE

MAKE: ASCO MODEL: K1 SIZE: 17/32 TEMP: 165 K: 14

CALCULATION SUMMARY

GPM REQUIRED: 1445.2 PSI REQUIRED: 120
"C" FACTOR USED: OVERHEAD: 120 UNDERGROUND: 140

WATER SUPPLY

WATER FLOW TEST

DATE:
STATIC PSI: 55
RESIDUAL PSI: 48
GPM FLOWING: 1734
ELEVATION: same

PUMP DATA

RATED CAPACITY: 1000
AT PSI: 125lbs
ELEVATION: same

LOCATION: Route 70 & 88
SOURCE: Water Department

August 4, 1992

HYDRAULIC SYSTEM DESIGN REPORT

PRICE CLUB
RT. # 88
BRICKTOWN, N.J.

A.J. CARNEGIE, INC.
P.O. BOX 3024
NORTH BRUNSWICK, N.J.

Design Engineer
A.J.C., INC.

ROOF SPRINKLER SYSTEM CALCULATED TO FLOW
(12) ESFR SPRINKLERS, (4) EACH ON (3) MOST
REMOTE LINES AT MIN. 50 PSI EACH. K=14.0
250 GPM HOSE ALLOWANCE AT PUMP.

PROJECT NAME: PRICE CLUB ROOF ESFR SYSTEM #1(MOST REMOTE)

PROJECT NUMBER: AJC

-----UNITS TABLE-----

LENGTHS AND ELEVATIONS IN FEET PIPE DIAMETERS IN INCHES
PRESSURES IN POUNDS PER SQUARE INCH VOLUMES IN U.S. GALLONS
FLOWS IN U.S. GALLONS PER MINUTE VELOCITIES IN FEET PER SECOND

DENSITY REQUIREMENT: .990 GPM/SQ.FT. OVER MOST REMOTE 1200. SQ.FT.

THE SYSTEM HAS 9 LOOPS

-----WATER SUPPLY WSI ASSIGNED AT NODE 0-----

STATIC PRESSURE = 205.0 PSI 177.0 PSI FLOWING 1000.0 GPM
130.00 PSI FLOWING 1500.0 GPM

-----SPRINKLER ASSIGNMENT TO MAIN OR LOOP NODES-----

S1 = 14.00 K-FACTOR SPRINKLER ASSIGNED TO COVER 100.0 SQ.FT.

----- AT NODES: 41 42 43 44 50 51 52 53 59 60 61 62

-----FITTING TABLE-----

5 = TF = 1 TURNING FLOW TEE FITTING
12 = 2 TURNING FLOW TEE FITTINGS
14 = 4 LONG TURN 90 DEGREE ELBOWS
17 = COMBINATION OF T2
18 = COMBINATION OF GV CV LE
19 = COMBINATION OF TF GV AV
20 = COMBINATION OF L4

MAIN AND LOOP PIPES

PIPE CONFIG	H&W COEF	PIPE DIAM	FIT COMB	PIPE LGT	FIT E LGT	TOTAL LGT	ELEV CHANGE	ELEV PRES	FRIC PRES	PRES LOSS	PIPE ID.	TOTAL PRES	PIPE FLOW	VEL	VEL PRES	NORMAL PRES	IN/OUT FLOW
WSI																	(1445.2)
0 >																	
1	120.	8.00		.0		.0			.00	.00	8.2490	119.96	1445.2	8.68			
2	120.	8.00	18	10.0	28.0	38.0			.59	.59	8.2490	119.37	1445.2	8.68			250.0
3	120.	6.00	19	6.0	79.0	84.0	6.0	2.60	3.27	5.87	6.3570	113.50	1195.2	12.08			
L1 >	4	120.	6.00	20	305.0	36.0	341.0	17.0	7.36	13.27	20.63	6.3570	92.88	1195.2	12.08		
----- LOOP 1 -----																	
5																	
6	120.	2.00	5	2.0	10.0	12.0	2.0	.87	.71	1.58	2.1570	91.30	87.2	7.66			
7	120.	2.00	17	209.0	20.0	229.0			13.57	13.57	2.1570	77.73	87.2	7.66			
8	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	.71	-.15	2.1570	77.88	87.2	7.66			
L2 <=	7	120.	4.00		10.0	10.0			.02	.02	4.2600	77.86	87.2	1.96			

EFSR System

	10	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.70	.17	2.1570	77.69	-86.2	7.57
	11	120.	2.00	17	209.0	20.0	229.0			-13.29	-13.29	2.1570	90.98	-86.2	7.57
L2	12	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.70	-1.56	2.1570	92.54	-86.2	7.57
4	(13)	120.	6.00		10.0		10.0			-.34	-.34	6.3570	92.88	-1107.9	11.20

LOOP 2

L3	14	120.	4.00		10.0		10.0			.08	.08	4.2600	77.78	173.4	3.90
	15	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.69	.18	2.1570	77.60	-85.5	7.51
	16	120.	2.00	17	209.0	20.0	229.0			-13.09	-13.09	2.1570	90.70	-85.5	7.51
L3	17	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.69	-1.55	2.1570	92.25	-85.5	7.51
12	(18)	120.	6.00		10.0		10.0			-.29	-.29	6.3570	92.54	-1021.7	10.33

LOOP 3

L4	19	120.	4.00		10.0		10.0			.16	.16	4.2600	77.62	258.9	5.83
	20	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.68	.18	2.1570	77.44	-85.3	7.48
	21	120.	2.00	17	209.0	20.0	229.0			-13.01	-13.01	2.1570	90.45	-85.3	7.48
L4	22	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.68	-1.55	2.1570	92.00	-85.3	7.48
17	(23)	120.	6.00		10.0		10.0			-.25	-.25	6.3570	92.25	-936.2	9.46

LOOP 4

L5	24	120.	4.00		10.0		10.0			.27	.27	4.2600	77.35	344.2	7.75
	25	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.69	.18	2.1570	77.17	-85.5	7.50
	26	120.	2.00	17	209.0	20.0	229.0			-13.07	-13.07	2.1570	90.24	-85.5	7.50
L5	27	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.69	-1.55	2.1570	91.79	-85.5	7.50
22	(28)	120.	6.00		10.0		10.0			-.21	-.21	6.3570	92.00	-851.0	8.60

LOOP 5

L6	29	120.	4.00		10.0		10.0			.41	.41	4.2600	76.94	429.7	9.67
	30	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.70	.17	2.1570	76.77	-86.2	7.57
	31	120.	2.00	17	209.0	20.0	229.0			-13.29	-13.29	2.1570	90.06	-86.2	7.57
L6	32	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.70	-1.56	2.1570	91.62	-86.2	7.57
27	(33)	120.	6.00		10.0		10.0			-.17	-.17	6.3570	91.79	-765.5	7.74

LOOP 6

L7	34	120.	4.00		10.0		10.0			.58	.58	4.2600	76.36	515.9	11.61
	35	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.72	.15	2.1570	76.21	-87.6	7.69
	36	120.	2.00	17	209.0	20.0	229.0			-13.69	-13.69	2.1570	89.90	-87.6	7.69
L7	37	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.72	-1.58	2.1570	91.49	-87.6	7.69
32	(38)	120.	6.00		10.0		10.0			-.14	-.14	6.3570	91.62	-679.3	6.87

LOOP 7

L8	39	120.	4.00		10.0		10.0			.77	.77	4.2600	75.59	603.5	13.58
	40	120.	2.00	5	2.0	10.0	12.0	2.0	.87	3.36	4.23	2.1570	71.36	201.9	17.72
S1	41	120.	2.00	5	58.0	10.0	68.0			19.04	19.04	2.1570	52.32	201.9	17.72
S1	42	120.	2.00		10.0		10.0			.80	.80	2.1570	51.52	102.7	9.02
S1	43	120.	2.00		10.0		10.0			.00	.00	2.1570	51.51	2.7	.24
S1	44	120.	2.00		10.0		10.0			-.73	-.73	2.1570	52.25	-97.8	8.58
	45	120.	2.00	5	121.0	10.0	131.0			-35.06	-35.06	2.1570	87.30	-197.0	17.29
L8	46	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-3.21	-4.08	2.1570	91.38	-197.0	17.29
37	(47)	120.	6.00		10.0		10.0			-.11	-.11	6.3570	91.49	-591.6	5.98

LOOP 8

L9	48	120.	4.00		10.0		10.0			.36	.36	4.2600	75.22	401.6	9.04
	49	120.	2.00	5	2.0	10.0	12.0	2.0	.87	3.33	4.20	2.1570	71.03	200.9	17.64
S1	50	120.	2.00	5	55.0	10.0	68.0			18.88	18.88	2.1570	52.15	200.9	17.64
S1	51	120.	2.00		10.0		10.0			.79	.79	2.1570	51.36	101.9	8.95
S1	52	120.	2.00		10.0		10.0			.00	.00	2.1570	51.36	2.1	.18
S1	53	120.	2.00		10.0		10.0			-.74	-.74	2.1570	52.09	-98.2	8.63
	54	120.	2.00	5	121.0	10.0	131.0			-35.15	-35.15	2.1570	87.24	-197.3	17.32
L9	55	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-3.22	-4.09	2.1570	91.33	-197.3	17.32

46 (56) 120. 6.00 10.0 10.0 -.05 -.05 6.3570 91.38 -394.7 3.99

LOOP 9

48
 57 120. 4.00 10.0 10.0 .10 .10 4.2600 75.12 200.7 4.52
 59 120. 2.00 5 2.0 10.0 12.0 2.0 .87 3.32 4.19 2.1570 70.93 200.7 17.62
 SI 59 120. 2.00 5 58.0 10.0 68.0 18.84 18.84 2.1570 52.09 200.7 17.62 2.09 50.01 99.0
 SI 60 120. 2.00 10.0 10.0 .79 .79 2.1570 51.31 101.7 8.93 .54 50.77 99.8
 SI 61 120. 2.00 10.0 10.0 .00 .00 2.1570 51.31 1.9 .17 .00 51.31 100.3
 SI 62 120. 2.00 10.0 10.0 -.74 -.74 2.1570 52.05 -98.3 8.63 2.02 50.03 99.0
 63 120. 2.00 5 121.0 10.0 131.0 -35.18 -35.18 2.1570 87.23 -197.4 17.33
 64 120. 2.00 5 2.0 10.0 12.0 -2.0 -.87 -3.22 -4.09 2.1570 91.32 -197.4 17.33
 55 (65) 120. 6.00 10.0 10.0 .01 .01 6.3570 91.33 -197.4 1.99

136.8 PSI PRESSURE AVAILABLE AND 120.0 PSI PRESSURE REQUIRED AT THE WATER SUPPLY WHEN FLOWING 1445.2 GPM
 1188.0 GPM MINIMUM DESIGN FLOW REQUIREMENT
 250.0 GPM REQUIRED ADDITIONAL FLOW 1526.5 GPM MAXIMUM FLOW

TRACK 111.00 FT. (FORWARD POSITION) 68.00 FT. TRACK
 120.24 PSI FLOWING 1445.06 GPM REQUIRED

FRONT TRACK 131.00 FT. (BACK POSITION) 48.00 FT. BACK TRACK
 120.20 PSI FLOWING 1445.27 GPM REQUIRED

FRONT TRACK 121.00 FT. (MOST REMOTE POSITION) 58.00 FT. BACK TRACK
 120.30 PSI FLOWING 1444.91 GPM REQUIRED

136.87 PSI FLOWING 1444.91 GPM AVAILABLE

MAIN PIPE DIAMETERS = 8.00 8.00 6.00 6.00
 GRID FRONT TRACK DIAMETER = 6.00
 GRID BACK TRACK DIAMETER = 4.00
 CROSS TIE RISER DIAMETER = 2.00
 GRID CROSS TIE DIAMETER = 2.00
 SPRINKLER K-FACTOR = 14.0000

Proceed to prepare data for FULL GRID (Y/N) ?


PRICE CLUB

Price Club
Roo & EFR System

CONTRACT NAME:

NO:

PRESSURE (PSI) $\times 2$



A.J. CARNEGIE, INC.
1600 Jersey Avenue

Automatic Fire Protection Systems

Box 3024
North Brunswick, N.J. 08902

908-249-3930
FAX 908-246-3631

HYDRAULIC DESIGN INFORMATION SHEET

DATE: August 7, 1992
NAME: Price Club
LOCATION: Brick Township
CONSTRUCTION: Non-combustible
OCCUPANCY: Roof - Sales Area

SYSTEM DESIGN

NFPA #13:
LIGHT HAZ.: _____ ORD. HAZ. GROUP: #1 _____ #2 _____ #3 _____ EX. HAZ.: _____

NFPA #231:
NFPA #231C: _____ FIGURE: _____ CURVE: _____

OTHER: (specify) FM Standard EFSR Heads .99 gpm/sf over 1200

AREA OF SPRINKLER OPERATION: 1200
DENSITY: .99
AREA PER SPRINKLER: 100
HOSE ALLOWANCE GPM: (inside) >
HOSE ALLOWANCE GPM: (outside) > 250
RACK SPRINKLER ALLOWANCE: -0-

SYSTEM TYPE

WET: ☒ DRY: _____ DELUGE: _____ PRE - ACTION: _____

SPRINKLER OR NOZZLE

MAKE: ASCO MODEL: K1 SIZE: 17/32 TEMP: 165 K: 14

CALCULATION SUMMARY

GPM REQUIRED: 1445.2 PSI REQUIRED: 120
"C" FACTOR USED: OVERHEAD: 120 UNDERGROUND: 140

WATER SUPPLY

WATER FLOW TEST

DATE:
STATIC PSI: 55
RESIDUAL PSI: 48
GPM FLOWING: 1734
ELEVATION: same

PUMP DATA

RATED CAPACITY: 1000
AT PSI: 125lbs
ELEVATION: same

LOCATION: Route 70 & 88
SOURCE: Water Department

PRICE CLUB
RT. # 88
BRICKTOWN, N.J.

HYDRAULIC SYSTEM DESIGN REPORT

A.J. CARNEGIE, INC.
P.O. BOX 3024
NORTH BRUNSWICK, N.J.

Design Engineer
A.J.C., INC.

ROOF SPRINKLER SYSTEM CALCULATED TO FLOW
(12) ESFR SPRINKLERS, (4) EACH ON (3) MOST
REMOTE LINES AT MIN. 50 PSI EACH. K=14.0
250 GPM HOSE ALLOWANCE AT PUMP.

PROJECT NAME: PRICE CLUB ROOF ESFR SYSTEM #1(MOST REMOTE)

PROJECT NUMBER: AJC

ESFR System

-----UNITS TABLE-----
LENGTHS AND ELEVATIONS IN FEET PIPE DIAMETERS IN INCHES
PRESSURES IN POUNDS PER SQUARE INCH VOLUMES IN U.S. GALLONS
FLOWS IN U.S. GALLONS PER MINUTE VELOCITIES IN FEET PER SECOND

DENSITY REQUIREMENT: .990 GPM/SQ.FT. OVER MOST REMOTE 1200. SQ.FT.

THE SYSTEM HAS 9 LOOPS

-----WATER SUPPLY WSI ASSIGNED AT NODE 0-----
STATIC PRESSURE = 205.0 PSI 177.0 PSI FLOWING 1000.0 GPM
130.00 PSI FLOWING 1500.0 GPM

-----SPRINKLER ASSIGNMENT TO MAIN OR LOOP NODES-----
S1 = 14.00 K-FACTOR SPRINKLER ASSIGNED TO COVER 100.0 SQ.FT.
----- AT NODES: 41 42 43 44 50 51 52 53 59 60 61 62

-----FITTING TABLE-----
S = TF = 1 TURNING FLOW TEE FITTING
T2 = 2 TURNING FLOW TEE FITTINGS
L4 = 4 LONG TURN 90 DEGREE ELBOWS
17 = COMBINATION OF T2
18 = COMBINATION OF GV CV LE
19 = COMBINATION OF TF GV AV
20 = COMBINATION OF L4

MAIN AND LOOP PIPES

PIPE CONFIG	H&W COEF	PIPE DIAM	FIT COMB	PIPE LGT	FIT E LGT	TOTAL LGT	ELEV CHANGE	ELEV PRES	FRIC PRES	PRES LOSS	PIPE ID	TOTAL PRES	PIPE FLOW	PIPE VEL	VEL PRES	NORMAL PRES	IN/OUT FLOW
WSI																	(1445.2)
0																	
1	120.	8.00		.0		.0			.00	.00	8.2490	119.96	1445.2	3.68			
2	120.	8.00	18	10.0	28.0	38.0			.59	.59	8.2490	119.37	1445.2	8.68			250.0
3	120.	6.00	19	6.0	78.0	84.0	6.0	2.60	3.27	5.87	6.3570	113.50	1195.2	12.08			
4	120.	6.00	20	305.0	36.0	341.0	17.0	7.36	13.27	20.63	6.3570	92.88	1195.2	12.08			
----- LOOP 1 -----																	
5																	
6	120.	2.00	5	2.0	10.0	12.0	2.0	.87	.71	1.58	2.1570	91.30	87.2	7.66			
7	120.	2.00	17	209.0	20.0	229.0			13.57	13.57	2.1570	77.73	87.2	7.66			
8	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	.71	-.15	2.1570	77.88	87.2	7.66			
9	120.	4.00		10.0		10.0			.02	.02	4.2600	77.86	87.2	1.96			

10	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.70	.17	2.1570	77.69	-86.2	7.57
11	120.	2.00	17	209.0	20.0	229.0			-13.29	-13.29	2.1570	90.98	-86.2	7.57
12	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.70	-1.56	2.1570	92.54	-86.2	7.57
(13)	120.	6.00		10.0		10.0			-.34	-.34	6.3570	92.88	-1107.9	11.20

LOOP 2

14	120.	4.00		10.0		10.0			.08	.08	4.2600	77.78	173.4	3.90
15	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.69	.18	2.1570	77.60	-85.5	7.51
16	120.	2.00	17	209.0	20.0	229.0			-13.09	-13.09	2.1570	90.70	-85.5	7.51
17	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.69	-1.55	2.1570	92.25	-85.5	7.51
(18)	120.	6.00		10.0		10.0			-.29	-.29	6.3570	92.54	-1021.7	10.33

LOOP 3

19	120.	4.00		10.0		10.0			.16	.16	4.2600	77.62	258.9	5.83
20	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.68	.18	2.1570	77.44	-85.3	7.48
21	120.	2.00	17	209.0	20.0	229.0			-13.01	-13.01	2.1570	90.45	-85.3	7.48
22	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.68	-1.55	2.1570	92.00	-85.3	7.48
(23)	120.	6.00		10.0		10.0			-.25	-.25	6.3570	92.25	-936.2	9.46

LOOP 4

24	120.	4.00		10.0		10.0			.27	.27	4.2600	77.35	344.2	7.75
25	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.69	.18	2.1570	77.17	-85.5	7.50
26	120.	2.00	17	209.0	20.0	229.0			-13.07	-13.07	2.1570	90.24	-85.5	7.50
27	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.69	-1.55	2.1570	91.79	-85.5	7.50
(28)	120.	6.00		10.0		10.0			-.21	-.21	6.3570	92.00	-851.0	8.60

LOOP 5

29	120.	4.00		10.0		10.0			.41	.41	4.2600	76.94	429.7	9.67
30	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.70	.17	2.1570	76.77	-86.2	7.57
31	120.	2.00	17	209.0	20.0	229.0			-13.29	-13.29	2.1570	90.06	-86.2	7.57
32	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.70	-1.56	2.1570	91.62	-86.2	7.57
(33)	120.	6.00		10.0		10.0			-.17	-.17	6.3570	91.79	-765.5	7.74

LOOP 6

34	120.	4.00		10.0		10.0			.58	.58	4.2600	76.36	515.9	11.61
35	120.	2.00	5	2.0	10.0	12.0	2.0	.87	-.72	.15	2.1570	76.21	-87.6	7.69
36	120.	2.00	17	209.0	20.0	229.0			-13.69	-13.69	2.1570	89.90	-87.6	7.69
37	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-.72	-1.58	2.1570	91.49	-87.6	7.69
(38)	120.	6.00		10.0		10.0			-.14	-.14	6.3570	91.62	-679.3	6.87

LOOP 7

39	120.	4.00		10.0		10.0			.77	.77	4.2600	75.59	603.5	13.58
40	120.	2.00	5	2.0	10.0	12.0	2.0	.87	3.36	4.23	2.1570	71.36	201.9	17.72
41	120.	2.00	5	58.0	10.0	68.0			19.04	19.04	2.1570	52.32	201.9	17.72
42	120.	2.00		10.0		10.0			.80	.80	2.1570	51.52	102.7	9.02
43	120.	2.00		10.0		10.0			.00	.00	2.1570	51.51	2.7	.24
44	120.	2.00		10.0		10.0			-.73	-.73	2.1570	52.25	-97.8	8.58
45	120.	2.00	5	121.0	10.0	131.0			-35.06	-35.06	2.1570	87.30	-197.0	17.29
46	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-3.21	-4.08	2.1570	91.38	-197.0	17.29
(47)	120.	6.00		10.0		10.0			-.11	-.11	6.3570	91.49	-591.6	5.98

LOOP 8

48	120.	4.00		10.0		10.0			.36	.36	4.2600	75.22	401.6	9.04
49	120.	2.00	5	2.0	10.0	12.0	2.0	.87	3.33	4.20	2.1570	71.03	200.9	17.64
50	120.	2.00	5	58.0	10.0	68.0			18.88	18.88	2.1570	52.15	200.9	17.64
51	120.	2.00		10.0		10.0			.79	.79	2.1570	51.36	101.9	8.95
52	120.	2.00		10.0		10.0			.00	.00	2.1570	51.36	2.1	.18
53	120.	2.00		10.0		10.0			-.74	-.74	2.1570	52.09	-98.2	8.63
54	120.	2.00	5	121.0	10.0	131.0			-35.15	-35.15	2.1570	87.24	-197.3	17.32
55	120.	2.00	5	2.0	10.0	12.0	-2.0	-.87	-3.22	-4.09	2.1570	91.33	-197.3	17.32


PRICE CLUB

Price Club
Roof EFR System

CONTRACT NAME:

NO:

PRESSURE (PSI) X 2



BRICK TOWNSHIP

BY

Date

Class

Plan Review

Zoning

Plumbing


Building

Fire

Energy

Electrical

8/14/92



A.J. CARNEGIE, INC.
1600 Jersey Avenue

Automatic Fire Protection Systems

Box 3024

North Brunswick, N.J. 08902

908-249-3930
FAX 908-246-3631

HYDRAULIC DESIGN INFORMATION SHEET

DATE: August 7, 1992
NAME: Price Club
LOCATION: Brick Township
CONSTRUCTION: Non-combustible
OCCUPANCY: Rack System

SYSTEM DESIGN

NFPA #13: _____
LIGHT HAZ.: _____ ORD.HAZ.GROUP: #1 _____ #2 _____ #3 _____ EX.HAZ.: _____

NFPA #231: _____
NFPA #231C: _____ FIGURE: _____ CURVE: _____

OTHER: (specify) FM Standard 6 heads flowing 50psi at end hd

AREA OF SPRINKLER OPERATION: 600
DENSITY: .572
AREA PER SPRINKLER: 100
HOSE ALLOWANCE GPM: (inside) 7500
HOSE ALLOWANCE GPM: (outside)
RACK SPRINKLER ALLOWANCE:

SYSTEM TYPE

WET: x DRY: _____ DELUGE: _____ PRE - ACTION: _____

SPRINKLER OR NOZZLE

MAKE: Central MODEL: A-Rack SIZE: 17/32 TEMP: 165 K: 8.1

CALCULATION SUMMARY

GPM REQUIRED: 362 PSI REQUIRED: 121.6
"C" FACTOR USED: OVERHEAD: 120 UNDERGROUND: 140

WATER SUPPLY

WATER FLOW TEST

DATE: _____
STATIC PSI: 55
RESIDUAL PSI: 48
GPM FLOWING: 1734
ELEVATION: same

PUMP DATA

RATED CAPACITY: 1000
AT PSI: 125lbs
ELEVATION: same

LOCATION: Route 70 & 88
SOURCE: Water Department

Design • Engineering • Turn-Key Installation

Serial Number 1012122 Run Number 03257

CAFE

August 5, 1992

PRICE CLUB
RT. # 88
BRICKTOWN, N.J.

HYDRAULIC SYSTEM DESIGN REPORT

A.J. CARNEGIE, INC.
P.O. BOX 3024
NORTH BRUNSWICK, N.J.Design Engineer
A.J.C., INC.GRID SYSTEM USED AS SUPPLY MAIN TO 500 GPM
OUTFLOW AT REAR OF GRID FOR CALCULATION
OF SYSTEMS OFF REAR GRID CROSS-MAIN. 500
GPM HOSE ALLOWANCE AT PUMP.IN-RACK SPRINKLER SYSTEM CALCULATED TO
PRODUCE 50 PSI AT END HEAD FOR (3) HEADS ON
(2) REMOTE LINES. 17/32" OREF. SPRINKLERS.
K=8.1

PROJECT NAME: PRICE CLUB STORAGE RACK

PROJECT NUMBER: AJC

-----UNITS TABLE-----

LENGTHS AND ELEVATIONS IN FEET PIPE DIAMETERS IN INCHES
PRESSURES IN POUNDS PER SQUARE INCH VOLUMES IN U.S. GALLONS
FLOWS IN U.S. GALLONS PER MINUTE VELOCITIES IN FEET PER SECOND

DENSITY REQUIREMENT: .572 GPM/SQ. FT. OVER MOST REMOTE 600. SQ. FT.

-----WATER SUPPLY WSI ASSIGNED AT NODE 0-----
STATIC PRESSURE = 205.0 PSI 157.0 PSI FLOWING 500.0 GPM

LINE	PIPE	FIT	FIT	TOTAL	PIPE	ELEV	H&W	AREA	K	PIPE	ELEV	FRIC	NORMAL	VEL	TOTAL	HEAD	PIPE	
81	LGT	COMB	E LGT	LGT	DIAM	CHANGE	COEF	COVER	FACTOR	ID	PRES	PRES	PRES	PRES	PRES	FLOW	FLOW	VEL
5	4.00	18	12.00	16.00	1.25		120.	100.0	8.10	1.380		4.61	60.97	.00	60.97	63.25	63.25	13.57
6	.01			.01	2.50		120.	.0	.00	2.635		.00	65.58	.00	65.58		179.44	10.56
7	1.00	18	12.00	13.00	1.25		120.	100.0	8.10	1.380		11.53	49.87	4.18	54.05	57.20	116.19	24.92
8	4.00			4.00	1.25		120.	100.0	8.10	1.380		1.01	53.04	.00	53.04	58.99	58.99	12.65

65.58 PSI PRESSURE REQUIRED FLOWING 179.4 GPM

171.60 GPM = MIN REQUIRED FLOW 4.6% EXCESS FLOW

-----LINE ASSIGNMENT TO MAIN NODES-----

LINE 81 JOINS AT NODES: 3 4

-----FITTING TABLE-----

5 = TF = 1 TURNING FLOW TEE FITTING
E2 = 2 STANDARD 90 DEGREE ELBOWS
T2 = 2 TURNING FLOW TEE FITTINGS
17 = COMBINATION OF T2 GV
18 = COMBINATION OF TF E2

MAIN PIPES

PIPE	H&W	PIPE	FIT	PIPE	FIT	TOTAL	ELEV	ELEV	FRIC	PRES	PIPE	TOTAL	PIPE	VEL	NORMAL	IN/OUT
CONFIG	COEF	DIAM	COMB	LGT	E LGT	LGT	CHANGE	PRES	PRES	LOSS	ID	PRES	FLOW	VEL	PRES	FLOW
WS1																<361.6>
1	120.	4.00		.0		.0	21.0	9.09	.00	9.09	4.2600	114.48	361.6	8.14		
2	120.	2.50	17	50.0	25.0	75.0	-6.0	-2.60	23.30	20.70	2.6350	93.79	361.6	21.28		
81	3	120.	2.50	5	69.0	12.0	81.0		25.16	25.16	2.6350	68.63	361.6	21.28	3.05	65.58 179.4

TH-RACK

81 4 120. 2.50 12.0 12.0 1.05 1.05 2.6350 67.58 182.2 10.72 .00 67.58 182.2

178.6 PSI PRESSURE AVAILABLE AND 123.6 PSI PRESSURE REQUIRED AT THE WATER SUPPLY WHEN FLOWING 361.6 GPM

343.2 GPM MINIMUM DESIGN FLOW REQUIREMENT

.0 GPM REQUIRED ADDITIONAL FLOW

434.8 GPM MAXIMUM FLOW


PRICE BOOK

Price Club
Rack System

CONTRACT NAME:

NO.

PRESSURE (PSI) *2*



FLOW - GPM

A.J. CARNEGIE, INC.
1600 Jersey Avenue

Automatic Fire Protection Systems

Box 3024

North Brunswick, N.J. 08902

908-249-3930
FAX 908-246-3631

HYDRAULIC DESIGN INFORMATION SHEET

DATE: August 7, 1992
NAME: Price Club
LOCATION: Brick Township
CONSTRUCTION: Non-combustible
OCCUPANCY: Rack System

SYSTEM DESIGN

NEPA #13:
LIGHT HAZ.: _____ ORD. HAZ. GROUP: #1 _____ #2 _____ #3 _____ EX. HAZ.: _____

NEPA #231:
NEPA #231C: _____ FIGURE: _____ CURVE: _____

OTHER: (specify) FM Standard 6 heads flowing 50psi at end hd

AREA OF SPRINKLER OPERATION: 600
DENSITY: .572
AREA PER SPRINKLER: 100
HOSE ALLOWANCE GPM: (inside) 7500
HOSE ALLOWANCE GPM: (outside)
RACK SPRINKLER ALLOWANCE:

SYSTEM TYPE

WET: ☒ DRY: _____ DELUGE: _____ PRE - ACTION: _____

SPRINKLER OR NOZZLE

MAKE: Central MODEL: A-Rack SIZE: 17/32 TEMP: 165 K: 8.1

CALCULATION SUMMARY

GPM REQUIRED: 362 PSI REQUIRED: 121.6
"C" FACTOR USED: OVERHEAD: 120 UNDERGROUND: 140

WATER SUPPLY

WATER FLOW TEST

DATE:
STATIC PSI: 55
RESIDUAL PSI: 48
GPM FLOWING: 1734
ELEVATION: same

PUMP DATA

RATED CAPACITY: 1000
AT PSI: 125lbs
ELEVATION: same

LOCATION: Route 70 & 88
SOURCE: Water Department

Serial Number 1012122 Run Number 03257

CAFE

August 5, 1992

PRICE CLUB
RT. # 88
BRICKTOWN, N.J.

HYDRAULIC SYSTEM DESIGN REPORT

A.J. CARNEGIE, INC.
P.O. BOX 3024
NORTH BRUNSWICK, N.J.

Design Engineer
A.J.C., INC.

GRID SYSTEM USED AS SUPPLY MAIN TO 500 GPM
OUTFLOW AT REAR OF GRID FOR CALCULATION
OF SYSTEMS OFF REAR GRID CROSS-MAIN. 500
GPM HOSE ALLOWANCE AT PUMP.

IN-RACK SPRINKLER SYSTEM CALCULATED TO
PRODUCE 50 PSI AT END HEAD FOR (3) HEADS ON
(2) REMOTE LINES. 17/32" OREF. SPRINKLERS.
K=8.1

PROJECT NAME: PRICE CLUB STORAGE RACK

PROJECT NUMBER: AJC

-----UNITS TABLE-----

LENGTHS AND ELEVATIONS IN FEET PIPE DIAMETERS IN INCHES
PRESSURES IN POUNDS PER SQUARE INCH VOLUMES IN U.S. GALLONS
FLOWS IN U.S. GALLONS PER MINUTE VELOCITIES IN FEET PER SECOND

DENSITY REQUIREMENT: .572 GPM/SQ. FT. OVER MOST REMOTE 600. SQ. FT.

-----WATER SUPPLY WS1 ASSIGNED AT NODE 0-----
STATIC PRESSURE = 205.0 PSI 157.0 PSI FLOWING 500.0 GPM

LINE	PIPE	FIT	FIT	TOTAL	PIPE	ELEV	H&W	AREA	K	PIPE	ELEV	FRIC	NORMAL	VEL	TOTAL	HEAD	PIPE	
81	LGT	COMB	E LGT	LGT	DIAM	CHANGE	COEF	COVER	FACTOR	ID	PRES	PRES	PRES	PRES	PRES	FLOW	FLOW	VEL
5	4.00	18	12.00	16.00	1.25		120.	100.0	8.10	1.380		4.61	60.97	.00	60.97	63.25	63.25	13.57
6	.01			.01	2.50		120.	.0	.00	2.635		.00	65.58	.00	65.58		179.44	10.56
7	1.00	18	12.00	13.00	1.25		120.	100.0	8.10	1.380		11.53	49.87	4.18	54.05	57.20	116.19	24.92
8	4.00			4.00	1.25		120.	100.0	8.10	1.380		1.01	53.04	.00	53.04	58.99	58.99	12.65

65.58 PSI PRESSURE REQUIRED FLOWING 179.4 GPM

171.60 GPM = MIN REQUIRED FLOW 4.6% EXCESS FLOW

-----LINE ASSIGNMENT TO MAIN NODES-----

LINE 81 JOINS AT NODES: 3 4

-----FITTING TABLE-----

S = TF = 1 TURNING FLOW TEE FITTING
E2 = 2 STANDARD 90 DEGREE ELBOWS
T2 = 2 TURNING FLOW TEE FITTINGS
17 = COMBINATION OF T2 GV
18 = COMBINATION OF TF E2

MAIN PIPES

PIPE	H&W	PIPE	FIT	PIPE	FIT	TOTAL	ELEV	ELEV	FRIC	PRES	PIPE	TOTAL	PIPE	VEL	NORMAL	IN/OUT
CONFIG	COEF	DIAM	COMB	LGT	E LGT	LGT	CHANGE	PRES	PRES	LOSS	ID	PRES	FLOW	VEL	PRES	FLOW
WS1																<361.6>
1	120.	4.00		.0		.0	21.0	9.09	.00	9.09	4.2600	114.48	361.6	8.14		
2	120.	2.50	17	50.0	25.0	75.0	-6.0	-2.60	23.30	20.70	2.6350	93.79	361.6	21.28		
81	3	120.	2.50	5	69.0	12.0	81.0		25.16	25.16	2.6350	68.63	361.6	21.28	3.05	65.58 179.4

01 4 120. 2.50 12.0 12.0 1.05 1.05 276350 67.58 182.2 10.72 .00 67.58 182.2

178.6 PSI PRESSURE AVAILABLE AND 123.6 PSI PRESSURE REQUIRED AT THE WATER SUPPLY WHEN FLOWING 361.6 GPM

343.2 GPM MINIMUM DESIGN FLOW REQUIREMENT

.0 GPM REQUIRED ADDITIONAL FLOW

434.8 GPM MAXIMUM FLOW


PRICE BOOK

Price Club
Rack System

CONTRACT NAME:

NO:

PRESSURE (PSI) *2*



FLOW - GPM

Scale Used D
Scale A
Scale B
Scale C

A.J. CARNEGIE, INC.
1600 Jersey Avenue

Automatic Fire Protection Systems

Box 3024
North Brunswick, N.J. 08902

908-249-3930
FAX 908-246-3631

HYDRAULIC DESIGN INFORMATION SHEET

DATE: August 7, 1992
NAME: Price Club
LOCATION: Brick Township
CONSTRUCTION: Non-combustible
OCCUPANCY: Rack System

SYSTEM DESIGN

NFPA #13:
LIGHT HAZ.: _____ ORD. HAZ. GROUP: #1 _____ #2 _____ #3 _____ EX. HAZ.: _____

NFPA #231:
NFPA #231C: _____ FIGURE: _____ CURVE: _____

OTHER: (specify) FM Standard 6 heads flowing 50psi at end hd

AREA OF SPRINKLER OPERATION: 600
DENSITY: .572
AREA PER SPRINKLER: 100
HOSE ALLOWANCE GPM: (inside) 7500
HOSE ALLOWANCE GPM: (outside)
RACK SPRINKLER ALLOWANCE:

SYSTEM TYPE

WET: x DRY: _____ DELUGE: _____ PRE - ACTION: _____

SPRINKLER OR NOZZLE

MAKE: Central MODEL: A-Rack SIZE: 17/32 TEMP: 165 K: 8.1

CALCULATION SUMMARY

GPM REQUIRED: 362 PSI REQUIRED: 121.6
"C" FACTOR USED: OVERHEAD: 120 UNDERGROUND: 140

WATER SUPPLY

WATER FLOW TEST

DATE:
STATIC PSI: 55
RESIDUAL PSI: 48
GPM FLOWING: 1734
ELEVATION: same

PUMP DATA

RATED CAPACITY: 1000
AT PSI: 125lbs
ELEVATION: same

LOCATION: Route 70 & 88
SOURCE: Water Department

Serial Number 1012122 Run Number 03257

CAFE

August 5, 1992

PRICE CLUB

RT. # 88

BRICKTOWN, N.J.

HYDRAULIC SYSTEM DESIGN REPORT

A.J. CARNEGIE, INC.
P.O. BOX 3024
NORTH BRUNSWICK, N.J.Design Engineer
A.J.C., INC.GRID SYSTEM USED AS SUPPLY MAIN TO 500 GPM
OUTFLOW AT REAR OF GRID FOR CALCULATION
OF SYSTEMS OFF REAR GRID CROSS-MAIN. 500
GPM HOSE ALLOWANCE AT PUMP.
IN-RACK SPRINKLER SYSTEM CALCULATED TO
PRODUCE 50 PSI AT END HEAD FOR (3) HEADS ON
(2) REMOTE LINES. 17/32" OREF. SPRINKLERS.
K=8.1

PROJECT NAME: PRICE CLUB STORAGE RACK

PROJECT NUMBER: AJC

UNITS TABLE

LENGTHS AND ELEVATIONS IN FEET
PRESSURES IN POUNDS PER SQUARE INCH
FLOWS IN U.S. GALLONS PER MINUTE

PIPE DIAMETERS IN INCHES
VOLUMES IN U.S. GALLONS
VELOCITIES IN FEET PER SECOND

DENSITY REQUIREMENT: .572 GPM/SQ. FT. OVER MOST REMOTE 600. SQ. FT.

WATER SUPPLY WS1 ASSIGNED AT NODE 0
STATIC PRESSURE = 205.0 PSI 157.0 PSI FLOWING 500.0 GPM

LINE	PIPE	FIT	FIT	TOTAL	PIPE	ELEV	H&W	AREA	K	PIPE	ELEV	FRIC	NORMAL	VEL	TOTAL	HEAD	PIPE	
81	LGT	COMB	E LGT	LGT	DIAM	CHANGE	COEF	COVER	FACTOR	ID	PRES	PRES	PRES	PRES	PRES	FLOW	FLOW	VEL
5	4.00	18	12.00	16.00	1.25		120.	100.0	8.10	1.380		4.61	60.97	.00	60.97	63.25	63.25	13.57
6	.01			.01	2.50		120.	.0	.00	2.635		.00	65.58	.00	65.58		179.44	10.56
7	1.00	18	12.00	13.00	1.25		120.	100.0	8.10	1.380		11.53	49.87	4.18	54.05	57.20	116.19	24.92
8	4.00			4.00	1.25		120.	100.0	8.10	1.380		1.01	53.04	.00	53.04	58.99	58.99	12.65

65.58 PSI PRESSURE REQUIRED FLOWING 179.4 GPM

171.60 GPM = MIN REQUIRED FLOW 4.6% EXCESS FLOW

LINE ASSIGNMENT TO MAIN NODES

LINE 81 JOINS AT NODES: 3 4

FITTING TABLE

5 = TF = 1 TURNING FLOW TEE FITTING
E2 = 2 STANDARD 90 DEGREE ELBOWS
T2 = 2 TURNING FLOW TEE FITTINGS
17 = COMBINATION OF T2 GV
18 = COMBINATION OF TF E2

MAIN PIPES

PIPE	H&W	PIPE	FIT	PIPE	FIT	TOTAL	ELEV	ELEV	FRIC	PRES	PIPE	TOTAL	PIPE	VEL	NORMAL	IN/OUT
CONFIG	COEF	DIAM	COMB	LGT	E LGT	LGT	CHANGE	PRES	PRES	LOSS	ID	PRES	FLOW	VEL	PRES	FLOW
WS1																<361.6>
0																
1	120.	4.00		.0		.0	21.0	9.09	.00	9.09	4.2600	114.48	361.6	8.14		
2	120.	2.50	17	50.0	25.0	75.0	-6.0	-2.60	23.30	20.70	2.6350	93.79	361.6	21.28		
81	120.	2.50	5	69.0	12.0	81.0			25.16	25.16	2.6350	68.63	361.6	21.28	3.05	65.58 179.4

TH-RACK

81 4 120. 2.50 12.0 12.0 1.05 1.05 2.6350 67.58 182.2 10.72 .00 67.58 182.2

178.6 PSI PRESSURE AVAILABLE AND 123.6 PSI PRESSURE REQUIRED AT THE WATER SUPPLY WHEN FLOWING 361.6 GPM

343.2 GPM MINIMUM DESIGN FLOW REQUIREMENT

.0 GPM REQUIRED ADDITIONAL FLOW

434.8 GPM MAXIMUM FLOW


PRICE BOOK

Price Club
Rack System

CONTRACT NAME:

NO:

PRESSURE (PSI) *X 2*



FLOW - GPM

BRICK TOWNSHIP

Plan Review Class Date By

Zoning _____

Plumbing _____

Building _____

Fire 8/14/92 ja

Energy _____

Electrical _____

A.J. CARNEGIE, INC.
1600 Jersey Avenue

Automatic Fire Protection Systems

Box 3024
North Brunswick, N.J. 08902

908-249-3930
FAX 908-246-3631

HYDRAULIC DESIGN INFORMATION SHEET

DATE: August 7, 1992
NAME: Price Club
LOCATION: Brick Township
CONSTRUCTION: Non-combustible
OCCUPANCY: Canopy System

SYSTEM DESIGN

NFPA #13:
LIGHT HAZ.: _____ ORD. HAZ. GROUP: #1 _____ #2 _____ #3 _____ EX. HAZ.: _____

NFPA #231:
NFPA #231C: _____ FIGURE: _____ CURVE: _____

OTHER: (specify) FM Standard .19gpm/sf over 1950 sf

AREA OF SPRINKLER OPERATION: 1950
DENSITY: .19
AREA PER SPRINKLER: 127.5
HOSE ALLOWANCE GPM: (inside) > 250
HOSE ALLOWANCE GPM: (outside)
RACK SPRINKLER ALLOWANCE: -0-

SYSTEM TYPE

WET: _____ DRY: x _____ DELUGE: _____ PRE - ACTION: _____

SPRINKLER OR NOZZLE

MAKE: Central MODEL: A SIZE: 1/2 TEMP: 165 K: 5.7

CALCULATION SUMMARY

GPM REQUIRED: 584.4 PSI REQUIRED: 87
"C" FACTOR USED: OVERHEAD: 120 UNDERGROUND: 140

WATER SUPPLY

WATER FLOW TEST

DATE:
STATIC PSI: 55
RESIDUAL PSI: 48
GPM FLOWING: 1734
ELEVATION: same

PUMP DATA

RATED CAPACITY: 1000
AT PSI: 125lbs
ELEVATION: same

LOCATION: Route 70 & 88
SOURCE: Water Department

PRICE CLUB

RT. # 98

BRICKTOWN, N.J.

HYDRAULIC SYSTEM DESIGN REPORT

A.J. CARNEGIE, INC.

P.O. BOX 3024

NORTH BRUNSWICK, N.J.

Design Engineer

A.J.C., INC.

GRID SYSTEM USED AS SUPPLY MAIN TO 500 GPM
 OUTFLOW AT REAR OF GRID FOR CALCULATION
 OF SYSTEMS OFF REAR GRID CROSS-MAIN. 500
 GPM HOSE ALLOWANCE AT PUMP.
 CANOPY DRY-PIPE SYSTEM CALCULATED TO
 PRODUCE .19/1950 USING 17/32", K=8.1 SPRK.
 C-120 FOR GALV. PIPE

PROJECT NAME: PRICE CLUB CANOPY SYST.

PROJECT NUMBER: AJC

-----UNITS TABLE-----

LENGTHS AND ELEVATIONS IN FEET PIPE DIAMETERS IN INCHES
 PRESSURES IN POUNDS PER SQUARE INCH VOLUMES IN U.S. GALLONS
 FLOWS IN U.S. GALLONS PER MINUTE VELOCITIES IN FEET PER SECOND

DENSITY REQUIREMENT: .190 GPM/SQ.FT. OVER MOST REMOTE 1950. SQ.FT.

-----WATER SUPPLY WS1 ASSIGNED AT NODE 0-----

STATIC PRESSURE = 205.0 PSI 157.0 PSI FLOWING 500.0 GPM

LINE	PIPE	FIT	FIT	TOTAL	PIPE	ELEV	H&W	AREA	K	PIPE	ELEV	FRIC	NORMAL	VEL	TOTAL	HEAD	PIPE	
81	LGT	COMB	E LGT	LGT	DIAM	CHANGE	COEF	COVER	FACTOR	ID	PRES	PRES	PRES	PRES	PRES	FLOW	FLOW	VEL
5	9.00			9.00	1.50		120.	127.5	8.10	1.610		.49	22.78	.00	22.78	38.66	38.66	6.09
6	9.00			9.00	1.50		120.	127.5	8.10	1.610		1.76	22.28	.99	23.27	38.23	76.89	12.12
7	9.00			9.00	2.00		120.	127.5	8.10	2.067		1.13	24.19	.84	25.02	39.84	116.73	11.16
8	9.00			9.00	2.00		120.	127.5	8.10	2.067		1.95	24.64	1.52	26.15	40.20	156.93	15.00
9	9.00			9.00	2.00		120.	127.5	8.10	2.067		2.99	25.69	2.41	28.10	41.05	197.98	18.93
10	2.00	5	10.00	12.00	2.00		120.	127.5	8.10	2.067		5.72	27.53	3.56	31.09	42.50	240.48	22.99
11	.01	5	15.00	15.01	3.00		120.	.0	.00	3.260		4.02	36.80	.00	36.80		584.37	22.46
12	7.00	5	12.00	19.00	2.50		120.	127.5	8.10	2.635		5.38	28.67	2.75	31.43	43.37	343.88	20.23
13	9.00			9.00	2.50		120.	127.5	8.10	2.635		1.98	27.34	2.10	29.44	42.35	300.51	17.68
14	9.00	19	30.00	39.00	2.50		120.	127.5	8.10	2.635		6.49	21.39	1.55	22.95	37.47	258.16	15.19
15	9.00			9.00	2.00		120.	127.5	8.10	2.067		3.66	16.29	3.00	19.29	32.70	220.69	21.10
16	9.00			9.00	2.00		120.	127.5	8.10	2.067		2.72	14.40	2.17	16.57	30.73	188.00	17.97
17	9.00			9.00	2.00		120.	127.5	8.10	2.067		1.95	13.10	1.52	14.62	29.31	157.26	15.04
18	9.00			9.00	2.00		120.	127.5	8.10	2.067		1.33	12.28	1.01	13.28	28.38	127.95	12.23
19	9.00	19	20.00	29.00	2.00		120.	127.5	8.10	2.067		2.70	9.97	.61	10.58	25.58	99.57	9.52
20	9.00			9.00	2.00		120.	127.5	8.10	2.067		.48	9.76	.34	10.10	25.30	74.00	7.07
21	9.00			9.00	1.50		120.	127.5	8.10	1.610		.75	8.94	.40	9.34	24.23	48.69	7.67
22	9.00			9.00	1.50		120.	127.5	8.10	1.610		.21	9.13	.00	9.13	24.47	24.47	3.86

40.82 PSI PRESSURE REQUIRED FLOWING 584.4 GPM

411.82 GPM = MIN REQUIRED FLOW 41.9% EXCESS FLOW

-----LINE ASSIGNMENT TO MAIN NODES-----

LINE 81 JOINS AT NODE: 4

-----FITTING TABLE-----

- 3 = LE = 1 LONG TURN 90 DEGREE ELBOW
- 5 = TF = 1 TURNING FLOW TEE FITTING
- T2 = 2 TURNING FLOW TEE FITTINGS
- L4 = 4 LONG TURN 90 DEGREE ELBOWS

B1 = 10 45 DEGREE ELBOWS
 17 = COMBINATION OF T2 L4
 18 = COMBINATION OF GV GV
 19 = COMBINATION OF B1

PIPE CONFIG	H&W COEF	PIPE DIAM	FIT COMB	PIPE LGT	FIT E LGT	TOTAL LGT	ELEV CHANGE	MAIN PIPES		PRES LOSS	PIPE ID	TOTAL PRES	PIPE FLOW	VEL VEL	VEL PRES	NORMAL PRES	IN/OUT FLOW
								ELEV PRES	FRIC PRES								
WS1																	<584.4>
0																	
1	120.	3.00		.0		.0			.00	.00	3.2600	87.01	584.4	22.46			
2	120.	3.00	17	44.0	50.0	94.0	-19.0	-8.23	25.16	16.94	3.2600	70.07	584.4	22.46			
3	120.	3.00	18	.0	60.0	60.0	2.0	.87	16.06	16.93	3.2600	53.14	584.4	22.46			
B1	4	120.	3.00	3	20.0	5.0	25.0	13.0	5.63	6.69	12.32	3.2600	40.82	584.4	22.46	.00	40.82 584.4

141.0 PSI PRESSURE AVAILABLE AND 87.0 PSI PRESSURE REQUIRED AT THE WATER SUPPLY WHEN FLOWING 584.4 GPM

370.5 GPM MINIMUM DESIGN FLOW REQUIREMENT

.0 GPM REQUIRED ADDITIONAL FLOW


743.7 GPM MAXIMUM FLOW

PRICE SCHEDULE

Price Club
Canopy System

CONTRACT NAME:

NO:



The Brick Township Municipal Utilities Authority

COMMISSIONERS

JOHN C. EKARIUS
CHAIRMAN
THOMAS G. MAIORINE
VICE-CHAIRMAN
MICHAEL THULEN
SECRETARY
WILLIAM MILLER
TREASURER
ALAN COHEN
ASS'T. SEC/TREAS

1551 HIGHWAY 88 WEST • BRICK, NEW JERSEY 08724-2399

PHONE: (908) 458-7000 • FAX: (908) 458-7725

KEVIN F. DONALD
Executive Director

APPLICATION FOR AUXILIARY METER

DATE: 12-2-92

APPLICANT'S NAME The Price Club TELEPHONE # _____

MAILING ADDRESS: 46000 Manekin Plaza Sterling VA

SERVICE LOCATION: Rt. 88 - The Price

ACCOUNT#: _____ BLOCK: 1170 LOT: 51

SIZE OF EXISTING SERVICE: 2" SIZE OF EXISTING METER: _____

APPLICANT'S SIGNATURE _____

Gathi Evan
AUTHORITY REPRESENTATIVE

At the customer's option, a separate account may be established for this usage, subject to all conditions of the rate schedule as applicable water usage.

After completing this application the following steps must be taken:

- 1- Obtain special device permit from the Township of Brick Plumbing Department.
- 2- A licensed plumber or homeowner must cut into the pipe before the existing yoke and install a second meter yoke.
- 3- Call Township of Brick Plumbing Dept. for inspection (477-3000).
- 4- Upon approval from the plumbing inspector a second meter will be installed. A copy of the completed permit will be required before the meter is installed. Contact the BTMUA for the meter installation.
- 5- A charge for the cost of the meter will be applied to the first billing. Bills for water only will be sent on this account quarterly.

A.J. CARNEGIE, INC.1600 Jersey Avenue
NORTH BRUNSWICK, NEW JERSEY 08902**LETTER OF TRANSMITTAL**

(201) 249-3930

TO Twsp of Brick
401 Chambers Bridge Rd
Brick, N.J. 08783

DATE <u>8/14/92</u>	JOB NO.
ATTENTION <u>Joe Eversito</u>	
RE: <u>Price Club</u>	

WE ARE SENDING YOU ☒ Attached ☐ Under separate cover via _____ the following items:

- | | | | | |
|---|---------------------------------------|--|----------------------------------|---|
| ☒ Shop drawings | ☐ Prints | ☐ Plans | ☐ Samples | ☐ Specifications |
| ☐ Copy of letter | ☐ Change order | ☒ <u>Hydraulic Calcs</u> | | |

COPIES	DATE	NO.	DESCRIPTION
<u>3 sets</u>			<u>Sprinkler Shop Drawings</u>
<u>2 sets</u>			<u>Hydraulic Calcs - Auto Center - Whse Roof - Outflow</u>
			<u>Canopy - Racks</u>
<u>1 set</u>			<u>Fire Pump - (For your Information)</u>

THESE ARE TRANSMITTED as checked below:

- | | | |
|--|---|---|
| ☒ For approval | ☐ Approved as submitted | ☐ Resubmit _____ copies for approval |
| ☐ For your use | ☐ Approved as noted | ☐ Submit _____ copies for distribution |
| ☐ As requested | ☐ Returned for corrections | ☐ Return _____ corrected prints |
| ☐ For review and comment | ☐ _____ | |
| ☐ FOR BIDS DUE _____ 19 _____ ☐ PRINTS RETURNED AFTER LOAN TO US | | |

REMARKS _____

COPY TO _____

SIGNED: _____

Thammi