



Construction

Property Summary

Owner: JYB PROPERTIES LLC
Location: 110 JOHN STREET
Block: 33
Lot: 14
Lead Parcel: Yes
Qualifier: R-4
Zoning: R-4

[Portal](#) | [Refresh](#) | [Open All](#) | [Close All](#)

- ▶ About the Owner...
- ▶ About the Property...
- ▶ About the Taxes...
- ▶ Construction...

Applications... Expand

<u>Permit Issue Date</u>	<u>Control Number</u>	<u>Permit Number</u>	<u>Work Type</u>	<u>Subcodes</u>	<u>Status</u>	<u>Close Date</u>	<u>Certificates</u>	<u>Total Cost</u>	<u>Agent</u>
5/15/2023	C-23-0088	23-0131	Alteration	B P E F M	CO and Close Date Issued	11/22/2023	CO	\$77,500	Hudson Home Improvement LLC
Proposed Interior renovations per Plan by William Figdor dated 2/27/23.									
5/25/2001		20010158	Alteration	B		5/26/2001	CA	\$4,600	

Would you like to add a application to this parcel? Yes

Inspections... Expand

<u>Date</u>	<u>Control Number</u>	<u>Permit Number</u>	<u>Subcode</u>	<u>Type</u>	<u>Inspector</u>	<u>Result</u>
11/21/2023	C-23-0088	23-0131	Plumbing	Final Reinsp	Steve Rodzinak	Pass

Comment
Agent: Hudson Home Improvement LLC
Phone: (551) 655-5219/
Agent: Hudson

Result Comment

11/9/2023	C-23-0088	23-0131	Building	Final	Frank LaGuardia	Pass	Home Improvement LLC Phone: (551) 655-5219/ Agent: Hudson Home Improvement LLC Phone: (551) 655-5219/ Agent: Hudson Home Improvement LLC Phone: (551) 655-5219/ Beverly, touching ductwork and foam insulation must have 1 inch of clearance
11/9/2023	C-23-0088	23-0131	Electrical	Final	John Elichko	Pass	Home Improvement LLC Phone: (551) 655-5219/ Agent: Hudson Home Improvement LLC Phone: (551) 655-5219/ Beverly, touching ductwork and foam insulation must have 1 inch of clearance
11/8/2023	C-23-0088	23-0131	Plumbing	Final	Steve Rodzrak	Fail	Home Improvement LLC Phone: (551) 655-5219/ Agent: Hudson Home Improvement LLC Phone: (551) 655-5219/ Beverly, touching ductwork and foam insulation must have 1 inch of clearance
9/28/2023	C-23-0088	23-0131	Fire	Final	Karl McAleer	Pass	Home Improvement LLC Phone: (551) 655-5219/ Agent: Hudson Home Improvement LLC Phone: (551) 655-5219/ Beverly, touching ductwork and foam insulation must have 1 inch of clearance
9/25/2023	C-23-0088	23-0131	Fire	Final	Karl McAleer	Fail	Home Improvement LLC Phone: (551) 655-5219/ Agent: Hudson Home Improvement LLC Phone: (551) 655-5219/ Beverly, touching ductwork and foam insulation must have 1 inch of clearance
9/19/2023	C-23-0088	23-0131	Electrical	Final	John Elichko	Pass	Home Improvement LLC Phone: (551) 655-5219/ Agent: Hudson Home Improvement LLC Phone: (551) 655-5219/ Beverly, touching ductwork and foam insulation must have 1 inch of clearance
9/14/2023	C-23-0088	23-0131	Electrical	Final	John Elichko	Fail	Home Improvement LLC Phone: (551) 655-5219/ Agent: Hudson Home Improvement LLC Phone: (551) 655-5219/ Beverly, touching ductwork and foam insulation must have 1 inch of clearance
7/11/2023	C-23-0088	23-0131	Building	INSULATION	Frank LaGuardia	Pass	Home Improvement LLC Phone: (551) 655-5219/ Agent: Hudson Home Improvement LLC Phone: (551) 655-5219/ Beverly, touching ductwork and foam insulation must have 1 inch of clearance
7/6/2023	C-23-0088	23-0131	Building	Framing Reinsp	Frank LaGuardia	Pass	Home Improvement LLC Phone: (551) 655-5219/ Agent: Hudson Home Improvement LLC Phone: (551) 655-5219/ Beverly, touching ductwork and foam insulation must have 1 inch of clearance

Violations...

There is no violation data for the selected parcel.

Would you like to add an violation to this parcel? Yes

Ongoing Applications...

There is no application data for the selected parcel.

Would you like to add an application to this parcel? Yes

▼ **Complaints...**

▼ **Attachments...**

▼ **Comments...**