

STATE OF NEW JERSEY
DEPARTMENT OF ENVIRONMENTAL PROTECTION
TRENTON, NJ

Permit No. 3100066491

MAIL TO

NJDEP
BUREAU OF WATER ALLOCATION
PO BOX 426
TRENTON, NJ 08625-0426

PERMIT TO DRILL WELL

EMERGENCY

VALID ONLY AFTER APPROVAL BY THE DEP

COORD #

31.15.426

Property Owner Michael Driver

Driller Anderson's Well Drilling

Address 35 Bobolink Way

Address 235 Sycamore Avenue

Medford, NJ 08055

Marlton, NJ 08053

Name of Facility _____

Address same as above


Diameter of Well	4	Inches	Proposed Depth of Well	70	Feet
Proposed Capacity of Pump	12	GPM	Method of Drilling (Cable tool, Rotary, etc.)	Rotary	
Use of Well (See Reverse) Domestic - Replacement					
Drinking Water Supply? XXXXXX yes (see #7 on reverse) no					

LOCATION OF WELL

Lot # 18 Block # 4701 Municipality Medford Twp County Burlington


Draw sketch showing distance and location of well site to nearest public roads, streets, components of the nearest sewage disposal system, etc

State Atlas Map No. 31-15426



95' to s tank
105' to s field
22' to street
64' to dwelling
West

No known fuel tanks



PROVIDED WELL LOCATION (NAD 83 HORIZONTAL DATUM)
NJ STATE PLANE COORDINATE IN US SURVEY FEET

NORTHING _____	OR	EASTING _____
LATITUDE ____° ____' ____"		LONGITUDE ____° ____' ____"

SEE REVERSE SIDE FOR IMPORTANT PROVISIONS AND REGULATIONS PERTAINING TO THIS PERMIT. APPROVAL OF THIS PERMIT IS MADE SUBJECT TO ACCEPTANCE OF AND COMPLIANCE WITH THE FOLLOWING ADDITIONAL CONDITIONS

- ☐ PUBLIC COMMUNITY Water Supply Wells shall obtain construction and operation permits from the Bureau of Safe Drinking Water in accordance with N.J.A.C. 7:10-11.1 et seq.
- ☐ INDUSTRIAL SUPPLY A physical connection control permit shall be obtained pursuant to the provisions of N.J.A.C. 7:10-10.1 et seq.
- ☐ IRRIGATION SUPPLY A physical connection control permit may be required pursuant to the provisions of N.J.A.C. 7:10-10.1 et seq.
- ☒ REPLACEMENT WELL Existing well must be sealed by a New Jersey licensed well driller of the proper class upon abandonment.
- ☐ PINELANDS Well must be drilled and cased to a minimum depth of 100 unless the provisions of N.J.A.C. 7:50-6.84(a)4 v are met.
- ☐ MINIMUM distance requirements as per N.J.A.C. 7:9D-2.7 have not been met - see attached condition(s).
- ☐ The well shall be equipped with a totalizing flow meter per N.J.A.C. 7:19-2 et seq.

WELL PERMIT APPROVED NJ DEP
AUG 25 2003
BUREAU OF WATER ALLOCATION

In compliance with N.J.S.A. 58:4A-14, application is made for a permit to drill a well as described above

Date 8/25/03

Signature of Driller

Kevin Anderson

Registration No.

20132

Signature of Property Owner

Michael Driver