

Mail to

Water Allocation  
CN 029  
Trenton, N.J. 08625

## PERMIT TO DRILL WELL

VALID ONLY AFTER APPROVAL BY THE D.E.P.

COORD #: 31.15.4 35

Owner Mn. Armin Steckler  
Address 4 Thrush Way (a/k/a Thrust Way)  
Medford, N.J. 08055  
Name of Facility Same as above  
Address \_\_\_\_\_Driller A&H Environmental Drilling Inc.  
Address 516 Davis Road  
Barrington, NJ. 08007



|                                                                                                                     |    |        |                                               |        |      |
|---------------------------------------------------------------------------------------------------------------------|----|--------|-----------------------------------------------|--------|------|
| Diameter of Well                                                                                                    | 4" | Inches | Proposed Depth of Well                        | 100'   | Feet |
| Proposed Capacity of Pump                                                                                           | 11 | GPM    | Method of Drilling (cable-tool, rotary, etc.) | Rotary |      |
| Use of Well (See Reverse) Domestic-Replacement                                                                      |    |        |                                               |        |      |
| Drinking Water Supply? XXXX <input checked="" type="checkbox"/> yes (see #6 on reverse) <input type="checkbox"/> no |    |        |                                               |        |      |

## LOCATION OF WELL

|                   |         |              |            |
|-------------------|---------|--------------|------------|
| Lot #             | Block # | Municipality | County     |
| <del>228</del> 27 | 4701    | Medford      | Burlington |

Draw sketch showing distance and relations of well site to nearest public roads, streets, septic systems, etc.

State Atlas Map No. 31-15435



SEE REVERSE SIDE FOR IMPORTANT PROVISIONS AND REGULATIONS PERTAINING TO THIS PERMIT. APPROVAL OF THIS PERMIT IS MADE SUBJECT TO ACCEPTANCE OF AND COMPLIANCE WITH THE FOLLOWING ADDITIONAL CONDITIONS.

- ☒ DOMESTIC/PUBLIC NON-COMMUNITY Water Supply Wells shall comply with N.J.A.C. 7:10-12.1 et. seq.
- ☐ PUBLIC COMMUNITY Water Supply Wells shall obtain construction and operation permits from the Bureau of Safe Drinking Water in accordance with N.J.A.C. 7:10-11.1 et. seq.
- ☐ DOMESTIC IRRIGATION SUPPLY - No piping from the well for which the permit applies shall enter any building.
- ☐ HEAT PUMP WELLS - Wells must be a minimum of 50 feet apart and the water must be returned to the same aquifer as the production well. A two hour pump test must be performed on the return well at a rate of 1½ times the estimated return flow of water.
- ☐ INDUSTRIAL SUPPLY - A physical connection control permit shall be obtained pursuant to the provisions of N.J.A.C. 7:10-10.1 et. seq.
- ☒ REPLACEMENT WELL - Existing well must be sealed by a certified New Jersey licensed well driller upon abandonment.
- ☐ IRRIGATION PURPOSES ONLY ☐ TEST PURPOSES ONLY
- ☒ PINELANDS - Well must be drilled and cased to a minimum depth of 100' unless the provisions of N.J.A.C. 7:50-6.84(a)4.v. are met.
- ☐ GEOPHYSICAL LOGS of this well must be made. Permanent pumping equipment SHALL NOT be installed until such logs are made.
- ☐ SAMPLES of cuttings required every \_\_\_\_\_ feet or change in material.
- ☒ MINIMUM distance requirements as per N.J.A.C. 7:10-12.13 have not been met - see attached additional condition(s).

This Space for Approval Stamp

WELL PERMIT APPROVED  
Dept. of Environmental Protection  
Water Resources/Water Allocation  
OCT 25 1991

In compliance with N.J.S.A. 58:4A-14, application is made for a permit to drill a well as described above.

Date October 25, 1991

Signature of Driller

Ronald K. Anderson License No. 0980/1110

Signature of Owner

Mn. Armin Steckler

3137871  
10-25-91

- A. THE WELL SHALL BE PROVIDED WITH A CASING TO A DEPTH OF 50 FEET OR MORE, AND SAID CASING SHALL EXTEND TO AND BE SEALED INTO A CONFINING LAYER SEPARATING THE AQUIFER FROM THE STRATUM OF SOIL USED FOR SEWAGE DISPOSAL.

OR

- B. THE WELL SHALL BE CONSTRUCTED WITH A MINIMUM OF 70 FEET OF CASING, AND BE PRESSURE GROUTED FROM THE BOTTOM OF THE CASING TO THE SURFACE.