



Passaic City
330 Passaic Street
Passaic, NJ 07055

Inspection Activity Report

Inspections for Permit Number NP-22-00026

Permit Number
NP-22-00026

Inspection Date		Inspection Type	Inspector	Subcode	Result	Owner Location	Work Type	Work Description	Inspection Comments
03/02/2022		CERTIFICATE	Thomas J. ...	Plumbing	Pass	12 MYRTLE AVE 12 MYRTLE AVE	(None)		Agent: ... Phone: ...
03/03/2022		CERTIFICATE	Thomas J. ...	Fire	Fail	12 MYRTLE AVE 12 MYRTLE AVE	(None)		Agent: ... Phone: ... All cooking appliances do not fit under kitchen hood remove deep fryer or install new hood a address windowless basement violation with the fire official
03/03/2022		CERTIFICATE	Thomas J. ...	Building	Pass	12 MYRTLE AVE 12 MYRTLE AVE	(None)		Agent: ... Phone: ...
03/03/2022		CERTIFICATE	Thomas J. ...	Electrical	Pass	12 MYRTLE AVE 12 MYRTLE AVE	(None)		Agent: ... Phone: ...
04/11/2022		CERTIFICATE	Thomas J. ...	Fire	Pass	12 MYRTLE AVE 12 MYRTLE AVE	(None)		Agent: ... Phone: ...