



Township of Rockaway
Bureau of Fire Prevention
65 Mt Hope Rd
Rockaway, NJ 07866
Phone: 973-627-7200

Invoice Number **Inv-26-00008**

Printed Date 3/10/2026

Invoice Date 1/15/2026

Due

Receipt #: _____

Carter's
395 Mt Hope Ave
Rockaway, NJ 07866

RE: Local ID: 0277

Block\Lot\Qual: 11001\11.03

Carter's
395 Mt Hope Ave
Rockaway NJ 07866

Dedicated Fee	\$250.00
Violation Fee	\$250.00

Total Due:

\$500.00

Amount Remitted:

Payable to :

Rockaway Township Fire Prevention

And mail to:

**Rockaway Township
Bureau of Fire Prevention
65 Mt Hope Rd
Rockaway, NJ 07866**

V-25-00896 Penalty

V-25-00896 Dedicated Penalty of 500

Please return this invoice with your payment. Thank you.

Please do not hesitate to contact our offices if you require any assistance.

Jeffrey Heintzelman

Fire Official

RENEWAL NOTICE



Township of Rockaway
Bureau of Fire Prevention
65 Mt Hope Rd
Rockaway, NJ 07866
Phone: 973-627-7200

Invoice Number **Inv-26-00137**

Printed Date 3/10/2026

Invoice Date 3/10/2026

Due 4/10/2026

Official Use Only:

Receipt #: _____

RE: B/L/Q: 11001\11.03

Local ID: 0277

State Registration Number:

Carter's
395 Mt Hope Ave
Rockaway NJ 07866

Carter's
395 Mt Hope Ave
Rockaway, NJ 07866

Non-Life Hazard Use(s)

NLHU-24-018

Type: B-2 1501 to 5000 square feet

Fee: \$98.00

Local/State Permit(s)

Total Due:

\$98.00

Amount Remitted: \$ _____

If you would like to pay online go to <https://www.sdlportal.com/search/payments>
Payment ID: OP-26-0926

Payable to : Rockaway Township Fire Prevention

And mail to: Rockaway Township
Bureau of Fire Prevention
65 Mt Hope Rd
Rockaway, NJ 07866

Please return this invoice with your payment. Thank you.

Please do not hesitate to contact our offices if you require any assistance.

Yours in Fire Safety,

Jeffrey Heintzelman

Fire Official



Township of Rockaway
Bureau of Fire Prevention
65 Mt Hope Rd
Rockaway, NJ 07866
Phone: 973-627-7200

All Violations Associated with 5/1/2026 Inspection

Location

Block: 11001 Lot: 11.03 Qualifier: _____ Street Address: 367 Mt Hope Ave

Business Name Mezeh Grill

Use Group _____

Unit Number _____

☐ Life Hazard Use

State Number _____

Inspection Violations

NO.	Location	Nature & Description	Code Reference	Inspection Summary
1	Provide a test report with no deficiencies	Wet chemical systems shall be inspected, tested and maintained in accordance with NFPA 17A	904.5	Abate by: 3/19/2026
				I-FPI-26-00251(Edward Nunn)2/17/2026
				A-FPI-26-00252(Edward Nunn)3/15/2026
2	Entire premises	Fire extinguishers shall be inspected, tested and maintained in accordance with NFPA 10	906.2	Abate by: 3/19/2026
				I-FPI-26-00251(Edward Nunn)2/17/2026
				A-FPI-26-00252(Edward Nunn)3/15/2026

Inspection Summary Key:


I - Initial U - Violation Unabated A - Violation Abated R - Repeat Violation W - Withdrawn
Violation Status - Inspection Number (Inspector ID) Inspection Date

Note: The numbering of violation(s) is for identification purposes only and shall not be construed as bearing in anyway on the seriousness of any violation.

5:71-3.7(b)3.

N.J.A.C. 5:70-3.2(a), modifications to articles and sections of the State Fire Prevention Code.

N.J.A.C. 5:70-4, Subchapter 4 Retrofit Requirements



Location

Block: 11001 Lot: 11.03 Qualifier: Street Address: 367 Mt Hope Ave

Business Name PetSmart

Use Group

Unit Number

☐ Life Hazard Use

State Number

Inspection Violations

NO.	Location	Nature & Description	Code Reference	Inspection Summary
1	Provide a test report with no deficiencies Repeat	Fire alarm systems shall be inspected, tested and maintained in accordance with NFPA 72	907.8	Abate by: 3/14/2026
				I-FPI-26-00233(Edward Nunn)2/12/2026
				U-FPI-26-00234(Edward Nunn)3/14/2026
2	Provide a test report with no deficiencies Repeat	Sprinkler systems shall be inspected, tested and maintained in accordance with NFPA 25	903.5	Abate by: 3/14/2026
				I-FPI-26-00233(Edward Nunn)2/12/2026
				U-FPI-26-00234(Edward Nunn)3/14/2026

Inspection Summary Key:

I - Initial U - Violation Unabated A - Violation Abated R - Repeat Violation W - Withdrawn

Violation Status	Inspection Number (Inspector ID)	Inspection Date
Minor	101 (Inspector A)	2023-01-15
Major	102 (Inspector B)	2023-02-01
Minor	103 (Inspector A)	2023-02-15
Major	104 (Inspector C)	2023-03-01
Minor	105 (Inspector B)	2023-03-15
Major	106 (Inspector A)	2023-04-01
Minor	107 (Inspector C)	2023-04-15
Major	108 (Inspector B)	2023-05-01
Minor	109 (Inspector A)	2023-05-15
Major	110 (Inspector C)	2023-06-01

Note: The numbering of violation(s) is for identification purposes only and shall not be construed as bearing in anyway on the seriousness of any violation.

5:71-3.7(b)3.

N.J.A.C. 5:70-3.2(a), modifications to articles and sections of the State Fire Prevention Code.

N.J.A.C. 5:70-4, Subchapter 4 Retrofit Requirements



Township of Rockaway
Bureau of Fire Prevention
65 Mt Hope Rd
Rockaway, NJ 07866
Phone: 973-627-7200

All Violations Associated with 3/13/2026 Inspection

Location

Block: 11001 Lot: 11.03 Qualifier: Street Address: 367 Mt Hope Ave

Business Name Primo Hoagies

Use Group

Unit Number

☐ Life Hazard Use

State Number

Inspection Violations

NO.	Location	Nature & Description	Code Reference	Inspection Summary
1	Entire premises	Fire extinguishers shall be inspected, tested and maintained in accordance with NFPA 10	906.2	Abate by: 3/13/2026
				I-FPI-26-00227(Edward Nunn)2/11/2026
				U-FPI-26-00228(Edward Nunn)3/13/2026

Inspection Summary Key:

I - Initial U - Violation Unabated A - Violation Abated R - Repeat Violation W - Withdrawn
Violation Status - Inspection Number (Inspector ID) Inspection Date

Note: The numbering of violation(s) is for identification purposes only and shall not be construed as bearing in anyway on the seriousness of any violation.

5:71-3.7(b)3.

N.J.A.C. 5:70-3.2(a), modifications to articles and sections of the State Fire Prevention Code.

N.J.A.C. 5:70-4, Subchapter 4 Retrofit Requirements



Township of Rockaway
Bureau of Fire Prevention
65 Mt Hope Rd
Rockaway, NJ 07866
Phone: 973-627-7200

Invoice Number **Inv-26-00094**

Printed Date 3/27/2026

Invoice Date 2/17/2026

Warning Date 3/27/2026

Due 4/17/2026

Local ID: 0275

Penalty Warning

To:

Sleep Number #11235
395 Mt Hope Ave
Rockaway, NJ 07866

Sleep Number
395 Mt Hope Ave
Rockaway NJ 07866
B:11001 L:11.03

Dear Rockaway Township Business Operator

Take Notice that on 2/17/2026. We mailed you an application and invoice for renewal of the following permits to operate your business.

Please provide full payment by 4/17/2026

Non-Life Hazard Use(s)

NLHU-23-020

Type: B-2 1501 to 5000 square feet

Fee: \$98.00

Local/State Permit(s)

Total Due:	\$98.00
-------------------	---------

Amount Remitted: \$ _____

Please do not hesitate to contact our offices if you require any assistance.

Payable to : Rockaway Township Fire Prevention

And mail to: Rockaway Township
Bureau of Fire Prevention
65 Mt Hope Rd
Rockaway, NJ 07866

Yours in Fire Safety,

Certified Tracking Number: _____

Mailed Date: 3/27/2026

Jeffrey Heintzelman

Fire Official

Delivered by: JEFF 158226