

John Protonentis, REHS
Environmental Health Coordinator
Environmental & Consumer Health
Email: Jprotonentis@ochd.org



OCEAN COUNTY HEALTH DEPARTMENT

P.O. Box 2191
175 Sunset Avenue
Toms River, NJ 08754-2191
(732) 341-9700 ext. 7416
Fax: (732) 286-1495
www.ochd.org

DATE: 5-30-24 FILE #: 060384

CERTIFICATE OF COMPLIANCE

Issued to: Dowling

THIS IS TO CERTIFY THAT THE:

Individual Sewage System:

Repair Field Only

Individual Water System:

none

Located in:

Plumsted
Municipality

At Block:

74

Lot:

3

Is in compliance with the application for permit to locate, construct and/or alter such systems.

File #:

Dated:

5-15-24

The issuance of this certification shall not be construed as a guarantee that the system will function satisfactorily nor shall it in any way restrict the powers or responsibilities of the Board of Health in the enforcement of any law or ordinance relating to public health.

X Final Approval

S. WICKER
Inspecting Official

John Protonentis, REHS
Environmental Health Coordinator
Environmental & Consumer Health
Email: Jprotonentis@ochd.org



Public Health
Prevent. Promote. Protect.

OCEAN COUNTY HEALTH DEPARTMENT

P.O. Box 2191
Toms River, N.J. 08754-2191
(732) 341-9700 ext. 7464
Fax: (732) 286-1495

FILE # 060384

APPLICATION FOR A PERMIT TO REPAIR AN ONSITE SUBSURFACE SEWAGE
DISPOSAL SYSTEM

Municipality: New Plumsted
Block: 74
Lot: 3

Address of Repair: 34 Highbridge Road
New Egypt, NJ
08533

Owner Information:

Name: Juanita Dowling
Address: 34 Highbridge Rd.
New Egypt NJ 08533
Phone: 609-903-4200

Contractor Information:

Name: ABC Septic Service
Address: 116 E. Susquehanna Dr.
LEH NJ 08087
Phone: 609-384-9400

SYSTEM INFORMATION: Type of building: X Residential Commercial Other
Bedrooms 4 Type of System SEPTIC TANK + FIELD

Repair shall consist of (Check all that apply):

- ☒ 1. Disposal field replacement (Including stone, pipe, fabric, etc.) **LETTER REQUIRED**
- ☐ 2. Seepage pit restoning **LETTER REQUIRED**
- ☐ 3. Baffle replacement
- ☐ 4. Effluent filter installation/replacement
- ☐ 5. Septic tank replacement/repair Size: 20 x 20
- ☐ 6. Seepage pit replacement/repair Size:
- ☐ 7. Distribution box replacement/repair
- ☐ 8. Pipe repair other than disposal field
- ☐ 9. Other (Please specify)

For office use only Approved? (Y) N Stipulations * Approved for on-site inspection
Approved by (Print/Sign): [Signature]
Previous file available? Y N File #? 020937 / 041334

4 copies of the plot plan must be attached. Show well and waste material site location on plan, if applicable.
Inspection REQUIRED prior to backfill. Any deviation from this approved plan shall require engineering design.



OCEAN COUNTY HEALTH DEPARTMENT


P.O. Box 2191
Toms River, NJ 08754-2191
(732) 341-9700 ext. 7449
Fax: (732) 286-1495
www.ochd.org

**APPLICATION FOR PERMIT TO CONSTRUCT/ALTER/REPAIR AN INDIVIDUAL
SUBSURFACE SEWAGE DISPOSAL SYSTEM**

Repair, Alteration, Malfunction or Change of Use Questionnaire

1. Have any additional bedrooms been added to the structure since the last inspection? NO
Has there been a change of use to the structure? (i.e., residential to commercial)
2. Are there any root - invading trees within the area of the system? NO
3. Are there any other sewage disposal locations on the property? NO
4. Does the current grading cause surface water to accumulate on or around the system? NO
5. Is the disposal field free of any encroachment (driveway, pool, fences, etc)? YES
6. Are there any known well(s) located on the property or any adjacent properties? YES
7. Is there an ejector pump installed? NO If so, was the system designed for one?

Name of Professional Engineer: William C. Longo, P.E.

Signature of Professional Engineer:  Date: 5/2/24



LORTECH^{INC.}

CONSTRUCTION ENGINEERING

May 13, 2024

Ocean County Health Department
P.O. Box 2191
Toms River, NJ 08754

Re: Septic Repair
Block 74 Lot 3
34 Highbridge Road
Plumsted, NJ

To Whom It May Concern:

A septic repair is proposed on the above referenced property. The existing septic tank will remain in service.

The existing 20' x 20' disposal field will be re-stoned. The water table is below bottom of the field. The work will correct the current malfunction. The system will not be altered; all original components will remain, in their current locations. The system will be adequate to treat and dispose of the volume and type waste (residential) being put into the system.


This letter is not to be interpreted as a guarantee of future system operation.

Please contact this office with any questions you may have.



Sincerely,

William C. Longo, P.E.
N.J.P.E. #35284

BOXY
WASTE



←
TANK
TO
REMAIN



DRIVEWAY