

DATE	LOCATION	FOOTAGE	TROUBLE
10/22/17	HILTOP PEAR ALLEY	116 ft	not our line
11/28/17	600 BARRYMORE ST	316 ft	not our line
12-4-17	3211 LINCOLN	293 ft	NOT OUR LINE
12/18/17	441 LEWIS ST		NOT OUR LINE
12/18/17	474 KNEEDLER AVE	20 ft	Rags
12/29/17	22 1/2 WEST BROAD	184 ft	GREASE GREASE
1/1/2018	ON BANK MORRIS ST Between CHAMBERLAIN + FILMORE	357'	RAGS
1/21/18	MORRIS & SUMMIT	10 ft	GREASE and Rags
1/18/18	517 KATHLEEN CT		DYE TEST ^{NOT} our line
1/22/18	1 STATELINE RD	118 ft	RAGS & ^{PIECE OF} METAL RIA
2/1/18	386 Kent St.	145 ft	Rags
2/1/18	114 WASHINGTON ST	183 ft	Rags
2/11/18	244 SITGRAVES	10 ft	Rags
2/12/18	107 CHAMBER	—	NOT OUR LINE
2/15/18	142 SITGRAVES	—	NOT OUR LINE
2-22-18	75 South Main ^{MAN HOLE at IRON STEPS}	—	lateral plugged solid
3/5/18	134 BROAD ST	148 ft	RAGS
2/8/18	478 CONGRESS	65 ft	ON COLUMBUS RAGS + ROOT
2/8/18	478 CONGRESS	320 ft	CONGRESS ST HALL

DATE	LOCATION	FOOTAGE	TROUBLE
4/14/18	162 SITGREAVES ST		NOT OUR LINE
4/16/18	CHAMBERLAIN DR	192'	HEAVY RAIN GREASE + BRICKS
5/7/18	22 + POHLS	132'	Rags/Soap
5/17/18	22 GLEN AVE	281 FT	NOT OUR LINE
5/26/18	BROADVIEW behind LYNDALE	11 FT	TREE ROOTS
5/31/18	193 LEWIS	310 FT	NOT OUR LINE
6/14/18	193 LEWIS	310 FT	NOT OUR LINE
6/15/18	548 FISHER	378 FT	Sludge
6/16/18	181 NORTH RIVERVIEW	190 FT	TREE ROOTS
7/2/18	901 GATES	200 FT	HEAVY SLUDGE
7/18/18	562 BELVIDERE RD	75 FT	HEAVY SLUDGE and RAGS + STONES
7/23/18	Marshall and Grant	365 FT	Rags + Soap + Sludge
7/29/18	740 Columbus AV	235 FT	line open
8/4/18	Center + SAYRE	20 FT	HEAVY RAGS + GREASE
8/5/18	664 Columbus Ave	64 FT	Sludge
9/17/18	SPRUE + MCKEEN	15 FT	RAGS
9/24/18	498 KNEEDLE AVE	210 FT	RAG
10/22/18	22 WEST	160 FT	HEAVY SLUDGE
11/22/18	Cedar + McKee	300 FT	not a line

DATE	LOCATION	FOOTAGE	TROUBLE
11-7-18	292 MORRIS	8 FT	Rags + SLUDGE
12-7-18	Memorial ^{PROV} & Potts	325 FT	Grease + Sludge
2-10-18	63 DAVIS ST	0	not our line
12-12-18	472 Fisher	325 FT	Sludge + TP
12-30-18	477 Kneeder Ave	10 ft	Rags
1-1-19	Memorial + Potts	300 FT	GREASE + SLUDGE
1-2-19	559 So. main ST	332 FT	LARGE GREASE CLUMP
1-7-19	559 So. main st	380 FT	RAN SAW ASER FULL length TREE ROOTS
1-7-19	672 Belvidier ROAD	60 FT	STONES
1-23-19	Fisher & Kneeder	10 FT	Sludge
1-24-19	Morris & Filmore	4.70	Sludge & Grease
1/24/19	22 west	277 FT	GREASE
2-7-19	572 ELDER	0 FT	Not our line
2-12-19	Hockst + Melrose st	93 FT	Rags
2-15-19	814 South main st	262 ft	not our line
2-16-19	814 South main st	262 ft	not our line
2-16-19	147 Riverview	266 ft	not our line
2-23-19	628 HILLCREST BLV	190	NOT OUR LINE RAGS + STONE
3-12-19	498 HECKMAN St.	5 FT.	GREASE

DATE	LOCATION	FOOTAGE	TROUBLE
3-15-19	MORRIS ST	293 FT	SLUDGE
3-31-19	131 Best AVE	130 FT	NOT OUR LINE
4-2-19	424 WARREN ST	120 FT	NOT OUR LINE
4-5-19	119 RIVERVIEW RD	3 FT	GREASE & RAGS
4-15-19	122 Lock St	370 FT	Rags & Grease
4-15-19	Hillside & Ridge	45 FT	GREASE & RAGS
4-16-19	680 Belvide RD	180 FT	not our LINE
4-30-19	121 WASHINGTON ST	80 FT	CLEAN OUT STONE
5-2-19	B Elizabeth	240 FT	Clean out
5-15-19	731 COLUMBUS ST	248 FT	NOT OUR LINE
5-16-19	EIDER + Birkdale Way	164 FT	TREE ROOTS & SLUDGE
5-17-19	3 BURKE ST	310 FT	NOT OUR LINE
6-7-19	393 LINCOLN	275	FLUSH DIRT
7-17-19	451 Lyndale	91 FT	ROOTS
8-4-19	140 COLUMBUS ST	240 FT	NOT OUR LINE
9-10-19	502 CORLISS AVE	325 FT	GREASE

3-15-19

3-31-

4-2-

4-5-

4-1-

4-15-

4-16-

4-30-

5-2-

5-15-

5-16-

5-17-

6-7-

7-1-

8-4-

9-10

2-20-19 BOBBITTS GARAGE AT SAWMILL +
S MAIN, BOBBITS LATERAL WAS
FOUND EXITING INTO FIRST
MANHOLE ON SAWMILL

DUE TO FLUXUATION OF FLOW —
INTO 30" MAIN LATERAL WAS
BACKFLOWING INTO BATHROOMS

OWARER WAS TOLD TO PUT
IN BACKFLOW PREVENTER VALVE
BY DAN BARANZSKI HEAD OF
SEWER PLANT,
(STEVE ELLIS) MAYOR CONTACTED ALSO

LATERAL FLOODED BATHROOMS 4 DAYS
PRIOR