

Inspection and Testing Certificate

Presented To

Fairfield Board of Education

For

Winston Churchill School

233 Fairfield Road
Fairfield, New Jersey 07004
United States

This site has been inspected and tested in compliance with applicable standards.

Completed
Wednesday, July 09, 2025

Test Session :09 Jul 2025 10:15

ACCEPTED BY

Fairfield Board of Education
277 Fairfield Rd Suite 208
Fairfield, New Jersey 07004
United States

TESTED BY

Ron Striegel
A.C. Daughtry Inc
381 Main Road
Montville, NJ 07045
United States

INSPECTION STATUS

Acceptable
Inspection or maintenance completed



AC DAUGHTRY
SECURITY SYSTEMS

Inspection Summary

Building Information

PROPERTY	Winston Churchill School	CONTACT
ADDRESS	233 Fairfield Road	PHONE
CITY/STATE/ZIP	Fairfield, New Jersey 07004	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	A.C. Daughtry Inc	LICENSE NUMBER	P00782
		PHONE	973-335-3931
ADDRESS	381 Main Road Montville, NJ 07045	EMAIL	contactus@acdsecurity.com

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Power Supplies	2	2(100%)	2(100%)	0(0%)
Initiating Device	111	111(100%)	111(100%)	0(0%)
Fire Control Panel	2	2(100%)	2(100%)	0(0%)
Alarm Notification Appliance	25	25(100%)	25(100%)	0(0%)
Supervising Station Transmitting Equipment	1	1(100%)	1(100%)	0(0%)

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Wednesday, July 09, 2025

ACCEPTED BY 07/09/2025

Building Representative

TESTED BY 07/09/2025
Ron Striegel
Technician

System Details

Control Units

MANUFACTURER	Notifier	DESCRIPTION	Behind stage
MODEL	AFP-400	S/W VERSION	
SERIAL NUMBER		LAST UPDATE	
INSTALL DATE		S/W LOCATION	

Primary Power

TYPE	Primary Power	DESCRIPTION	
NOMINAL VOLTAGE	120	PROTECTION	Breaker
NOMINAL AMPS	0.5	AMPS	20
LOCATION		DISCONNECT	EP

Secondary Power

TYPE	Battery - Nickel-cadmium	DESCRIPTION	
ADDRESS / SCAN ADDRESS	Z102	NOMINAL VOLTAGE	12
LOAD VOLTAGE		AMP HOURS	14
STANDBY HOURS		ALARM MINUTES	
BATTERY LOCATION	Battery - Nickel-cadmium	CHARGER CURRENT	

Monitoring Information

Z105			
TYPE	Radio Alarm Transmitter	TEST START	07/09/2025
MANUFACTURER	Aes	TEST COMPLETE	07/09/2025
MODEL	7787f		
MONITORING ORGANIZATION	Rapid Response		
MONITORING ORGANIZATION PHONE	18009323822		
MONITORING ORGANIZATION ACCOUNT NUMBER	3912886		
MONITORING PHONE LINE 1			
MONITORING PHONE LINE 2			
MONITORING RETRANSMISSION ENTITY	Fairfield Fire Bureau		

Testing Details

Alarm Notification Appliance

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Horn/Strobe	HS125	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:16:17 AM
Horn/Strobe	HS123	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:16:19 AM
Horn/Strobe	HS122	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:16:21 AM
Horn/Strobe	HS121	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:16:23 AM
Horn/Strobe	HS120	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:16:24 AM
Horn/Strobe	HS124	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:16:28 AM
Horn/Strobe	HS119	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:16:28 AM
Horn/Strobe	HS118	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:16:29 AM
Horn/Strobe	HS117	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:16:31 AM
Horn/Strobe	HS116	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:16:33 AM
Horn/Strobe	HS115	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:16:34 AM
Horn/Strobe	HS114	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:16:36 AM
Horn/Strobe	HS113	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:16:38 AM
Horn/Strobe	HS112	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:16:40 AM
Horn/Strobe	HS111	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:16:41 AM
Horn/Strobe	HS110	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:16:43 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Horn/Strobe	HS109	Visual Inspection	Manual	7/9/2025 10:16:45 AM
		Functional Inspection	Passed (Manual)	
			Passed	
Horn/Strobe	HS108	Visual Inspection	Manual	7/9/2025 10:16:46 AM
		Functional Inspection	Passed (Manual)	
			Passed	
Horn/Strobe	HS107	Visual Inspection	Manual	7/9/2025 10:16:48 AM
		Functional Inspection	Passed (Manual)	
			Passed	
Horn/Strobe	HS106	Visual Inspection	Manual	7/9/2025 10:16:50 AM
		Functional Inspection	Passed (Manual)	
			Passed	
Horn/Strobe	HS105	Visual Inspection	Manual	7/9/2025 10:16:52 AM
		Functional Inspection	Passed (Manual)	
			Passed	
Horn/Strobe	HS104	Visual Inspection	Manual	7/9/2025 10:17:02 AM
		Functional Inspection	Passed (Manual)	
			Passed	
Horn/Strobe	HS103	Visual Inspection	Manual	7/9/2025 10:17:04 AM
		Functional Inspection	Passed (Manual)	
			Passed	
Horn/Strobe	HS102	Visual Inspection	Manual	7/9/2025 10:17:12 AM
		Functional Inspection	Passed (Manual)	
			Passed	
Horn/Strobe	HS101	Visual Inspection	Manual	7/9/2025 10:17:14 AM
		Functional Inspection	Passed (Manual)	
			Passed	

Fire Control Panel

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator	Z104	Visual Inspection	Manual	7/9/2025 10:24:00 AM
		Functional Inspection	Passed (Manual)	
			Passed	
Fire Alarm Control Panel	Z101	Behind stage	Manual	7/9/2025 10:24:10 AM
		Manufacturer	Notifier	
		Model	AFP-400	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

Initiating Device

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Pull Station	D103	Visual Inspection	Manual	7/9/2025 10:15:52 AM
		Functional Inspection	Passed (Manual)	
			Passed	
Pull Station	D104	Visual Inspection	Manual	7/9/2025 10:15:54 AM
		Functional Inspection	Passed (Manual)	
			Passed	
Pull Station	D105	Visual Inspection	Manual	7/9/2025 10:15:56 AM
		Functional Inspection	Passed (Manual)	
			Passed	
Pull Station	D106	Visual Inspection	Manual	7/9/2025 10:15:58 AM
		Functional Inspection	Passed (Manual)	
			Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Pull Station	D107	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:15:59 AM
Pull Station	D108	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:16:01 AM
Pull Station	D109	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:16:03 AM
Pull Station	D110	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:16:04 AM
Pull Station	D112	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:16:06 AM
Pull Station	D101	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:16:09 AM
Pull Station	D111	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:16:10 AM
Pull Station	D113	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:16:12 AM
Pull Station	D114	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:16:14 AM
Pull Station	D115	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:16:15 AM
Beam	D211	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:17:18 AM
Beam	D210	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:17:20 AM
Heat Detector	D209	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:17:29 AM
Heat Detector	D208	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:17:31 AM
Heat Detector	D207	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:17:33 AM
Heat Detector	D206	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:17:38 AM
Heat Detector	D205	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:17:39 AM
Heat Detector	D204	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:17:41 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector	D203	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:17:44 AM
Heat Detector	D202	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:17:45 AM
Heat Detector	D201	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:17:47 AM
Heat Detector	D200	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:17:55 AM
Heat Detector	D199	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:17:57 AM
Heat Detector	D198	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:17:59 AM
Heat Detector	D197	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:18:01 AM
Heat Detector	D196	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:18:03 AM
Heat Detector	D195	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:18:05 AM
Heat Detector	D194	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:18:07 AM
Heat Detector	D193	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:18:09 AM
Heat Detector	D192	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:18:11 AM
Heat Detector	D191	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:18:18 AM
Heat Detector	D190	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:18:20 AM
Heat Detector	D189	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:18:22 AM
Heat Detector	D188	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:18:24 AM
Heat Detector	D187	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:18:26 AM
Heat Detector	D186	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:18:30 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector	D185	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:18:32 AM
Heat Detector	D184	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:18:33 AM
Heat Detector	D183	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:18:36 AM
Heat Detector	D182	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:18:37 AM
Heat Detector	D181	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:18:39 AM
Heat Detector	D180	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:18:41 AM
Heat Detector	D179	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:18:42 AM
Heat Detector	D178	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:18:44 AM
Heat Detector	D177	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:18:46 AM
Heat Detector	D176	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:18:48 AM
Heat Detector	D175	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:18:49 AM
Heat Detector	D174	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:18:51 AM
Heat Detector	D173	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:18:53 AM
Heat Detector	D172	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:19:05 AM
Heat Detector	D171	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:19:07 AM
Heat Detector	D170	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:19:10 AM
Heat Detector	D169	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:19:12 AM
Heat Detector	D168	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:19:14 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector	D167	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:19:15 AM
Heat Detector	D166	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:19:17 AM
Heat Detector	D165	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:19:19 AM
Heat Detector	D164	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:19:23 AM
Heat Detector	D163	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:19:25 AM
Heat Detector	D162	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:19:27 AM
Heat Detector	D161	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:19:29 AM
Heat Detector	D160	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:19:30 AM
Heat Detector	D159	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:19:32 AM
Heat Detector	D158	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:19:44 AM
Heat Detector	D157	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:19:47 AM
Heat Detector	D156	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:19:49 AM
Heat Detector	D155	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:19:52 AM
Heat Detector	D154	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:19:54 AM
Heat Detector	D153	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:19:57 AM
Heat Detector	D152	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:19:59 AM
Heat Detector	D151	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:20:01 AM
Heat Detector	D150	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:20:14 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector	D149	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:20:16 AM
Heat Detector	D148	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:20:19 AM
Heat Detector	D147	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:20:23 AM
Heat Detector	D146	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:20:25 AM
Heat Detector	D145	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:20:28 AM
Heat Detector	D144	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:20:30 AM
Heat Detector	D143	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:20:31 AM
Heat Detector	D142	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:20:54 AM
Heat Detector	D141	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:20:58 AM
Duct Detector	D140	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:21:00 AM
Duct Detector	D139	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:21:02 AM
Smoke Detector	D138	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:21:04 AM
Smoke Detector	D137	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:21:07 AM
Smoke Detector	D136	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:21:17 AM
Smoke Detector	D135	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:21:26 AM
Smoke Detector	D134	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:21:40 AM
Smoke Detector	D133	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:21:43 AM
Smoke Detector	D132	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:21:45 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector	D131	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:21:47 AM
Smoke Detector	D130	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:22:00 AM
Smoke Detector	D129	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:22:02 AM
Smoke Detector	D128	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:22:04 AM
Smoke Detector	D127	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:22:07 AM
Smoke Detector	D126	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:22:11 AM
Smoke Detector	D125	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:22:14 AM
Smoke Detector	D124	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:22:23 AM
Smoke Detector	D123	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:22:24 AM
Smoke Detector	D122	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:22:31 AM
Smoke Detector	D121	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:22:33 AM
Smoke Detector	D120	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:23:35 AM
Smoke Detector	D119	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:23:37 AM
Pull Station	D118	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:23:39 AM
Pull Station	D117	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:23:41 AM
Pull Station	D116	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:23:43 AM
Pull Station	D102	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/9/2025 10:23:45 AM

Power Supplies

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Battery - Nickel-cadmium	Z102		Manual	7/9/2025 10:23:52 AM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	14	
		Battery Location	FACP	
		Nominal Voltage	12	
Primary Power	Z103		Manual	7/9/2025 10:23:57 AM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Disconnect Location	EP	
		Nominal Amps	0.5	
		Nominal Voltage	120	
		Over Current Amps	20	
		Over Current Type	Breaker	

Supervising Station Transmitting Equipment

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Radio Alarm Transmitter	Z105		Manual	7/9/2025 10:23:33 AM
		Manufacturer	Aes	
		Model	7787f	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Monitoring Account Number	3912886	
		Monitoring Organization	Rapid Response	
		Monitoring Organization Phone	18009323822	
		Monitoring Retransmission Entity	Fairfield Fire Bureau	

Inspection and Testing Certificate

Presented To

Fairfield Board of Education

For

Adlai E. Stevenson School

15 Knoll Road
Fairfield, New Jersey 07004
United States

This site has been inspected and tested in compliance with applicable standards.

Completed
Monday, August 19, 2024

Test Session :19 Aug 2024 08:52

ACCEPTED BY

Fairfield Board of Education
277 Fairfield Rd Suite 208
Fairfield, New Jersey 07004
United States

TESTED BY

Nick Kuhar
A.C. Daughtry Inc
381 Main Road
Montville, NJ 07045
United States

INSPECTION STATUS

Acceptable

Inspection or maintenance completed



AC DAUGHTRY
SECURITY SYSTEMS

Inspection Summary

Building Information

PROPERTY	Adlai E. Stevenson School	CONTACT
ADDRESS	15 Knoll Road	PHONE
CITY/STATE/ZIP	Fairfield, New Jersey 07004	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	A.C. Daughtry Inc	LICENSE NUMBER	P00782
ADDRESS	381 Main Road Montville, NJ 07045	PHONE	973-335-3931
		EMAIL	contactus@acdsecurity.com

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	22	22(100%)	22(100%)	0(0%)
Fire Control Panel	2	2(100%)	2(100%)	0(0%)
Inflating Device	80	80(100%)	80(100%)	0(0%)
Power Supplies	2	2(100%)	2(100%)	0(0%)
Supervising Station Transmitting Equipment	2	2(100%)	2(100%)	0(0%)

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Monday, August 19, 2024

NE
NE

ACCEPTED BY 08/19/2024

Building Representative

TESTED BY 08/19/2024
Nick Kuhar
Technician

System Details

Control Units

MANUFACTURER	Firelite	DESCRIPTION
MODEL	ES-200X	S/W VERSION
SERIAL NUMBER		LAST UPDATE
INSTALL DATE		S/W LOCATION

Primary Power

TYPE	Primary Power	DESCRIPTION	
NOMINAL VOLTAGE	12	PROTECTION	Breaker
NOMINAL AMPS	0.5	AMPS	20
LOCATION		DISCONNECT	Electrical Panel

Secondary Power

TYPE	Battery - Nickel-cadmium	DESCRIPTION	
ADDRESS / SCAN ADDRESS	Z102	NOMINAL VOLTAGE	12
LOAD VOLTAGE		AMP HOURS	14
STANDBY HOURS		ALARM MINUTES	
BATTERY LOCATION	Battery - Nickel-cadmium	CHARGER CURRENT	

Monitoring Information

Z105

TYPE	Radio Alarm Transmitter	TEST START	08/19/2024
MANUFACTURER	AES Tap	TEST COMPLETE	08/19/2024
MODEL	778F		
MONITORING ORGANIZATION	RAPID RESPONSE		
MONITORING ORGANIZATION PHONE	800-932-3822		
MONITORING ORGANIZATION ACCOUNT NUMBER	3912916		
MONITORING PHONE LINE 1			
MONITORING PHONE LINE 2			
MONITORING RETRANSMISSION ENTITY	Fairfield Fire Bureau		

Z106

TYPE	Digital Alarm Communicator Transmitter	TEST START	08/19/2024
MANUFACTURER	AES	TEST COMPLETE	08/19/2024
MODEL	7794		
MONITORING ORGANIZATION	RAPID RESPONSE		
MONITORING ORGANIZATION PHONE	800-932-3822		
MONITORING ORGANIZATION ACCOUNT NUMBER	3915926		
MONITORING PHONE LINE 1			
MONITORING PHONE LINE 2			
MONITORING RETRANSMISSION ENTITY	Fairfield Fire Bureau		

Testing Details

Alarm Notification Appliance

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Horn/Strobe	HS122	Visual Inspection	Manual	8/19/2024 8:53:33 AM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS121	Visual Inspection	Manual	8/19/2024 8:53:36 AM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS120	Visual Inspection	Manual	8/19/2024 8:53:38 AM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS119	Visual Inspection	Manual	8/19/2024 8:53:46 AM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS118	Visual Inspection	Manual	8/19/2024 8:53:47 AM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS117	Visual Inspection	Manual	8/19/2024 8:53:49 AM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS116	Visual Inspection	Manual	8/19/2024 8:56:06 AM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS115	Visual Inspection	Manual	8/19/2024 8:56:08 AM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS114	Visual Inspection	Manual	8/19/2024 8:56:09 AM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS113	Visual Inspection	Manual	8/19/2024 8:56:11 AM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS112	Visual Inspection	Manual	8/19/2024 8:56:13 AM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS111	Visual Inspection	Manual	8/19/2024 8:56:19 AM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS110	Visual Inspection	Manual	8/19/2024 8:56:20 AM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS109	Visual Inspection	Manual	8/19/2024 8:56:22 AM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS108	Visual Inspection	Manual	8/19/2024 8:56:24 AM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS107	Visual Inspection	Manual	8/19/2024 8:56:26 AM
		Functional Inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Horn/Strobe	HS106	Visual Inspection	Manual	8/19/2024 8:56:28 AM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS105	Visual Inspection	Manual	8/19/2024 8:56:30 AM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS104	Visual Inspection	Manual	8/19/2024 8:56:31 AM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS103	Visual Inspection	Manual	8/19/2024 8:56:33 AM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS102	Visual Inspection	Manual	8/19/2024 8:56:34 AM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS101	Visual Inspection	Manual	8/19/2024 8:56:35 AM
		Functional Inspection	Passed (Manual)	

Fire Control Panel

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Fire Alarm Control Panel	Z101	Manufacturer	Manual	8/19/2024 8:53:06 AM
		Model	Firelite	
		Visual Inspection	ES-200X	
		Functional Inspection	Passed (Manual)	
Remote Annunciator	Z104	Visual Inspection	Manual	8/19/2024 8:53:16 AM
		Functional Inspection	Passed (Manual)	
		Functional Inspection	Passed	

Initiating Device

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector	D180	Visual Inspection	Manual	8/19/2024 8:56:37 AM
		Functional Inspection	Passed (Manual)	
Heat Detector	D179	Visual Inspection	Manual	8/19/2024 8:56:38 AM
		Functional Inspection	Passed (Manual)	
Heat Detector	D178	Visual Inspection	Manual	8/19/2024 8:56:40 AM
		Functional Inspection	Passed (Manual)	
Heat Detector	D177	Visual Inspection	Manual	8/19/2024 8:56:41 AM
		Functional Inspection	Passed (Manual)	
Heat Detector	D176	Visual Inspection	Manual	8/19/2024 8:56:44 AM
		Functional Inspection	Passed (Manual)	
Heat Detector	D175	Visual Inspection	Manual	8/19/2024 8:56:45 AM
		Functional Inspection	Passed (Manual)	
Heat Detector	D174	Visual Inspection	Manual	8/19/2024 8:56:47 AM
		Functional Inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector	D173	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:56:48 AM
Heat Detector	D172	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:56:49 AM
Heat Detector	D171	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:56:51 AM
Heat Detector	D170	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:56:52 AM
Heat Detector	D169	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:56:54 AM
Heat Detector	D168	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:56:55 AM
Heat Detector	D167	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:56:57 AM
Heat Detector	D166	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:56:58 AM
Heat Detector	D165	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:57:00 AM
Heat Detector	D164	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:57:01 AM
Heat Detector	D163	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:57:05 AM
Heat Detector	D162	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:57:06 AM
Heat Detector	D161	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:57:08 AM
Heat Detector	D160	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:57:09 AM
Heat Detector	D159	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:57:11 AM
Heat Detector	D158	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:57:12 AM
Heat Detector	D157	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:57:14 AM
Heat Detector	D156	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:57:15 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector	D155	Visual Inspection	Manual	8/19/2024 8:57:17 AM
		Functional Inspection	Passed (Manual)	
Smoke Detector	D154	Visual Inspection	Manual	8/19/2024 8:57:18 AM
		Functional Inspection	Passed	
Smoke Detector	D153	Visual Inspection	Manual	8/19/2024 8:57:20 AM
		Functional Inspection	Passed (Manual)	
Smoke Detector	D152	Visual Inspection	Manual	8/19/2024 8:57:21 AM
		Functional Inspection	Passed	
Smoke Detector	D151	Visual Inspection	Manual	8/19/2024 8:57:22 AM
		Functional Inspection	Passed (Manual)	
Smoke Detector	D150	Visual Inspection	Manual	8/19/2024 8:57:24 AM
		Functional Inspection	Passed	
Smoke Detector	D149	Visual Inspection	Manual	8/19/2024 8:57:27 AM
		Functional Inspection	Passed (Manual)	
Smoke Detector	D148	Visual Inspection	Manual	8/19/2024 8:57:29 AM
		Functional Inspection	Passed (Manual)	
Smoke Detector	D147	Visual Inspection	Manual	8/19/2024 8:57:30 AM
		Functional Inspection	Passed	
Smoke Detector	D146	Visual Inspection	Manual	8/19/2024 8:57:33 AM
		Functional Inspection	Passed (Manual)	
Smoke Detector	D145	Visual Inspection	Manual	8/19/2024 8:57:34 AM
		Functional Inspection	Passed	
Smoke Detector	D144	Visual Inspection	Manual	8/19/2024 8:57:36 AM
		Functional Inspection	Passed (Manual)	
Smoke Detector	D143	Visual Inspection	Manual	8/19/2024 8:57:37 AM
		Functional Inspection	Passed	
Smoke Detector	D142	Visual Inspection	Manual	8/19/2024 8:57:38 AM
		Functional Inspection	Passed (Manual)	
Smoke Detector	D141	Visual Inspection	Manual	8/19/2024 8:57:40 AM
		Functional Inspection	Passed	
Smoke Detector	D140	Visual Inspection	Manual	8/19/2024 8:57:41 AM
		Functional Inspection	Passed (Manual)	
Smoke Detector	D139	Visual Inspection	Manual	8/19/2024 8:57:43 AM
		Functional Inspection	Passed	
Smoke Detector	D138	Visual Inspection	Manual	8/19/2024 8:57:44 AM
		Functional Inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector	D137	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:57:45 AM
Smoke Detector	D136	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:57:47 AM
Smoke Detector	D135	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:57:48 AM
Smoke Detector	D134	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:57:49 AM
Smoke Detector	D133	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:57:51 AM
Smoke Detector	D132	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:57:52 AM
Smoke Detector	D131	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:57:53 AM
Smoke Detector	D130	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:57:55 AM
Smoke Detector	D129	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:57:56 AM
Smoke Detector	D128	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:57:58 AM
Smoke Detector	D127	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:57:59 AM
Smoke Detector	D126	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:58:00 AM
Smoke Detector	D125	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:58:02 AM
Smoke Detector	D124	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:58:04 AM
Smoke Detector	D123	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:58:05 AM
Smoke Detector	D122	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:58:07 AM
Smoke Detector	D121	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:58:09 AM
Smoke Detector	D120	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	8/19/2024 8:58:10 AM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector	D119	Visual Inspection	Manual	8/19/2024 8:58:12 AM
		Functional Inspection	Passed (Manual) Passed	
Smoke Detector	D118	Visual Inspection	Manual	8/19/2024 8:58:13 AM
		Functional Inspection	Passed (Manual) Passed	
Smoke Detector	D117	Visual Inspection	Manual	8/19/2024 8:58:15 AM
		Functional Inspection	Passed (Manual) Passed	
Smoke Detector	D116	Visual Inspection	Manual	8/19/2024 8:58:16 AM
		Functional Inspection	Passed (Manual) Passed	
Smoke Detector	D115	Visual Inspection	Manual	8/19/2024 8:58:18 AM
		Functional Inspection	Passed (Manual) Passed	
Pull Station	D114	Visual Inspection	Manual	8/19/2024 8:58:19 AM
		Functional Inspection	Passed (Manual) Passed	
Pull Station	D113	Visual Inspection	Manual	8/19/2024 8:58:21 AM
		Functional Inspection	Passed (Manual) Passed	
Pull Station	D112	Visual Inspection	Manual	8/19/2024 8:58:23 AM
		Functional Inspection	Passed (Manual) Passed	
Pull Station	D111	Visual Inspection	Manual	8/19/2024 8:58:24 AM
		Functional Inspection	Passed (Manual) Passed	
Pull Station	D110	Visual Inspection	Manual	8/19/2024 8:58:25 AM
		Functional Inspection	Passed (Manual) Passed	
Pull Station	D109	Visual Inspection	Manual	8/19/2024 8:58:27 AM
		Functional Inspection	Passed (Manual) Passed	
Pull Station	D108	Visual Inspection	Manual	8/19/2024 8:58:28 AM
		Functional Inspection	Passed (Manual) Passed	
Pull Station	D107	Visual Inspection	Manual	8/19/2024 8:58:30 AM
		Functional Inspection	Passed (Manual) Passed	
Pull Station	D106	Visual Inspection	Manual	8/19/2024 8:58:31 AM
		Functional Inspection	Passed (Manual) Passed	
Pull Station	D105	Visual Inspection	Manual	8/19/2024 8:58:32 AM
		Functional Inspection	Passed (Manual) Passed	
Pull Station	D104	Visual Inspection	Manual	8/19/2024 8:58:34 AM
		Functional Inspection	Passed (Manual) Passed	
Pull Station	D103	Visual Inspection	Manual	8/19/2024 8:58:35 AM
		Functional Inspection	Passed (Manual) Passed	
Pull Station	D102	Visual Inspection	Manual	8/19/2024 8:58:37 AM
		Functional Inspection	Passed (Manual) Passed	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Pull Station	D101		Manual	8/19/2024 8:58:38 AM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

Power Supplies

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Battery - Nickel-cadmium	Z102		Manual	8/19/2024 8:53:12 AM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	14	
		Battery Location	FACP	
		Nominal Voltage	12	
Primary Power	Z103		Manual	8/19/2024 8:53:14 AM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Disconnect Location	Electrical Panel	
		Nominal Amps	0.5	
		Nominal Voltage	12	
		Over Current Amps	20	
		Over Current Type	Breaker	

Supervising Station Transmitting Equipment

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Radio Alarm Transmitter	Z105		Manual	8/19/2024 8:57:03 AM
		Manufacturer	AES Tap	
		Model	778F	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Monitoring Account Number	3912916	
		Monitoring Organization	RAPID RESPONSE	
		Monitoring Organization Address	400 W. Division St. , Syracuse, NY 13204	
		Monitoring Organization Phone	800-932-3822	
		Monitoring Retransmission Entity	Fairfield Fire Bureau	
Digital Alarm Communicator Transmitter	Z106		Manual	8/19/2024 8:57:04 AM
		Manufacturer	AES	
		Model	7794	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Monitoring Account Number	3915926	
		Monitoring Organization	RAPID RESPONSE	
		Monitoring Organization Address	400 W. Division St. , Syracuse, NY 13204	
		Monitoring Organization Phone	800-932-3822	
		Monitoring Retransmission Entity	Fairfield Fire Bureau	

Inspection and Testing Certificate

Presented To

Fairfield Board of Education

For

Winston Churchill School

233 Fairfield Road
Fairfield, New Jersey 07004
United States

This site has been inspected and tested in compliance with applicable standards.

Completed
Friday, July 21, 2023

Test Session :21 Jul 2023 15:11

ACCEPTED BY

Fairfield Board of Education
277 Fairfield Rd Suite 208
Fairfield, New Jersey 07004
United States

TESTED BY

nicholas kuhar
A.C. Daughtry Inc
381 Main Road
Montville, NJ 07045
United States

INSPECTION STATUS

Acceptable

Inspection or maintenance completed



AC DAUGHTRY
SECURITY SYSTEMS

Inspection Summary

Building Information

PROPERTY	Winston Churchill School	CONTACT
ADDRESS	233 Fairfield Road	PHONE
CITY/STATE/ZIP	Fairfield, New Jersey 07004	MOBILE
COUNTRY	United States	EMAIL

Inspector Information

COMPANY	A.C. Daughtry Inc	LICENSE NUMBER	P00782
ADDRESS	381 Main Road Montville, NJ 07045	PHONE	973-335-3931
		EMAIL	contactus@acdsecurity.com

Testing Summary

EQUIPMENT TYPE	TOTAL	TESTED	PASSED	FAILED
Alarm Notification Appliance	25	25(100%)	25(100%)	0(0%)
Fire Control Panel	2	2(100%)	2(100%)	0(0%)
Initiating Device	111	111(100%)	111(100%)	0(0%)
Power Supplies	2	2(100%)	2(100%)	0(0%)
Supervising Station Transmitting Equipment	1	1(100%)	1(100%)	0(0%)

Certification

The equipment specified herein was inspected and tested according to the NFPA 72 standard for fire alarm and signaling systems, with the inspection completed on Friday, July 21, 2023

PD
72

ACCEPTED BY 07/21/2023

Building Representative

TESTED BY 07/21/2023

nicholas kuhar

Technician

System Details

Control Units

MANUFACTURER	Notifier	DESCRIPTION	Behind stage
MODEL	AFP-400	SW VERSION	
SERIAL NUMBER		LAST UPDATE	
INSTALL DATE		SW LOCATION	

Primary Power

TYPE	Primary Power	DESCRIPTION	
NOMINAL VOLTAGE	120	PROTECTION	Breaker
NOMINAL AMPS	0.5	AMPS	20
LOCATION		DISCONNECT	EP

Secondary Power

TYPE	Battery - Nickel-cadmium	DESCRIPTION	
ADDRESS / SCAN ADDRESS	Z102	NOMINAL VOLTAGE	12
LOAD VOLTAGE		AMP HOURS	14
STANDBY HOURS		ALARM MINUTES	
BATTERY LOCATION	Battery - Nickel-cadmium	CHARGER CURRENT	

Monitoring Information

Z105

TYPE	Radio Alarm Transmitter	TEST START	07/21/2023
MANUFACTURER	Aes	TEST COMPLETE	07/21/2023
MODEL	7787f		
MONITORING ORGANIZATION	Rapid Response		
MONITORING ORGANIZATION PHONE	18009323822		
MONITORING ORGANIZATION ACCOUNT NUMBER	3912886		
MONITORING PHONE LINE 1			
MONITORING PHONE LINE 2			
MONITORING RETRANSMISSION ENTITY	Fairfield Fire Bureau		

Testing Details

Alarm Notification Appliance

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Horn/Strobe	HS125	Visual Inspection	Manual	7/21/2023 3:13:48 PM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS123	Visual Inspection	Manual	7/21/2023 3:13:49 PM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS122	Visual Inspection	Manual	7/21/2023 3:13:53 PM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS121	Visual Inspection	Manual	7/21/2023 3:13:56 PM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS120	Visual Inspection	Manual	7/21/2023 3:13:58 PM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS124	Visual Inspection	Manual	7/21/2023 3:14:01 PM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS119	Visual Inspection	Manual	7/21/2023 3:14:03 PM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS118	Visual Inspection	Manual	7/21/2023 3:14:04 PM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS117	Visual Inspection	Manual	7/21/2023 3:14:06 PM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS116	Visual Inspection	Manual	7/21/2023 3:14:08 PM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS115	Visual Inspection	Manual	7/21/2023 3:14:10 PM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS114	Visual Inspection	Manual	7/21/2023 3:14:11 PM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS113	Visual Inspection	Manual	7/21/2023 3:14:13 PM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS112	Visual Inspection	Manual	7/21/2023 3:14:14 PM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS111	Visual Inspection	Manual	7/21/2023 3:14:16 PM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS110	Visual Inspection	Manual	7/21/2023 3:14:18 PM
		Functional Inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Horn/Strobe	HS109	Visual Inspection	Manual	7/21/2023 3:14:20 PM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS108	Visual Inspection	Manual	7/21/2023 3:14:21 PM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS107	Visual Inspection	Manual	7/21/2023 3:14:23 PM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS106	Visual Inspection	Manual	7/21/2023 3:14:25 PM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS105	Visual Inspection	Manual	7/21/2023 3:14:27 PM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS104	Visual Inspection	Manual	7/21/2023 3:14:28 PM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS103	Visual Inspection	Manual	7/21/2023 3:14:30 PM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS102	Visual Inspection	Manual	7/21/2023 3:14:31 PM
		Functional Inspection	Passed (Manual)	
Horn/Strobe	HS101	Visual Inspection	Manual	7/21/2023 3:14:33 PM
		Functional Inspection	Passed (Manual)	

Fire Control Panel

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Remote Annunciator	Z104	Visual Inspection	Manual	7/21/2023 3:18:52 PM
		Functional Inspection	Passed (Manual)	
Fire Alarm Control Panel	Z101	Behind stage	Manual	7/21/2023 3:19:49 PM
		Manufacturer	Notifier	
		Model	AFP-400	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	

Initiating Device

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Pull Station	D103	Visual Inspection	Manual	7/21/2023 3:12:57 PM
		Functional Inspection	Passed (Manual)	
Pull Station	D104	Visual Inspection	Manual	7/21/2023 3:13:03 PM
		Functional Inspection	Passed (Manual)	
Pull Station	D105	Visual Inspection	Manual	7/21/2023 3:13:05 PM
		Functional Inspection	Passed (Manual)	
Pull Station	D106	Visual Inspection	Manual	7/21/2023 3:13:07 PM
		Functional Inspection	Passed (Manual)	

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Pull Station	D107	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:13:10 PM
Pull Station	D108	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:13:13 PM
Pull Station	D109	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:13:17 PM
Pull Station	D110	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:13:18 PM
Pull Station	D112	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:13:23 PM
Pull Station	D101	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:13:29 PM
Pull Station	D111	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:13:33 PM
Pull Station	D113	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:13:35 PM
Pull Station	D114	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:13:36 PM
Pull Station	D115	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:13:39 PM
Beam	D211	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:14:37 PM
Beam	D210	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:14:41 PM
Heat Detector	D209	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:14:43 PM
Heat Detector	D208	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:14:45 PM
Heat Detector	D207	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:14:47 PM
Heat Detector	D206	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:14:50 PM
Heat Detector	D205	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:14:52 PM
Heat Detector	D204	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:14:54 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector	D203	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:14:55 PM
Heat Detector	D202	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:14:57 PM
Heat Detector	D201	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:14:58 PM
Heat Detector	D200	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:00 PM
Heat Detector	D199	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:02 PM
Heat Detector	D198	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:03 PM
Heat Detector	D197	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:05 PM
Heat Detector	D196	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:06 PM
Heat Detector	D195	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:07 PM
Heat Detector	D194	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:10 PM
Heat Detector	D193	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:11 PM
Heat Detector	D192	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:12 PM
Heat Detector	D191	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:14 PM
Heat Detector	D190	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:16 PM
Heat Detector	D189	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:18 PM
Heat Detector	D188	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:20 PM
Heat Detector	D187	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:21 PM
Heat Detector	D186	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:23 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector	D185	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:25 PM
Heat Detector	D184	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:26 PM
Heat Detector	D183	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:28 PM
Heat Detector	D182	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:29 PM
Heat Detector	D181	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:30 PM
Heat Detector	D180	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:32 PM
Heat Detector	D179	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:34 PM
Heat Detector	D178	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:36 PM
Heat Detector	D177	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:37 PM
Heat Detector	D176	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:39 PM
Heat Detector	D175	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:40 PM
Heat Detector	D174	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:41 PM
Heat Detector	D173	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:43 PM
Heat Detector	D172	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:45 PM
Heat Detector	D171	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:47 PM
Heat Detector	D170	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:48 PM
Heat Detector	D169	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:49 PM
Heat Detector	D168	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:51 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector	D167	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:52 PM
Heat Detector	D166	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:54 PM
Heat Detector	D165	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:57 PM
Heat Detector	D164	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:15:59 PM
Heat Detector	D163	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:16:00 PM
Heat Detector	D162	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:16:02 PM
Heat Detector	D161	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:16:03 PM
Heat Detector	D160	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:16:05 PM
Heat Detector	D159	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:16:07 PM
Heat Detector	D158	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:16:13 PM
Heat Detector	D157	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:16:15 PM
Heat Detector	D156	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:16:16 PM
Heat Detector	D155	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:16:19 PM
Heat Detector	D154	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:16:24 PM
Heat Detector	D153	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:16:26 PM
Heat Detector	D152	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:16:27 PM
Heat Detector	D151	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:16:29 PM
Heat Detector	D150	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:16:30 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Heat Detector	D149	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:16:31 PM
Heat Detector	D148	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:16:33 PM
Heat Detector	D147	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:16:35 PM
Heat Detector	D146	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:16:37 PM
Heat Detector	D145	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:16:38 PM
Heat Detector	D144	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:16:40 PM
Heat Detector	D143	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:16:43 PM
Heat Detector	D142	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:16:53 PM
Heat Detector	D141	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:16:56 PM
Duct Detector	D140	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:16:59 PM
Duct Detector	D139	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:17:00 PM
Smoke Detector	D138	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:17:04 PM
Smoke Detector	D137	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:17:05 PM
Smoke Detector	D136	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:17:07 PM
Smoke Detector	D135	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:17:09 PM
Smoke Detector	D134	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:17:11 PM
Smoke Detector	D133	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:17:13 PM
Smoke Detector	D132	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:17:14 PM

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Smoke Detector	D131	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:17:16 PM
Smoke Detector	D130	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:17:18 PM
Smoke Detector	D129	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:17:22 PM
Smoke Detector	D128	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:17:23 PM
Smoke Detector	D127	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:17:25 PM
Smoke Detector	D126	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:17:28 PM
Smoke Detector	D125	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:17:30 PM
Smoke Detector	D124	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:17:32 PM
Smoke Detector	D123	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:17:34 PM
Smoke Detector	D122	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:17:36 PM
Smoke Detector	D121	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:17:40 PM
Smoke Detector	D120	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:17:43 PM
Smoke Detector	D119	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:17:45 PM
Pull Station	D118	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:17:48 PM
Pull Station	D117	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:17:50 PM
Pull Station	D116	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:17:53 PM
Pull Station	D102	Visual Inspection Functional Inspection	Manual Passed (Manual) Passed	7/21/2023 3:17:58 PM

Power Supplies

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Battery - Nickel-cadmium	Z102		Manual	7/21/2023 3:18:13 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Amp Hours	14	
		Battery Location	FACP	
		Nominal Voltage	12	
Primary Power	Z103		Manual	7/21/2023 3:18:45 PM
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Disconnect Location	EP	
		Nominal Amps	0.5	
		Nominal Voltage	120	
		Over Current Amps	20	
		Over Current Type	Breaker	

Supervising Station Transmitting Equipment

EQUIPMENT TYPE	ADDRESS	DESCRIPTION	METHOD	DATE/TIME
Radio Alarm Transmitter	Z105		Manual	7/21/2023 3:17:42 PM
		Manufacturer	Aes	
		Model	7787f	
		Visual Inspection	Passed (Manual)	
		Functional Inspection	Passed	
		Monitoring Account Number	3912886	
		Monitoring Organization	Rapid Response	
		Monitoring Organization Phone	18009323822	
		Monitoring Retransmission Entity	Fairfield Fire Bureau	

SYSTEM RECORD OF INSPECTION AND TESTING



Inspection/Test Start Date/Time: 7/26/22 Inspection/Test Completion Date/Time: 9/26/22

Supplemental Form(s) Attached: _____ (yes/no)

1. PROPERTY INFORMATION

Name of property: Windsor Churchill School

Address: 233 Fairfield Rd Fairfield

Description of property: School

Name of property representative: _____

Address: _____

Phone: _____ Fax: _____ E-mail: _____

2. TESTING AND MONITORING INFORMATION

Testing organization: A.C. DAUGHTRY INC.

Address: 381 MAIN ROAD, MONTVILLE, NJ 07045

Phone: (973) 335-3931 Fax: (973) 331-5503 E-mail: _____

Monitoring organization: RAPID RESPONSE MONITORING

Address: 400 W. DIVISION STREET, SYRACUSE, NY 13204

Phone: (800) 932-3822 Fax: (315) 479-9573 E-mail: _____

Account number: 391-2896 Phone line 1: _____ Phone line 2: _____

Means of transmission: RF ACS RADIO

Entity to which alarms are retransmitted: C.S. Phone: _____

3. DOCUMENTATION

Onsite location of the required record documents and site-specific software: _____

4. DESCRIPTION OF SYSTEM OR SERVICE

4.1 Control Unit

Manufacturer: Notifier Model number: APP-400

4.2 Software Firmware

Firmware revision number: _____

4.3 System Power

4.3.1 Primary (Main) Power

Nominal voltage: 120 Amps: .5 Location: Behind SMBOF

Overcurrent protection type: Breaker Amps: 20 Disconnecting means location: EPD

SYSTEM RECORD OF INSPECTION AND TESTING (continued)

4. DESCRIPTION OF SYSTEM OR SERVICE (continued)

4.3.2 Secondary Power

Type: Backup Location: ETAP

Battery type (if applicable): VAL

Calculated capacity of batteries to drive the system:

In standby mode (hours): 14/11/11 In alarm mode (minutes):

5. NOTIFICATIONS MADE PRIOR TO TESTING

Monitoring Organization Contact: RAPID RESPONSE Time: 9:45

Building management Contact: MJ Time:

Building occupants Contact: SEMP Time:

Authority having jurisdiction Contact: FB Time:

Other, if required Contact: Time:

6. TESTING RESULTS

6.1 Control Unit and Related Equipment

Description	Visual Inspection	Functional Test	Comments
Control Unit	☒	☒	
Laps/LEDs/LCDs	☒	☒	
Fuses	☒	☒	
Trouble signals	☒	☒	
Disconnect switches	☒	☒	
Ground-fault monitoring	☒	☒	
Supervision	☒	☒	
Local annunciator	☒	☒	
Remote annunciators	☒	☒	
Remote power panels	☒	☒	

6.2 Secondary Power

Description	Visual Inspection	Functional Test	Comments
Battery condition	☒	☒	
Load voltage	☒	☒	
Discharge test	☒	☒	
Charger test	☒	☒	
Remote panel batteries	☒	☒	

SYSTEM RECORD OF INSPECTION AND TESTING (continued)

6. TESTING RESULTS (continued)

6.3 Alarm and Supervisory Alarm Initiating Device Summary

Quantity	Circuit Style	Visual	Functional	Pass	Fail
18	Manual Fire Alarm Boxes	☐	☐	☐	☐
	Ion Detectors	☐	☐	☐	☐
20	Photo Detectors	☐	☐	☐	☐
3	Duct Detectors	☐	☐	☐	☐
64	Heat Detectors	☐	☐	☐	☐
	Waterflow Switches	☐	☐	☐	☐
	Supervisory Switches	☐	☐	☐	☐
2	Other (Specify): <u>Photo Det</u>	☐	☐	☐	☐

Alarm verification feature is disabled 1 enabled

6.4 Notification Appliances

Quantity	Circuit Style	
25		Bells
		Horns/Strobes
		Chimes
		Strobes
		Speakers
		Other (Specify):

No. of alarm notification appliance circuits: 10

Are circuits monitored for integrity? ☒ Yes ☐ No

During testing of the system, each zone containing initiating devices exhibited no unexpected change or variation in restoration of loop. All zones were trouble free upon arrival and after the completion of all testing.

During testing of the system, inspected and tested all visible and accessible initiating and notification devices. We may not have been the fire alarm system designer and were not provided any as built drawings.


6.5 Interface Equipment

Attach supplementary interface component test sheets for all interface components.

6.6 Supervising Station Monitoring

Description	Yes	No	Time	Comments
Alarm signal	☒	☐		
Alarm restoration	☒	☐		
Trouble signal	☒	☐		
Trouble restoration	☒	☐		
Supervisory signal	☐	☐		
Supervisory restoration	☐	☐		

6.7 Public Emergency Alarm Reporting System

Description	Yes	No	Time	Comments
Alarm signal	☐	☐		
Alarm restoration	☐	☐		
Trouble signal	☐	☐		
Trouble restoration	☐	☐		
Supervisory signal	☐	☐		
Supervisory restoration	☐	☐		

SYSTEM RECORD OF INSPECTION AND TESTING (continued)

7. NOTIFICATIONS THAT TESTING IS COMPLETE

Monitoring Organization	Contact: <u>RAPID RESPONSE</u>	Time: <u>9:30</u>
Building management	Contact: <u>My</u>	Time: <u>↓</u>
Building occupants	Contact: <u>5028</u>	Time: <u>↓</u>
Authority having jurisdiction	Contact: <u>PR</u>	Time: <u>↓</u>
Other, if required	Contact: _____	Time: _____

8. SYSTEM RETURNED TO NORMAL OPERATION

Date: 9/26/22 Time: 9:35

9. CERTIFICATION

This system as specified herein has been inspected and tested according to NFPA 72, 2013 edition, Chapter 14.

Signed: [Signature] Printed Name: AS RS Date: 9/26/22

Organization: A.C. DAUGHTRY INC. Title: INSPECTOR Phone: (973) 335-3931

Qualifications (refer to 10.5.3): _____

10. DEFECTS OR MALFUNCTIONS NOT CORRECTED AT CONCLUSION OF SYSTEM INSPECTION, TESTING, OR MAINTENANCE

10.1 Acceptance by Owner or Owner's Representative:

The undersigned accepted the test report for the system as specified herein:

Signed: _____ Printed Name: _____ Date: _____

Organization: _____ Title: _____ Phone: _____

11. RECOMMENDATIONS AT CONCLUSION OF SYSTEM INSPECTION, TESTING, OR MAINTENANCE

☐ During testing of the system, found that heat detectors are older than 15 years and recommend that they be replaced.

☐ During testing of the system, found that the path of communication is via phone lines and recommend going to a wireless radio communicator.

SYSTEM RECORD OF INSPECTION AND TESTING



Inspection/Test Start Date/Time: 8/9/11 Inspection/Test Completion Date/Time: 8/9/11

Supplemental Form(s) Attached: _____ (yes/no) no

1. PROPERTY INFORMATION

Name of property: Windsor Churchill School

Address: 233 Fairfield Rd, Fairlee VT

Description of property: School

Name of property representative: _____

Address: _____

Phone: _____ Fax: _____ E-mail: _____

2. TESTING AND MONITORING INFORMATION

Testing organization: A.C. DAUGHTRY INC.

Address: 381 MAIN ROAD, MONTVILLE, NJ 07045

Phone: (973) 335-3931 Fax: (973) 331-5503 E-mail: _____

Monitoring organization: RAPID RESPONSE MONITORING

Address: 400 W. DIVISION STREET, SYRACUSE, NY 13204

Phone: (800) 932-3822 Fax: (315) 479-9573 E-mail: _____

Account number: 391-2886 Phone line 1: _____ Phone line 2: _____

Means of transmission: RF - AES RADIO

Entity to which alarms are retransmitted: CS Phone: _____

3. DOCUMENTATION

Onsite location of the required record documents and site-specific software: _____

4. DESCRIPTION OF SYSTEM OR SERVICE

4.1 Control Unit

Manufacturer: Notifier Model number: APP-400

4.2 Software Firmware

Firmware revision number: _____

4.3 System Power

4.3.1 Primary (Main) Power

Nominal voltage: 120 Amps: 20 Location: Behind storage

Overcurrent protection type: Breaker Amps: 20 Disconnecting means location: EP

SYSTEM RECORD OF INSPECTION AND TESTING (continued)

4. DESCRIPTION OF SYSTEM OR SERVICE (continued)

4.3.2 Secondary Power

Type: Batteries Location: FAC

Battery type (if applicable): Sealed Lead Acid

Calculated capacity of batteries to drive the system:

In standby mode (hours): 14.4 H In alarm mode (minutes): _____

5. NOTIFICATIONS MADE PRIOR TO TESTING

Monitoring Organization

Contact: RAPID RESPONSE Time: 9:15

Building management

Contact: MSG Time: _____

Building occupants

Contact: SCOFF Time: _____

Authority having jurisdiction

Contact: FB Time: _____

Other, if required

Contact: _____ Time: ✓

6. TESTING RESULTS

6.1 Control Unit and Related Equipment

Description	Visual Inspection	Functional Test	Comments
Control Unit	☒	☒	
Laps/LEDs/LCDs	☒	☒	
Fuses	☐	☐	
Trouble signals	☒	☒	
Disconnect switches	☐	☐	
Ground-fault monitoring	☒	☒	
Supervision	☐	☐	
Local annunciator	☒	☒	
Remote annunciators	☐	☐	
Remote power panels	☐	☐	

6.2 Secondary Power

Description	Visual Inspection	Functional Test	Comments
Battery condition	☒	☒	
Load voltage	☒	☒	
Discharge test	☐	☐	
Charger test	☐	☐	
Remote panel batteries	☐	☐	

SYSTEM RECORD OF INSPECTION AND TESTING (continued)

6. TESTING RESULTS (continued)

6.3 Alarm and Supervisory Alarm Initiating Device Summary

Quantity	Circuit Style		Visual	Functional	Pass	Fail
13		Manual Fire Alarm Boxes	☒	☒	☒	☐
		Ion Detectors	☐	☐	☐	☐
20		Photo Detectors	☒	☒	☒	☐
		Duct Detectors	☒	☐	☒	☐
64		Heat Detectors	☒	☐	☒	☐
		Waterflow Switches	☐	☐	☐	☐
		Supervisory Switches	☐	☐	☐	☐
2		Other (Specify): <u>BEAM Det</u>	☒	☐	☒	☐

Alarm verification feature is disabled ☒ enabled ☐

Attach supplementary device test sheets for all initiating devices.

6.4 Notification Appliances

Quantity	Circuit Style	
25		Bells
		Horns/Strobes
		Chimes
		Strobes
		Speakers
		Other (Specify): _____

No. of alarm notification appliance circuits: 10

Are circuits monitored for integrity? ☒ Yes ☐ No

Attach supplementary appliance test sheets for all notification appliances.

6.5 Interface Equipment

Attach supplementary interface component test sheets for all interface components.

6.6 Supervising Station Monitoring

Description	Yes	No	Time	Comments
Alarm signal	☒	☐		
Alarm restoration	☒	☐		
Trouble signal	☒	☐		
Trouble restoration	☒	☐		
Supervisory signal	☐	☐		
Supervisory restoration	☐	☐		

6.7 Public Emergency Alarm Reporting System

Description	Yes	No	Time	Comments
Alarm signal	☐	☐		
Alarm restoration	☐	☐		
Trouble signal	☐	☐		
Trouble restoration	☐	☐		
Supervisory signal	☐	☐		
Supervisory restoration	☐	☐		

SYSTEM RECORD OF INSPECTION AND TESTING



Inspection/Test Start Date/Time: 6-22-20 Inspection/Test Completion Date/Time: 6-22-20

Supplemental Form(s) Attached: _____ (yes/no)

1. PROPERTY INFORMATION

Name of property: Winston Churchill School
Address: 233 Fairfield Rd. Fairfield
Description of property: School
Name of property representative: John
Address: _____
Phone: _____ Fax: _____ E-mail: _____

2. TESTING AND MONITORING INFORMATION

Testing organization: A.C. DAUGHTRY INC.
Address: 381 MAIN ROAD, MONTVILLE, NJ 07045
Phone: (973) 335-3931 Fax: (973) 331-5503 E-mail: _____
Monitoring organization: RAPID RESPONSE MONITORING
Address: 400 W. DIVISION STREET, SYRACUSE, NY 13204
Phone: (800) 932-3822 Fax: (315) 479-9573 E-mail: _____
Account number: 3912886 Phone line 1: _____ Phone line 2: _____
Means of transmission: RF - AES
Entity to which alarms are retransmitted: Control Station Phone: _____

3. DOCUMENTATION

Onsite location of the required record documents and site-specific software: _____

4. DESCRIPTION OF SYSTEM OR SERVICE

4.1 Control Unit

Manufacturer: Notifier Model number: AFP-400

4.2 Software Firmware

Firmware revision number: _____

4.3 System Power

4.3.1 Primary (Main) Power

Nominal voltage: 120 Amps: 5 Location: Behind stage
Overcurrent protection type: _____ Amps: _____ Disconnecting means location: _____

SYSTEM RECORD OF INSPECTION AND TESTING (continued)

4. DESCRIPTION OF SYSTEM OR SERVICE (continued)

4.3.2 Secondary Power

Type: Batteries Location: FACT

Battery type (if applicable): Seal lead acid

Calculated capacity of batteries to drive the system:

In standby mode (hours): 14AH In alarm mode (minutes): _____

5. NOTIFICATIONS MADE PRIOR TO TESTING

Monitoring Organization

Contact: RAPID RESPONSE Time: 10:00

Building management

Contact: John Time: _____

Building occupants

Contact: Jane Time: _____

Authority having jurisdiction

Contact: J. J. Buser Time: _____

Other, if required

Contact: _____ Time: _____

6. TESTING RESULTS

6.1 Control Unit and Related Equipment

Description	Visual Inspection	Functional Test	Comments
Control Unit	☒	☒	
Laps/LEDs/LCDs	☒	☒	
Fuses	☐	☐	
Trouble signals	☒	☒	
Disconnect switches	☐	☐	
Ground-fault monitoring	☒	☒	
Supervision	☐	☐	
Local annunciator	☒	☒	
Remote annunciators	☐	☐	
Remote power panels	☐	☐	

6.2 Secondary Power

Description	Visual Inspection	Functional Test	Comments
Battery condition	☒	☒	
Load voltage	☐	☒	
Discharge test	☐	☐	
Charger test	☐	☐	
Remote panel batteries	☐	☐	

SYSTEM RECORD OF INSPECTION AND TESTING (continued)

6. TESTING RESULTS (continued)

6.3 Alarm and Supervisory Alarm Initiating Device Summary

Quantity	Circuit Style		Visual	Functional	Pass	Fail
<u>18</u>		Manual Fire Alarm Boxes	☒	☒	☒	☐
		Ion Detectors	☐	☐	☐	☐
<u>20</u>		Photo Detectors	☒	☒	☒	☐
<u>2</u>		Duct Detectors	☒	☐	☒	☐
<u>69</u>		Heat Detectors	☒	☐	☒	☐
		Waterflow Switches	☐	☐	☐	☐
		Supervisory Switches	☐	☐	☐	☐
<u>2</u>		Other (Specify): <u>Beam D</u>	☒	☐	☒	☐

Alarm verification feature is disabled ☒ enabled ☐

Attach supplementary device test sheets for all initiating devices.

6.4 Notification Appliances

Quantity	Circuit Style	
<u>25</u>		Bells
		Horns/Strobes
		Chimes
		Strobes
		Speakers
		Other (Specify): _____

No. of alarm notification appliance circuits: 10

Are circuits monitored for integrity? ☒ Yes ☐ No

Attach supplementary appliance test sheets for all notification appliances.

6.5 Interface Equipment

Attach supplementary interface component test sheets for all interface components.

6.6 Supervising Station Monitoring

Description	Yes	No	Time	Comments
Alarm signal	☒	☐		
Alarm restoration	☒	☐		
Trouble signal	☒	☐		
Trouble restoration	☒	☐		
Supervisory signal	☐	☐		
Supervisory restoration	☐	☐		

6.7 Public Emergency Alarm Reporting System

Description	Yes	No	Time	Comments
Alarm signal	☐	☐		
Alarm restoration	☐	☐		
Trouble signal	☐	☐		
Trouble restoration	☐	☐		
Supervisory signal	☐	☐		
Supervisory restoration	☐	☐		

SYSTEM RECORD OF INSPECTION AND TESTING (continued)

7. NOTIFICATIONS THAT TESTING IS COMPLETE

Monitoring Organization

Contact: **RAPID RESPONSE**

Time: 1.00

Building management

Contact: John

Time: 1

Building occupants

Contact: 1 NAME

Time: 1

Authority having jurisdiction

Contact: 1240/244

Time:

Other, if required

Contact: _____ Time: _____

8. SYSTEM RETURNED TO NORMAL OPERATION

Date: 6-22-20 Time: 11:00

9. CERTIFICATION

This system as specified herein has been inspected and tested according to NFPA 72, 2013 edition, Chapter 14.

Signed: [Signature] Printed Name: M. J. [Signature] Date: 6-22-20

Organization: A.C. DAUGHTRY INC. Title: INSPECTOR Phone: (973) 335-3931

Qualifications (refer to 10.5.3): _____

10. DEFECTS OR MALFUNCTIONS NOT CORRECTED AT CONCLUSION OF SYSTEM INSPECTION, TESTING, OR MAINTENANCE

μ_{eff}^2

10.1 Acceptance by Owner or Owner's Representative:

The undersigned accepted the test report for the system as specified herein:

Signed: _____ Printed Name: _____ Date: _____

Organization: _____ Title: _____ Phone: _____

SYSTEM RECORD OF INSPECTION AND TESTING



Inspection/Test Start Date/Time: 8-27-19 Inspection/Test Completion Date/Time: 8-27-19

Supplemental Form(s) Attached: _____ (yes/no)

1. PROPERTY INFORMATION

Name of property: Winston Churchill

Address: 233 Jayfield Rd Jayfield

Description of property: School

Name of property representative: _____

Address: _____

Phone: _____ Fax: _____ E-mail: _____

2. TESTING AND MONITORING INFORMATION

Testing organization: A.C. DAUGHTRY INC.

Address: 381 MAIN ROAD, MONTVILLE, NJ 07045

Phone: (973) 335-3931 Fax: (973) 331-5503 E-mail: _____

Monitoring organization: RAPID RESPONSE MONITORING

Address: 400 W. DIVISION STREET, SYRACUSE, NY 13204

Phone: (800) 932-3822 Fax: (315) 479-9573 E-mail: _____

Account number: 21221026 Phone line 1: _____ Phone line 2: _____

Means of transmission: Phone

Entity to which alarms are retransmitted: Control Station Phone: _____

3. DOCUMENTATION

Onsite location of the required record documents and site-specific software: _____

4. DESCRIPTION OF SYSTEM OR SERVICE

4.1 Control Unit

Manufacturer: 10 lifer Model number: AID-400

4.2 Software Firmware

Firmware revision number: _____

4.3 System Power

4.3.1 Primary (Main) Power

Nominal voltage: 120 Amps: 5 Location: Behind stage

Overcurrent protection type: Breaker Amps: 20 Disconnecting means location: E9

SYSTEM RECORD OF INSPECTION AND TESTING (continued)

4. DESCRIPTION OF SYSTEM OR SERVICE (continued)

4.3.2 Secondary Power

Type: Batteries Location: JACP

Battery type (if applicable): Sealed lead acid

Calculated capacity of batteries to drive the system:

In standby mode (hours): 14.14 In alarm mode (minutes): _____

5. NOTIFICATIONS MADE PRIOR TO TESTING

Monitoring Organization Contact: RAPID RESPONSE Time: 1:45

Building management Contact: _____ Time: _____

Building occupants Contact: Staff Time: _____

Authority having jurisdiction Contact: D. The Bureau Time: _____

Other, if required Contact: _____ Time: _____

6. TESTING RESULTS

6.1 Control Unit and Related Equipment

Description	Visual Inspection	Functional Test	Comments
Control Unit	☒	☒	
Laps/LEDs/LCDs	☒	☒	
Fuses	☒	☒	
Trouble signals	☒	☒	
Disconnect switches	☒	☒	
Ground-fault monitoring	☒	☒	
Supervision	☒	☒	
Local annunciator	☒	☒	
Remote annunciators	☒	☒	
Remote power panels	☒	☒	

6.2 Secondary Power

Description	Visual Inspection	Functional Test	Comments
Battery condition	☒	☒	
Load voltage	☒	☒	
Discharge test	☒	☒	
Charger test	☒	☒	
Remote panel batteries	☒	☒	

SYSTEM RECORD OF INSPECTION AND TESTING *(continued)*

6. TESTING RESULTS *(continued)*

6.3 Alarm and Supervisory Alarm Initiating Device Summary

Quantity	Circuit Style		Visual	Functional	Pass	Fail
<u>18</u>		Manual Fire Alarm Boxes	☒	☒	☒	☐
<u>20</u>		Ion Detectors	☐	☐	☒	☐
<u>2</u>		Photo Detectors	☒	☒	☒	☐
<u>69</u>		Duct Detectors	☒	☐	☒	☐
		Heat Detectors	☒	☐	☒	☐
		Waterflow Switches	☐	☐	☐	☐
<u>2</u>		Supervisory Switches	☐	☐	☐	☐
		Other (Specify): <u>Alarm D</u>	☒	☐	☒	☐

Alarm verification feature is disabled ☒ enabled ☐

Attach supplementary device test sheets for all initiating devices.

6.4 Notification Appliances

Quantity	Circuit Style	
<u>25</u>		Bells
		Horns/Strobes
		Chimes
		Strobes
		Speakers
		Other (Specify): _____

No. of alarm notification appliance circuits: 10

Are circuits monitored for integrity? ☒ Yes ☐ No

Attach supplementary appliance test sheets for all notification appliances.

6.5 Interface Equipment

Attach supplementary interface component test sheets for all interface components.

6.6 Supervising Station Monitoring

Description	Yes	No	Time	Comments
Alarm signal	☒	☐		
Alarm restoration	☒	☐		
Trouble signal	☒	☐		
Trouble restoration	☒	☐		
Supervisory signal	☐	☐		
Supervisory restoration	☐	☐		

6.7 Public Emergency Alarm Reporting System

Description	Yes	No	Time	Comments
Alarm signal	☐	☐		
Alarm restoration	☐	☐		
Trouble signal	☐	☐		
Trouble restoration	☐	☐		
Supervisory signal	☐	☐		
Supervisory restoration	☐	☐		

SYSTEM RECORD OF INSPECTION AND TESTING (continued)

7. NOTIFICATIONS THAT TESTING IS COMPLETE

Monitoring Organization Contact: RAPID RESPONSE Time: 3:00
Building management Contact: _____ Time: _____
Building occupants Contact: Staff Time: ✓
Authority having jurisdiction Contact: John Brown Time: _____
Other, if required Contact: _____ Time: _____

8. SYSTEM RETURNED TO NORMAL OPERATION

Date: 8-27-19 Time: 3:00

9. CERTIFICATION

This system as specified herein has been inspected and tested according to NFPA 72, 2013 edition, Chapter 14.

Signed: [Signature] Printed Name: AG 11/14 Date: 8-27-19
Organization: A.C. DAUGHTRY INC. Title: INSPECTOR Phone: (973) 335-3931

Qualifications (refer to 10.5.3): _____

10. DEFECTS OR MALFUNCTIONS NOT CORRECTED AT CONCLUSION OF SYSTEM INSPECTION, TESTING, OR MAINTENANCE

10.1 Acceptance by Owner or Owner's Representative:

The undersigned accepted the test report for the system as specified herein:

Signed: _____ Printed Name: _____ Date: _____
Organization: _____ Title: _____ Phone: _____

METRO FIRE & SAFETY EQUIPMENT CO., INC.

509 Washington Avenue
 Carlstadt, NJ 07072
 Phone: (201) 635-0400 - Fax: (201) 635-0410

Invoice #: SM 18222

Invoice Date: 7/16/2019

Completion Date: 7/11/2019

Bill To: Fairfield Board of Education
 15 Knoll Road
 Fairfield, NJ 07004

Service Id: FAIRFIELDBOE-STEVEN
Service At: Adlai E. Stevenson School
 15 Knoll Road
 Fairfield, NJ 07004

Division: Extinguishers - Service/Repair
Description: E-Extinguisher Inspection Needed

PO Number:
Alt #:

Terms: 10 Days
Due Date: 7/26/2019

WO#	Item	Description	Qty	Unit Price	Amount
<u>23918</u>	Service	E - Fire Extinguisher Inspection	24.00	6.50	156.00

The Fire Safety Professionals Since 1962

Subtotal:	156.00
Sales Tax:	0.00
Total Due:	156.00

Please return this part with a check or money order made payable to Metro Fire & Safety.

Credit Card Information

METRO FIRE & SAFETY EQUIPMENT CO., INC.

509 Washington Avenue
 Carlstadt, NJ 07072
 Phone: (201) 635-0400 - Fax: (201) 635-0410

Card Number: _____

Expiration: ____ / ____

CVV: ____

mm

yy



☐

☐

☐

☐

E-mail: _____

(If Receipt Is Required/Requested)

Account ID	FAIBOA	Amount Due	\$ 156.00
Invoice	18222	Amount Paid	

METRO FIRE & SAFETY EQUIPMENT CO., INC.

509 Washington Avenue
 Carlstadt, NJ 07072
 Phone: (201) 635-0400 - Fax: (201) 635-0410

Invoice #: SM 20250

Invoice Date: 9/23/2019

Completion Date: 9/20/2019

Bill To: Fairfield Board of Education
 15 Knoll Road
 Fairfield, NJ 07004

Service Id: FAIRFIELDBOE-STEVEN
Service At: Adlai E. Stevenson School
 15 Knoll Road
 Fairfield, NJ 07004

Division: Extinguishers - Service/Repair
Description: E-Extinguisher New Needed

PO Number:
Alt #:

Terms: 10 Days
Due Date: 10/3/2019

WO#	Item	Description	Qty	Unit Price	Amount
26885					
	Service				
		E - Service Call	1.00	45.00	45.00
	Parts				
		01703 FE 331 New 15# Carbon Dioxide	2.00	405.00	810.00
		15271 FE B386T New 5# Halotron	1.00	274.50	274.50

The Fire Safety Professionals Since 1962

Subtotal:	1,129.50
Sales Tax:	0.00
Total Due:	1,129.50

Please return this part with a check or money order made payable to Metro Fire & Safety.

Credit Card Information



509 Washington Avenue
 Carlstadt, NJ 07072
 Phone: (201) 635-0400 - Fax: (201) 635-0410

Card Number: _____

Expiration: ____ / ____

CVV: ____

mm

yy



☐

☐

☐

☐

E-mail: _____

(If Receipt Is Required/Requested)

Account ID	FAIBOA	Amount Due	\$ 1,129.50
Invoice	20250	Amount Paid	

MF METRO FIRE & SAFETY

EQUIPMENT CO., INC.

509 Washington Avenue
Carlstadt, NJ 07072
Phone: (201) 635-0400 - Fax: (201) 635-0410

Invoice #: SM 27432

Invoice Date: 6/29/2020

Completion Date: 6/24/2020

Bill To: Fairfield Board of Education
15 Knoll Road
Fairfield, NJ 07004

Service Id: FAIRFIELDBOE-STEVEN
Service At: Adlai E. Stevenson School
15 Knoll Road
Fairfield, NJ 07004

Division: Extinguishers - Service/Repair
Description: E-Extinguisher Inspection Needed

PO Number:
Alt #:

Terms: 10 Days
Due Date: 7/9/2020

WO#	Item	Description	Qty	Unit Price	Amount
35941					
	Service				
		E - Fire Extinguisher Inspection	20.00	6.50	130.00
		E - 10# ABC Dry Chem 6 Year Tear Down	1.00	42.25	42.25
		E - Valve Stem	1.00	11.50	11.50
		E - O-Ring	1.00	3.95	3.95
		E - VOS Collar	1.00	2.25	2.25
		E - UN 1044 Compliance Label	1.00	1.60	1.60
		E - Hazmat Transportation	1.00	15.00	15.00

The Fire Safety Professionals Since 1962

Subtotal:	206.55
Sales Tax:	0.00
Total Due:	206.55

Please return this part with a check or money order made payable to Metro Fire & Safety.

Credit Card Information



509 Washington Avenue
Carlstadt, NJ 07072
Phone: (201) 635-0400 - Fax: (201) 635-0410

Card Number: _____

Expiration: ____ / ____

mm yy

CVV: ____



E-mail: _____

(If Receipt is Required/Requested)

Account ID	FAIBOA	Amount Due	\$ 206.55
Invoice	27432	Amount Paid	

METRO FIRE & SAFETY EQUIPMENT CO., INC.

509 Washington Avenue
 Carlstadt, NJ 07072
 Phone: (201) 635-0400 - Fax: (201) 635-0410

Invoice #: SM 37914

Invoice Date: 7/8/2021

Completion Date: 7/7/2021

Bill To: Fairfield Board of Education
 15 Knoll Road
 Fairfield, NJ 07004

Service Id: FAIRFIELDBOE-STEVEN
Service At: Adial E. Stevenson School
 15 Knoll Road
 Fairfield, NJ 07004

Division: Extinguishers - Service/Repair
Description: E-Extingulsher Inspection Needed

PO Number:
Alt #:

Terms: 10 Days
Due Date: 7/18/2021

WO#	Item	Description	Qty	Unit Price	Amount
48491					
	Service				
		E - 5# BC Dry Chem 6 Year Tear Down	1.00	31.25	31.25
		E - 5# ABC Dry Chem Hydro/Recharge	1.00	41.50	41.50
		E - 10# ABC Dry Chem Hydro/Recharge	5.00	52.50	262.50
		E - Fire Extingulsher Inspection	22.00	6.50	143.00
		E - O-Ring	7.00	3.95	27.65
		E - VOS Collar	7.00	2.25	15.75
		E - UN 1044 Compliance Label	4.00	1.60	6.40
		E - Valve Stem	3.00	11.50	34.50
		E - CO2 Continunity Test	4.00	2.25	9.00
		E - Hazmat Transportation	1.00	15.00	15.00

The Fire Safety Professionals Since 1962

Subtotal:	586.55
Sales Tax:	0.00
Total Due:	586.55

Please return this part with a check or money order made payable to Metro Fire & Safety.

Credit Card Information



509 Washington Avenue
 Carlstadt, NJ 07072
 Phone: (201) 635-0400 - Fax: (201) 635-0410

Card Number: _____

Expiration: ____ / ____ CVV: ____
 mm yy



E-mail: _____

(If Receipt Is Required/Requested)

Account ID	FAIBOA	Amount Due	\$ 586.55
Invoice	37914	Amount Paid	

METRO FIRE & SAFETY EQUIPMENT CO., INC.

509 Washington Avenue
 Carlstadt, NJ 07072
 Phone: (201) 635-0400 - Fax: (201) 635-0410

Invoice #: SM 48392

Invoice Date: 7/7/2022

Completion Date: 7/6/2022

Bill To: Fairfield Board of Education
 15 Knoll Road
 Fairfield, NJ 07004

Service Id: FAIRFIELDBOE-STEVEN
Service At: Adlai E. Stevenson School
 15 Knoll Road
 Fairfield, NJ 07004

Division: Extinguishers - Service/Repair
Description: E-Extinguisher Inspection Needed

PO Number:
Alt #:

Terms: 10 Days
Due Date: 7/17/2022

WO#	Item	Description	Qty	Unit Price	Amount
61105					
	Service				
	E -	Fire Extinguisher Inspection	17.00	6.50	110.50
	E -	15# CO2 Hydro/Recharge	1.00	67.50	67.50
	E -	11# Halotron 6 Year Tear Down	1.00	101.00	101.00
	E -	5# ABC Dry Chem Hydro/Recharge	1.00	45.50	45.50
	E -	10# ABC Dry Chem Hydro/Recharge	7.00	57.75	404.25
	E -	Valve Rebuilt	1.00	25.00	25.00
	E -	O-Ring	9.00	4.00	36.00
	E -	UN 1013 Compliance Label	1.00	2.00	2.00
	E -	VOS Collar	10.00	2.25	22.50
	E -	CO2 Continuity Test	1.00	2.25	2.25
	E -	Hazmat Transportation	1.00	15.00	15.00
	E -	Fuel Surcharge	1.00	10.00	10.00

The Fire Safety Professionals Since 1962

Subtotal:	841.50
Sales Tax:	0.00
Total Due:	841.50

Please return this part with a check or money order made payable to Metro Fire & Safety.

Credit Card Information



509 Washington Avenue
 Carlstadt, NJ 07072
 Phone: (201) 635-0400 - Fax: (201) 635-0410

Card Number: _____

Expiration: ____ / ____

CVV: ____



mm

yy

☐

☐

☐

☐

E-mail: _____

(If Receipt Is Required/Requested)

Account ID	FAIBOA	Amount Due	\$ 841.50
Invoice	48392	Amount Paid	

METRO FIRE & SAFETY EQUIPMENT CO., INC.

509 Washington Avenue
 Carlstadt, NJ 07072
 Phone: (201) 635-0400 - Fax: (201) 635-0410

Invoice #: SM 59380

Invoice Date: 7/17/2023

Completion Date: 7/14/2023

Bill To: Fairfield Board of Education
 15 Knoll Road
 Fairfield, NJ 07004

Service Id: FAIRFIELDBOE-STEVEN
Service At: Adlai E. Stevenson School
 15 Knoll Road
 Fairfield, NJ 07004

Division: Extinguishers - Service/Repair
Description: E-Extinguisher Inspection Needed

PO Number:
Alt #:

Terms: 10 Days
Due Date: 7/27/2023

WO#	Item	Description	Qty	Unit Price	Amount
<u>73973</u>					
	Service				
		E - Fire Extinguisher Inspection	27.00	6.50	175.50
		E - Fuel Surcharge	1.00	5.00	5.00

The Fire Safety Professionals Since 1962

Subtotal:	180.50
Sales Tax:	0.00
Total Due:	180.50

Please return this part with a check or money order made payable to Metro Fire & Safety.

Credit Card Information



509 Washington Avenue
 Carlstadt, NJ 07072
 Phone: (201) 635-0400 - Fax: (201) 635-0410

Card Number: _____

Expiration: ____ / ____ CVV: ____
 mm yy



E-mail: _____

(If Receipt is Required/Requested)

Account ID	FAIBOA	Amount Due	\$ 180.50
Invoice	59380	Amount Paid	



INVOICE

Pye Barker Fire & Safety
 DBA: Metro Fire & Safety
 509 WASHINGTON AVE
 CARLSTADT, NJ 07072-2802
www.pyebarkerfs.com
 201-635-0400
 1233PZ@pyebarkerfs.com

Customer PO:	Order No:	Invoice No:	Due Date:
	ST00237211	IV00260111	09/28/2024
Invoice Date:	Terms:	Invoice Total:	Amount Due:
08/29/2024	Net 30	403.85	0.00

License: NJDFS#P00111

BILL TO:
 69025 - Fairfield Board Of Education
 15 Knoll Rd
 Fairfield, NJ 07004

WORKSITE:
 63185 - Adlai E. Stevenson School
 15 Knoll Rd
 Fairfield, NJ 07004

Authorized By:	Job Number:	Service Location:	Bill To ID:	Worksite ID:	Technician:
Joe	SER0000065043	Carlstadt, NJ	69025	63185	Dominick Ostuni
Item	Description	Qty	Unit Price	Total	Tax
SYABC10	10Lb ABC Six Year	1	6.25	6.25	0.00
HYCO215	15Lb CO2 Hydro	2	30.50	61.00	0.00
RCABC10	10Lb ABC Recharge	1	40.25	40.25	0.00
DRY_CHEM_EXT_PARTS	Dry Chem Extinguisher Parts	1	7.85	7.85	0.00
427875	Inspection Tags	24	6.50	156.00	0.00
TC	Trip Charge	1	100.00	100.00	0.00
FUEL	Fuel Surcharge	1	5.00	5.00	0.00
DF	DOT hazmat/transportation fee	1	15.00	15.00	0.00
0693-P096	Valve Stem	1	12.50	12.50	0.00
Work Notes:					
 Save time and stamps by going paperless. View, print, and pay your invoices online at https://customer.pyebarkerfire.com/					

Unless otherwise set forth in a signed agreement between the parties, you agree that the services subject to this Invoice are governed by the Pye-Barker General Terms and Conditions located at <https://pyebarkerfs.com/generalterms>, which shall be incorporated herein by reference.

Remit To Address:
Pye-Barker Fire & Safety, LLC
DBA: Metro Fire & Safety
PO BOX 735358
Dallas, TX 75373-5358

PAY NOW:

Use the token below to create your
account
MxBLvuKjfAA=
<https://customer.pyebarkerfire.com>

Reference: PBFS-PZ

Subtotal	403.85
Tax	0.00
Freight	0.00
Total	403.85



INVOICE

Pye Barker Fire & Safety
 DBA: Metro Fire & Safety
 509 WASHINGTON AVE
 CARLSTADT, NJ 07072-2802
www.pyebarkerfs.com
 201-635-0400
 1233PZ@pyebarkerfs.com

Customer PO:	Order No:	Invoice No:	Due Date:
	ST00610368	IV00653259	08/28/2025
Invoice Date:	Terms:	Invoice Total:	Amount Due:
07/29/2025	Net 30	371.50	0.00

License: NJDFS#P00111

BILL TO:
 69025 - Fairfield Board Of Education
 15 Knoll Rd
 Fairfield, NJ 07004

WORKSITE:
 63185 - Adlai E. Stevenson School
 15 Knoll Rd
 Fairfield, NJ 07004

Authorized By:	Job Number:	Service Location:	Bill To ID:	Worksite ID:	Technician:
Joe	CON0000049360	Carlstadt, NJ	69025	63185	Dominick Ostuni

Item	Description	Qty	Unit Price	Total	Tax
INSPTAG	Tag Insp	23	6.50	149.50	0.00
HYABC10	10Lb ABC Hydro	1	20.00	20.00	0.00
SYABC10	10Lb ABC Six Year	1	7.00	7.00	0.00
RCABC10	10Lb ABC Recharge	2	44.00	88.00	0.00
CLEAN_AGENT_EXT_P	Clean Agent Extinguisher Parts	2	36.00	72.00	0.00
ARTS					
DRY_CHEM_EXT_PART	Dry Chem Extinguisher Parts	2	9.00	18.00	0.00
S					
DF	DOT hazmat/transportation fee	1	17.00	17.00	0.00



Work Notes:
 Save time and stamps by going
 paperless. View, print, and pay your
 invoices online at
<https://customer.pyebarkerfire.com/>

Unless otherwise set forth in a signed agreement between the parties, you agree that the services subject to this invoice are governed by the Pye-Barker General Terms and Conditions located at <https://pyebarkerfs.com/generalterms>, which shall be incorporated herein by reference.

Remit To Address:
Pye-Barker Fire & Safety, LLC
DBA: Metro Fire & Safety
PO BOX 735358
Dallas, TX 75373-5358

PAY NOW:

Use the token below to create your
account
L11dl/xVEyU=
<https://customer.pyebarkerfire.com>

Reference: PBFS-PZ

Subtotal	371.50
Tax	0.00
Freight	0.00
Total	371.50



The Fire Safety Professionals Since 1962

NJ State Certified Contractor #: P00111

509 Washington Ave.
Carlstadt, NJ 07072
(201) 635-0400
Fax: (201) 635-0410

Fire Extinguisher Certificate of Inspection and Compliance

July 7, 2021

Property:
Winston S. Churchill School
233 Fairfield Road
Fairfield, NJ 07004

The portable fire extinguishers at the above referenced property were inspected, tested, and recharged, as needed, in accordance with NFPA 10 and state & local codes/ regulations. The inspection was completed July 7, 2021. The next regularly scheduled inspection will take place during the month of July 2022.

Sincerely,

John Pimentel
Metro Fire & Safety Equipment Co., Inc.



Pye-Barker Fire & Safety DBA: Metro Fire & Safety
509 WASHINGTON AVE
CARLSTADT NJ 07072-2802
2016350400
1233PZ@pyebarkerfs.com

Report Cover Page

SERVICE DATE: 7/16/2025

SERVICE TICKET: ST00610367

BUILDING	STREET	CITY	STATE	ZIP
Winston S. Churchill School	233 Fairfield Rd	Fairfield	NJ	07004
BUILDING CONTACT	PHONE			
Na	9732271340			

Please see the attached reports. If there are any questions, please reach out to the above office.

Download your Report at:

<https://customer.pyebarkerfire.com>

Signed 7/16/2025

Inspector: Dominick Ostuni

Licenses:
NJDFS#P00111

Customer Signature

Signature of Customer
ST00610367

Signed 7/16/2025

Building Contact: Na
Title:

Service Ticket No. : ST00610367



Date : 7/16/2025

Frequency : Annual

Service Ticket No. : ST00610367

Inspection Contract No. : 0000049359

PO No. :

Equipment Location :

Fire Extinguisher Summary Report

Property	: Winston S. Churchill School	Owner	: Fairfield Board Of Education
Address	: 233 Fairfield Rd	Address	: 15 Knoll Rd
City	: Fairfield	City	: Fairfield
State	: NJ	State	: NJ
Zip	: 07004	Zip	: 07004
Phone	: 9732272131	Phone	: 9732271340

DEFICIENCIES

None found at time of inspection.

BUILDING SURVEY

General Questions

What is the frequency of this service?	Annual
**Are there any other deficiencies?	No

TOTAL UNITS

Total Units Serviced

Enter the total number of units	26
---------------------------------	----

SIGNATURE

This report was reviewed with:

Pye-Barker Fire & Safety

Print Name : Na

Technician : Dominick Ostuni

Signature :

Customer did not sign
3/15/15 2:35:00 PM
ST00610367

Signature :

Date : 7/16/2025

Date : 7/16/2025

DBA: Metro Fire & Safety • 509 WASHINGTON AVE • CARLSTADT NJ • 07072-2802