



SURVIVOR

FIRE & SAFETY EQUIPMENT CO., INC.

39A MYRTLE STREET - PO BOX 782 - CRANFORD, NJ 07016
TEL 908-272-0066 - WWW.SURVIVORFIRESAFETY.COM - FAX 908-272-8144

Invoice #: SM 14434

Invoice Date: 10/21/2019

Completion Date: 10/18/2019

AR Id: DENTOW
Bill To: Township of Denville
1 Saint Mary's Place
Denville, NJ 07834

Service Id: VALLEYVIEWFIRECO3
Service At: Valley View Fire Company #3
2 River Road
Denville, NJ 07834

Division: Alarms - Service/Repair
Description: A-Inspection Needed

PO Number:
Alt #:

Terms: 15 Days
Due Date: 11/5/2019

WO#	Item	Description	Qty	Unit Price	Amount
20723		Fire Alarm Inspection Completed as per NFPA 72 and the State of New Jersey Uniform Fire Code. NAC 1 is not functional due to water damage, this fires off horn/strobes in the truck bay area. Will need to replace fire panel to correct the issue.			
	Service				
		A - Fire Alarm Inspection	1.00	470.00	470.00

SERVING ALL OF NEW JERSEY

Subtotal:	470.00
Sales Tax:	0.00
Total Due:	470.00

Please return this part with a check or money order made payable to Survivor Fire & Safety.



SURVIVOR

39A MYRTLE STREET - PO BOX 782 - CRANFORD, NJ 07016
TEL 908-272-0066 - WWW.SURVIVORFIRESAFETY.COM - FAX

Credit Card Information

Card Number:

* American Express is not accepted at this time.



Expiration:

mm / yy

CVV:

E-mail:

(If Receipt is Required/Requested)

Account ID	DENTOW	Amount Due	\$470.00
Invoice	14434	Amount Paid	