

Invoice 202501082

FAST

**Fire and
Security
Technologies**

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:

06/02/2025

Purchase Order #:

TERMS:

NET 60

Due Date:

08/01/2025

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

SERVICE LOCATION

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

Job Number: 251110 Job Category: Repair/Service

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCNJ 24/25-11
Fire Alarms - 57-CCCPs, MCCPC S2

Customer Request: Door holders not working

Completion Notes:

Service/Install Ticket

Date Selector:

05/30/2025

Service Report #:

25106

District Name:

RVCC

Location Name:

Bookstore

Panel Status on Arrival:

3 Troubles

Panel Status on Departure:

3 Troubles

Job Complete:

Yes - Complete

Tech 1:

MH

Reason for Call:

Door Holder Not Working

Work Performed:

Bookstores Door Holders are at entrance are not working. Ran new wire from main entrance reception Door Holders to Bookstore Entrance Doors. Wired up Door Mags and Bookstore Door Holders are now working again.

Equipment Used:

160ft - 18/2 - Fire Wire

RVCC
JUN 03 2025
Facilities

FINANCE OFFICE
RARITAN VALLEY
COMMUNITY COLLEGE
2025 JUN -2 AM 10:38
[Signature]

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate	3.00	\$76.00	\$0.000	\$228.00
Solid 18/2 Wire Fire Wire	0.16	\$242.00	\$0.000	\$38.72

CUSTOMER MESSAGE

Invoice Total:
Sales Tax:

\$266.72
\$0.00

Invoice 202401663

FAST

**Fire and
Security
Technologies**

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

DATE:

08/02/2024

Purchase Order #:

TERMS:

NET 60

Due Date:

10/01/2024

SERVICE LOCATION

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

Job Number: 241995

Job Category: Repair/Service

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCNJ 20/21-23
Fire Alarms - 57-CCCPS / Ed Data #14

Customer Request: New Enrollment - Entrance

Completion Notes:

Service/Install Ticket

Date Selector:

07/31/2024

Service Report #:

38332

District Name:

Rvcc

Location Name:

New enrollment entrance

Panel Status on Arrival:

Disabled points

Panel Status on Departure:

Disabled points

Job Complete:

Yes - Complete

Location Address:

118 lamington road

Tech 1:

Cody h

Reason for Call:

Relocate pull station

Work Preformed:

Ran MC to new location , installed single gang metal box and extender to each passed future drywall . Wire nut the wires on new side an hooood up on old side.

Equipment Used:

10 feet—16/2 MC

1—metal single gang box

1—single gang extender

Description	Qty	Rate	Tax	Total
Vehicle Allowance Vehicle Allowance	1.00	\$0.00	\$0.000	\$0.00
Discount Regular Labor Discount Regular Labor - Monday to Friday 7:30AM to 4:00 PM.	3.00	\$75.00	\$0.000	\$225.00

16/2 Fire alarm wire	0.02	\$270.00	\$0.000	\$5.40
MISC Item	1.00	\$20.00	\$0.000	\$20.00

CUSTOMER MESSAGE

Invoice Total: \$250.40
Sales Tax: \$0.00
Payments (-): \$0.00
Total Due: \$250.40

Invoice 202402437



217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	11/07/2024
Purchase Order #:	
TERMS:	NET 60
Due Date:	01/06/2025

BILL TO
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

SERVICE LOCATION
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

Job Number: 242911	Job Category: Repair/Service	CO-OPS Fire Extinguishers - MCCPC #13A / EdData #15A / ESCNJ 24/25-11 Fire Alarms - 57-CCCPS, MCCPC 52
Customer Request: Add 4 Door Holders		

Completion Notes:

11/05/2024
Service Report #: 36629
District Name: RVCC
Location Name: Somerset
Panel Status on Arrival: Normal
Panel Status on Departure: Normal
Job Complete: Yes - Complete
Tech 1: MH
Tech 2: RM
Tech 3: JM
Reason for Call: Door Mags
Work Performed: Ran wire for added door magnets in somerset by security office and by info desk. Mounted wire mold and door magnets. Wired door magnets.
Equipment Used:
100ft - 18/2 Fire Wire
x4 - Door Magnet Kits
4ft - Wire Mold

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate	16.50	\$76.00	\$0.000	\$1,254.00
Solid 18/2 Wire Fire Wire	0.10	\$242.00	\$0.000	\$24.20

MISC Item

1.00

\$25.00

\$0.000

\$25.00

CUSTOMER MESSAGE

Invoice Total:

\$1,303.20

Sales Tax:

\$0.00

Payments (-):

\$0.00

Total Due:

\$1,303.20

Invoice 202401326

FAST Fire and Security Technologies

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	06/24/2024
Purchase Order #:	
TERMS:	NET 60
Due Date:	08/23/2024

BILL TO
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

SERVICE LOCATION
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

Job Number: 241570	Job Category: Repair/Service	CO-OPS Fire Extinguishers - MCCPC #13A / EdData #15A / ESCNJ 24/25-11 Fire Alarms - 57-CCCPS, MCCPC 52
Customer Request: False Alarm in Somerset Hall		

Completion Notes:

Date Selector:
06/21/2024
Service Report #:
39792
District Name:
RVCC
Location Name:
Somerset Hall
Panel Status on Arrival:
Trouble
Panel Status on Departure:
Trouble Ground Fault
Job Complete:
Yes - Complete
Tech 1:
DJS
Reason for Call:
False alarm
Work Performed:
Located device that false alarmed in Rm 351. Saw no obvious cause of false alarm. Replaced faulty device.
Equipment Used:
1x IDP-PHOTO-W

Description	Qty	Rate	Tax	Total
Vehicle Allowance Vehicle Allowance	1.00	\$0.00	\$0.000	\$0.00
Discount Regular Labor Discount Regular Labor - Monday to Friday 7:30AM to 4:00 PM.	3.00	\$75.00	\$0.000	\$225.00
 Addressable photo electric smoke detector	1.00	\$145.00	\$0.000	\$145.00

CUSTOMER MESSAGE

Invoice Total:	\$370.00
Sales Tax:	\$0.00
Payments (-):	\$0.00
Total Due:	\$370.00

Invoice 202401491



217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	07/15/2024
Purchase Order #:	
TERMS:	NET 60
Due Date:	09/13/2024

BILL TO
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

SERVICE LOCATION
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

Job Number: 241672	Job Category: Monitoring (All Types)	CO-OPS Fire Extinguishers - MCCPC #13A / EdData #15A / ESCNJ 24/25-11 Fire Alarms - 57-CCCPS, MCCPC 52
Customer Request: LM0030 - Alarm Monitoring		

Completion Notes:
Annual Alarm Monitoring

Description	Qty	Rate	Tax	Total
Coverage Date - 1 Year This invoice is for annual alarm monitoring. The Coverage Date is from the 1st day of the month the invoice is dated - plus one year.	1.00	\$0.00	\$0.000	\$0.00
Fire or Fire/Burg Alarm Monitoring W/Daily Test Annual Fire or Fire/Burg Alarm Monitoring W/Daily Test (IP/Cell Data and Central Station Monitoring) 0619242F- Science Building 0619242- Hunterdon/Somerset 0619242W - West 0619243- Arts 0619244- Child Care 0619246- Power Plant	6.00	\$384.00	\$0.000	\$2,304.00
NJ Sales Tax		0.000%		\$0.00

CUSTOMER MESSAGE

Invoice Total: \$2,304.00
Sales Tax: \$0.00
Payments (-): \$0.00
Total Due: \$2,304.00

Invoice 202401300

FAST

**Fire and
Security
Technologies**

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:

06/14/2024

Purchase Order #:

TERMS:

NET 60

Due Date:

08/13/2024

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

SERVICE LOCATION

Somerset Hall
75 Lamington Road
Branchburg, NJ, 08876

Job Number: 241494

Job Category: Repair/Service

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCNJ 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52

Customer Request: Active Alarm

Completion Notes:

Service/Install Ticket

Date Selector:

06/13/2024

Service Report #:

39690

District Name:

RVCC

Location Name:

All

Panel Status on Arrival:

Ground fault - active alarm - short

Panel Status on Departure:

Normal

Job Complete:

Yes - Complete

Location Address:

118 lamington rd

Tech 1:

Cody h

Tech 2:

Kenny L

Tech 3:

Nick M

Reason for Call:

Active alarm came in and troubles in panel

Work Performed:

Located active alarm device, changed device due to it being dirty and damaged, located ground fault 2nd floor by tracing with meter and found it in speaker strobe device on old system, cleared and fixed. Traced ground fault and short in women locker room in physical education building, found device 56 loaded up with water, and device damaged, took device down and tied wires then deleted device for now.

Panel normal

Equipment Used:

2w-b detector

Description	Qty	Rate	Tax	Total
Vehicle Allowance	1.00	\$0.00	\$0.000	\$0.00

Vehicle Allowance

Discount Regular Labor

Discount Regular Labor - Monday to
Friday 7:30AM to 4:00 PM.

14.50

\$75.00

\$0.000

\$1,087.50

2 wire photoelectric smoke detector

1.00

\$125.00

\$0.000

\$125.00

CUSTOMER MESSAGE

Invoice Total:

\$1,212.50

Sales Tax:

\$0.00

Payments (-):

\$0.00

Total Due:

\$1,212.50

Invoice 202401295

FAST Fire and Security Technologies

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	06/13/2024
Purchase Order #:	
TERMS:	NET 60
Due Date:	08/12/2024

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

SERVICE LOCATION

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

Job Number: 241297

Job Category: Repair/Service

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCNJ 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52

Customer Request: 150 troubles on RVCC-1 Security Office Panel

Completion Notes:

Service/Install Ticket

Date Selector:

05/22/2024

Service Report #:

38604

District Name:

RVCC

Location Name:

RVCC-Security Office/Phys Ed

Panel Status on Arrival:

150 M:08 Troubles

Panel Status on Departure:

50 M:08 Troubles

Job Complete:

No - Not Complete

Location Address:

Lamington Rd Branchburg NJ

Tech 1:

Nick M

Reason for Call:

150 troubles, some going in and out

Work Performed:

Located M08 loop card in Phys Ed mech room. Read short on feed. Tried to break in field but couldn't. Located junction box in mech room by the card. Took apart splice and read short on a feed and isolated. Now only 50 troubles.

Equipment Used:

None

Service/Install Ticket

Date Selector:

06/11/2024

Service Report #:

38542

District Name:

RVCC

Location Name:

Somerset/Gym

Panel Status on Arrival:

Pool Area Heat Missing

Panel Status on Departure:

Normal

Job Complete:

Yes - Complete

Location Address:

Lamington Rd Branchburg NJ

Tech 1:

Nick & Kenny

Tech 2:

Rob & Ryan M

Tech 3:

Jason M

Reason for Call:

Short in Gym Area, add points back

Work Performed:

Returned to check for short and it was still present. Opened loop in employee restroom and got all locker room points back. Added points back to program in panel.

Equipment Used:

None

Description	Qty	Rate	Tax	Total
Vehicle Allowance Vehicle Allowance	1.00	\$0.00	\$0.000	\$0.00
Discount Regular Labor -5/22 Discount Regular Labor - Monday to Friday 7:30AM to 4:00 PM.	4.50	\$75.00	\$0.000	\$337.50
Vehicle Allowance Vehicle Allowance	1.00	\$0.00	\$0.000	\$0.00
Discount Regular Labor -6/11 Discount Regular Labor - Monday to Friday 7:30AM to 4:00 PM.	17.50	\$75.00	\$0.000	\$1,312.50

CUSTOMER MESSAGE

Invoice Total:

\$1,650.00

Sales Tax:

\$0.00

Payments (-):

\$0.00

Total Due:

\$1,650.00

Invoice 202401243



217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	06/06/2024
Purchase Order #:	
TERMS:	NET 60
Due Date:	08/05/2024

BILL TO
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

SERVICE LOCATION
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

Job Number: 241110	Job Category: Installation	CO-OPS Fire Extinguishers - MCCPC #13A / EdData #15A / ESCNJ 24/25-11 Fire Alarms - 57-CCCPS, MCCPC 52
Customer Request: C-124 Devices TO install		

Completion Notes:

date 6-5-25

techs rob

job status complete

work performed - programmed 11 smoke detectors into system. tied speaker strobes into existing circuit in c-124

everything should be ready for inspection

Service/Install Ticket

Date Selector:

05/03/2024

Service Report #:

38893

District Name:

RVCC

Location Name:

C-124

Panel Status on Arrival:

Gym Pool Heat Disabled M08S116, Sbus Communications RA-2000 13

Panel Status on Departure:

Gym Pool Heat Disabled M08S116, Sbus Communications RA-2000 13

Job Complete:

No - Not Complete

Tech 1:

MH

Tech 2:

RM

Tech 3:

JM

Reason for Call:

Install Devices

Work Performed:

Continued mounting and wiring speaker strobes in C-124. Finished running wire in room next to C-124 for Speaker Strobes and SLC devices.

Have to wait until ceiling grid is put up to Han boxes and devices.

Equipment Used:

x3 - SPSCRL - Ceiling Mount Speaker Strobes

420ft - 18/2 Fire Wire

430ft - 16/4 Fire Wire

Service/Install Ticket

Date Selector:

05/02/2024

Service Report #:

38892

District Name:

RVCC

Location Name:

C-124

Panel Status on Arrival:

Gym Pool Heat Disabled M08S116, Sbus Communications RA-2000 13

Panel Status on Departure:

Gym Pool Heat Disabled M08S116, Sbus Communications RA-2000 13

Job Complete:

No - Not Complete

Tech 1:

MH

Tech 2:

RM

Reason for Call:

C-124 Devices to install

Work Performed:

Started mounting and wiring speaker strobes in C-124. Moved pull station in C-124 as requested.

Still have to continue mounting devices and running wire in next section.

Equipment Used:

x8 - SPSCRL - Ceiling Mount Speaker Strobes

6ft - Wire Mold

x1 - Wire Mold Box

Description	Qty	Rate	Tax	Total
Vehicle Allowance Vehicle Allowance	1.00	\$0.00	\$0.000	\$0.00
Discount Regular Labor - 5/2 Discount Regular Labor - Monday to Friday 7:30AM to 4:00 PM.	9.00	\$75.00	\$0.000	\$675.00
Vehicle Allowance Vehicle Allowance	1.00	\$0.00	\$0.000	\$0.00
Discount Regular Labor - 5/3 Discount Regular Labor - Monday to Friday 7:30AM to 4:00 PM.	9.00	\$75.00	\$0.000	\$675.00
Vehicle Allowance Vehicle Allowance	1.00	\$0.00	\$0.000	\$0.00
Discount Regular Labor - 6/5 Discount Regular Labor - Monday to Friday 7:30AM to 4:00 PM.	8.00	\$75.00	\$0.000	\$600.00
Speaker Strobe Red Ceiling Mount Marked FIRE	11.00	\$141.00	\$0.000	\$1,551.00
Solid 18/2 Wire Fire Wire	0.42	\$242.00	\$0.000	\$101.64
Solid-16/4 Fire alarm wire	0.86	\$360.00	\$0.000	\$309.60

CUSTOMER MESSAGE

Invoice Total:

\$3,912.24

Sales Tax:

\$0.00

Payments (-):

\$0.00

Total Due:

\$3,912.24

Invoice 202402581

FAST Fire and
Security
Technologies

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	12/02/2024
Purchase Order #:	
TERMS:	NET 60
Due Date:	01/31/2025

BILL TO
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

SERVICE LOCATION
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

Job Number: 243062	Job Category: Monitoring (All Types)	CO-OPS Fire Extinguishers - MCCPC #13A / EdData #15A / ESCNJ 24/25-11 Fire Alarms - 57-CCCPS, MCCPC 52
Customer Request: AM1203 - Alarm Monitoring		

Completion Notes:
Annual Alarm Monitoring

Description	Qty	Rate	Tax	Total
AM(annual) Alarm Monitoring - Annual Alarm Monitoring Account 1786875 Planetarium	1.00	\$360.00	\$0.000	\$360.00
Coverage Date - 1 Year This invoice is for annual alarm monitoring. The Coverage Date is from the 1st day of the month the invoice is dated - plus one year.	1.00	\$0.00	\$0.000	\$0.00

CUSTOMER MESSAGE

Invoice Total: \$360.00
Sales Tax: \$0.00
Payments (-): \$0.00
Total Due: \$360.00

Invoice 202402605



217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	12/03/2024
Purchase Order #:	
TERMS:	NET 60
Due Date:	02/01/2025

BILL TO
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

SERVICE LOCATION
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

Job Number: 241937	Job Category: Repair/Service	CO-OPS Fire Extinguishers - MCCPC #13A / EdData #15A / ESCNJ 24/25-11 Fire Alarms - S7-CCCPS, MCCPC 52
Customer Request: Boiler House Trouble		

Completion Notes:

Service/Install Ticket
Date Selector:
07/23/2024
Service Report #:
0000
District Name:
Raritan Valley Community College
Location Name:
Boiler House
Panel Status on Arrival:
Trouble - Low battery
Panel Status on Departure:
Trouble low battery
Job Complete:
No - Not Complete
Location Address:
118 Lamington Road
Tech 1:
JCK
Reason for Call:
Received emergency call for trouble / beeping on panel
Work Performed:
Upon Arrival found low battery for main FACP. Will return to replace 2- 12volt 18ah batteries

Service/Install Ticket
Date Selector:
07/23/2024
Service Report #:
39873
District Name:
Raritan Valley Community College
Location Name:
Boiler House
Panel Status on Arrival:
Disabled Points
Panel Status on Departure:
Disabled Points
Job Complete:
Yes - Complete
Location Address:

118 Lamington Road
Tech 1:
Cody
Reason for Call:
Replace batteries following morning visit
Work Performed:
Replaced batteries
Equipment Used:
(2) Fire Rated Fire Alarm Battery 202419

Description	Qty	Rate	Tax	Total
Vehicle Allowance Vehicle Allowance	1.00	\$0.00	\$0.000	\$0.00
Discount Regular Labor -7/23 morning Discount Regular Labor - Monday to Friday 7:30AM to 4:00 PM.	1.00	\$76.00	\$0.000	\$76.00
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate -7/23 afternoon	2.00	\$76.00	\$0.000	\$152.00
Fire Rated Fire Alarm Battery 202419	2.00	\$205.00	\$0.000	\$410.00

CUSTOMER MESSAGE

Invoice Total:	\$638.00
Sales Tax:	\$0.00
Payments (-):	\$0.00
Total Due:	\$638.00

Invoice 202402307



**Fire and
Security
Technologies**

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	10/22/2024
Purchase Order #:	
TERMS:	NET 60
Due Date:	12/21/2024

BILL TO
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

SERVICE LOCATION
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

Job Number: 242784	Job Category: Repair/Service	CO-OPS Fire Extinguishers - MCCPC #13A / EdData #15A / ESCNJ 24/25-11 Fire Alarms - 57-CCCPS, MCCPC 52
Customer Request: Troubles FACP		

Completion Notes:

date 10-22-24

techs rob

job status complete

work performed - upon arrival disable keys active and unused point. programmed point into system and system returned to normal.

customer stated F1 keys were acting strangely - keys were illuminated but not the amount of troubles as if everything was disabled. was able to fix by using panel across the hall and using those F1 keys

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate	3.00	\$76.00	\$0.000	\$228.00

CUSTOMER MESSAGE

Invoice Total:	\$228.00
Sales Tax:	\$0.00
Payments (-):	\$0.00
Total Due:	\$228.00

Invoice 202402163



**Fire and
Security
Technologies**

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	10/02/2024
Purchase Order #:	
TERMS:	NET 60
Due Date:	12/01/2024

BILL TO
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

SERVICE LOCATION
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

Job Number: 241221	Job Category: NFPA 72	CO-OPS Fire Extinguishers - MCCPC #13A / EdData #15A / ESCNJ 24/25-11 Fire Alarms - 57-CCCPS, MCCPC 52
Customer Request: NFPA 72		

Completion Notes:
NFPA 72 Inspections

Description	Qty	Rate	Tax	Total
NFPA 72 as per contract	1.00	\$3,800.00	\$0.000	\$3,800.00
Science Addition	1.00	\$1,125.00	\$0.000	\$1,125.00
Workforce Building	1.00	\$1,925.00	\$0.000	\$1,925.00
Additional Equipment Installed since 2016. Renovations and remodels.	1.00	\$1,800.00	\$0.000	\$1,800.00
New Speaker/Strobe System - minus old horn strobes	1.00	\$2,500.00	\$0.000	\$2,500.00

CUSTOMER MESSAGE

Invoice Total: \$11,150.00
Sales Tax: \$0.00
Payments (-): \$0.00
Total Due: \$11,150.00

Invoice 202402017



**Fire and
Security
Technologies**

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	09/19/2024
Purchase Order #:	
TERMS:	NET 60
Due Date:	11/18/2024

BILL TO
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

SERVICE LOCATION
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

Job Number: 242492	Job Category: Repair/Service	CO-OPS Fire Extinguishers - MCCPC #13A / EdData #15A / ESCNJ 24/25-11 Fire Alarms - 57-CCCPS, MCCPC 52
Customer Request: Ground / False alarm		

Completion Notes:

date 9-18-24
techs rob julian
job status complete

work performed - history shows false alarm on pull station at ATCC entrance. located and replaced. located module 6 booster in gym building that has ground fault in/out. read all circuits and no concrete ground. if problem persists will return to troubleshoot

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate	7.00	\$76.00	\$0.000	\$532.00

CUSTOMER MESSAGE

Invoice Total:	\$532.00
Sales Tax:	\$0.00
Payments (-):	\$0.00
Total Due:	\$532.00

Invoice 202402006

FAST Fire and Security Technologies

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	09/18/2024
Purchase Order #:	
TERMS:	NET 60
Due Date:	11/17/2024

BILL TO
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

SERVICE LOCATION
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

Job Number: 242106	Job Category: Repair/Service	CO-OPS Fire Extinguishers - MCCPC #13A / EdData #15A / ESCNJ 24/25-11 Fire Alarms - 57-CCCPS, MCCPC 52
Customer Request: Troubles on panel		

Completion Notes:

9-10-24

techs rob ryan m

job status complete

work performed - upon arrival two troubles. uploaded program and deleted point and turned off supervision. system returned to normal

date 9-9-24

techs rob ryan m cody

job status incomplete

work performed - upon arrival 5 troubles. located missing pull and alternate recall module in science building and replaced both.

isolated ground fault to SLC on main panel.

began tracing to 1st floor college center. located wire crushed by sheet rockers - wire goes into office that was currently occupied. will

return to continue

equipment used - (1) ADDRESSABLE PULL STATION, SINGLE ACTION, KEY RESET (1) ADDRESSABLE RELAY MODULE W/ 2 ISOLATED SETS OF FORM C CONTACTS

date 8-7-24

techs rob jason m

job status incomplete

work performed - began troubleshooting m33 ground fault. isolated to 22 devices in Rise Adjunct area - narrowed down from 22 to 16 - will return to continue

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate -8/7	12.00	\$76.00	\$0.000	\$912.00
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate 9/9	21.00	\$76.00	\$0.000	\$1,596.00
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate -9/10	3.00	\$76.00	\$0.000	\$228.00

**ADDRESSABLE RELAY MODULE W/ 2
ISOLATED SETS OF FORM C
CONTACTS**

1.00

\$211.00

\$0.000

\$211.00



**ADDRESSABLE PULL STATION,
SINGLE ACTION, KEY RESET**

1.00

\$215.00

\$0.000

\$215.00

CUSTOMER MESSAGE

Invoice Total:

\$3,162.00

Sales Tax:

\$0.00

Payments (-):

\$0.00

Total Due:

\$3,162.00

Invoice 202401642



**Fire and
Security
Technologies**

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:

07/31/2024

Purchase Order #:

TERMS:

NET 60

Due Date:

09/29/2024

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

SERVICE LOCATION

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

Job Number: 241993

Job Category: Repair/Service

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESNJ 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52

Customer Request: S126

Completion Notes:

Service Fusion #:

24-1993

Date Selector:

07/31/2024

Service Report #:

38983

District Name:

RVCC

Location Name:

Somerset Hall

Panel Status on Arrival:

78 total troubles + disables

Panel Status on Departure:

78 total troubles + disabled

Job Complete:

Yes - Complete

Tech 1:

MH

Tech 2:

RM

Tech 3:

JM

Reason for Call:

S126 Renovation

Work Performed:

Swapped 2 Detectors into new ceiling tiles. Added one speaker strobe in room. Ran wire from hallway speaker strobe. Cut tile and mounted hanger bar and box. Mounted speaker strobe and wired.

Equipment Used:

80FT - 16/4 - Fire Wire

x1 - Hanger Bar

x1 - Speaker Strobe Red Ceiling Mount Marked FIRE

x1 - 4" Deep Square Box

Description	Qty	Rate	Tax	Total
Vehicle Allowance Vehicle Allowance	1.00	\$0.00	\$0.000	\$0.00
Discount Regular Labor	3.00	\$75.00	\$0.000	\$225.00

Discount Regular Labor - Monday to
Friday 7:30AM to 4:00 PM.

Solid-16/4 Fire alarm wire	0.16	\$360.00	\$0.000	\$57.60
Speaker Strobe Red Ceiling Mount Marked FIRE	1.00	\$141.00	\$0.000	\$141.00
Hangbar	1.00	\$28.00	\$0.000	\$28.00
MISC Item	1.00	\$5.00	\$0.000	\$5.00

CUSTOMER MESSAGE

Invoice Total:	\$456.60
Sales Tax:	\$0.00
Payments (-):	\$0.00
Total Due:	\$456.60

Invoice 202401538



217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	07/18/2024
Purchase Order #:	
TERMS:	NET 60
Due Date:	09/16/2024

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

SERVICE LOCATION

The Foundations House
102 Lamington Road
Branchburg, NJ, 08876

Job Number: 241869

Job Category: Repair/Service

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCNJ 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52

Customer Request: False Alarm

Completion Notes:

Date Selector:
07/15/2024
Service Report #:
39864
District Name:
rvcc
Location Name:
bateman house
Panel Status on Arrival:
missing devises 501-510-505-509--510 in alarm
Panel Status on Departure:
missing devises 501-510-505-509
Job Complete:
No - Not Complete
Location Address:
102 lamington road
Tech 1:
cody h
Tech 2:
jason m
Reason for Call:
system went into alarm
Work Performed:
located devises and confirmed dead battery's, cleared alarm of alarm
Equipment Used:
none

Service/Install Ticket

Date Selector:
07/17/2024
Service Report #:
39866
District Name:
Rvcc
Location Name:
Bateman house
Panel Status on Arrival:
4 missing devises
Panel Status on Departure:
Normal
Job Complete:

Yes - Complete
Location Address:
102 lamington
Tech 1:
Cody h
Reason for Call:
Troubles on panel
Work Preformed:
Located and replaced all dead battery's in detectors
Equipment Used:
4—3v 1500mah batterys

Description	Qty	Rate	Tax	Total
Vehicle Allowance -7/15 Vehicle Allowance	1.00	\$0.00	\$0.000	\$0.00
Discount Regular Labor-7/15 Discount Regular Labor - Monday to Friday 7:30AM to 4:00 PM.	4.00	\$75.00	\$0.000	\$300.00
Vehicle Allowance-7/17 Vehicle Allowance	1.00	\$0.00	\$0.000	\$0.00
Discount Regular Labor-7/17 Discount Regular Labor - Monday to Friday 7:30AM to 4:00 PM.	3.00	\$75.00	\$0.000	\$225.00
Small Round Battery	4.00	\$8.00	\$0.000	\$32.00

CUSTOMER MESSAGE

Invoice Total: \$557.00
Sales Tax: \$0.00
Payments (-): \$0.00
Total Due: \$557.00

Invoice 202401518



217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	07/16/2024
Purchase Order #:	
TERMS:	NET 60
Due Date:	09/14/2024

BILL TO
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

SERVICE LOCATION
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

Job Number: 241565 Repairs	Job Category: NFPA Inspection	CO-OPS Fire Extinguishers - MCCPC #13A / EdData #15A / ESCNJ 24/25-11 Fire Alarms - 57-CCCPS, MCCPC 52
Customer Request: NFPA 72 Repairs		

Completion Notes:

06/18/2024

Service Report #:
38330

District Name:
Rvcc

Location Name:
All campus

Panel Status on Arrival:
Disabled bells

Panel Status on Departure:
Disabled bells

Job Complete:
No - Not Complete

Location Address:
118 lamington road

Tech 1:
Cody h

Reason for Call:
Replace batteries on campus

Work Performed:
Replaced failed batteries in fire panels and booster panels around campus buildings

Equipment Used:
(18) Fire Rated Fire Alarm Battery 202419
(4) Fire Rated Fire Alarm Battery 202408

07/13/2024

techs rob jason m
job status complete

work performed - started at arts building - upon arrival sensor in trouble. located sensor in room A-25 and replaced. system returned to normal. replaced backup batteries in booster panel.

In science building replaced backup batteries for booster and amplifier

equipment used - (1) Addressable photo electric smoke detector and (6) Fire Rated Fire Alarm Battery 202419

Description	Qty	Rate	Tax	Total
Vehicle Allowance -6/18 Vehicle Allowance	1.00	\$0.00	\$0.000	\$0.00
Discount Regular Labor -6/18	5.50	\$75.00	\$0.000	\$412.50

Discount Regular Labor - Monday to
Friday 7:30AM to 4:00 PM.

Fire Rated Fire Alarm Battery 202419	18.00	\$205.00	\$0.000	\$3,690.00
Fire Rated Fire Alarm Battery 202408	4.00	\$95.00	\$0.000	\$380.00
Vehicle Allowance -7/13 Vehicle Allowance	1.00	\$65.00	\$0.000	\$65.00
Discount Regular Labor -7/13 Discount Regular Labor - Monday to Friday 7:30AM to 4:00 PM.	4.00	\$75.00	\$0.000	\$300.00
 Addressable photo electric smoke detector	1.00	\$145.00	\$0.000	\$145.00
Fire Rated Fire Alarm Battery 202419	6.00	\$205.00	\$0.000	\$1,230.00

CUSTOMER MESSAGE

Invoice Total:	\$6,222.50
Sales Tax:	\$0.00
Payments (-):	\$0.00
Total Due:	\$6,222.50

Invoice 202401315



217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	06/19/2024
Purchase Order #:	
TERMS:	NET 60
Due Date:	08/18/2024

BILL TO
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

SERVICE LOCATION
Child Care 118 Lamington Road North Branch, NJ, 08876

Job Number: 241526	Job Category: Repair/Service	CO-OPS Fire Extinguishers - MCCPC #13A / EdData #15A / ESCNJ 24/25-11 Fire Alarms - 57-CCCPS, MCCPC 52
Customer Request: FM - Failures		

Completion Notes:

Service/Install Ticket
Date Selector:
06/18/2024
Service Report #:
38329
District Name:
Rvcc
Location Name:
Childcare
Panel Status on Arrival:
Normal
Panel Status on Departure:
Normal
Job Complete:
Yes - Complete
Location Address:
118 lamington road
Tech 1:
Cody h
Reason for Call:
Rehang CO detectors
Work Preformed:
Put CO detectors back into ceiling
Equipment Used:
None

Description	Qty	Rate	Tax	Total
Vehicle Allowance Vehicle Allowance	1.00	\$0.00	\$0.000	\$0.00
Discount Regular Labor Discount Regular Labor - Monday to Friday 7:30AM to 4:00 PM.	3.00	\$75.00	\$0.000	\$225.00

CUSTOMER MESSAGE

Invoice Total:	\$225.00
Sales Tax:	\$0.00
Payments (-):	\$0.00
Total Due:	\$225.00

Invoice 202401471

FAST Fire and
Security
Technologies

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	07/11/2024
Purchase Order #:	
TERMS:	NET 60
Due Date:	09/09/2024

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

SERVICE LOCATION

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

Job Number: 241769 Job Category: Repair/Service

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCN) 24/25-11
Fire Alarms - 57-CCCP5, MCCPC 52

Customer Request: Power Failure

Completion Notes:

Service/Install Ticket

Date Selector:

07/08/2024

Service Report #:

38955

District Name:

RVCC

Location Name:

RVCC

Panel Status on Arrival:

AC power loss RPS + AMP New Science

Panel Status on Departure:

AC power loss RPS + AMP New Science

Job Complete:

Yes - Complete

Tech 1:

MH

Reason for Call:

Loss AC Power

Work Performed:

Arrived to main panel working and has power. Panel shows troubles for no AC power new science wing RPS and AMP. Back up batteries are dead, didn't have 12v18ah on van. Need to restore AC power to building and our RPS and AMP will work again.

Description	Qty	Rate	Tax	Total
Vehicle Allowance Vehicle Allowance	1.00	\$0.00	\$0.000	\$0.00
Discount Regular Labor Discount Regular Labor - Monday to Friday 7:30AM to 4:00 PM.	3.00	\$75.00	\$0.000	\$225.00

CUSTOMER MESSAGE

Invoice Total:

\$225.00

Sales Tax:

\$0.00

Invoice 202401496



217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	07/15/2024
Purchase Order #:	
TERMS:	NET 60
Due Date:	09/13/2024

BILL TO
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

SERVICE LOCATION
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

Job Number: 241845	Job Category: Repair/Service	CO-OPS Fire Extinguishers - MCCPC #13A / EdData #15A / ESCNJ 24/25-11 Fire Alarms - 57-CCCPS, MCCPC 52
Customer Request: Boiler house - troubles		

Completion Notes:
date 7-13-24
techs rob jason m
job status complete

work performed - customer stated panel making noise. upon arrival both systems normal. history shows disables being activated and panel being silence. no noise coming from panels at this time. with all systems normal, nothing to troubleshoot

Description	Qty	Rate	Tax	Total
Vehicle Allowance Vehicle Allowance	1.00	\$0.00	\$0.000	\$0.00
Discount Regular Labor Discount Regular Labor - Monday to Friday 7:30AM to 4:00 PM.	3.00	\$75.00	\$0.000	\$225.00

CUSTOMER MESSAGE

Invoice Total: \$225.00
Sales Tax: \$0.00
Payments (-): \$0.00
Total Due: \$225.00

H-200
Invoice 202402708

FAST Fire and
Security
Technologies

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	12/16/2024 ✓
Purchase Order #:	P0037639 ✓
TERMS:	NET 60
Due Date:	02/14/2025

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

SERVICE LOCATION

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

Job Number: 243147

Job Category:

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCNJ 24/25-11
Fire Alarms - 57-CCCPs, MCCPC 52

Customer Request: H200

Completion Notes:

Service/Install Ticket

Date Selector:

12/10/2024

Service Report #:

30550

District Name:

RVCC

Location Name:

H200

Panel Status on Arrival:

NA

Panel Status on Departure:

NA

Job Complete:

No - Not Complete

Tech 1:

MH

Reason for Call:

Reno

Work Performed:

Cut ceiling tiles. Mounted hanger bars and boxes for speaker strobes. Mounted and wired 3 speaker strobes. Drop in existing detectors into ceiling tiles, still have to continue.

Equipment Used:

x6 - Hanger Bars

x6 - 4" Deep Square Box

x3 - SPEAKER STROBE LED RED CEILING - LED

Service/Install Ticket

Date Selector:

12/12/2024

Service Report #:

30551

District Name:

RVCC

Location Name:

H200

Panel Status on Arrival:

NA

Panel Status on Departure:

NA

Job Complete:

Yes - Complete
Tech 1:

MH

Tech 2:

JM

Reason for Call:

Reno

Work Performed:

Mounted last hanger bar and box for speaker strobes. Mounted and wired speaker strobes. Dropped in existing detectors into ceiling tiles. Swapped all detectors and bases to new devices.

Equipment Used:

x1 - Hanger Bar

x1 - 4" Deep Square Box

x4 - SPEAKER STROBE LED RED CEILING - LED

x7 - Smoke Detector Base

x7 - ADDRESSABLE THRML DETC FIX TEMP 135°F, RATE OF RISE, WHITE

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate	18.00	\$76.00	\$0.000	\$1,368.00
Hangbar	7.00	\$28.00	\$0.000	\$196.00
MISC Item	1.00	\$35.00	\$0.000	\$35.00
SPEAKER STROBE LED RED CEILING - LED	7.00	\$153.00	\$0.000	\$1,071.00
Smoke Detector Base	7.00	\$44.00	\$0.000	\$308.00
ADDRESSABLE THRML DETC FIX TEMP 135°F, RATE OF RISE, WHITE	7.00	\$121.00	\$0.000	\$847.00



CUSTOMER MESSAGE

Invoice Total:

\$3,825.00

Sales Tax:

\$0.00

Payments (-):

\$0.00

Total Due:

\$3,825.00

Invoice 202500081

FAST

**Fire and
Security
Technologies**

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

SERVICE LOCATION

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

Job Number: 243307 Job Category: Repair/Service

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESNJ 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52

Customer Request: Troubles FACP

Completion Notes:

Service/Install Ticket

Date Selector:

01/02/2025

Service Report #:

37136

District Name:

RVCC

Location Name:

P.E / Pool

Panel Status on Arrival:

Missing Heat Gym Above Pool

Panel Status on Departure:

Normal

Job Complete:

Yes - Complete

Tech 1:

MH

Tech 2:

JM

Reason for Call:

Trouble On FACP

Work Performed:

Deleted missing point from system.

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate	3.00	\$76.00	\$0.000	\$228.00

CUSTOMER MESSAGE

Invoice Total: \$228.00
Sales Tax: \$0.00
Payments (-): \$0.00
Total Due: \$228.00

Invoice 202500128



217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	01/10/2025
Purchase Order #:	
TERMS:	NET 60
Due Date:	03/11/2025

BILL TO
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

SERVICE LOCATION
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

Job Number: 243152	Job Category: Repair/Service	CO-OPS Fire Extinguishers - MCCPC #13A / EdData #15A / ESCNJ 24/25-11 Fire Alarms - 57-CCCPS, MCCPC 52
Customer Request: Trouble FACP		

Completion Notes:

Service/Install Ticket

Date Selector:

12/12/2024

Service Report #:

30568

District Name:

RVCC

Location Name:

Hunterdon Panel

Panel Status on Arrival:

Trouble x4, Cal Trouble Smoke/Heat Missing

Panel Status on Departure:

Trouble x1, Missing heat Gym Above Pool

Job Complete:

No - Not Complete

Location Address:

118 Lamington Rd, Branchburg, NJ

Tech 1:

JED

Reason for Call:

Service/Repair Detector Trouble

Work Performed:

Located faulty sensor in filter room beneath pool, replaced onsite. Other troubles cleared as well except for the missing heat in gym. The ceilings in this gym are very high and will require a lift to access. Sub does not have one so we will need to bring one of ours. At least 6 that I could spot but not sure which one it is.

Equipment Used:

(1) Addressable photo electric smoke detector

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate	3.00	\$76.00	\$0.000	\$228.00
Addressable photo electric smoke detector	1.00	\$145.00	\$0.000	\$145.00



CUSTOMER MESSAGE

Invoice Total:	\$373.00
Sales Tax:	\$0.00
Payments (-):	\$0.00
Total Due:	\$373.00

Invoice 202500109

FAST Fire and
Security
Technologies

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	01/08/2025
Purchase Order #:	
TERMS:	NET 60
Due Date:	03/09/2025

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

SERVICE LOCATION

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

Job Number: 250097

Job Category: Repair/Service

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCNJ 24/25-11
Fire Alarms - S7-CCCPS, MCCPC 52

Customer Request: 74 Lamington Building Trouble

Completion Notes:

Service/Install Ticket

Date Selector:

01/07/2025

Service Report #:

37146

District Name:

RVCC

Location Name:

Foundation 74 Lamington Road

Panel Status on Arrival:

Alarm

Panel Status on Departure:

Normal

Job Complete:

Yes - Complete

Tech 1:

MH

Tech 2:

RM

Reason for Call:

Security Trouble / Alarm

Work Performed:

Alarm from back stairs, 2nd floor alarm, guest bed alarm, master bed alarm, master closet alarm and back office trouble for smoke detector. Reset sensors and alarms cleared but back office trouble stayed. Replaced battery in back office smoke detector and did not clear the trouble. Replaced smoke detector and programmed into system. System is now Normal

Equipment Used:

x1 - Wireless Smoke Detector with Synchronized Sounder

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate	3.00	\$76.00	\$0.000	\$228.00
Wireless Smoke Detector with Synchronized Sounder	1.00	\$169.00	\$0.000	\$169.00

CUSTOMER MESSAGE

Invoice Total:	\$397.00
Sales Tax:	\$0.00
Payments (-):	\$0.00
Total Due:	\$397.00

Invoice 202402472

FAST

Fire and
Security
Technologies

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

SERVICE LOCATION

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

Job Number: 241994 Job Category: Repair/Service

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCNJ 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52

Customer Request: H227 - Allied Health Labs - Nursing Reno

Completion Notes:

date 10-7-24
techs rob julian
job status incomplete
work performed - ran wire from 3rd floor Hunterdon m01 detector - detector near elevator - ran wire to 2nd floor h228 to tie into new devices

10/08/2024

Service Report #:

40357

District Name:

RVCC

Location Name:

H228

Panel Status on Arrival:

Ground Fault

Panel Status on Departure:

Ground Fault

Job Complete:

No - Not Complete

Tech 1:

MH

Reason for Call:

Reno

Work Performed:

Put hanger bars together with boxes. Cut ceiling tiles and mounted hanger bars on ceiling grid. Mounted and wired speaker strobes. Mounted and wired SLC detector bases. Still have to tie feed in and put detectors in bases.

Equipment Used:

x11 - Hanger Bars

x7 - 4" Round Boxes

x4 - 4" Deep Square Boxes

x7 - B300-6 - Detector Bases

x4 - SPEAKER STROBE LED RED CEILING - LED

date 10-10-24

techs rob julian

job status complete

work performed - landed devices into H228 - tied in SLC and speaker strobe circuit and programmed devices. H200 renovations not yet complete - according to plans there's 2 more cubicles that still need to be put together before fire alarm devices can be landed into ceiling grid. advised customer to contact fast when renovations are complete

assisted other techs in renovated area in enrollment - landed existing smokes into new grid and installed new smokes and speaker strobes into cubicles. programmed devices into system.
 equipment used - (12) Addressable photo electric smoke detector (5) ceiling speaker strobes

date 10-18-24

techs rob

job status incomplete

work performed - removed traditional devices from H228 and put in ceiling tiles - removed pull station in enrollment entrance and mounted inside - did not get a chance to program as Approved fire was on site testing sprinkler devices all day. will return to program point

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate	35.00	\$76.00	\$0.000	\$2,660.00
Hangbar	11.00	\$28.00	\$0.000	\$308.00
SPEAKER STROBE LED RED CEILING - LED	9.00	\$153.00	\$0.000	\$1,377.00
MISC Item	1.00	\$55.00	\$0.000	\$55.00
 Addressable photo electric smoke detector	12.00	\$145.00	\$0.000	\$1,740.00

CUSTOMER MESSAGE

Invoice Total:

\$6,140.00

Sales Tax:

\$0.00

Payments (-):

\$0.00

Total Due:

\$6,140.00 ✓

763- C24005-6020-70

Invoice 202402451

Facilities

FAST

Fire and
Security
Technologies

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:

11/11/2024

Purchase Order #:

Direct

TERMS:

NET 60

Due Date:

01/10/2025

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

SERVICE LOCATION

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

Job Number: 241998

Job Category: Repair/Service

**CO-OPS Fire Extinguishers - MCCPC #13A /
EdDate #15A / ESCNJ 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52**

Customer Request: C160 renovation

Completion Notes:

Service/Install Ticket

Date Selector:

07/30/2024

Service Report #:

38980

District Name:

RVCC

Location Name:

College Center

Panel Status on Arrival:

63 total troubles and disables

Panel Status on Departure:

63 total troubles and disables

Job Complete:

No - Not Complete

Tech 1:

MH

Tech 2:

RM

Reason for Call:

C160 Renovation

Work Performed:

Continued install, cut tiles for devices. Mounted hanger bars and boxes. Mounted and wired bases for detectors. Still have 2 rooms to finish and to get the feeds into C160.

Equipment Used:

x24 - Hanger Bars

x13 - 4" Round Box

x11 - 4" Square Deep Box

x11 - Smoke Detector Base

Service Fusion #:

24-1998

Date Selector:

07/31/2024

Service Report #:

38981

District Name:

RVCC

Location Name:

College Center

Panel Status on Arrival:

65 total troubles + disabled
Panel Status on Departure:

78 Troubles + Disables

Job Complete:

No - Not Complete

Tech 1:

MH

Tech 2:

RM

Tech 3:

JM

Tech 4:

CH

Reason for Call:

C160 Renovation

Work Performed:

Mounted last 3 hanger bars. Cut tiles for devices. Mounted and wired all speaker strobes. Mounted and wired lasted 3 detector bases. Put smoke heads in all bases and numbered devices. Removed exposed wire through wall after Reno and his wires. Labeled devices with numbers. Devices need to be programmed in.

Equipment Used:

x14 - Speaker Strobe Red Ceiling Mount Marked FIRE

x3 - Hanger Bars

x3 - 4" Deep Square Box

65ft - 16/4 - Fire Wire

x3 Smoke Detector Base

x14 - Addressable photo electric smoke detector

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate	28.50	\$76.00	\$0.000	\$2,166.00
Hangbar	24.00	\$28.00	\$0.000	\$672.00
Smoke Detector Base	14.00	\$44.00	\$0.000	\$616.00
Speaker Strobe Red Ceiling Mount Marked FIRE	14.00	\$141.00	\$0.000	\$1,974.00
 Addressable photo electric smoke detector	14.00	\$145.00	\$0.000	\$2,030.00
MISC Item	1.00	\$181.50	\$0.000	\$181.50
Solid-16/4 Fire alarm wire	0.13	\$360.00	\$0.000	\$46.80

CUSTOMER MESSAGE

Invoice Total:

\$7,686.30

Sales Tax:

\$0.00

Payments (-):

\$0.00

Total Due:

\$7,686.30

763-C24002-6020-70

Invoice 202500245

FAST

**Fire and
Security
Technologies**

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	01/31/2025
Purchase Order #:	
TERMS:	NET 60
Due Date:	04/01/2025

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

SERVICE LOCATION

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

Job Number: 250191 Job Category: Repair/Service

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCNJ 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52

Customer Request: Issues from Drill

Completion Notes:

date 1-22-25
techs rob ryan m
job status incomplete

work performed - customer stated no strobe first floor CC no A/V ground floor CC

took down speaker strobe ground floor - no voltage either side. 1st floor take down opens speaker but not strobe - no voltage on strobe 1st floor

speakers report back to m22 main entrance closet amp - program shows two 1st floor college center booster circuits on m03 01 and 02 - both of them are unsupervised in program.

was able to read 3.6k on circuit 2 nothing on circuit 1 however circuit 2 splices into additional 2 wires in other amp that's not m22

date 1-27-25
techs rob
job status incomplete

work performed - tested all pull stations on first floor CC - confirmed alarms reported. fixed strobe outside w214 that wasn't seated properly

started tracing first floor CC again - without being able to ring had to use toner and things just weren't adding up for me. would almost be easier to run new wire as there's only 6-8 devices in the area.

started troubleshooting second floor CC - appears to be open circuit in one of the renovated areas (c-180 i believe) - since the circuit isn't supervised we were never aware of issues when tying in new stuff.

there's voltage on device that's outside of c180 area that goes directly into c180 to the device that i tied into. circuit going into the wire nuts has power, but not on the device meaning voltage is lost coming back somewhere. once open is repaired 2nd floor should light back up

date 1-29-25
techs rob
job status complete

work performed - set off 2nd floor strobes with batteries - found bent metal prong causing the open circuit - repaired and now 2nd floor functional

ran new wire for 1st floor - tied into adjunct area - advised customer to keep an eye out for those areas next fire drill to confirm functional

equipment used - (700ft) 16/4 fire rated cable

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate -1/22	4.00	\$76.00	\$0.000	\$304.00
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate -1/27	7.00	\$76.00	\$0.000	\$532.00
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate -1/29	7.50	\$76.00	\$0.000	\$570.00
Solid-16/4 Fire alarm wire	1.00	\$360.00	\$0.000	\$360.00
Solid-16/4 Fire alarm wire	0.40	\$360.00	\$0.000	\$144.00

CUSTOMER MESSAGE

Invoice Total:	\$1,910.00
Sales Tax:	\$0.00
Payments (-):	\$0.00
Total Due:	\$1,910.00

Invoice 202402483 ✓

FAST

**Fire and
Security
Technologies**

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

DATE:

11/13/2024 ✓

Purchase Order #:

Pired.

TERMS:

NET 60

Due Date:

01/12/2025

SERVICE LOCATION

Somerset Hall
75 Lamington Road
Branchburg, NJ, 08876

Job Number: 242172

Job Category: Repair/Service

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCNJ 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52

Customer Request: S302

Completion Notes:

Service/Install Ticket

Date Selector:

08/16/2024

Service Report #:

39005

District Name:

RVCC

Location Name:

Somerset Hall

Panel Status on Arrival:

Troubles + Disables

Panel Status on Departure:

Troubles + Disables

Job Complete:

No - Not Complete

Tech 1:

MH

Tech 2:

RM

Tech 3:

JM

Tech 4:

CH

Reason for Call:

S302

Work Performed:

Ran new wire for SLC and NAC devices in s302. Mounted hanger bars and boxes on ceiling grid. Have to continue mounting hanger bars and boxes and mount devices.

Equipment Used:

450ft - 16/4 - Fire Wire

x24 - Hanger Bars

x17 - 4" Round Box

x7 - 4" Deep Square Box

500ft - 18/2 - Fire Wire

Service/Install Ticket

Date Selector:

09/12/2024

Service Report #:

40317

District Name:

RVCC
 Location Name:
 Somerset Hall
 Panel Status on Arrival:
 Normal
 Panel Status on Departure:
 Normal
 Job Complete:
 No - Not Complete

Tech 1:

MH

Tech 2:

RM

Tech 3:

JM

Tech 4:

CH

Reason for Call:

3rd Floor

Work Performed:

Finished installing all devices and dropped into ceiling tiles. Devices are not numbered/ addressed.

date 11-11-24

techs rob jason m

job status complete

work performed - upon arrival open circuit for pull station with no description. located at west building main entry and replaced.

Labeled and programmed all smoke heads in somerset 3rd floor suite

equipment used - (1) ADDRESSABLE PULL STATION, SINGLE ACTION, KEY RESET

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate	70.00	\$76.00	\$0.000	\$5,320.00
Solid-16/4 Fire alarm wire	0.90	\$360.00	\$0.000	\$324.00
Hangbar	24.00	\$28.00	\$0.000	\$672.00
MISC Item	1.00	\$120.00	\$0.000	\$120.00
Solid 18/2 Wire Fire Wire	0.50	\$242.00	\$0.000	\$121.00
Solid-16/4 Fire alarm wire	0.28	\$360.00	\$0.000	\$100.80
ADDRESSABLE PULL STATION, SINGLE ACTION, KEY RESET	1.00	\$215.00	\$0.000	\$215.00



CUSTOMER MESSAGE

Invoice Total:

\$6,872.80

Sales Tax:

\$0.00

Payments (-):

\$0.00

Total Due:

\$6,872.80

763-C 24008-6545-70

Invoice 202402452

FAST

**Fire and
Security
Technologies**

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

DATE:

11/11/2024

Purchase Order #:

Direct

TERMS:

NET 60

Due Date:

01/10/2025

SERVICE LOCATION

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

Job Number: 241997

Job Category: Repair/Service

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCNJ 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52

Customer Request: C143 Learning Center

Completion Notes:

Service/Install Ticket

Date Selector:

08/01/2024

Service Report #:

38984

District Name:

RVCC

Location Name:

College Center

Panel Status on Arrival:

78 total

Panel Status on Departure:

78 total

Job Complete:

No - Not Complete

Tech 1:

MH

Tech 2:

JM

Reason for Call:

C143 Renovation

Work Performed:

Ran new SLC and NAC circuit in C143. Cut tiles for devices. Mounted hanger bars and boxes. Mounted bases for detectors.

Equipment Used:

450ft - 16/4 - Fire Wire

450ft - 18/2 - Fire Wire

x18 - Hanger Bars

x15 - 4" Round Box

x3 - 4" Deep Square Box

x15 - Smoke Detector Base

Service/Install Ticket

Date Selector:

08/02/2024

Service Report #:

38986

District Name:

RVCC

Location Name:

College Center

Panel Status on Arrival:

80 Total
Panel Status on Departure:
80 Total
Job Complete:
No - Not Complete

Tech 1:
MH

Tech 2:
JM

Reason for Call:
C143 Renovation

Work Preformed:
Continued mounting hanger bars and boxes. Mounted and wired speaker strobes. Still have to continue.

Equipment Used:
x12 - Hanger Bars
x12 - 4" Square Deep Box
x10 - Speaker Strobe Red Ceiling Mount Marked FIRE

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate	20.00	\$76.00	\$0.000	\$1,520.00
Solid-16/4 Fire alarm wire	0.90	\$360.00	\$0.000	\$324.00
Solid 18/2 Wire Fire Wire	0.45	\$242.00	\$0.000	\$108.90
Smoke Detector Base	15.00	\$44.00	\$0.000	\$660.00
MISC Item	1.00	\$240.00	\$0.000	\$240.00
Hangbar	12.00	\$28.00	\$0.000	\$336.00
Speaker Strobe Red Ceiling Mount Marked FIRE	10.00	\$141.00	\$0.000	\$1,410.00

CUSTOMER MESSAGE

Invoice Total: \$4,598.90
Sales Tax: \$0.00
Payments (-): \$0.00
Total Due: \$4,598.90 ✓

763-624002-6545-70

Invoice 202402179 ✓

FAST

**Fire and
Security
Technologies**

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:

10/04/2024 ✓

Purchase Order #:

Direct

TERMS:

NET 60

Due Date:

12/03/2024

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

SERVICE LOCATION

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

Job Number: 242570

Job Category: Repair/Service

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCN 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52

Customer Request: Trouble in/out - Somerset/Hunterdon

Completion Notes:

date 9-27-24
techs rob julian
job status incomplete

work performed - upon arrival 2 ground faults. isolated one to m06 booster panel in phys ed. narrowed down from 145 troubles to 17 - will return to continue tracing.

date 10-1-24
techs rob kenny
job status incomplete

work performed - upon arrival two ground faults and battery trouble. replaced batteries in hunterdon RPS and trouble cleared. traced one ground in phys ed building and was able to clear - after 2 network troubles came in - will have to work with tech support to clear

equipment used - (2) Fire Rated Fire Alarm Battery 202408

date 10-2-24
techs rob nick m julian
job status complete

work performed - correctly network sync error with tech support - just one ground fault remained. traced to ride adjunct area and was able to clear ground fault. system returned to normal. replace a head in rise adjunct that was going in and out of trouble after clearing ground fault.

began running cable for renovated H228 room

equipment used - 125ft 18/2 and 125ft 16/4 fire rated cable - (1) Addressable photo electric smoke detector

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate -9/27	14.00	\$76.00	\$0.000	\$1,064.00
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate -10/1	15.50	\$76.00	\$0.000	\$1,178.00

Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate -10/2	21.00	\$76.00	\$0.000	\$1,596.00
Fire Rated Fire Alarm Battery 202408	2.00	\$95.00	\$0.000	\$190.00
Solid 18/2 Wire Fire Wire	0.13	\$242.00	\$0.000	\$31.46
Solid-16/4 Fire alarm wire	0.25	\$360.00	\$0.000	\$90.00
 Addressable photo electric smoke detector	1.00	\$145.00	\$0.000	\$145.00

CUSTOMER MESSAGE

Invoice Total:	\$4,294.46
Sales Tax:	\$0.00
Payments (-):	\$0.00
Total Due:	\$4,294.46 ✓

763- C24005 - 6545-70 ✓

Invoice 202402237



**Fire and
Security
Technologies**

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:

10/14/2024

Purchase Order #:

TERMS:

NET 60

Due Date:

12/13/2024

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

SERVICE LOCATION

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

Job Number: 241140

Job Category: Installation

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCNJ 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52

Customer Request: Install speaker strobes

Completion Notes:

Service/Install Ticket

Date Selector:

04/26/2024

Service Report #:

38884

District Name:

RVCC

Location Name:

Pebble Beach

Panel Status on Arrival:

Trouble

Panel Status on Departure:

Trouble

Job Complete:

No - Not Complete

Tech 1:

MH

Tech 2:

RM

Reason for Call:

Add speaker strobes

Work Performed:

Flush mounted one speaker strobe on back wall. Had to run new wire to extend to flush mount.

Equipment Used:

30ft 16/4 wire

Service/Install Ticket

Date Selector:

10/10/2024

Service Report #:

40360

District Name:

RVCC

Location Name:

Pebble Beach

Panel Status on Arrival:

Normal

Panel Status on Departure:

Normal

Job Complete:

Yes - Complete

Tech 1:
MH
Tech 2:
RM
Tech 3:
RB
Tech 4:
JG

Reason for Call:
Reno

Work Performed:

Ran wire for added devices. Cut ceiling tiles and mounted hanger bars and boxes. Mounted and wired speaker strobes. Mounted and wired SLC bases and installed detectors. Programmed detectors into system

Equipment Used:

100ft - 18/2 Fire Wire

100ft - 16/4 Fire Wire

x13 - Hanger Bars

x5 - 4" Round Box

x5 - 4" Deep Square Box

x5 - Addressable photo electric smoke detector

x5 - Speaker Strobe Red Ceiling Mount Marked FIRE

x5 - Smoke Detector Base

	Description	Qty	Rate	Tax	Total
	Vehicle Allowance -4/26	0.00	\$0.00	\$0.000	\$0.00
	Discount Labor Rate-4/26	3.00	\$76.00	\$0.000	\$228.00
	Vehicle Allowance-10/10	0.00	\$0.00	\$0.000	\$0.00
	Discount Labor Rate-10/10	15.00	\$76.00	\$0.000	\$1,140.00
	Solid-16/4 Fire alarm wire	0.26	\$360.00	\$0.000	\$93.60
	Solid 18/2 Wire Fire Wire	0.10	\$242.00	\$0.000	\$24.20
	Hangbar	13.00	\$28.00	\$0.000	\$364.00
	Addressable photo electric smoke detector	5.00	\$145.00	\$0.000	\$725.00
	Speaker Strobe Red Ceiling Mount Marked FIRE	5.00	\$141.00	\$0.000	\$705.00
	Smoke Detector Base	5.00	\$44.00	\$0.000	\$220.00
	MISC Item	10.00	\$5.00	\$0.000	\$50.00

CUSTOMER MESSAGE

Invoice Total: **\$3,549.80**
Sales Tax: **\$0.00**
Payments (-): **\$0.00**
Total Due: **\$3,549.80**

Invoice 202500310

FAST Fire and
Security
Technologies

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	02/06/2025
Purchase Order #:	
TERMS:	NET 60
Due Date:	04/07/2025

BILL TO
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

SERVICE LOCATION
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

Job Number: 250105	Job Category: Repair/Service	CO-OPS Fire Extinguishers - MCCPC #13A / EdData #15A / ESCNJ 24/25-11 Fire Alarms - 57-CCCPS, MCCPC 52
Customer Request: Sprinkler issues / quarterlies		

Completion Notes:

Service/Install Ticket

Date Selector:

01/08/2025

Service Report #:

37151

District Name:

RVCC

Location Name:

RVCC

Panel Status on Arrival:

Troubles + Disables

Panel Status on Departure:

Troubles + Disables

Job Complete:

No - Not Complete

Tech 1:

MH

Tech 2:

RM

Reason for Call:

Sprinkler Testing

Work Preformed:

Tested sprinklers with testing company. Need tamper and water flow descriptions updated in west building.

date 1-13-25

techs rob

job status complete

work performed - went to locations that had bad descriptions or incorrect device types - corrected programming for sprinkler devices in west building and student center/bateman - confirmed ATCC devices were already in program.

replaced two heat detectors in h200 that were going in and out of trouble while on site

equipment used - (2) ADDRESSABLE THRL DETC FIX TEMP 135°F, RATE OF RISE, WHITE

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00

Invoice 202500188 ✓

FAST

Fire and
Security
Technologies

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

DATE:

01/23/2025 ✓

Purchase Order #:

Direct

TERMS:

NET 60

Due Date:

03/24/2025

SERVICE LOCATION

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

Job Number: 243182

Job Category: Repair/Service

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCNJ 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52

Customer Request: New C160

Completion Notes:

12/17/2024

Service Report #:

30554

District Name:

RVCC

Location Name:

New C160

Panel Status on Arrival:

1 Trouble

Panel Status on Departure:

1 Trouble

Job Complete:

No - Not Complete

Tech 1:

MH

Tech 2:

RM

Tech 3:

JM

Reason for Call:

Reno

Work Performed:

Ran NAC + SLC circuit in new re-numbered room C160. Have to wait for grid to be installed to drop into ceiling grid/tiles.

Equipment Used:

240ft - 18/2 Fire Wire

240ft - 16/4 Fire Wire

01/10/2025

Service Report #:

37153

District Name:

RVCC

Location Name:

C160

Panel Status on Arrival:

Missing Relay Student Center M133

Panel Status on Departure:

Missing Relay Student Center M133

Job Complete:

No - Not Complete


RVCC

FEB 07 2025

Facilities

Tech 1:
MH
Tech 2:
JM
Reason for Call:
C160 Reno
Work Performed:
Assembled hangers and boxes. Cut ceiling tiles. Mounted ceiling tiles and boxes. Mounted and wired speaker strobes and detector bases.
Have to wait for ceiling grid to be finished in one room and have one other office to add 2 devices. Will tie circuits in at very end.
Equipment Used:
x12 - Hanger Bars
x6 - 4" Round Box
x6 - 4" Square Deep Box
x6 - SPEAKER STROBE LED RED CEILING - LED
x6 - Detector Base

01/14/2025
Service Report #:
37156
District Name:
RVCC
Location Name:
C160
Panel Status on Arrival:
Missing Relay
Panel Status on Departure:
Normal
Job Complete:
No - Not Complete

Tech 1:
MH
Tech 2:
RM
Tech 3:
JM
Reason for Call:
Reno
Work Performed:
Mounted 2 hanger bars and boxes. Mounted one speaker strobe and one detector base. Mounted smoke and heat detectors and addressed them. Swapped out LED speaker strobes to regular. Tied SLC circuit into system.
Programmed detectors into system.
Still have to wait for ceiling grid in one room.
Equipment Used:
x2 - Hanger Bars
x2 - 4" Deep Square Box
x2 - 4" Round Box
x8 - SPEAKER STROBE LED RED CEILING - LED
x1 - Detector Base
x2 - Addressable photo electric smoke detector
x6 - ADDRESSABLE THRML DETC FIX TEMP 135°F, RATE OF RISE, WHITE

01/17/2025
Service Report #:
37167
District Name:
RVCC
Location Name:
C-160
Panel Status on Arrival:
Normal
Panel Status on Departure:
Normal
Job Complete:
Yes - Complete
Tech 1:
MH
Tech 2:
RM
Reason for Call:
Reno
Work Performed:

Mounted last 2 hanger bars and boxes: Cut ceiling tiles, Mounted and wired speaker strobe and SLC. Tied speaker strobe circuit into system. C-160 is now complete.

Equipment Used:

Total Equipment

x18 - Hanger Bars

x9 - 4" Square Deep Box

x9 - 4" Round Box

x9 - SPEAKER STROBE LED RED CEILING - LED

x9 - Detector Bases

x2 - Addressable photo electric smoke detector

x7 - ADDRESSABLE THRML DETC FIX TEMP 135°F, RATE OF RISE, WHITE

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate -12/17	18.00	\$76.00	\$0.000	\$1,368.00
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate -1/10	12.00	\$76.00	\$0.000	\$912.00
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate -1/14	15.00	\$76.00	\$0.000	\$1,140.00
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate -1/17	3.00	\$76.00	\$0.000	\$228.00
Solid 18/2 Wire Fire Wire	0.24	\$242.00	\$0.000	\$58.08
Solid-16/4 Fire alarm wire	0.48	\$360.00	\$0.000	\$172.80
Hangbar	32.00	\$28.00	\$0.000	\$896.00
SPEAKER STROBE LED RED CEILING - LED	23.00	\$153.00	\$0.000	\$3,519.00
Smoke Detector Base	16.00	\$44.00	\$0.000	\$704.00
MISC Item	34.00	\$5.00	\$0.000	\$170.00
 Addressable photo electric smoke detector	4.00	\$145.00	\$0.000	\$580.00
 ADDRESSABLE THRML DETC FIX TEMP 135°F, RATE OF RISE, WHITE	13.00	\$121.00	\$0.000	\$1,573.00
15% Discount Discount off standard pricing	1.00	\$-1,698.00	\$0.000	\$-1,698.00

CUSTOMER MESSAGE

Invoice Total:

\$9,622.88

Sales Tax:

\$0.00

Payments (-):

\$0.00

Total Due:

\$9,622.88 ✓

763-C24002-6020-70

Invoice 202500368



**Fire and
Security
Technologies**

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

DATE:

02/18/2025

Purchase Order #:

TERMS:

NET 60

Due Date:

04/19/2025

SERVICE LOCATION

Somerset/Hunterdon Hall
118 Lamington Road
North Branch, NJ, 08876

Job Number: 250411

Job Category: Repair/Service

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCNJ 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52

Customer Request: Ground Fault

Completion Notes:

date 2-17-25
techs rob mike
job status complete

work performed - upon arrival system normal. checked panel history - alarm was for 1st FL hunterdon but alarm has since been clear.
ground fault restored itself at 3am.

located hanging speaker strobe and repaired as per customers request. with no troubles on the panel no troubleshooting required

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate	3.00	\$76.00	\$0.000	\$228.00

CUSTOMER MESSAGE

Invoice Total: \$228.00
Sales Tax: \$0.00
Payments (-): \$0.00
Total Due: \$228.00

Invoice 202500462

FAST

**Fire and
Security
Technologies**

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:

02/28/2025

Purchase Order #:

TERMS:

NET 60

Due Date:

04/29/2025

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

SERVICE LOCATION

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

Job Number: 250501

Job Category: Repair/Service

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCNJ 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52

Customer Request: Relocate Horn strobe

Completion Notes:

Service/Install Ticket

Date Selector:

02/27/2025

Service Report #:

37512

District Name:

Raritan Valley

Location Name:

Hunterdon RVCC

Panel Status on Arrival:

Normal

Panel Status on Departure:

Normal

Job Complete:

Yes - Complete

Location Address:

118 Lamington Rd, Branchburg, NJ 08876

Tech 1:

SC

Reason for Call:

Relocate speaker strobe

Work Performed:

Relocated speaker strobe from wall to ceiling. Hunter don level 1-1.

Equipment Used:

(1) SPEAKER STROBE LED RED CEILING - LED

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate	3.00	\$76.00	\$0.000	\$228.00
SPEAKER STROBE LED RED CEILING - LED	1.00	\$153.00	\$0.000	\$153.00

CUSTOMER MESSAGE

Invoice Total:

\$381.00

Sales Tax:

\$0.00

Payments (-):

\$0.00

Total Due:

\$381.00

Invoice 202500613

FAST

**Fire and
Security
Technologies**

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:

03/21/2025

Purchase Order #:

TERMS:

NET 60

Due Date:

05/20/2025

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

SERVICE LOCATION

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

Job Number: 250655

Job Category: Repair/Service

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCNJ 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52

Customer Request: Trouble - Power Plant

Completion Notes:

Service/Install Ticket

Date Selector:

03/20/2025

Service Report #:

37633

District Name:

RVCC

Location Name:

Power Plant

Panel Status on Arrival:

Normal

Panel Status on Departure:

Normal

Job Complete:

Yes - Complete

Tech 1:

MH

Tech 2:

AP

Reason for Call:

Power Plant Alarm Trouble

Work Performed:

Checked history on both Fire and CO panel, only recent History is for Battery trouble on CO panel. Found batteries badly corroded.
Replaced both backed up batteries and replaced jumper wire.

Equipment Used:

x2 - Fire Rated Fire Alarm Battery 202408

x1 - Battery Jumper Wire

Description	Qty	Rate	Tax	Total
Vehicle Allowance Vehicle Allowance	1.00	\$0.00	\$0.000	\$0.00
Discount Regular Labor Discount Regular Labor - Monday to Friday 7:30AM to 4:00 PM.	3.00	\$76.00	\$0.000	\$228.00

Fire Rated Fire Alarm Battery 202408	2.00	\$95.00	\$0.000	\$190.00
MISC Item	1.00	\$15.00	\$0.000	\$15.00

CUSTOMER MESSAGE

Invoice Total:	\$433.00
Sales Tax:	\$0.00
Payments (-):	\$0.00
Total Due:	\$433.00

Invoice 202500724

FAST

Fire and
Security
Technologies

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:

04/04/2025

Purchase Order #:

TERMS:

NET 60

Due Date:

06/03/2025

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

SERVICE LOCATION

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

Job Number: 250775

Job Category: Repair/Service

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCNJ 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52

Customer Request: System in alarm

Completion Notes:

Service/Install Ticket

Date Selector:

04/04/2025

Service Report #:

37642

District Name:

RVCC

Location Name:

Somerset/Hunterdon

Panel Status on Arrival:

Normal

Panel Status on Departure:

Normal

Job Complete:

Yes - Complete

Tech 1:

MH

Reason for Call:

System in Alarm

Work Performed:

History shows Alarm from 2 wire detector M07M050. Traditional device circuit/loop and panel is normal so no way of pin pointing device that went into alarm. Advised not to reset panel so we can fin alarms. Located circuit M07M050 on 3rd floor Somerset Hall.

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate	3.00	\$76.00	\$0.000	\$228.00

CUSTOMER MESSAGE

Invoice Total:

\$228.00

Sales Tax:

\$0.00

Payments (-):

\$0.00

Total Due:

\$228.00

Invoice 202500744



**Fire and
Security
Technologies**

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	04/07/2025
Purchase Order #:	
TERMS:	NET 60
Due Date:	06/06/2025

BILL TO
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

SERVICE LOCATION
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

Job Number: 250766	Job Category: Repair/Service	CO-OPS Fire Extinguishers - MCCPC #13A / EdData #15A / ESCNJ 24/25-11 Fire Alarms - 57-CCCPS, MCCPC 52
Customer Request: Meet with Sprinkler		

Completion Notes:

date 3-4-25
techs rob
job status complete

work performed - tested all sprinkler devices with sprinkler company and philip weaver - confirmed all devices reported and descriptions were correct

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate	3.50	\$76.00	\$0.000	\$266.00

CUSTOMER MESSAGE

Invoice Total:	\$266.00
Sales Tax:	\$0.00
Payments (-):	\$0.00
Total Due:	\$266.00

Invoice 202500762

FAST

**Fire and
Security
Technologies**

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	04/09/2025
Purchase Order #:	
TERMS:	NET 60
Due Date:	06/08/2025

BILL TO
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

SERVICE LOCATION
Workforce Building 118 Lamington Road North Branch, NJ, 08876

Job Number: 250699	Job Category: Repair/Service	CO-OPS Fire Extinguishers - MCCPC #13A / EdData #15A / ESCNJ 24/25-11 Fire Alarms - 57-CCCPS, MCCPC 52
Customer Request: Troubles on system		

Completion Notes:

Date Selector:

03/28/2025

Service Report #:

25408

District Name:

RVCC

Location Name:

Workforce

Panel Status on Arrival:

Missing Heat Autoshop M97S001, Phone Line 1 Trouble, Auto Test Failure

Panel Status on Departure:

Normal

Job Complete:

No - Not Complete

Tech 1:

MH

Tech 2:

AP

Reason for Call:

Troubles On FACP

Work Performed:

Located Heat Detector in Autoshop RM125 and replaced with new detector, trouble cleared. Found Dialer had 2 troubles, Low Battery, and failure to communicate. Replaced back up battery for dialer, cleared that trouble off dialer. Performed reset, and power cycle and dialer still won't send signals out. Recommend replacing TelGuard.

Equipment Used:

x1 - Fire Rated Fire Alarm Battery 202408

date 4-4-25

techs rob

job status complete

work performed - replaced cell dialer and system returned to normal. sent signals to central station and verified signals were received.

equipment used - (1) TG-7 cell dialer

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00

Discount Labor Rate -3/28	3.00	\$76.00	\$0.000	\$228.00
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate -4/4	3.00	\$76.00	\$0.000	\$228.00
MISC Item Cellular Dialer	1.00	\$575.00	\$0.000	\$575.00
Fire Rated Fire Alarm Battery 202408	1.00	\$95.00	\$0.000	\$95.00

CUSTOMER MESSAGE

Invoice Total:	\$1,126.00
Sales Tax:	\$0.00
Payments (-):	\$0.00
Total Due:	\$1,126.00

Invoice 202500899

FAST

**Fire and
Security
Technologies**

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

SERVICE LOCATION

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

Job Number: 250961
Types)

Job Category: Monitoring (All

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCNJ 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52

Customer Request: 102 Lamington Road - Annual Monitoring

Completion Notes:

Annual Alarm Monitoring for 102 Lamington Road

Description	Qty	Rate	Tax	Total
Fire or Fire/Burg Alarm Monitoring W/Daily Test Annual Fire or Fire/Burg Alarm Monitoring W/Daily Test (IP/Cell Data and Central Station Monitoring) 102 Lamington Road Account 9348456	1.00	\$768.00	\$0.000	\$768.00
Coverage Date - 1 Year This invoice is for annual alarm monitoring. Unless otherwise noted - The Coverage Date is from the 1st day of the month the invoice is dated - plus one year.	1.00	\$0.00	\$0.000	\$0.00

CUSTOMER MESSAGE

Invoice Total: \$768.00
Sales Tax: \$0.00
Payments (-): \$0.00
Total Due: \$768.00

Invoice 202500882

FAST

**Fire and
Security
Technologies**

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

DATE:

05/01/2025

Purchase Order #:

TERMS:

NET 60

Due Date:

06/30/2025

SERVICE LOCATION

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

Job Number: 250700

Job Category: Installation

**CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCNJ 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52**

Customer Request: Student Center 3rdFL

Completion Notes:

Service/Install Ticket

Date Selector:

04/28/2025

Service Report #:

37032

District Name:

Rvcc

Location Name:

Rvcc

Panel Status on Arrival:

1 trouble

Panel Status on Departure:

Normal

Job Complete:

Yes - Complete

Tech 1:

RE

Tech 2:

SC

Reason for Call:

library speaker strobe

Work Performed:

Added 2 speaker strobes in library offices, there was a missing heat in kitchen hall, once replaced, the system went normal

Equipment Used:

40 ft 16/4 fire wire

(2) Indoor Selectable Output Horn Strobe, 4-Wire, Ceiling Mount

(1) ADDRESSABLE THRLM DETC FIX TEMP 135°F, RATE OF RISE, WHITE

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate	7.00	\$76.00	\$0.000	\$532.00
Solid-16/4 Fire alarm wire	0.08	\$360.00	\$0.000	\$28.80
ADDRESSABLE THRLM DETC FIX	1.00	\$121.00	\$0.000	\$121.00

Invoice 202500896



**Fire and
Security
Technologies**

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:

05/01/2025

Purchase Order #:

TERMS:

NET 60

Due Date:

06/30/2025

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

SERVICE LOCATION

118 Lamington Road
North Branch, NJ, 08876

Job Number: 250935
Types)

Job Category: Monitoring (All

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCNJ 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52

Customer Request: AM0502 - Elevator Phone Monitoring

Completion Notes:
Annual Elevator Phone Monitoring

Description

Qty

Rate

Tax

Total

Elevator Phone

Annual Elevator Phone Monitoring
(Central Station Only)
Workforce Elev #9082310626

1.00

\$384.00

\$0.000

\$384.00

Coverage Date - 1 Year

This invoice is for annual alarm
monitoring. Unless otherwise noted -
The Coverage Date is from the 1st day
of the month the invoice is dated - plus
one year.

1.00

\$0.00

\$0.000

\$0.00

CUSTOMER MESSAGE

Invoice Total:

\$384.00

Sales Tax:

\$0.00

Payments (-):

\$0.00

Total Due:

\$384.00

Invoice 202500897



**Fire and
Security
Technologies**

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:

05/01/2025

Purchase Order #:

TERMS:

NET 60

Due Date:

06/30/2025

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

SERVICE LOCATION

118 Lamington Road
North Branch, NJ, 08876

Job Number: 250936
Types)

Job Category: Monitoring (All

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCNJ 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52

Customer Request: AM0503 - Annual Cellular Monitoring

Completion Notes:
Annual Cellular Monitoring

Description

Qty

Rate

Tax

Total

**Fire or Fire/Burg Alarm Monitoring
W/Daily Test**

Annual Fire or Fire/Burg Alarm
Monitoring W/Daily Test (IP/Cell Data and
Central Station Monitoring)
Workforce Building #0619798

1.00

\$768.00

\$0.000

\$768.00

Coverage Date - 1 Year

This invoice is for annual alarm
monitoring. Unless otherwise noted -
The Coverage Date is from the 1st day
of the month the invoice is dated - plus
one year.

1.00

\$0.00

\$0.000

\$0.00

New Jersey

6.625%

\$0.00

CUSTOMER MESSAGE

Invoice Total:

\$768.00

Sales Tax:

\$0.00

Payments (-):

\$0.00

Total Due:

\$768.00

Invoice 202500898



**Fire and
Security
Technologies**

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

SERVICE LOCATION

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

Job Number: 250960
Types)

Job Category: Monitoring (All

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCNJ 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52

Customer Request: 74 Lamington Road - Annual Monitoring

Completion Notes:

Annual Alarm Monitoring for 74 Lamington Road

Description	Qty	Rate	Tax	Total
Fire or Fire/Burg Alarm Monitoring W/Daily Test Annual Fire or Fire/Burg Alarm Monitoring W/Daily Test (IP/Cell Data and Central Station Monitoring) 74 Lamington Road Account 9348452	1.00	\$768.00	\$0.000	\$768.00
Coverage Date - 1 Year This invoice is for annual alarm monitoring. Unless otherwise noted - The Coverage Date is from the 1st day of the month the invoice is dated - plus one year.	1.00	\$0.00	\$0.000	\$0.00

CUSTOMER MESSAGE

Invoice Total: \$768.00
Sales Tax: \$0.00
Payments (-): \$0.00
Total Due: \$768.00

Invoice 202500980



217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	05/15/2025
Purchase Order #:	
TERMS:	NET 60
Due Date:	07/14/2025

BILL TO
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

SERVICE LOCATION
Somerset/Hunterdon Hall 118 Lamington Road North Branch, NJ, 08876

Job Number: 250922	Job Category: Repair/Service	CO-OPS Fire Extinguishers - MCCPC #13A / EdData #15A / ESCNJ 24/25-11 Fire Alarms - 57-CCCPS, MCCPC 52
Customer Request: Add Speaker strobe in Library		

Completion Notes:

Date Selector:

04/28/2025

Service Report #:

37032

District Name:

RVCC

Location Name:

Library

Panel Status on Arrival:

1 Trouble

Panel Status on Departure:

Normal

Job Complete:

Yes - Complete

Tech 1:

RE

Tech 2:

SC

Reason for Call:

Add speaker strobe in library

Work Performed:

Added 2 speaker strobes in library offices. There was also a missing heat in the kitchen hall, once replaced the system went normal.

Equipment Used:

40ft 16/4 wire

2x Speaker Strobe Red Ceiling Mount Marked FIRE

1x ADDRESSABLE THRLM DETC FIX TEMP 135°F, RATE OF RISE, WHITE

RVCC
MAY 23 2025
Facilities

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate	7.00	\$76.00	\$0.000	\$532.00
Solid-16/4 Fire alarm wire	0.08	\$360.00	\$0.000	\$28.80
Speaker Strobe Red Ceiling Mount Marked FIRE	2.00	\$141.00	\$0.000	\$282.00

ADDRESSABLE THRML DETC FIX
TEMP 135°F, RATE OF RISE, WHITE

1.00

\$121.00

\$0.000

\$121.00



CUSTOMER MESSAGE

Invoice Total:

\$963.80

Sales Tax:

\$0.00

Payments (-):

\$0.00

Total Due:

\$963.80

Invoice 202501015✓

FAST Fire and
Security
Technologies

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

DATE:

05/21/2025 ✓

Purchase Order #:

P0037933 ✓

TERMS:

NET 60

Due Date:

07/20/2025

SERVICE LOCATION

Workforce Building
118 Lamington Road
North Branch, NJ, 08876

Job Number: 242933

Job Category: Parts & Smarts

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCN] 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52

Customer Request: Workforce Building Addition

Completion Notes:

Workforce Building Addition as per Quote 202300677

Description	Qty	Rate	Tax	Total
Sales Order - as per quote Parts and programming. Per Notes on Drawings, Fire and Security Technologies will provide / install / program / test the devices for the fire alarm. The electrical contractor is responsible for all wiring / conduit / Boxes necessary for complete system installation.	1.00	\$72,350.00	\$0.000	\$72,350.00

CUSTOMER MESSAGE

Invoice Total:

\$72,350.00

Sales Tax:

\$0.00

Payments (-):

\$0.00

Total Due:

\$72,350.00✓

763-C24001-7010-70

Invoice 202501414

FAST

Fire and
Security
Technologies

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207



DATE:

07/16/2025

Purchase Order #:

TERMS:

NET 60

Due Date:

09/14/2025

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

SERVICE LOCATION

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

Job Number: 251535

Job Category: Repair/Service

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCNJ 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52

Customer Request: False Alarm

Completion Notes:

Service/Install Ticket

Date Selector:

07/08/2025

Service Report #:

26793

District Name:

RVCC

Location Name:

Power Plant / Planetarium

Panel Status on Arrival:

x3 Missing Detectors Main Building Panel

Panel Status on Departure:

x3 Missing Detectors Main Building Panel

Job Complete:

No - Not Complete

Tech 1:

MH

Reason for Call:

False Alarm

Work Performed:

Originally told Fire Alarm in Power Plant. Checked both Fire + C0 Panel History and no Alarms found recent or 7-7-25. Then advised False Alarm in Planetarium so checked main building history no Alarms found 7-7-25 just ground fault in and out many times around 7:40pm. will return to locate and replace 3 "missing" detectors. If this was an Alarm Advise RVCC + Fire Dept. not to reset fire panel, leave in alarm and silence. system still works in alarm.

Service/Install Ticket

Date Selector:

07/14/2025

Service Report #:

37440

District Name:

RVCC

Location Name:

Workforce and Power Plant

Panel Status on Arrival:

Both normal

Panel Status on Departure:

Both normal

Job Complete:

Yes - Complete

Location Address:

RVCC

JUL 17 2025

Facilities

Rt 28 Branchburg NJ
Tech 1:
Nick M
Reason for Call:

Check Workforce history for CO activations, check Power Plant for fire alarm activation

Work Preformed:

Workforce: Had 4 CO activations (supervisory, with sounder activation) on 07/09. They were not reset and unsilenced until 07/14. Documented and sent to Jason and DJ. I believe these to be credible CO activations.

Power Plant: Sent Zone 0 alarm which comes from the 5128 dialer when it is inundated with troubles. Panel event history shows trouble signals coming from different devices on the data loop. Troubles are clearing quickly. This is most likely a loop card issue or panel issue. Will consult and come up with a plan.

Equipment Used:

None

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate -7/8	3.00	\$76.00	\$0.000	\$228.00
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate -7/14	3.00	\$76.00	\$0.000	\$228.00

CUSTOMER MESSAGE

Invoice Total: \$456.00
Sales Tax: \$0.00
Payments (-): \$0.00
Total Due: \$456.00

Invoice 202501464

FAST

**Fire and
Security
Technologies**

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	07/23/2025
Purchase Order #:	
TERMS:	NET 60
Due Date:	09/21/2025

BILL TO
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

SERVICE LOCATION
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

Job Number: 251680	Job Category: Repair/Service	CO-OPS Fire Extinguishers - MCCPC #13A / EdData #15A / ESCNJ 24/25-11 Fire Alarms - 57-CCCPS, MCCPC 52
Customer Request: Somerset Hall Devices		

Completion Notes:

date 7-23-25
techs rob mike
job status complete

work performed - dropped heads into tiles in somerset room 351 - removed old decicss from s308-307 - rooms in service fusion did not match what was in field

we saw two old detectors next to new ones so we removed the old ones we saw

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate	3.00	\$76.00	\$0.000	\$228.00

CUSTOMER MESSAGE

Invoice Total: \$228.00
Sales Tax: \$0.00
Payments (-): \$0.00
Total Due: \$228.00



RVCC
JUL 24 2025
Facilities

✓ Invoice 202501250

FINANCE OFFICE
RARITAN VALLEY
COMMUNITY COLLEGE

FAST

Fire and
Security
Technologies

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

2025 JUN 25 AM 9:30

DATE:	06/25/2025 ✓
Purchase Order #:	Direct
TERMS:	NET 60
Due Date:	08/24/2025

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

SERVICE LOCATION

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

Job Number: 251363 Job Category: Installation

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCNJ 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52

Customer Request: addition

Completion Notes:

Service/Install Ticket

Date Selector:

06/23/2025

Service Report #:

25133

District Name:

RVCC

Location Name:

Workforce

Panel Status on Arrival:

Normal

Panel Status on Departure:

Normal

Job Complete:

Yes - Complete

Tech 1:

MH

Tech 2:

AP

Reason for Call:

Addition

Work Performed:

Ran MC above clean room.

Equipment Used:

115ft - 16/4 Metal Clad w/ Fire Wire

x8 - 4" Round Box + Plate Covers

OK [Signature]

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate	14.00	\$76.00	\$0.000	\$1,064.00
Solid-16/4 Fire alarm wire	0.23	\$360.00	\$0.000	\$82.80
MISC Item	1.00	\$80.00	\$0.000	\$80.00

CUSTOMER MESSAGE

Invoice Total:

\$1,226.80

Sales Tax:

\$0.00

Payments (-):

\$0.00

Total Due:

\$1,226.80 ✓

763-C 24001-6020-70

Invoice 202501582



**Fire and
Security
Technologies**

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

SERVICE LOCATION

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

Job Number: 251832

Job Category: Repair/Service

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCNJ 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52

Customer Request: 74 Lamington Road - alarm

Completion Notes:

date 8-7-25
techs rob
job status complete

work performed - upon arrival system in active alarm. reset keypad and system - replaced smoke in alarm in "sun room" - system returned to normal

equipment used - (1) Wireless Smoke Detector with Synchronized Sounder

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate	3.00	\$76.00	\$0.000	\$228.00
Wireless Smoke Detector with Synchronized Sounder	1.00	\$169.00	\$0.000	\$169.00

CUSTOMER MESSAGE

Invoice Total: \$397.00
Sales Tax: \$0.00
Payments (-): \$0.00
Total Due: \$397.00

Invoice 202501569



**Fire and
Security
Technologies**

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

SERVICE LOCATION

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

Job Number: 251814 Job Category: Repair/Service

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCNJ 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52

Customer Request: Re-locate Horn Strobe H225

Completion Notes:

Date Selector:
08/05/2025
Service Report #:
27111
District Name:
RVCC
Location Name:
H225
Panel Status on Arrival:
Normal
Panel Status on Departure:
Normal
Job Complete:
Yes - Complete
Tech 1:
MH
Reason for Call:
Relocate Horn Strobe
Work Performed:
Relocated Speaker Strobe in H225. Ran wire for splice box above original location.
Equipment Used:
15ft - 16/4 Fire Wire

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate	3.00	\$76.00	\$0.000	\$228.00
Solid-16/4 Fire alarm wire	0.03	\$360.00	\$0.000	\$10.80

CUSTOMER MESSAGE

Invoice Total: \$238.80
Sales Tax: \$0.00
Payments (-): \$0.00
Total Due: \$238.80

Invoice 202501597 ✓

FAST

Fire and
Security
Technologies

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:

08/12/2025 ✓

Purchase Order #:

Direct

TERMS:

NET 60

Due Date:

10/11/2025

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

SERVICE LOCATION

Arts Building
75 Lamington Road
Branchburg, NJ, 08876

Job Number: 251845

Job Category: Repair/Service

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCNJ 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52

Customer Request: Photo Lab Cut Device in

Completion Notes:

Service/Install Ticket

Date Selector:

08/11/2025

Service Report #:

27135

District Name:

RVCC

Location Name:

Arts Building

Panel Status on Arrival:

Normal

Panel Status on Departure:

Normal

Job Complete:

Yes - Complete

Tech 1:

MH

Reason for Call:

Cut Device Into Tile

Work Performed:

Located device in RM54 in Arts Building and cut one smoke detector into ceiling tiles

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate	3.00	\$76.00	\$0.000	\$228.00

CUSTOMER MESSAGE

Invoice Total:

\$228.00

Sales Tax:

\$0.00

Payments (-):

\$0.00

Total Due:

\$228.00 ✓

763-C24013-6020-70

Invoice 202501487



217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	07/28/2025
Purchase Order #:	
TERMS:	NET 60
Due Date:	09/26/2025

BILL TO
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

SERVICE LOCATION
Science Building 118 Lamington Road North Branch, NJ, 08876

Job Number: 251582	Job Category: Repair/Service	CO-OPS Fire Extinguishers - MCCPC #13A / EdData #15A / ESCNJ 24/25-11 Fire Alarms - 57-CCCPS, MCCPC 52
Customer Request: Trouble		

Completion Notes:

Date Selector:

07/23/2025

Service Report #:

27105

District Name:

RVCC

Location Name:

Somerset

Panel Status on Arrival:

Missing 1st Fl. Tunnel M08S032, Missing Mens Officials Bathroom M08S063, Missing 2nd Fl By W220

Panel Status on Departure:

Missing 1st Fl Tunnel M08S032

Job Complete:

No - Not Complete

Tech 1:

MH

Reason for Call:

Trouble On FACP

Work Performed:

Replaced mens officials bathroom Heat Detector, Trouble cleared. Replaced Smoke/Heat Combo detector by West 220. Couldnt Locate Tunnel , Asked RV staff no one knows, Will return to find tunnel device.

Equipment Used:

x1 - ADDRESSABLE THRML DETC FIX TEMP 135°F, RATE OF RISE, WHITE

x1 - Smoke/Heat Detector Combo

Service/Install Ticket

Date Selector:

07/24/2025

Service Report #:

27171

District Name:

RVCC

Location Name:

Somerset Hall

Panel Status on Arrival:

Missing Photo Tunnel M08S032

Panel Status on Departure:

Normal

Job Complete:

Yes - Complete

Tech 1:

MH
Reason for Call:
Trouble
Work Performed:
Located Tunnel Smoke Detector M08S032 and replaced.
Equipment Used:
x1 - Addressable photo electric smoke detector

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate -7/23	3.00	\$76.00	\$0.000	\$228.00
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate -7/24	3.00	\$76.00	\$0.000	\$228.00
ADDRESSABLE THRML DETC FIX TEMP 135°F, RATE OF RISE, WHITE	1.00	\$121.00	\$0.000	\$121.00
 ADDRESSABLE photo electric smoke detector	1.00	\$145.00	\$0.000	\$145.00
MISC Item Smoke/Heat Detector Combo	1.00	\$220.00	\$0.000	\$220.00

CUSTOMER MESSAGE

Invoice Total: \$942.00
Sales Tax: \$0.00
Payments (-): \$0.00
Total Due: \$942.00

Invoice 202501513

FAST Fire and
Security
Technologies

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	07/29/2025
Purchase Order #:	
TERMS:	NET 60
Due Date:	09/27/2025

BILL TO
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

SERVICE LOCATION
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

Job Number: 251768	Job Category: Monitoring (All Types)	CO-OPS Fire Extinguishers - MCCPC #13A / EdData #15A / ESCNJ 24/25-11 Fire Alarms - 57-CCCPS, MCCPC 52
Customer Request: LM0030 - Alarm Monitoring		

Completion Notes:
Annual Alarm Monitoring

Description	Qty	Rate	Tax	Total
Coverage Date - 1 Year This invoice is for annual alarm monitoring. The Coverage Date is from the 1st day of the month the invoice is dated - plus one year.	1.00	\$0.00	\$0.000	\$0.00
Fire or Fire/Burg Alarm Monitoring W/Daily Test Annual Fire or Fire/Burg Alarm Monitoring W/Daily Test (IP/Cell Data and Central Station Monitoring) 0619242F- Science Building 0619242- Hunterdon/Somerset 0619242W - West 0619243- Arts 0619244- Child Care 0619246- Power Plant	6.00	\$384.00	\$0.000	\$2,304.00
NJ Sales Tax		0.000%		\$0.00

CUSTOMER MESSAGE

Invoice Total: \$2,304.00
Sales Tax: \$0.00
Payments (-): \$0.00
Total Due: \$2,304.00

Invoice 202501864

FAST Fire and
Security
Technologies

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

SERVICE LOCATION

Workforce Building
118 Lamington Road
North Branch, NJ, 08876

Job Number: 252161

Job Category: Repair/Service

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCNJ 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52

Customer Request: Trouble

Completion Notes:

Service/Install Ticket

Date Selector:

09/19/2025

Service Report #:

27763

District Name:

RVCC

Location Name:

Work Force Building

Panel Status on Arrival:

Trouble (22)

Panel Status on Departure:

Trouble (21)

Job Complete:

Yes - Complete

Tech 1:

BM

Tech 2:

HN

Reason for Call:

Trouble on panel

Work Preformed:

Replaced detector in room 214 due to being "missing" on the panel

Equipment Used:

1x Addressable photo electric smoke detector

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate	6.00	\$76.00	\$0.000	\$456.00
 Addressable photo electric smoke detector	1.00	\$145.00	\$0.000	\$145.00

CUSTOMER MESSAGE

Invoice Total:	\$601.00
Sales Tax:	\$0.00
Payments (-):	\$0.00
Total Due:	\$601.00

Invoice 202502178 ✓

FAST Fire and
Security
Technologies

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	10/28/2025 ✓
Purchase Order #:	Direct
TERMS:	NET 60
Due Date:	12/27/2025

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

SERVICE LOCATION

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

Job Number: 251058

Job Category: Installation

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCN/ 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52

Customer Request: 3rd floor Bateman

Completion Notes:

Service/Install Ticket

Date Selector:

05/15/2025

Service Report #:

25706

District Name:

RVCC

Location Name:

Bateman Center

Panel Status on Arrival:

NA

Panel Status on Departure:

NA

Job Complete:

No - Not Complete

Tech 1:

MH

Reason for Call:

Mount devices

Work Performed:

Ran wire into 2 new offices for 2 heat detectors and 2 wall mounted speaker strobes. Tied wire into live loop and safed off. Once sheetrock is installed can return to complete the install.

Equipment Used:

70ft 16/4

60ft 18/2

4x 4in boxes

date 10-27-25

techs rob anthony

job status complete

work performed - tied in devices for bateman third floor and programmed - good.

equipment used - (2) ADDRESSABLE THRL DETC FIX TEMP 135°F, RATE OF RISE, WHITE

(2) SPEAKER/STROBE, OUTDOOR SELECTABLE CANDELA, WALL MT RED

(2) sbbsprl back box

Description	Qty	Rate	Tax	Total
-------------	-----	------	-----	-------

Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate -5/15	6.00	\$76.00	\$0.000	\$456.00
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate -10/27	13.00	\$76.00	\$0.000	\$988.00
 ADDRESSABLE THRML DETC FIX TEMP 135°F, RATE OF RISE, WHITE	1.00	\$121.00	\$0.000	\$121.00
SPEAKER/STROBE, OUTDOOR SELECTABLE CANDELA, WALL MT RED	1.00	\$325.00	\$0.000	\$325.00

CUSTOMER MESSAGE

Invoice Total:

\$1,890.00

Sales Tax:

\$0.00

Payments (-):

\$0.00

Total Due:

\$1,890.00 ✓

764-C25011 - 6545-70

Invoice 202502165



217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	10/27/2025
Purchase Order #:	
TERMS:	NET 60
Due Date:	12/26/2025

BILL TO
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

SERVICE LOCATION
Art Building 118 Lamington Road North Branch, NJ, 08876

Job Number: 252433	Job Category: Repair/Service	CO-OPS Fire Extinguishers - MCCPC #13A / EdData #15A / ESCNJ 24/25-11 Fire Alarms - 57-CCCPS, MCCPC 52
Customer Request: Smoke Detector trouble on panel		

Completion Notes:

date 10-27-25

techs rob
job status complete

work performed - located sensor 13 in trouble in room 20 and replaced

equipment used - (1) Addressable photo electric smoke detector (1) Smoke Detector Base

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate	3.00	\$76.00	\$0.000	\$228.00
 Addressable photo electric smoke detector	1.00	\$145.00	\$0.000	\$145.00
Smoke Detector Base	1.00	\$44.00	\$0.000	\$44.00

CUSTOMER MESSAGE

Invoice Total: \$417.00
Sales Tax: \$0.00
Payments (-): \$0.00
Total Due: \$417.00

Invoice 202502139



**Fire and
Security
Technologies**

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	10/23/2025
Purchase Order #:	
TERMS:	NET 60
Due Date:	12/22/2025

BILL TO
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

SERVICE LOCATION
Workforce Building 118 Lamington Road North Branch, NJ, 08876

Job Number: 252361	Job Category: Repair/Service	CO-OPS Fire Extinguishers - MCCPC #13A / EdData #15A / ESCNJ 24/25-11 Fire Alarms - 57-CCCPS, MCCPC 52
Customer Request: 2ndFI Strobe		

Completion Notes:

Service/Install Ticket

Date Selector:

10/16/2025

Service Report #:

27834

District Name:

Rvcc

Location Name:

Work force

Panel Status on Arrival:

57 disabled

Panel Status on Departure:

Normal

Job Complete:

Yes - Complete

Tech 1:

Re

Reason for Call:

2nd FI strobe

Work Performed:

Upon arrival, there were 57 disables on the panel. Once I reenabled them all the system went normal.

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate	3.00	\$76.00	\$0.000	\$228.00

CUSTOMER MESSAGE

Invoice Total:	\$228.00
Sales Tax:	\$0.00
Payments (-):	\$0.00
Total Due:	\$228.00

Invoice 202502095



**Fire and
Security
Technologies**

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

DATE:	10/19/2025
Purchase Order #:	
TERMS:	NET 60
Due Date:	12/18/2025

BILL TO
Raritan Valley Community College Receiving Dept- Rodney William North Branch, NJ, 08876

SERVICE LOCATION
Arts Building 75 Lamington Road Branchburg, NJ, 08876

Job Number: 251559 **Job Category: Repair/Service**

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCNJ 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52

Customer Request: Rehang Detectors

Completion Notes:
date 7-10-25

techs rob
job status incomplete

work performed - dropped detectors into new ceiling tiles in the following rooms - A27, A05, A9C - could not get to A02A as new floor either concrete or painted was done last night and still needs time to cure (electrician on site said maybe a day or two) so ticket is marked as incomplete for now but that's the last sensor that has to be dropped in

upon arrival low battery for booster - replaced

while doing splices in field for few detectors that had 3 wires under 1 terminal a sensor went missing despite having voltage. located and replaced head and base, system returned to normal

equipment used - (2) Fire Rated Fire Alarm Battery 202408(1) Addressable photo electric smoke detector(1) Smoke Detector Base

Description	Qty	Rate	Tax	Total
Vehicle Allowance	0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate	3.00	\$76.00	\$0.000	\$228.00
Fire Rated Fire Alarm Battery 202408	2.00	\$95.00	\$0.000	\$190.00
 Addressable photo electric smoke detector	1.00	\$145.00	\$0.000	\$145.00
Smoke Detector Base	1.00	\$44.00	\$0.000	\$44.00

Invoice Total:

\$607.00

Invoice 202502062



**Fire and
Security
Technologies**

217 Halls Mill Road Lebanon NJ 08833
Phone: (908) 823-4367 / Fax: (866) 844-3086
Email: Sales@fireandsecuritytech.com
Lic: NJ# 34BX00023300
NJ# P01207

BILL TO

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

DATE:

10/16/2025

Purchase Order #:

TERMS:

NET 60

Due Date:

12/15/2025

SERVICE LOCATION

Raritan Valley Community College
Receiving Dept- Rodney William
North Branch, NJ, 08876

Job Number: 252173

Job Category: Repair/Service

CO-OPS Fire Extinguishers - MCCPC #13A /
EdData #15A / ESCNJ 24/25-11
Fire Alarms - 57-CCCPS, MCCPC 52

Customer Request: Multiple Items

Completion Notes:

Service/Install Ticket

Date Selector:

09/23/2025

Service Report #:

27627

District Name:

RVCC

Location Name:

Somerset Hall

Panel Status on Arrival:

Missing M97M03, Missing M07M159, Open ckt M30P001

Panel Status on Departure:

Missing M97M03, Missing M07M159, Open ckt M30P001

Job Complete:

No - Not Complete

Tech 1:

MH

Reason for Call:

List

Work Performed:

S351 Completed 7/23/25. Located L029K and cut tile, mounted hanger bar + box, and mounted + wired ceiling mount speaker.
Removed 2 old Heat Detectors from S307.

Service/Install Ticket

Date Selector:

09/23/2025

Service Report #:

27626

District Name:

RVCC

Location Name:

Workforce

Panel Status on Arrival:

x22 Missing Troubles

Panel Status on Departure:

Normal

Job Complete:

Yes - Complete

Tech 1:

MH

Reason for Call:

Trouble on FACP

Work Performed:

Found 2 loose wires in wire nut in detector box, hallway detector in front of room 126. After reconnecting wires, 21 missing cleared all around RM126-128. Last missing smoke in 216 M97S082, located and replaced trouble cleared system is now normal.

Equipment Used:

x1 - Addressable photo electric smoke detector

Description		Qty	Rate	Tax	Total
Vehicle Allowance		0.00	\$0.00	\$0.000	\$0.00
Discount Labor Rate		6.00	\$76.00	\$0.000	\$456.00
	Addressable photo electric smoke detector	1.00	\$145.00	\$0.000	\$145.00

CUSTOMER MESSAGE

Invoice Total:

\$601.00

Sales Tax:

\$0.00

Payments (-):

\$0.00

Total Due:

\$601.00