



Approved

Fire Protection Co.

114 ST. NICHOLAS AVE. 50 PLAINFIELD, NJ

afpnj.com

908-755-2222

KITCHEN

System Status

☒ System is Compliant with NJAC 5:70-3

☐ System is Non-Compliant

THIS FORM WILL BE FILED WITH THE LOCAL AHJ

Company CLARK MUNICIPAL COMPLEX	Contact	Phone 7323883600	Date 2023-05-25
Address 430 WESTFIELD AVENUE,	City CLARK	State NJ	Zip 07066
System Location 430 WESTFIELD AVENUE,	City CLARK	State NJ	Zip 07066
Email	Cust. # 12650	Service Ticket # ST00092851	P00137

Initial Actions/Observations				System Functional Test			
	Y	N	NA		Y	N	NA
1 Last Service By? <u>Approved</u>				21 System disarmed per manufacturers recommendations?	☒	☐	☐
2 Were building personnel notified of the inspection?	☒	☐	☐	22 Mechanical detection line tested and found to operate properly?	☒	☐	☐
3 Was the monitoring company notified?	☐	☐	☒	23 Proper number and placement of detectors/links?	☒	☐	☐
4 System found charged and functioning at time of technician's arrival?	☒	☐	☐	24 Did the system operate properly from activation of a manual pull station?	☒	☐	☐
5 System un-tampered with since last visit?	☒	☐	☐	25 Gas shut-off valve installed and working properly? (Note location)	☒	☐	☐
6 System found to be at proper pressure upon arrival?	☒	☐	☐	26 Replaced links with proper temperature rating?	☒	☐	☐
Visually Check System				1 at <u>360</u> Degrees at <u> </u> Degrees <u> </u> at <u> </u> Degrees at <u> </u> Degrees <u> </u> at <u> </u> Degrees at <u> </u> Degrees			
7 Baffle-type filters installed in hood?	☐	☐	☒	27 Is the manual reset for electric gas vales operational?	☒	☐	☐
8 System (and appliance layout) appear unchanged since last service?	☒	☐	☐	28 Did all electrical appliances shut off upon system operation?	☒	☐	☐
9 Were the nozzle caps in place at time of arrival?	☒	☐	☐	29 Did all gas appliances shut off upon system operation?	☒	☐	☐
10 Visible piping and nozzles properly connected, braced, and free of damage?	☒	☐	☐	30 Did the make-up air shut down?	☐	☐	☒
11 Piping/conduit/cabling free from observable obstructions?	☒	☐	☐	31 Did the alarm system activate when the system tripped?	☐	☐	☒
12 Nozzle(s) inspected and found to be clear of obstructions?	☒	☐	☐	32 Did control head(s)/cylinder releasing device(s) operate properly?	☒	☐	☐
13 Correct nozzle type(s) for protected equipment, plenum, and ducts?	☒	☐	☐	Cylinder and Agent			
14 Nozzle(s) properly positioned over appliances?	☒	☐	☐	33 Cylinder Pressure <u>175</u> (psi)	☒	☐	☐
15 Nozzle(s) properly positioned in duct(s) and plenum(s)?	☒	☐	☐	34 Hydrostatic test date of cylinder checked. Due: <u>2027</u>	☒	☐	☐
16 Is there a fan warning sign on hood?	☒	☐	☐	35 Were all cylinders free of signs of external corrosion and/or damage?	☒	☐	☐
17 Flow points/extinguishing agent within mfg's allowed maximums?	☒	☐	☐	36 Are all cylinders securely mounted?	☒	☐	☐
Hazard Inspection				37 Cartridge inspected or replaced within mfg's recommended interval (if applicable)? Weight: <u>240 G</u>	☒	☐	☐
18 Hazard configuration appeared to remained unchanged?	☒	☐	☐	38 Were the lines clear when blown out?	☒	☐	☐
19 Are all observable penetrations to the hood and duct sealed?	☒	☐	☐				
20 No readily observable obstructions or interference that could impact effectiveness of the suppression	☒	☐	☐				

KITCHEN

NOTIFICATION OF DEFICIENCIES

CUSTOMER SIGNATURE Alan Lambert

- ☐ A mark made in the adjacent box indicates that deficiencies exist with the current condition of the Fire Suppression System. If this is the case, the customer's authorized representative, by his or her signature acknowledges these deficiencies represent an IMMEDIATE AND SERIOUS SAFETY CONCERN that the customer must correct. Service Company shall not be responsible if the Fire Suppression System malfunctions or fail to function. It is the owner's responsibility to ensure that all deficiencies are removed or repaired

System Reactivation				Final				
	Y	N	NA			Y	N	NA
39 Test adapters/links, keeper pins, etc, removed from system?	☒	☐	☐	49 Operator's manual on site?		☒	☐	☐
40 Detection (link) line has proper tensioning?	☒	☐	☐	50 Class K portable extinguisher available and properly serviced?		☒	☐	☐
41 Was the control head reset?	☒	☐	☐	51 Remote manual release free from obstructions and operable?		☒	☐	☐
42 Were all fuel sources and power restored?	☒	☐	☐	52 Has the system been placed back in service?		☒	☐	☐
43 Were all pilot lights supplied by the gas valve relit?	☒	☐	☐	53 Monitoring company notified that the system is back in full service?		☐	☐	☒
44 Microswitch/relay(s) reset - electric appliances on?	☐	☐	☒	54 Were building personnel notified of the system condition?		☒	☐	☐
45 Are all nozzle caps in place?	☒	☐	☐	55 Have you received a signature from the building personnel?		☒	☐	☐
46 Were all filters reinstalled?	☒	☐	☐	56 Inspection tag affixed to system?		☒	☐	☐
47 Were all cartridges reinstalled? (if applicable)	☒	☐	☐					
48 Tandem/slave releasing device(s) reset properly?	☐	☐	☒					

Description of Deficiencies

None found at time of inspection.

Comments and Recommendations

N/A

NOTIFICATION OF EXHAUT SYSTEM GREASE BUILD UP

CUSTOMER SIGNATURE Alan Lambert

- ☐ A mark made in the adjacent box indicates that we recommend that the entire exhaust and ventilation system as well as all appliances be inspected by a properly trained, qualified, and certified company or person(s) acceptable to the authority of having jurisdiction to determine if cleaning is required. Any visual observations or comments noted by our Service Technician regarding grease build up are for informational purposes only and are based on readily observable conditions at the time of service.

Hood Size: 7' 11"

Duct Quantity and Size: 1 and 12 X 10

List All Appliances and their Size:

4 burner stove 29 x 24

Griddle 3' x 29

See photos below

Comments:



INCLUDE ALL APPLIANCES. LABEL WITH TYPE AND SIZE

KITCHEN

System Connected to Alarm? Yes ☐ No ☐	Gas Valve: Yes ☒ No ☐ Size: <u>3/4 inch</u>
Nozzle Quantity: Duct <u>2</u> Plenum <u>0</u> Appliance <u>2</u>	Gas Valve Style: Electrical ☐ Mechanical ☒ Electric Shunt Trip ☐
Remote Pull: Yes ☒ No ☐ Location <u>Across from door</u>	Gas Valve Location: <u>Left of appliance</u>

ALL CONDITIONS NOTED ARE LIMITED TO ONLY THOSE THAT COULD BE OBSERVED AT THE TIME OF THIS INSPECTION

PICTURES



KITCHEN

AGREEMENT

Please read carefully. We are not an insurer. Our maximum liability is limited to \$250.00. Vendor shall not be responsible for the improper operation of any inspected equipment that, after serviceman has left premises, has been discharged, vandalized, tampered with or damaged. User acknowledges receipt of copy.


This report was reviewed with:

Approved Fire Protection Systems, Inc.


Print Name : Adam

Technician : Brian Neto

Signature :


Adam

Signature :



ST00092851 - I acknowledge the work has been completed as per this order

Date : 5/25/2023

Date : 5/25/2023



Approved

Fire Protection Co.

114 ST. NICHOLAS AVE., 50 PLAINFIELD, NJ

afpnj.com

908-755-2222

WET CHEMICAL SUPPRESSION SYSTEM INSPECTION CERTIFICATE

System Status

System In Service and Will Operate As Intended

THIS FORM WILL BE FILED WITH THE LOCAL AHJ

Company CLARK MUNICIPAL COMPLEX	Contact JENNIFER KOBLISKA X-003	Phone B:732-388-3600	Date 2022-06-14
Address 430 WESTFIELD AVENUE,	City CLARK	State NJ	Zip 07066
System Location 430 WESTFIELD AVENUE	City CLARK	State NJ	Zip 07066
Email JKOBLISKA@OURCLARK.COM	Cust. # 12650	Service Ticket # ST00078265	P00137

WET CHEMICAL PRIMARY QUESTIONS

System Manufacturer	KIDDE
System Model	WHDR260
Inspection Type	Semi-Annual
What Size Wet Chemical System are you inspecting?	2.6 Gallon
System Connected to a Fire Alarm?	No
If Connected to a Fire Alarm; Local or FACP?	Na
Indicate Location of this system (ex: front serving area)	Kitchen

WET CHEMICAL TESTING QUESTIONS

Initial Actions/observations	
Quantity of Duct Nozzles	2
Quantity of Plenum Nozzles	0
Quantity of Appliance Nozzles	2
Does the System have a Gas Valve?	Yes
Gas Valve Size (inches)	3/4 in
Gas Valve Style?	Mechanical
Gas Valve Type?	Release
Location of Gas Valve? (If NO gas Valve, indicate N/A)	Left of appliance
Does the System have a Remote Pull?	Yes
Location of Remote Pull?	Across from doorway to restroom
Last Service By?	Approved Fire Protection
Were Building Personnel Notified of this Inspection?	Yes
Was the Monitoring Company Notified?	N/A
Was System Charged and Functioning at Time of Technician's arrival?	Yes
System was NOT tampered with since last inspected?	Yes
Was System at Proper Pressure upon Arrival?	Yes

WET CHEMICAL SUPPRESSION SYSTEM INSPECTION CERTIFICATE

Visual Check Of System	
Baffled Type Filters Installed in Hood?	N/A
System and Appliance Line-up unchanged since Last Inspection?	Yes
Were Nozzle Caps in Place Upon Arrival?	Yes
Visible Piping and Nozzles are Properly Connected, Braced, and Free from Damage	Yes
Piping, Conduit, Cabling Free from Observable Obstructions?	Yes
Nozzles Inspected and Found to be Clear of Obstructions?	Yes
Correct Nozzle Type(s) are Present for the Protected Appliances/Equipment, Plenum and Ducts	Yes
ALL Nozzles are Properly Positioned over Appliances?	Yes
ALL Nozzles are Properly Positioned in Duct(s) and Plenum(s)	Yes
Is there a Fan Warning Sign on the Hood?	N/A
Flow Points per Extinguishing Agent are Within the MFG's Allowed Maximums (see manufacturers manual)	Yes
Hazard Inspected	
The Hazard Configuration appears to be Unchanged from last Inspection?	Yes
Are All Observable Penetrations to the Hood and Duct Sealed?	Yes
No Readily Observable Obstructions or Interface that could Impact Effectiveness of the Suppression System?	Yes
Please Take Picture Of Appliance Line Up As You See It Today	
Did you take a picture of the Appliance Line Up as it is today?	Yes
System Functional Testing	
The System was Disarmed as per the MFG's Recommendations?	Yes
Mechanical Detection Line Tested and Operates Properly?	Yes
Proper Number and Placement of Detectors/Links?	Yes
Did System Operate Properly from Activation of Manual Pull Station?	Yes
Is Gas Shut-Off Installed and Working Properly?	Yes
Were All Links Replaced with the Proper Temperature Rating?	Yes
Is the Manual Reset for Electric Gas Valve Operational (If Applicable)?	Na
All Electrical Appliances Shut Off Upon System Activation?	Na
Did All Gas Appliances Shut Off Upon System Activation?	Yes
Did The Make-Up Air Shut Down	Yes
Did the Fire Alarm System Activate when the System was Tripped?	Na
Did the Control Head(s)/Cylinder releasing Device(s) Operate Properly?	Yes
Cylinders And Agent	
Are All Cylinders Free of Visible External Corrosion and/or Damage?	Yes
Are All Cylinders Securely Mounted?	Yes
Cartridges Inspected and Replaced within MFG's Recommended Intervals (if Applicable)	Yes
Are All Agent Delivery Lines Clear after Blow out?	Yes

LINKS - Location: Rec.Center Kitchen

Link Type	360ML
Quantity Changed	1

WET CHEMICAL SUPPRESSION SYSTEM INSPECTION CERTIFICATE**WET CHEMICAL REACTIVATION AND FINAL****System Reactivation**

Test Adapters/Links, Keeper Pins, other adapters Removed From System?	Yes
Detection (Link) Line has Proper Tension?	Yes
Has the Control Head Been Reset?	Yes
Are ALL Fuel Sources and Power Restored?	Yes
Are ALL Pilot Lights Supplied by the Gas Valve Relit?	Yes
For Electric Appliances; Is the Microswitch/Relay(s) Reset?	N/A
Are All Nozzle Caps In Place?	Yes
Have ALL Filters Been Reinstalled?	N/A
(If Applicable) Are ALL Cartridges Reinstalled?	Yes
Are ALL Tandem/Slave Releasing Device(s) Properly Reset?	N/A

Final

Is the Operators Manual on Site?	Yes
Is there a Class K Portable Fire Extinguisher Available and Properly Service as Per NFPA 10?	Yes
IS the Manual Release Free from Obstructions and Operable?	Yes
Has the System Been Placed Back in Service? IF NO; PLEASE COMPLETE AN OUT OF SERVICE TICKET	Yes
Has the Monitoring Company Been Notified the System is Back in FULL Service?	N/A
Were Building Personnel Notified of the Systems Condition upon Completion of Inspection?	Yes
Have you Received a Signature from the Building Personnel?	Yes
Has the Inspection Tag Been Affixed to the System?	Yes

Cylinder Full (W)eight/Liquid (L)evel	Cylinder Charge Weight	Serial Number	Cylinder Hydrostatic Test Date	Cartridge Type	Cartridge Weight	Cartridge Hydrostatic Test Date	Cartridge Changed	Regular test Date and PSI
53 lbs	2.6 gallons lbs	84768	06/14/2015	KIDDE N2	240 oz	06/14/2015	no	N/A 0

List All Protected Appliances Under the Hood

Protected Appliances	Quantity
Flat Top Griddle	1
4 Burner Stove	1

DRAWING OR PICTURE

WET CHEMICAL SUPPRESSION SYSTEM INSPECTION CERTIFICATE

DRAWING OR PICTURE



NOTIFICATION OF EXHAUST SYSTEM GREASE BUILD UP

A mark made in the YES box indicates that we recommend that the entire exhaust and ventilation control system as well as all appliances be inspected by a properly trained, qualified, and certified company or person(s) acceptable to the authority having jurisdiction to determine if cleaning is required. Any visual observations or comments noted by our Service Technician regarding grease build up are for informational purposes only and are based on readily observable conditions at the time of service.

DEFICIENCIES

None found at time of inspection.

AGREEMENT

Please read carefully. We are not an insurer. Our maximum liability is limited to \$250.00. Vendor shall not be responsible for the improper operation of any inspected equipment that, after serviceman has left premises, has been discharged, vandalized, tampered with or damaged. User acknowledges receipt of copy.

This report was reviewed with:

Approved Fire Protection Systems, Inc.

Print Name : Emily

Technician : Michael Bigelow

Signature :

Signature :

Date : 6/14/2022

Date : 6/14/2022

Ralph
JUNE 14, 2022 02:15 PM
ST00078285 - I acknowledge the work has been completed as per this order



Approved

Fire Protection Co.

114 ST. NICHOLAS AVE. 50 PLAINFIELD, NJ **afpnj.com** 908-755-2222

WET CHEMICAL SUPPRESSION SYSTEM INSPECTION CERTIFICATE

System Status

System In Service and Will Operate As Intended

THIS FORM WILL BE FILED WITH THE LOCAL AHJ

Company CLARK MUNICIPAL COMPLEX	Contact JENNIFER KOBLISKA X-003	Phone B:732-388-3600	Date 2022-06-14
Address 430 WESTFIELD AVENUE,	City CLARK	State NJ	Zip 07066
System Location 430 WESTFIELD AVENUE	City CLARK	State NJ	Zip 07066
Email JKOBLISKA@OURCLARK.COM	Cust. # 12650	Service Ticket # ST00078265	P00137

WET CHEMICAL PRIMARY QUESTIONS

System Manufacturer	KIDDE
System Model	WHDR260
Inspection Type	Semi-Annual
What Size Wet Chemical System are you Inspecting?	2.6 Gallon
System Connected to a Fire Alarm?	No
If Connected to a Fire Alarm; Local or FACP?	Na
Indicate Location of this system (ex: front serving area)	Kitchen

WET CHEMICAL TESTING QUESTIONS

Initial Actions/observations	
Quantity of Duct Nozzles	2
Quantity of Plenum Nozzles	0
Quantity of Appliance Nozzles	2
Does the System have a Gas Valve?	Yes
Gas Valve Size (inches)	3/4 in
Gas Valve Style?	Mechanical
Gas Valve Type?	Release
Location of Gas Valve? (If NO gas Valve, indicate N/A)	Left of appliance
Does the System have a Remote Pull?	Yes
Location of Remote Pull?	Across from doorway to restroom
Last Service By?	Approved Fire Protection
Were Building Personnel Notified of this Inspection?	Yes
Was the Monitoring Company Notified?	N/A
Was System Charged and Functioning at Time of Technician's arrival?	Yes
System was NOT tampered with since last inspected?	Yes
Was System at Proper Pressure upon Arrival?	Yes

WET CHEMICAL SUPPRESSION SYSTEM INSPECTION CERTIFICATE

Visual Check Of System	
Baffled Type Filters Installed in Hood?	N/A
System and Appliance Line-up unchanged since Last Inspection?	Yes
Were Nozzle Caps in Place Upon Arrival?	Yes
Visible Piping and Nozzles are Properly Connected, Braced, and Free from Damage	Yes
Piping, Conduit, Cabling Free from Observable Obstructions?	Yes
Nozzles Inspected and Found to be Clear of Obstructions?	Yes
Correct Nozzle Type(s) are Present for the Protected Appliances/Equipment, Plenum and Ducts	Yes
ALL Nozzles are Properly Positioned over Appliances?	Yes
ALL Nozzles are Properly Positioned in Duct(s) and Plenum(s)	Yes
Is there a Fan Warning Sign on the Hood?	N/A
Flow Points per Extinguishing Agent are Within the MFG's Allowed Maximums (see manufacturers manual)	Yes
Hazard Inspected	
The Hazard Configuration appears to be Unchanged from last Inspection?	Yes
Are All Observable Penetrations to the Hood and Duct Sealed?	Yes
No Readily Observable Obstructions or Interface that could Impact Effectiveness of the Suppression System?	Yes
Please Take Picture Of Appliance Line Up As You See It Today	
Did you take a picture of the Appliance Line Up as it is today?	Yes
System Functional Testing	
The System was Disarmed as per the MFG's Recommendations?	Yes
Mechanical Detection Line Tested and Operates Properly?	Yes
Proper Number and Placement of Detectors/Links?	Yes
Did System Operate Properly from Activation of Manual Pull Station?	Yes
Is Gas Shut-Off Installed and Working Properly?	Yes
Were All Links Replaced with the Proper Temperature Rating?	Yes
Is the Manual Reset for Electric Gas Valve Operational (If Applicable)?	Na
All Electrical Appliances Shut Off Upon System Activation?	Na
Did All Gas Appliances Shut Off Upon System Activation?	Yes
Did The Make-Up Air Shut Down	Yes
Did the Fire Alarm System Activate when the System was Tripped?	Na
Did the Control Head(s)/Cylinder releasing Device(s) Operate Properly?	Yes
Cylinders And Agent	
Are All Cylinders Free of Visible External Corrosion and/or Damage?	Yes
Are All Cylinders Securely Mounted?	Yes
Cartridges Inspected and Replaced within MFG's Recommended Intervals (if Applicable)	Yes
Are All Agent Delivery Lines Clear after Blow out?	Yes

LINKS - Location: Rec Center Kitchen

Link Type	360ML
Quantity Changed	1

WET CHEMICAL SUPPRESSION SYSTEM INSPECTION CERTIFICATE

WET CHEMICAL REACTIVATION AND FINAL

System Reactivation

Test Adapters/Links, Keeper Pins, other adapters Removed From System?	Yes
Detection (Link) Line has Proper Tension?	Yes
Has the Control Head Been Reset?	Yes
Are ALL Fuel Sources and Power Restored?	Yes
Are ALL Pilot Lights Supplied by the Gas Valve Relit?	Yes
For Electric Appliances; Is the Microswitch/Relay(s) Reset?	N/A
Are All Nozzle Caps In Place?	Yes
Have ALL Filters Been Reinstalled?	N/A
(If Applicable) Are ALL Cartridges Reinstalled?	Yes
Are ALL Tandem/Slave Releasing Device(s) Properly Reset?	N/A

Final

Is the Operators Manual on Site?	Yes
Is there a Class K Portable Fire Extinguisher Available and Properly Service as Per NFPA 10?	Yes
IS the Manual Release Free from Obstructions and Operable?	Yes
Has the System Been Placed Back in Service?	Yes
IF NO; PLEASE COMPLETE AN OUT OF SERVICE TICKET	Yes
Has the Monitoring Company Been Notified the System is Back in FULL Service?	N/A
Were Building Personnel Notified of the Systems Condition upon Completion of Inspection?	Yes
Have you Received a Signature from the Building Personnel?	Yes
Has the Inspection Tag Been Affixed to the System?	Yes

Cylinder Full (W)eight/Liquid (L)evel	Cylinder Charge Weight	Serial Number	Cylinder Hydrostatic Test Date	Cartridge Type	Cartridge Weight	Cartridge Hydrostatic Test Date	Cartridge Changed	Regular test Date and PSI
53 lbs	2.6 gallons lbs	84768	06/14/2015	KIDDE N2	240 oz	06/14/2015	no	N/A 0

List All Protected Appliances Under the Hood

Protected Appliances	Quantity
Flat Top Griddle	1
4 Burner Stove	1

DRAWING OR PICTURE

WET CHEMICAL SUPPRESSION SYSTEM INSPECTION CERTIFICATE

DRAWING OR PICTURE



NOTIFICATION OF EXHAUST SYSTEM GREASE BUILD UP

A mark made in the YES box indicates that we recommend that the entire exhaust and ventilation control system as well as all appliances be inspected by a properly trained, qualified, and certified company or person(s) acceptable to the authority having jurisdiction to determine if cleaning is required. Any visual observations or comments noted by our Service Technician regarding grease build up are for informational purposes only and are based on readily observable conditions at the time of service.

DEFICIENCIES

None found at time of inspection.

AGREEMENT

Please read carefully. We are not an insurer. Our maximum liability is limited to \$250.00. Vendor shall not be responsible for the improper operation of any inspected equipment that, after serviceman has left premises, has been discharged, vandalized, tampered with or damaged. User acknowledges receipt of copy.

This report was reviewed with:

Approved Fire Protection Systems, Inc.

Print Name : Emily

Technician : Michael Bigelow

Signature :

Signature :

Date : 6/14/2022

Date : 6/14/2022

Ralph
JUN 14 2022 02:39 PM
ST00078265 - I acknowledge the work has been completed as per this order



Approved

Fire Protection Co.

114 ST. NICHOLAS AVE. 50 PLAINFIELD, NJ

afpnj.com

908-755-2222

Fire System Inspection Certificate

☒ System Compliant per NJAC 5:70-3

☐ System Non-Compliant per NJAC 5:70-3

THIS FORM WILL BE FILED WITH THE LOCAL AHJ

Company CLARK MUNICIPAL COMPLEX		Contact KOBLSKA X-003, JENNIFER	Phone 7323883600	Date 05/27/2021
Address 430 WESTFIELD AVENUE		City CLARK	State NJ	Zip 07066
Email	System MFG. Kidde	System Type WHDR260		P00459
Inspection Type ☐ Initial ☐ Annual ☒ Semi-Annual ☐ Other		Cust. # 1317		Service Ticket # ST00065112
Location of System REC CENTER KITCHEN				

System Connected to Alarm? Yes ☐ No ☒
Local ☐ FACP ☐

Gas Valve: Yes ☒ No ☐

Size: 3/4

Nozzle Quantity: Duct 1 Plenum 1 Appliance 2

Gas Valve Style: Electrical ☐ Mechanical ☒ Electric Shunt ☐

Remote Pull: Yes ☒ No ☐

Location: Exit of kitchen

Gas Valve Location: Left of appliance

Type: Release ☒ Pull ☐

Initial Actions / Observations		Y	N	N/A	Visually Check System Continued		Y	N	N/A
1	Last Serviced By? <u>AFP</u>				10	Visible piping and nozzles properly connected, braced, and free of damage?	☒	☐	☐
2	Were building personnel notified of the inspection?	☒	☐	☐	11	Piping/conduit/cabling free from observable obstructions?	☒	☐	☐
3	Was the monitoring company notified?	☐	☐	☒	12	Nozzle(s) inspected and found to be clear of obstructions?	☒	☐	☐
4	System found charged and functioning at time of technician's arrival?	☒	☐	☐	13	Correct nozzle type(s) for protected equipment, plenum and ducts?	☒	☐	☐
5	System un-tampered with since last visit?	☒	☐	☐	14	Nozzle(s) properly positioned over appliances?	☒	☐	☐
6	System found to be at proper pressure upon arrival?	☒	☐	☐	15	Nozzle(s) properly positioned in duct(s) and plenum(s)?	☒	☐	☐
					16	Is there a fan warning sign on hood?	☐	☒	☐
					17	Flow points/extinguishing agent within mfg's allowed maximums?	☒	☐	☐
Visually Check System		Y	N	N/A	Hazard Inspection		Y	N	N/A
7	Baffle- type filters installed in hood?	☒	☐	☐	18	Hazard configuration appeared to remain unchanged?	☒	☐	☐
8	System [and appliance layout] appears unchanged since last service?	☒	☐	☐	19	Are all observable penetrations to the hood and duct sealed?	☒	☐	☐
9	Were the nozzle caps in place at time of arrival?	☒	☐	☐					

Fire System Inspection Certificate

System Functional Test		Y	N	N/A	System Reactivation		Y	N	N/A
20a	No readily observable obstructions or interface that could impact effectiveness of the suppression system?	☒	☐	☐	37	Test adapters/links, keeper pins, etc., removed from system?	☒	☐	☐
20b	System disarmed per manufacturer's recommendations?	☒	☐	☐	38	Detection [link] line has proper tensioning?	☒	☐	☐
21	Mechanical detection line tested and operates properly?	☒	☐	☐	39	Was the control head reset?	☒	☐	☐
22	Proper number and placement of detectors/links?	☒	☐	☐	40	Were all fuel sources and power restored?	☒	☐	☐
23	Did the system operate properly from activation of manual pull station?	☒	☐	☐	41	Were all pilot lights supplied by the gas valve relit?	☒	☐	☐
24	Gas shut-off valve installed and working properly?	☒	☐	☐	42	Microswitch/relay(s) reset -- electric appliances "on"?	☐	☐	☒
25	Replaced links with proper temperature rating?	☒	☐	☐	43	Are all nozzle caps in place?	☒	☐	☐
1 at 360 ML Degrees at Degrees at Degrees at Degrees at Degrees at Degrees					44	Were all filters reinstalled?	☒	☐	☐
					45	Were all cartridges reinstalled? (if applicable)	☒	☐	☐
					46	Tandem/slave releasing device(s) reset properly?	☐	☐	☒
					Final				
26	Is the manual reset for electric gas valves operational?	☐	☐	☒	47	Operator's manual on site?	☒	☐	☐
27	All electrical appliances shut off upon system operation?	☐	☐	☒	48	Class K portable extinguisher available and properly serviced?	☒	☐	☐
28	Did all gas appliances shut off upon system operation?	☒	☐	☐	49	Remote manual release free from obstructions and operable?	☒	☐	☐
29	Did the make-up air shut down?	☐	☐	☒	50	Has the system been placed back in service?	☒	☐	☐
30	Did the alarm system activate when the system tripped?	☐	☐	☒	51	Monitoring company notified that the system is back in full service?	☐	☐	☒
31	Did control head(s)/cylinder releasing device(s) operate properly?	☒	☐	☐	52	Were building personnel notified of the system condition?	☒	☐	☐
					53	Have you received a signature from the building personnel?	☒	☐	☐
					54	Inspection tag affixed to system?	☒	☐	☐
Cylinders and Agent									
32	Were all cylinders free of signs of external corrosion and/or damage?	☒	☐	☐					
33	Are all cylinders securely mounted?	☒	☐	☐					
34	Cartridge inspected or replaced within mfg's recommended interval (if applicable)?	☒	☐	☐					
35	Were the lines clear when blown out?	☒	☐	☐					
36	Tag affixed and system back in service?	☒	☐	☐					

DRAWING OR PICTURE

List All Protected Appliances Under the Hood:

Griddle	4 burner stove		

* Ph.(908)755-2222 * * Page 4 of 5 *

[illegible]

Approved Fire Protection Systems, Inc. * 114 Saint Nicholas Ave. * South Plainfield, NJ 07080

* Ph.(908)755-2222 * * Page 5 of 5 *

Fire System Inspection Certificate

Recommendations:	Comments:

NOTIFICATION OF DEFICIENCIES

CUSTOMER INITIALS: _____

☐ A mark made in the adjacent box indicates that deficiencies exist with the current condition of the Fire Suppression System. If this is the case, the customer's authorized representative, by his or her signature and initials acknowledges these deficiencies represent an **IMMEDIATE AND SERIOUS SAFETY CONCERN** that the customer must correct. Service Company shall not be responsible if the Fire Suppression System malfunctions or fails to function. It is the owner's responsibility to ensure that all deficiencies are removed or repaired.

Authorized Customer Representative


SIGNATURE: _____

PRINT NAME: _____ Jennifer Kobliska

Authorized Approved Fire Protection Representative

SIGNATURE: _____ 

PRINT NAME: _____ Bill Andrew



That is NOT a gas
fume you are
smelling, rather
the R-24 pellets
from the stove.
We have had the
checked and
everything is fine