

TOWNSHIP OF CRANFORD

WWW.CRANFORDNJ.ORG
8 SPRINGFIELD AVE
CRANFORD, NJ 07016

SHIP TO	Fire Department 7 Springfield Avenue Cranford, NJ 07016 T:908-709-7360 F:908-276-6183
	VENDOR #
VENDOR	Survivor Fire & Security Survivor Fire & Safety Equip 39A Myrtle St. Cranford, NJ 07016
	Phone: (908)272-0066 Fax: (908)272-8144

PURCHASE ORDER	
THIS NUMBER MUST APPEAR ON ALL INVOICES, PACKING LISTS, CORRESPONDENCE, ETC.	
NO.	24-00267

ORDER DATE: 01/23/24
REQUISITION NO: R2400266
DELIVERY DATE:
STATE CONTRACT:
F.O.B. TERMS:

PAYMENT RECORD
CHECK NO.
DATE PAID

NOTICE: TAX ID #22-6001739 - TAX EXEMPT

QTY/UNIT	DESCRIPTION	ACCOUNT NO.	UNIT PRICE	TOTAL COST
1.00	Labor - Sprinkler Service Call	4-01-26-310-115-221	293.0000	293.00
		B&G Firehouse: Maintenance & Repairs		
1.00	Fuel Surcharge	4-01-26-310-115-221	7.5000	7.50
		B&G Firehouse: Maintenance & Repairs		
			TOTAL	300.50

CLAIMANT'S CERTIFICATION & DECLARATION	OFFICER'S CERTIFICATION	APPROVAL TO PURCHASE
I do solemnly declare and certify under penalties of the law that the within bill is correct in all its particulars; that the articles have been furnished or services rendered as stated therein; that no bonus has been given or received by any person or persons within the knowledge of this claimant in connection with the above claim; that the amount therein stated is justly due and owing; and that the amount charged is a reasonable one. X <u>Cyndie Van Bavel</u> VENDOR SIGN HERE Office Administrator 1/23/24 OFFICIAL POSITION DATE TAX ID NO. OR SOCIAL SECURITY NO.	I, having knowledge of the facts, certify that the materials and supplies have been received or the services rendered; said certification being based on signed delivery slips or other reasonable procedures. <u>[Signature]</u> 1/23/24 DEPT. HEAD DATE VENDOR MUST SIGN CERTIFICATION STATEMENT ON THIS VOUCHER. MAIL VOUCHER & ITEMIZED BILLS TO: TOWNSHIP OF CRANFORD WWW.CRANFORDNJ.ORG 8 SPRINGFIELD AVE CRANFORD, NJ 07016	DO NOT ACCEPT THIS ORDER UNLESS IT IS SIG <u>[Signature]</u> Chief Financial Officer



INVOICE

Pye Barker Fire & Safety
DBA: Survivor Fire & Safety
39A MYRTLE ST
CRANFORD, NJ 07016-3471
9082720066
pyebarkerfire.com

Customer PO:	Order No:	Invoice No:	Due Date:
Service	ST00120175	IV00110934	02/02/2024
Invoice Date:	Terms:	Invoice Total:	Amount Due:
01/18/2024	Net 15	300.50	300.50

License: NJDFS#P01672

BILL TO:

69384 - Cranford Fire Department
7 Springfield Avenue
Cranford, NJ 07016

WORKSITE:

69384 - Cranford Fire Department
7 Springfield Avenue
Cranford, NJ 07016

Authorized By:	Job Number:	Service Location:	Bill To ID:	Worksite ID:	Technician:
Matt Lubin	SER0000022098	DBA: Survivor Fire & Safety	69384	69384	Wilson Hernandez

Item	Description	Qty	Unit Price	Total	Tax
Labor-Sprinkler	Labor-Sprinkler Service Call	1	293.00	293.00	0.00
FUEL	Fuel Surcharge	1	7.50	7.50	0.00
	Work Notes: Find And Repair Sprinkler System Leak				
	 Save time and stamps by going paperless. View, print, and pay your invoices online at https://customer.pyebarkerfire.com/				

Remit To Address:

Pye-Barker Fire & Safety, LLC
PO BOX 735358
Dallas, TX 75373-5358

PAY NOW:

<https://customer.pyebarkerfire.com>

Subtotal	300.50
Tax	0.00
Total	300.50



Pye-Barker Fire & Safety DBA: Survivor Fire & Safety
39A MYRTLE ST
CRANFORD NJ 07016-3471
9082720066
1234PZ@pyebarkerfs.com

Report Cover Page

SERVICE DATE: 1/15/2024

SERVICE TICKET: ST00120175

BUILDING	STREET	CITY	STATE	ZIP
Cranford Fire Department	7 Springfield Avenue	Cranford	NJ	07016
BUILDING CONTACT	PHONE			
Fire Tech	9082760146			

Please see the attached reports. If there are any questions, please reach out to the above office.

Download your Report at:

<https://customer.pyebarkerfire.com>

Signed 1/15/2024

Inspector: Wilson Hernandez

Key To:
ST00120175

Signed 1/15/2024

Building Contact: Fire Tech
Title:

Licenses:
NJDFS#P01672



Date : 1/15/2024
Frequency :
Service Ticket No. : ST00120175
Inspection Contract No. :
PO No. : Service
Equipment Location : null

DEMAND SERVICE FORM

Property	: Cranford Fire Department	Owner	: Cranford Fire Department
Address	: 7 Springfield Avenue	Address	: 7 Springfield Avenue
City	: Cranford	City	: Cranford
State	: NJ	State	: NJ
Zip	: 07016	Zip	: 07016
Phone	: 9082760146	Phone	: 9082760146

DEFICIENCIES

Repair Service Ticket - (Demand Ticket)

- Deficiency When arrived, fire alarm system was in trouble realigned, one tamper switch, Tighten packing on three valves OS& Y
Also Regulator Was Leaking Air we remove regulator opening up, cleaned out, diaphragm in spring. It s slow down the leak. The customer would like it replaced. Also add T for a drip catch in a nipple with a plug.
Farlow system is back to normal. We will back back with New RegulatorRegulator

DEMAND SERVICE TICKET

What type of repair is this? Sprinkler System

Description of work:

When arrived, fire alarm system was in trouble realigned, one tamper switch, Tighten packing on three valves OS& Y
Also Regulator Was Leaking Air we remove regulator opening up, cleaned out, diaphragm in spring. It s slow down the leak.
The customer would like it replaced. Also add T for a drip catch in a nipple with a plug.
Farlow system is back to normal. We will back back with New RegulatorRegulator

At completion of ticket did all repaired or replaced equipment function properly? No

SIGNATURE

This report was reviewed with: Pye-Barker Fire & Safety

Print Name : Fire Tech Technician : Wilson Hernandez
Signature : [Signature] Signature : [Signature]

ST00120175 -

DBA: Survivor Fire & Safety • 39A MYRTLE ST • CRANFORD NJ • 07016-3471

Date : 1/15/2024

Date : 1/15/2024



Pye-Barker Fire & Safety DBA: Survivor Fire & Safety
39A MYRTLE ST
CRANFORD NJ 07016-3471
9082720066
1234PZ@pyebarkerfs.com

Report Cover Page

SERVICE DATE: 1/15/2024

SERVICE TICKET: ST00120175

BUILDING	STREET	CITY	STATE	ZIP
Cranford Fire Department	7 Springfield Avenue	Cranford	NJ	07016
BUILDING CONTACT	PHONE			
Fire Tech				

Please see the attached reports. If there are any questions, please reach out to the above office.

Download your Report at:

<https://customer.pyebarkerfire.com>

Signed 1/15/2024

Inspector: Wilson Hernandez

Signed 1/15/2024

Building Contact: Fire Tech
Title:

Licenses:
NJDFS#P01672



Date : 1/15/2024
Frequency :
Service Ticket No. : ST00120175
Inspection Contract No. :
PO No. : Service
Equipment Location : null

Systems Deficiency Report

Property	: Cranford Fire Department	Owner	: Cranford Fire Department
Address	: 7 Springfield Avenue	Address	: 7 Springfield Avenue
City	: Cranford	City	: Cranford
State	: NJ	State	: NJ
Zip	: 07016	Zip	: 07016
Contact	: Matt Lubin	Contact	: Cathy Scotti
Phone	:	Phone	:
Email	: M-Lubin@Cranfordnj.Org	Email	: C-Scotti@cranfordnj.org

Reporting Technician: Wilson Hernandez

What type of service is this for? ☐ Fire Alarm ☐ Clean Agent Suppression ☐ Security
☐ Access Control ☐ Video ☐ Fire Door(s)

How many deficiencies need to be quoted? **1

How many technicians are needed to perform this repair? 1

List how many hours of drive time will be needed for this repair? 4

How many hours (per technician) will be needed to perform this repair? 4

Will this repair require any special equipment? (lift, confined space equipment, testing equipment, etc.) No

If special equipment is needed, list it here:

Will this repair require a permit fee or another type of fee? No

Can this work be performed during the normal business hours of 8 am to 5 pm? Yes

Please explain the scope of work that needs to be completed. This includes specific parts needed for an accurate proposal to the customer:

Regulator Was Leaking Air we remove regulator opening up, cleaned out, diaphragm in spring. It s slow down the leak. The customer would like it replacé. Also add T for a drip catch in a nipple with a plug.
Farlow system is back to normal. We will back back with New Regulator
1/2 T Galvanized With 1/2 x2 Nipple 1. -1/2 Cap For Drip Existing 1/2 Elbow 90 Degree to Be Removed Inlet To Regulator

Did the device have voltage, what was the reading?

Will programming be needed for the repair?

DBA: Survivor Fire & Safety • 39A MYRTLE ST • CRANFORD NJ • 07016-3471

Please provide any programming information that might be pertinent to quoting or performing the repair:

General Notes:

SIGNATURE

This report was reviewed with:

Pye-Barker Fire & Safety

Print Name : Fire Tech

Technician : Wilson Hernandez

Signature : 
ST00120175 -

Signature : 

Date : 1/15/2024

Date : 1/15/2024