

TOWNSHIP OF CRANFORD

WWW.CRANFORDNJ.ORG

8 SPRINGFIELD AVE

CRANFORD, NJ 07016

SHIP TO	Fire Department 7 Springfield Avenue Cranford, NJ 07016 T:908-709-7360 F:908-276-6183
	VENDOR # : SURVIV Survivor Fire & Security Survivor Fire & Safety Equip 39A Myrtle St. Cranford, NJ 07016 Phone: (908)272-0066 Fax: (908)272-8144

PURCHASE ORDER	
THIS NUMBER MUST APPEAR ON ALL INVOICES, PACKING LISTS, CORRESPONDENCE, ETC.	
NO.	25-00133-06

ORDER DATE: 01/14/25

REQUISITION NO:

DELIVERY DATE: 08/07/25



STATE CONTRACT:

F.O.B. TERMS:

PAYMENT RECORD
CHECK NO.
DATE PAID

NOTICE: TAX ID #22-6001739 - TAX EXEMPT

QTY/UNIT	DESCRIPTION	ACCOUNT NO.	UNIT PRICE	TOTAL COST
1.00	Annual Fire Alarm Insp	5-01-25-266-145-280	375.0000	375.00
		Uniform Fire Code		
2.00	12V12Amp Battery	5-01-25-266-145-280	70.0000	140.00
		Uniform Fire Code		
			TOTAL	515.00

CLAIMANT'S CERTIFICATION & DECLARATION	OFFICER'S CERTIFICATION	APPROVAL TO PURCHASE
I do solemnly declare and certify under penalties of the law that the within bill is correct in all its particulars; that the articles have been furnished or services rendered as stated therein; that no bonus has been given or received by any person or persons within the knowledge of this claimant in connection with the above claim; that the amount therein stated is justly due and owing; and that the amount charged is a reasonable one. X  VENDOR SIGN HERE OFFICIAL POSITION _____ DATE _____ TAX ID NO. OR SOCIAL SECURITY NO. _____	I, having knowledge of the facts, certify that the materials and supplies have been received or the services rendered; said certification being based on signed delivery slips or other reasonable procedures.  8/6/25 DEPT. HEAD _____ DATE _____ VENDOR MUST SIGN CERTIFICATION STATEMENT ON THIS VOUCHER. MAIL VOUCHER & ITEMIZED BILLS TO: TOWNSHIP OF CRANFORD WWW.CRANFORDNJ.ORG 8 SPRINGFIELD AVE CRANFORD, NJ 07016	DO NOT ACCEPT THIS ORDER UNLESS IT IS SIGNED BELOW. Chief Financial Officer _____



INVOICE

Pye Barker Fire & Safety
DBA: Survivor Fire & Safety
39A MYRTLE ST
CRANFORD, NJ 07016-3471
www.pyebarkerfs.com
908-272-0066
1234PZ@pyebarkerfs.com

Customer PO:	Order No:	Invoice No:	Due Date:
NEED PO	ST00646316	IV00669244	09/20/2025
Invoice Date:	Terms:	Invoice Total:	Amount Due:
08/06/2025	Net 45	515.00	515.00

License: NJDFS#P01672

BILL TO:
69384 - Cranford Fire Department
7 Springfield Avenue
Cranford, NJ 07016

WORKSITE:
69384 - Cranford Fire Department
7 Springfield Avenue
Cranford, NJ 07016

Authorized By:	Job Number:	Service Location:	Bill To ID:	Worksite ID:	Technician:
Matt Lubin	CON0000054221	Cranford, NJ	69384	69384	Tullaram Seerattan

Item	Description	Qty	Unit Price	Total	Tax
INSPFAA	Annual Fire Alarm Insp	1	375.00	375.00	0.00
12V12AMP	12V12Amp Battery	2	70.00	140.00	0.00
Work Notes: Fire Alarm Inspection Completed as per NFPA 72 and the State of New Jersey Uniform Fire Code.  Save time and stamps by going paperless. View, print, and pay your invoices online at https://customer.pyebarkerfire.com/					

You agree that the services subject to this invoice are governed by the Pye-Barker General Terms and Conditions located at <https://pyebarkerfs.com/generalterms>, which shall be incorporated herein by reference.

Remit To Address:
Pye-Barker Fire & Safety, LLC
DBA: Survivor Fire & Safety
PO BOX 735358
Dallas, TX 75373-5358

PAY NOW:

Use the token below to create your account

KcmbnchfcDA=

<https://customer.pyebarkerfire.com>

Subtotal	515.00
Tax	0.00
Freight	0.00
Total	515.00



Pye-Barker Fire & Safety DBA: Survivor Fire & Safety
39A MYRTLE ST
CRANFORD NJ 07016-3471
9082720066
1234PZ@pyebarkerfs.com

Report Cover Page

SERVICE DATE: 8/5/2025

SERVICE TICKET: ST00646316

BUILDING	STREET	CITY	STATE	ZIP
Cranford Fire Department	7 Springfield Avenue	Cranford	NJ	07016
BUILDING CONTACT	PHONE			
Matt Lubin	9082760146			

System Status: Pass

Tag Color: White

Please see the attached reports. If there are any questions, please reach out to the above office.

Download your Report at:

<https://customer.pyebarkerfire.com>

Signed 8/5/2025

Inspector: Tullaram Seerattan

Matt Lubin
August 05, 2025 03:21 PM
ST00646316

Signed 8/5/2025

Building Contact: Matt Lubin
Title: Fire House

Licenses:
NJDFS#P01672

Service Ticket No. : ST00646316Date : 8/5/2025Frequency : AnnualService Ticket No. : ST00646316Inspection Contract No. : 0000054221PO No. : Recurring Inspection

Equipment Location : _____

Fire Alarm Inspection

Property	: <u>Cranford Fire Department</u>	Owner	: <u>Cranford Fire Department</u>
Address	: <u>7 Springfield Avenue</u>	Address	: <u>7 Springfield Avenue</u>
City	: <u>Cranford</u>	City	: <u>Cranford</u>
State	: <u>NJ</u>	State	: <u>NJ</u>
Zip	: <u>07016</u>	Zip	: <u>07016</u>
Phone	: <u>9082760146</u>	Phone	: <u>9082760146</u>

FIRE ALARM INSPECTION SUMMARY

Smoke Detector:	<u>18</u>	Heat Detector:	<u>16</u>
Supervisory:	<u>3</u>	Waterflow Switch:	<u>1</u>

DEFICIENCIES

None found at time of inspection.

SYSTEM DETAILS

Authority Having Jurisdiction	N/A
System Tested and Inspected in Accordance with NFPA 72, Edition Dated	2025
System Meets NFPA 72 Standard, Edition Dating?	2025
System Installed Per Manufacturer Specifications?	Yes
System Complies With Local Code & Standards?	Yes
Panel Manufacturer	kidde
Model	vigilant vs1
Panel Number and/or Location	dispatcher room
Circuit Class	A
Primary Normal Volts	120
Control Panel Amps	18
Over Current Type	Fuse
Over Current Amps/ MHOs	18
Battery Size	12 Volts 12 Amps
Battery Type	Sealed Lead-Acid
Battery #1 Voltage	12
Battery #1 Amp Hour Rating	12
Install Date	2025
Battery #2 Voltage	12

DBA: Survivor Fire & Safety • 39A MYRTLE ST • CRANFORD NJ • 07016-3471

Battery #2 Amp Hour Rating	12
Install Date	2025
Charger Voltage	25.2
Load Test Left	11.8
Load Test Right	12.2
Last Service Date	08/2025
**Any Panel Defects or Deficiencies?	No
Comments or Recommendations	2 - 12 Votes 12 Amps Batteries Were Replaced, Due to Batteries Failed.

SYSTEM TEST AND INSPECTIONS

Control Panel (FACP)	
Specify type of inspection	Visual and Functional
Sequence Of Operation	
Specify type of inspection	Visual & Functional
Release Sequence Type	Single Zoned
Interface Equipment	
Specify type of inspection	Visual and Functional
Lamps / Led	
Specify type of inspection	Visual and Functional
Fuses	
Specify type of inspection	Visual
Primary Power Supply	
Specify type of inspection	Visual and Functional
Trouble Signals	
Specify type of inspection	Visual and Functional
Disconnect Switches	
Specify type of inspection	Visual and Functional
Ground Fault Monitoring	
Specify type of inspection	Visual and Functional
Transient Suppressors	
Specify type of inspection	N/A
Remote Annunciators	
Specify type of inspection	N/A
Door Holders	
Specify type of inspection	N/A
Heat Detectors	
Does System Have Fixed Temperature, Non-Restorable Link Type or Spot Type Heat Detectors?	N/A
**Are There Any Deficiencies To Report?	No

EMERG. COMM. EQUIP / NOTIFICATION APP.	
System Performance	
Visual	Pass
Functional	Pass
Audible	
Visual	Pass
Functional	Pass
Visual	
Visual	Pass
Functional	Pass
Speakers	
Visual	N/A
Functional	N/A
Phone Set	
Visual	N/A
Functional	N/A
Phone Jack	
Visual	N/A
Functional	N/A
Off Hook Indicator	
Visual	N/A
Functional	N/A
Amplifiers	
Visual	N/A
Functional	N/A
Tone Generators	
Visual	N/A
Functional	N/A
Call In Signal	
Visual	N/A
Functional	N/A
Voice Clarity	
Visual	N/A
Functional	N/A
Fireman Phone	
Visual	N/A
Functional	N/A
**Are There Any Emergency Equipment Deficiencies To Report?	No

MONITORING & NOTIFICATION

On/off Premises Monitoring	
Panel Condition Normal On Arrival?	Yes
Time Placed On Test	11:00am
Monitoring Agency Name	PD
Operator Name	Carol Cole
Monitoring Agency Phone #	0
Account Number	N/A
Account Password	N/A
Phone Line #1	0
Phone Line #2	0
Transmission Equipment Type	Local
Alarm Signal - Received?	Pass
Alarm Restore - Received?	Pass
Trouble Signal - Received?	Pass
Trouble Restored - Received?	Pass
Supervisory Signal - Received?	Pass
Supervisory Restore - Received?	Pass
Time of Alarm Activation on Panel	01:30pm
Alarm Signal Received 90 Seconds or Less?	Yes
Notifications Of Testing Completion	
Building Management Notified?	Yes
Monitoring Agency Notified?	Yes
Building Occupants Notified?	Yes
Authority Having Jurisdiction Notified?	No
Date System Restored to Normal Operation	08/05/2025
Time System Restored to Normal Operation	03:30pm
Fire Alarm Panel Condition Normal On Departure?	Yes
**Inspected and/or Tested Items in This Section Pass or Fail?	Pass

WATERFLOW SWITCH - Location: In Sprinkler Room, Truck Bay

Switch Type	Pressure Type
Manufacturer	Potter
Size (inches)	.50
**Inspected and/or Tested Items in This Section Pass or Fail?	Pass

DEVICE INSPECTION REPORT

Total Inspected:37

Total Failed:0

Total Passed:37

Device Location	Zone or Address	Type	Make	Model	Sensitivity Range	Sensitivity Alarm Point	Pass / Fail	Comments
Dispatch Office		Smoke Detector					Pass	
Day Room		Smoke Detector					Pass	
Day Room		Smoke Detector					Pass	
Day Room Kitchen		Heat Detector					Pass	
Day Room Bathroom		Heat Detector					Pass	
Main Entrance Lobby		Smoke Detector					Pass	
Main Entrance Bathroom		Heat Detector					Pass	
Office And Closet		Smoke Detector					Pass	
Office And Closet		Smoke Detector					Pass	
Office And Closet		Smoke Detector					Pass	
Office And Closet		Smoke Detector					Pass	
Office And Closet		Smoke Detector					Pass	
Office And Closet		Heat Detector					Pass	
Storage Room Off Rear Corridor		Heat Detector					Pass	
Locker Room		Smoke Detector					Pass	
Rear Corridor		Smoke Detector					Pass	
Locker Room		Smoke Detector					Pass	
Bathroom		Heat Detector					Pass	
Small Hallway Locker Bathroom		Smoke Detector					Pass	
Fire Fighters Dorm		Smoke Detector					Pass	
Fire Fighters Dorm		Smoke Detector					Pass	
Office Dorm		Smoke Detector					Pass	
Officers Lock And Bathroom		Smoke Detector					Pass	
Officers Lock And Bathroom		Smoke Detector					Pass	
Officers Lock And Bathroom		Heat Detector					Pass	
Janitors Room		Heat Detector					Pass	
Furnace Room		Heat Detector					Pass	
Furnace Room		Heat Detector					Pass	
Scuba Room		Heat Detector					Pass	
Mezzanine Level Scuba Room		Heat Detector					Pass	
Truck Bay		Heat Detector					Pass	
Truck Bay		Heat Detector					Pass	
Truck Bay		Heat Detector					Pass	
Shop		Heat Detector					Pass	

In Sprinkler Room, Truck Bay		Supervisory					Pass	
In Sprinkler Room, Truck Bay		Supervisory					Pass	
In Sprinkler Room, Truck Bay		Supervisory					Pass	

SIGNATURE

This report was reviewed with:

Pye-Barker Fire & Safety

Print Name : Matt LubinTechnician : Tullaram SeerattanSignature : 
Matt Lubin
August 05, 2025 9:23 PM
ST00646316 -Signature : Date : 8/5/2025Date : 8/5/2025