



BERGEN COUNTY UTILITIES AUTHORITY

Box 9, Foot of Mehrhof Road, Little Ferry, New Jersey 07643

ROBERT E. LAUX
Executive Director

Via E-Mail ONLY: opra+request-89249-f05c3262@requests.opramachine.com

April 14, 2026

Tony Michael

Re: OPRA Request Response – Request dated April 3, 2026

Dear Mr. Michael:

The Bergen County Utilities Authority (the “BCUA”) has received your request submitted by e-mail dated April 3, 2026 (the “Request”) submitted to the BCUA under the Open Public Records Act, N.J.S.A. 47:1A-1 et seq. (“OPRA”).

OPRA provides that the BCUA’s response to your OPRA Request is due seven (7) business days from receipt thereof. This correspondence shall be deemed to be the BCUA’s response to your OPRA Request, which is timely made.

In response to your request, please be advised that the Authority has located records responsive to your request. Enclosed herewith (via electronic transmission) are copies of available invoices and related documentation pertaining to fire extinguisher inspection and servicing for the requested time period.

The responsive records include, but may not be limited to:

- Vendor invoices and supporting payment documentation (e.g., Cerullo Fire Protection, Inc.) reflecting annual inspections and services;
- Associated purchase orders and vouchers for payment;
- Inspection reports and service logs related to fire extinguisher maintenance.

These materials correspond to the records maintained by the Authority in the ordinary course of business.

Should you have any questions or require further clarification, please feel free to contact the undersigned.

Very truly yours,

Robert Laux
Executive Director

Attachments: OPRA request dated April 3, 2026
Items listed above

Ortiz, Jessica

From: Laux, Robert
Sent: Monday, April 6, 2026 9:59 AM
To: Ortiz, Jessica
Subject: Fwd: OPRA request - Spending

From: Tony Michael <opra+request-89249-xxxxxxx@xxxxxxxxxxxxxxxxxxx>
Date: April 3, 2026 at 8:59:24 PM EDT
To: "Laux, Robert" <rlaux@bcua.org>
Subject: **OPRA request - Spending**

CAUTION: This email originated from outside of the BCUA. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Dear Bergen County Utilities Authority,

Please accept this electronic request for public records made under OPRA and the common law right of access. I am not required to fill out an official form or use a particular software platform to submit my request per NJSA 47:1A-6(f), which states that an email from a requestor including all of the information required on the adopted form shall suffice in place of a completed form as a valid government record request.

I HAVE NOT been convicted of any indictable offense under the laws of New Jersey, any other state, or the United States.

I WILL NOT use the requested government records for a commercial purpose.

I AM NOT seeking records in connection with a legal proceeding.

Records requested:

Copies of ALL invoices for all fire extinguisher, kitchen fire suppression and fire alarm services from 2020 to present

My preferred delivery method for response(s) to this request is by E-mail as attachments. Please confirm you have received this request. If you are not the custodian of records, please forward my request to that person and provide their email address to me for future reference.

Yours faithfully,

Tony Michael

Please deliver records electronically via email to the below UNIQUE address for all replies to this request:

xx@xxxxxxxx.xxxxxxxxxxxx.xxx

Is xxxxx@xxxx.xxx the wrong address for OPRA requests to Bergen County Utilities Authority? If so, please contact us using this form:

https://link.edgepilot.com/s/c62c3186/Vhw3ildoTUysK6Jp3d0LLQ?u=https://opramachine.com/change_request/new?body=bergen_county_utilities_authority

Disclaimer: This message and any reply that you make will be published on the internet. Our privacy and copyright policies:

<https://link.edgepilot.com/s/a88cc3a7/5hLihDbFA020k0Z7qediCg?u=https://opramachine.com/help/officers>

View this OPRA request & responses online:

https://link.edgepilot.com/s/53edac22/EqqUyvEaVU2yTmBgXZfU-Q?u=https://opramachine.com/request/spending_367

Please note that in some cases publication of requests and responses will be delayed.

If you find this service useful as an OPRA custodian, please ask your web manager to link to us from your organisation's website.

"OPRAmachine's mission is to give people easy and affordable access to New Jersey public records.

For more information, contact us at: (732) 707-1628 or PO Box 3180, New Brunswick, NJ 08903."



**Bergen County
Utilities Authority**
www.bcua.org



VOUCHER For Payment

PO Number: **20252713**

*This PO Number Must Appear On All
Correspondence, Invoices, and Shipments*

Date: 01/05/2026

Vendor Number: 5942

29451

CERULLO FIRE PROTECTION, INC.
901-NEW BRUNSWICK AVE.
RAHWAY, NJ 07065

**Note: For Payment, This VOUCHER Page Must Be Signed By Claimant (Vendor)
And Presented Along With An Original Invoice Stating Terms**

DESCRIPTION: DESCRIPTION: ANNUAL FIRE EXTINGUISHER INSPECTIONS. E60631

Line Number	Quantity	UoM	Description	Unit Cost	Extended Cost
1	262.0000	EA	LITTLE FERRY, EDGEWATER AND PUMP STAION EXTINGUISHERS. ANNUAL INSPECTION FOR ALL	\$7.2500	\$1,899.50

Subtotal	\$1,899.50
Purchase Order Total	\$1,899.50

I do solemnly declare and certify under the penalties of the law that the within bill is correct in all its particulars; that the articles have been furnished or services rendered as stated therein; that no bonus has been given or received by any person or persons within the knowledge of this claimant in connection with the above claim; that the amount therein stated is justly due and owing; and that the amount charged is a reasonable one.

Claimant Signature _____

Printed _____

Title _____

Date _____

Federal ID# or Social Security # _____

Send Correspondence, Invoice, Voucher, to:

Bergen County Utilities Authority
PO Box 9
Little Ferry, NJ 07643-0009
Telephone: 201-641-2552
Fax: 201-807-8681
Email: AccountsPayable@bcua.org

----- For BCUA Use Only -----

FINANCIAL APPROVAL: I certify that the goods or services indicated above were received and payment is due as claimed.

Treasurer/Chief Financial Officer: _____

Date _____

Cerullo Fire Protection, Inc.
901 New Brunswick Avenue
Rahway, NJ 07065
(732) 388-1949 Fax (732) 388-0096

CUSTOMER #: 1458

INVOICE #: 141540

INVOICE DATE: 01/08/26

DUE DATE: 02/07/26

BILL TO:

Bergen Co Utilities Authority
PO Box 9
Little Ferry, NJ 07643-0009

ATTN: Michael Cammett

PHONE (201) 641-2552 FAX (201) 807-8641

LOCATION: 4025

Bergen County Utilities Auth
298 Foot of Mehrhof Road
Little Ferry, NJ

WORK ORDER NUMBER: 50936

YOUR REFERENCE NUMBER: PO#20252713

DESCRIPTION	QUANTITY	PRICE	AMOUNT
OTHER			
01/08/26 Extinguisher inspection E60631	262.00	7.2500	1,899.50
		TOTAL OTHER:	1,899.50
		TOTAL:	1,899.50

PAYMENT DUE UPON RECEIPT

A 2% charge will be applied monthly to all past due accounts, totaling 24% per annum.

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, New Jersey 07065

Phone # 732-388-1949 / Fax # 732-388-0096

Permit # P00140

Mobile Recharge Unit

SOLD TO:

BCUA

298 Mehrof Rd

Little Ferry, NJ

SHIP TO:

DATE PERFORMED	PERSON TO SEE OR REF. NO.	EMAIL	PHONE #	FAX #
01/08/2026	Mike		201-641-2552	

EQUIPMENT #	LAST / TREQ.	SERVICE CONTRACT #
		E60631

QTY.	DESCRIPTION	UNIT PRICE	AMOUNT
262	☒ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL Portable Fire Extinguisher - inspection/service	\$7.25	\$1,899.50
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00

EQUIPMENT NOTE:

SITE NOTES:

QTY.	MATERIALS/PARTS	PRICE	AMOUNT	LABOR/TECH	HOURS	RATE	AMOUNT
			\$0.00				\$0.00
			\$0.00				\$0.00
			\$0.00				\$0.00
			\$0.00				\$0.00
			\$0.00				\$0.00
	MATERIAL SUB-TOTAL		\$ 0.00	LABOR SUB-TOTAL			\$ 0.00

SERVICES AND/OR MATERIALS
SPECIFIED IN GOOD ORDER

TERMS:
CUSTOMER WILL BE RESPONSIBLE FOR ALL
COLLECTION FEES, LEGAL FEES,
COURT COSTS AND SIMILAR EXPENSES
INCURRED IN ORDER TO
COLLECT PAST DUE ACCOUNTS

SERVICE PERFORMED BW

X

AUTHORIZED SIGNATURE

INSTRUCTIONS:

MATERIAL SUB-TOTAL	\$ 0.00
TOTAL	\$ 1,899.50
TAX	
PAY THIS AMOUNT →	\$ 1,899.50

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue - Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCVA

Mehrup Rd

Date: 1-8-26

Little Ferry NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
1		X	ABC	10			BA	
2		X	ABC	10			BA	
3		X	ABC	10			BE	
4		X	ABC	10			KID	
5	Office	X	ABC	10			BA	
6		X	ABC	10			BA	
7	Ex 50	X	CO2	15			AM	
8	E-2	X	ABC	20			BE	
9		X	ABC	10			BE	
10	WBR-4	X	CO2	10			BE	
11		X	ABC	10			BA	
12	W46	X	ABC	10			BE	
13	W3 Lunch	X	ABC	10			BE	
14	MA 1	X	ABC	10			BA	
15	MA 2	X	ABC	10			BE	
16	MA 3	X	ABC	10			BA	
17		X	CO2	50				
18	W3	X	ABC	10			BA	
19		X	ABC	20			BE	
20	W1	X	ABC	10			BA	
21	V1	X	ABC	10			BA	
22	V2	X	ABC	10			BE	
23	V3	X	ABC	10			BE	
24		X	ABC	10			BA	
25		X	ABC	10			KID	
26		X	ABC	10			BE	
27		X	ABC	10			AM	
28		X	ABC	5			BE	
29		X	ABC	10			BE	
30		X	ABC	10			AM	
31	Elect Rm	X	ABC	20			BC	
32		X	ABC	10			AN	
33		X	ABC	10			BA	
34	Old Admin	X	ABC	10			BA	
35		X	ABC	10			AM	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: Bill Willard

Print: Bill Willard

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: **BCUA**

**Mehrhof Rd
Little Ferry NJ**

Date: **1-8-26**

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	5Yr	Brand	Performed
36	Boil Screen	X	CO2	10			KIN	
37		X	CO2	15			BA	
38		X	ABC	10			BA	
39		X	ABC	20			KID	
40		X	ABC	70			AM	
41	Outside	X	ABC	10			KID	
42	Switchgear	X	CO2	10				
43		X	CO2	10				
44	Admin	X	ABC	10			BE	
45		X	PW	2.5			BE	
46	7	X	ABC	10			BE	
47		X	ABC	10			BE	
48	3	X	ABC	10			BC	
49	4	X	PW	2.5			BE	
50		X	PW	2.5			BE	
51		X	PW	2.5			BE	
52		X	ABC	10			BE	
53	BSMT	X	ABC	10			BA	
54		X	CO2	70			FF	
55		X	CO2	15			FF	
56	Mail R	X	ABC	10			BE	
57		X	ABC	10			AM	
58		X	ABC	10			BA	
59	10	X	ABC	20			BE	
60	CB	X	ABC	10			BA	
61	3	X	ABC	20			BC	
62	2.5	X	PW	2.5			BE	
63	26	X	ABC	10			BE	
64	27	X	CO2	15			KID	
65	W/D	X	ABC	10			BC	
66		X	ABC	10			BE	
67	29	X	ABC	10				
68	30	X	ABC	20			BE	
69	31	X	ABC	10			BE	
70	32	X	ABC	10			BE	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: **BCVA**

Mehrhof Rd

Date: **1-8-26**

Little Ferry NJ

	Location	OK X	Type	Size#	Due Hydro	Due 6Yr	Brand	Service Performed
71	CB 34	X	ABC	10			BA	
72	4	X	ABC	10			BE	
73	Super	X	PW	2.5			BA	
74	5	X	ABC	10			BE	
75	7	X	ABC	10			BE	
76	Women	X	ABC	10			BE	
77		X	ABC	10			BE	
78	8	X	ABC	10			BE	
79		X	ABC	10			BE	
80		X	ABC	10			BE	
81		X	ABC	10			BE	
82		X	ABC	10			BE	
83		X	ABC	10			BE	
84		X	ABC	10			BE	
85		X	ABC	10			BE	
86	15	X	ABC	10			BA	
87		X	ABC	10			BE	
88		X	PW	2.5			BE	
89	8	X	ABC	10			BE	
90	Lunch	X	ABC	20			BE	
91		X	ABC	20			BE	
92		X	ABC	10			BE	
93		X	CO2	15			BC	
94		X	PW	2.5			BL	
95		X	ABC	20			BC	
96		X	ABC	10			BE	
97	Women	X	CO2	10			FP	
98		X	ABC	50			AM	
99		X	CO2	15			BA	
100		X	CO2	10			AM	
101	Blower	X	CO2	15			KID	
102		X	ABC	20			AM	
103		X	ABC	20			AM	
104		X	ABC	20			AM	
105		X	ABC	50			AM	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCVA

Date: 1-8-26

Mehrhof Rd
Little Falls NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
106	BLOWER	X	ABC	20			BC	
107		X	CO2	15			KID	
108		X	CO2	10			KID	
109	DIGESTER	X	ABC	20			AM	
110		X	ABC	20			KID	
111		X	CO2	15			KID	
112		X	ADL	20			AM	
113		X	CO2	10			AM	
114		X	CO2	15			KID	
115		X	ABC	20			AN	
116		X	ABC	20			AM	
117	Gnt	X	ABC	10			BA	
118	Gnt 2	X	ADL	10			KID	
119	Thickener	X	ADL	10			BA	
120		X	ABC	10			BA	
121		X	ABC	10			BA	
122		X	ABC	10			AM	
123	WAS	X	ABC	10			BA	
124		X	ABC	10			BE	
125		X	ABC	10			PI	
126		X	ABC	10			BA	
127		X	ABC	10			AM	
128		X	ABC	10			KID	
129		X	ABC	10			AN	
130		X	ABC	10			AN	
131		X	ABC	10			BA	
132		X	ABC	10			KID	
133		X	ABC	10			KID	
134		X	CO2	15			KID	
135	HD Storage	X	CO2	15			KID	
136		X	CO2	15			KID	
137	Return 2	X	CO2	10			KID	
138	Oil	X	ABC	10			AN	
139		X	ABC	10			KID	
140	Return 1	X	ABC	10			BA	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCVA

Mehrhof Rd

Date: 1-8-26

Little Ferry NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
141		X	ABC	10			BA	
142		X	ABC	20			AM	
143	Polymer	X	ABC	10			BA	
144		X	ABC	10			BA	
145		X	ABC	10			BA	
146		X	CO2	15			KID	
147		X	ABC	10			AM	
148	Ref 1 2	X	ABC	20			BE	
149	DST 1st	X	ABC	10			BC	
150		X	ABC	10			BA	
151	Elev	X	ABC	10			BC	
152	Boiler	X	ABC	20			BE	
153		X	ABC	10			BE	
154		X	ABC	10			AM	
155		X	ABC	10			BE	
156		X	ABC	10			KIP	
157		X	ABC	10			BE	
158		X	ABC	10			PC	
159		X	ABC	10			DE	
160		X	ABC	10			DE	
161		X	ABC	10			KIP	
162	2nd F	X	ABC	10			AM	
163		X	ABC	10			BA	
164			ABC	10	—	—	BE	
165		X	ABC	10			BE	
166		X	ABC	10			AN	
167		X	ABC	10			KID	
168		X	ABC	10			BE	
169	3rd	X	ABC	10			BA	
170		X	ABC	10			BC	
171	Prime B	X	ABC	10			BA	
172	Elect	X	ABC	20			BE	
173		X	ABC	10			BA	
174	Ramp B. 1st	X	ABC	10			BE	
175		X	CO2	20			BA	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: **BCUA**

Mehrhof Rd

Date: **1-8-26**

Little Ferry NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
176	Ramp Build 1	X	DOZ	15			FP	
177		X	ABL	20			KM	
178		X	COZ	10			KID	
179		X	ABC	10			BA	
180		X	ABC	10			BA	
181		X	ABC	10			BA	
182		X	COZ	15			KID	
183	Ramp 2	X	ABC	10			PA	
184		X	ABC	20			AM	
185	Incl	X	ABL	20			PR	
186		X	COZ	10			KIM	
187		X	ABC	20			BC	
188	Sub	X	ABL	20			BC	
189		X	ABC	20			DA	
190	Sub 2	X	ABC	20			BC	
191		X	ABL	10			AM	
192	Prime 3	X	ABC	10			PA	
193	Elect	X	COZ	15			KID	
194	Prime P	X	ABL	10			KID	
195	Elect	X	COZ	15			FP	
196		X	COZ	10			BC	
197		X	COZ	10			KID	
198		X	ABC	10			BA	
199	Pipe	X	ABC	10			KID	
200		X	ABC	11			BA	
201		X	ABL	10			KID	
202		X	ABL	10			BA	
203		X	ABC	10			BA	
204		X	ABC	10			DE	
205		X	ABC	10			BA	
206		X	ABC	10			AM	
207	Sludger 4	X	ABL	10			BA	
208		X	COZ	10			KID	
209		X	COZ	10			KID	
210	SPARE	X	ABC	10			AM	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCVA

Mehrhof Rd

Date: 1-8-26

Little Ferry NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
211	SPARES	X	CO2	10'				
212		X	CO2	10'				
213		X	CO2	10'				
214		X	CO2	10'				
215		X	CO2	10'				
216		X	ABC	2.5'				
217		X	ABC	5'				
218		X	ABC	5'				
219		X	ABC	5'				
220		X	ABC	5'				
221		X	ABC	5'				
222		X	ABC	5'				
223		X	ABC	5'				
224		X	ABC	5'				
225		X	ABC	5'				
226		X	ABC	5'				
227		X	ABC	10'				
228		X	ABC	10'				
229	SPARES	X	ABC	10'				
230	Ramp House	X	CO2	10'				
231		X	ABC	20'				
232		X	ABC	5A'				
233		X	ABC	10'				
234		X	ABC	10'				
235		X	ABC	10'				
236		X	ABC	10'				
237		X	ABC	10'				
238		X	ABC	10'				
239	Ramp House	X	ABC	10'				
240	Edgewater	X	CO2	10'				
241		X	CO2	10'				
242		X	CO2	10'				
243		X	CO2	10'				
244		X	CO2	10'				
245	Edgewater	X	CO2	10'				

Signature: _____

Time In: _____

Print: _____

Time Out: _____

Date: _____

Tech Signature: _____

Print: _____

901 New Brunswick Avenue • Rahway, NJ 07065
Tel: (732) 388-1949 Fax: (732) 388-0096
License # P00140

License # P00140

Little Ferry NJ

Time In: _____
Time Out: _____
Tech Signature: _____
Print: _____

Cerullo Fire Protection, Inc.
901 New Brunswick Avenue
Rahway, NJ 07065
(732) 388-1949 Fax (732) 388-0096

CUSTOMER #: 1458

INVOICE #: 141540

INVOICE DATE: 01/08/26

DUE DATE: 02/07/26

BILL TO:

Bergen Co Utilities Authority
PO Box 9
Little Ferry, NJ 07643-0009

ATTN: Michael Cammett

PHONE (201) 641-2552 FAX (201) 807-8641

LOCATION: 4025

Bergen County Utilities Auth
298 Foot of Mehrhof Road
Little Ferry, NJ

WORK ORDER NUMBER: 50936

YOUR REFERENCE NUMBER: PO#20252713

DESCRIPTION	QUANTITY	PRICE	AMOUNT
OTHER			
01/08/26 Extinguisher inspection E60631	262.00	7.2500	1,899.50
		TOTAL OTHER:	1,899.50
		TOTAL:	1,899.50

PAYMENT DUE UPON RECEIPT

A 2% charge will be applied monthly to all past due accounts, totaling 24% per annum.

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, New Jersey 07065

Phone # 732-388-1949 / Fax # 732-388-0096

Permit # P00140

Mobile Recharge Unit

SOLD TO:

BCUA

298 Mehrof Rd

Little Ferry, NJ

SHIP TO:

DATE PERFORMED	PERSON TO SEE OR REF. NO.	EMAIL	PHONE #	FAX #
01/08/2026	Mike		201-641-2552	

EQUIPMENT #	LAST / FREQ.	SERVICE CONTRACT #
		E60631

QTY.	DESCRIPTION	UNIT PRICE	AMOUNT
262	☒ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL Portable Fire Extinguisher - Inspection/service	\$7.25	\$1,899.50
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00

EQUIPMENT NOTE:

SITE NOTES:

QTY.	MATERIALS/PARTS	PRICE	AMOUNT	LABOR/TECH	HOURS	RATE	AMOUNT
			\$0.00				\$0.00
			\$0.00				\$0.00
			\$0.00				\$0.00
			\$0.00				\$0.00
			\$0.00				\$0.00
	MATERIAL SUB-TOTAL		\$ 0.00	LABOR SUB-TOTAL			\$ 0.00

SERVICES AND/OR MATERIALS
SPECIFIED IN GOOD ORDER

TERMS:
CUSTOMER WILL BE RESPONSIBLE FOR ALL
COLLECTION FEES, LEGAL FEES,
COURT COSTS AND SIMILAR EXPENSES
INCURRED IN ORDER TO
COLLECT PAST DUE ACCOUNTS

X
AUTHORIZED SIGNATURE

SERVICE PERFORMED BY

INSTRUCTIONS:

MATERIAL SUB-TOTAL	\$ 0.00
TOTAL	\$ 1,899.50
TAX	
PAY THIS AMOUNT →	\$ 1,899.50

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue - Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCVA

Mehrup Rd

Date: 1-8-26

Little Ferry NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	GYr	Brand	Performed
1		X	ABC	10			BA	
2		X	ABC	10			BA	
3		X	ABC	10			BE	
4		X	ABC	10			KID	
5	Office	X	ABC	10			BA	
6		X	ABC	10			BA	
7	Perp	X	CO2	15			AM	
8	E-2	X	ABC	20			BE	
9		X	ABC	10			BE	
10	WBR-4	X	CO2	10			BE	
11		X	ABC	10			BA	
12	W46	X	ABC	10			BE	
13	W3 Lunch	X	ABC	10			BE	
14	MA 1	X	ABC	10			BA	
15	MA 2	X	ABC	10			BE	
16	MA 3	X	ABC	10			BA	
17		X	CO2	50				
18	W3	X	ABC	10			BA	
19		X	ABC	20			BE	
20	W1	X	ABC	10			BA	
21	V1	X	ABC	10			BA	
22	V2	X	ABC	10			BE	
23	V3	X	ABC	10			BE	
24		X	ABC	10			BA	
25		X	ABC	10			KID	
26		X	ABC	10			BE	
27		X	ABC	10			AM	
28		X	ABC	5			BE	
29		X	ABC	10			BE	
30		X	ABC	10			AM	
31	Elec Rm	X	ABC	20			BC	
32		X	ABC	10			AN	
33		X	ABC	10			BA	
34	Old Admin	X	ABC	10			BA	
35		X	ABC	10			AM	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: Bill Willard

Print: Bill Willard

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCUA		Mehrhof Rd Little Ferry NJ						
Date: 1-8-26		OK	Type	Size#	Due Hydro	Due 5Yr	Brand	Service Performed
36	Boil Screen	X	CO2	10			KID	
37		X	CO2	15			BA	
38		X	ABC	10			BA	
39		X	ABC	20			KID	
40		X	ABC	70			AM	
41	Outside	X	ABC	10			KID	
42	Switchgear	X	CO2	10				
43		X	CO2	10				
44	Admin	X	ABC	10			BE	
45		X	PW	2.5			BE	
46	7	X	ABC	10			BE	
47		X	ABC	10			BE	
48	3	X	ABC	10			BC	
49	4	X	PW	2.5			BE	
50		X	PW	2.5			BE	
51		X	PW	2.5			BE	
52		X	ABC	10			BE	
53	BSMT	X	ABC	10			BA	
54		X	CO2	70			FF	
55		X	CO2	15			FF	
56	MAIR	X	ABC	10			BE	
57		X	ABC	10			AM	
58		X	ABC	10			BA	
59	10	X	ABC	20			BE	
60	CB	X	ABC	10			BA	
61	3	X	ABC	20			BE	
62	2.5	X	PW	2.5			BE	
63	20	X	ABC	10			BE	
64	20	X	CO2	15			KID	
65	LD	X	ABC	10			BC	
66		X	ABC	10			BE	
67	20	X	ABC	10				
68	30	X	ABC	20			BE	
69	31	X	ABC	10			BE	
70	32	X	ABC	10			BE	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: **BCVA**

Mehrhof Rd

Date: **1-8-26**

Little Ferry NJ

	Location	OK X	Type	Size#	Due Hydro	Due 6Yr	Brand	Service Performed
71	CB 34	X	ABC	10			BA	
72	4	X	ABC	10			BE	
73	Super	X	PW	2.5			BA	
74	5	X	ABC	10			BE	
75	7	X	ABC	10			BE	
76	Women	X	ABC	10			BE	
77		X	ABC	10			BE	
78	8	X	ABC	10			BE	
79		X	ABC	10			BE	
80		X	ABC	10			BE	
81		X	ABC	10			BE	
82		X	ABC	10			BE	
83		X	ABC	10			BE	
84		X	ABC	10			BE	
85		X	ABC	10			BE	
86	15	X	ABC	10			BA	
87		X	ABC	10			BE	
88		X	PW	2.5			BE	
89	AB	X	ABC	10			BE	
90	Lunch	X	ABC	20			BE	
91		X	ABC	20			BE	
92		X	ABC	10			BE	
93		X	CO2	15			BE	
94		X	PW	2.5			BE	
95		X	ABC	20			BE	
96		X	ABC	10			BE	
97	CO2	X	CO2	10			FP	
98		X	ABC	50			AM	
99		X	CO2	15			BA	
100		X	CO2	10			AN	
101	Klowner	X	CO2	15			KID	
102		X	ABC	20			AM	
103		X	ABC	20			AM	
104		X	ABC	20			AM	
105		X	ABC	50			AM	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCVA

Mehrhof Rd
Little Falls NJ

Date: 1-8-26

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
106	BLOWER	X	ABC	20			BA	
107		X	CO2	15			KID	
108		X	CO2	10			KID	
109	DIGESTER	X	ABC	20			AM	
110		X	ABC	20			KID	
111		X	CO2	15			KID	
112		X	ADL	20			AM	
113		X	CO2	10			AM	
114		X	CO2	15			KID	
115		X	ABC	20			AN	
116		X	ABC	20			AM	
117	Gnt	X	ABC	10			BA	
118	Gnt 2	X	ADL	10			KID	
119	Thickener	X	ABC	10			BA	
120		X	ABC	10			BA	
121		X	ABC	10			BA	
122		X	ABC	10			AM	
123	WAS	X	ABC	10			BA	
124		X	ABC	10			BE	
125		X	ABC	10			PI	
126		X	ABC	10			BA	
127		X	ABC	10			AM	
128		X	ABC	10			KID	
129		X	ABC	10			AN	
130		X	ABC	10			AN	
131		X	ABC	10			BA	
132		X	ABC	10			KID	
133		X	ABC	10			KID	
134		X	CO2	15			KID	
135	HD Sump	X	CO2	15			KID	
136		X	CO2	15			KID	
137	Return 2	X	CO2	10			KID	
138	Oil	X	ABC	10			AN	
139		X	ABC	10			KID	
140	Return 1	X	ABC	10			BA	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCVA

Mehrhaf Rd

Date: 1-8-26

Little Ferry NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
141		X	ABC	10			BA	
142		X	ABC	20			AM	
143	Polymer	X	ABC	10			BA	
144		X	ABC	10			BA	
145		X	ABC	10			BA	
146		X	CO2	15			KID	
147		X	ABC	10			AM	
148	Ref 2	X	ABC	20			BE	
149	DST 1st	X	ABC	10			BC	
150		X	ABC	10			BA	
151	Elev	X	ABC	10			BC	
152	Boiler	X	ABC	20			BE	
153		X	ABC	10			BE	
154		X	ABC	10			AM	
155		X	ABC	10			BE	
156		X	ABC	10			KIP	
157		X	ABC	10			BE	
158		X	ABC	10			PC	
159		X	ABC	10			DE	
160		X	ABC	10			DE	
161		X	ABC	10			KIP	
162	2nd F	X	ABC	10			AM	
163		X	ABC	10			BA	
164			ABC	10	—	—	BE	
165		X	ABC	10			BE	
166		X	ABC	10			AN	
167		X	ABC	10			KID	
168		X	ABC	10			BE	
169	3rd	X	ABC	10			BA	
170		X	ABC	10			BC	
171	Prime B	X	ABC	10			BA	
172	Elect	X	ABC	20			BE	
173		X	ABC	10			BA	
174	Ramp B. 1st	X	ABC	10			BE	
175		X	CO2	20			BA	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: **BCUA**

Mehrhof Rd

Date: **1-8-26**

Little Ferry NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
176	Pump Build 1	X	CO2	15			FF	
177		X	ABC	20			KID	
178		X	CO2	10			KID	
179		X	ABC	10			BA	
180		X	ABC	10			BA	
181		X	ABC	10			BA	
182		X	CO2	15			KID	
183	Pump 2	X	ABC	10			PA	
184		X	ABC	20			AM	
185	Incl	X	ABC	20			BA	
186		X	CO2	10			KID	
187		X	ABC	20			BC	
188	Sub	X	ABC	20			BC	
189		X	ABC	20			BA	
190	Sub 2	X	ABC	20			BC	
191		X	ABC	10			AM	
192	Prime 3	X	ABC	10			BA	
193	Elect	X	CO2	15			KID	
194	Prime P	X	ABC	10			KID	
195	Elect	X	CO2	15			FF	
196		X	CO2	10			BA	
197		X	CO2	10			KID	
198		X	ABC	10			BA	
199	Pipe	X	ABC	10			KID	
200		X	ABC	11			BA	
201		X	ABC	10			KID	
202		X	ABC	10			BA	
203		X	ABC	10			BA	
204		X	ABC	10			DE	
205		X	ABC	10			BA	
206		X	ABC	10			AN	
207	Sucker 4	X	ABC	10			BA	
208		X	CO2	10			KID	
209		X	CO2	10			KID	
210	SPARE	X	ABC	10			AN	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCVA

Date: 1-8-26

Mehrhof Rd

Little Ferry NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
211	SPARES	X	CO2	10'				
212		X	CO2	10'				
213		X	CO2	10'				
214		X	CO2	10'				
215		X	CO2	10'				
216		X	ABC	2.5'				
217		X	ABCL	5'				
218		X	ABCL	5'				
219		X	ABCL	5'				
220		X	ABCL	5'				
221		X	ABCL	5'				
222		X	ABCL	5'				
223		X	ABCL	5'				
224		X	ABCL	5'				
225		X	ABCL	5'				
226		X	ABCL	5'				
227		X	ABCL	10'				
228		X	ABCL	10'				
229	SPARES	X	ABCL	10'				
230	Ramp House	X	CO2	10'				
231		X	ABCL	20'				
232		X	ABCL	5A'				
233		X	ABCL	10'				
234		X	ABCL	10'				
235		X	ABCL	10'				
236		X	ABCL	10'				
237		X	ABCL	10'				
238		X	ABCL	10'				
239	Ramp House	X	ABCL	10'				
240	Edgewater	X	CO2	10'				
241		X	CO2	10'				
242		X	CO2	10'				
243		X	CO2	10'				
244		X	CO2	10'				
245	Edgewater	X	CO2	10'				

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

License # P00140

Date: 1-8-26

Mehrhof Rd
Little Ferry NJ

Signature: _____
Print: _____
Date: _____

Time In: _____
Time Out: _____
Tech Signature: _____
Print: _____



**Bergen County
Utilities Authority**
www.bcua.org



PO FILE COPY

PO Number: **20252713**

Date: 01/05/2026

Vendor Number: 5942

CERULLO FIRE PROTECTION, INC.
901-NEW BRUNSWICK AVE.
RAHWAY, NJ 07065

Requisition Number: 25002703

Buyer: Cammett, Michael

Phone: 732-388-1949

Fax: 732-388-0096

DESCRIPTION: DESCRIPTION: ANNUAL FIRE EXTINGUISHER INSPECTIONS. E60631

Line Number	Quantity	UoM	Description	Unit Cost	Extended Cost
1	262.0000	EA	LITTLE FERRY, EDGEWATER AND PUMP STAION EXTINGUISHERS. ANNUAL INSPECTION FOR ALL GL #: 15224000 - 532610 Safety Prog - Trainng/Supplies	\$7.2500	\$1,899.50

1/12/26 Need invoice
OK to pay

Subtotal	\$1,899.50
Purchase Order Total	\$1,899.50



Bergen County
Utilities Authority
www.bcua.org



PO FILE COPY

PO Number: **00154260-001**

Date: 11/15/2021

Requisition Number: 125249

Buyer: Cammett, Michael

Vendor Number: 5942

CERULLO FIRE PROTECTION, INC.
901-NEW BRUNSWICK AVE.
RAHWAY, NJ 07065



V
I
R

CHANGE ORDER

Phone: 732-388-1949

Fax: 732-388-0096

Inv# 115 233

DESCRIPTION: DESCRIPTION: ANNUAL FIRE EXTINGUISHER INSPECTION AND MAINTENANCE

Line Number	Quantity	UoM	Description	Unit Cost	Extended Cost
1	259.0000	EACH	ANNUAL INSPECTION AND MAINTENANCE ON ALL LITTLE FERRY, EDGEWATER AND PUMPING STATION FIRE EXTINGUISHERS.	\$6.5000	\$1,683.50
GL #: 15224000 - 532610 Safety Prog - Trainng/Supplies				\$1,683.50	

1/3/22:

Bob: bobk@cerullofire.com

Subtotal	\$1,683.50
Purchase Order Total	\$1,683.50



Bergen County
Utilities Authority
www.bcua.org



PO FILE COPY

PO Number: **00154260-001**

Date: 11/15/2021

Requisition Number: 125249

Buyer: Cammett, Michael

Vendor Number: 5942

CERULLO FIRE PROTECTION, INC.
901-NEW BRUNSWICK AVE.
RAHWAY, NJ 07065



V
I
R

CHANGE ORDER

Phone: 732-388-1949

Fax: 732-388-0096

Inv# 115 233

DESCRIPTION: DESCRIPTION: ANNUAL FIRE EXTINGUISHER INSPECTION AND MAINTENANCE

Line Number	Quantity	UoM	Description	Unit Cost	Extended Cost
1	259.0000	EACH	ANNUAL INSPECTION AND MAINTENANCE ON ALL LITTLE FERRY , EDGEWATER AND PUMPING STATION FIRE EXTINGUISHERS.	\$6.5000	\$1,683.50
GL #: 15224000 - 532610 Safety Prog - Trainng/Supplies					\$1,683.50

1/3/22:

Bob: bobk@cerullofire.com

Subtotal	\$1,683.50
Purchase Order Total	\$1,683.50



Bergen County
Utilities Authority
www.bcua.org



PO FILE COPY

PO Number: **00154260-001**

Date: 11/15/2021

Requisition Number: 125249

Buyer: Cammett, Michael

Vendor Number: 5942

CERULLO FIRE PROTECTION, INC.
901-NEW BRUNSWICK AVE.
RAHWAY, NJ 07065



V
I
R

CHANGE ORDER

Phone: 732-388-1949

Fax: 732-388-0096

Inv# 115 233

DESCRIPTION: DESCRIPTION: ANNUAL FIRE EXTINGUISHER INSPECTION AND MAINTENANCE

Line Number	Quantity	UoM	Description	Unit Cost	Extended Cost
1	259.0000	EACH	ANNUAL INSPECTION AND MAINTENANCE ON ALL LITTLE FERRY , EDGEWATER AND PUMPING STATION FIRE EXTINGUISHERS.	\$6.5000	\$1,683.50
GL #: 15224000 - 532610 Safety Prog - Trainng/Supplies					\$1,683.50

1/3/22:

Bob: bobk@cerullofire.com

Subtotal	\$1,683.50
Purchase Order Total	\$1,683.50



Bergen County
Utilities Authority
www.bcua.org



VOUCHER For Payment

PO Number: **00154260-001**

*This PO Number Must Appear On All
Correspondence, Invoices, and Shipments*

Date: 11/15/2021

Vendor Number: 5942

CERULLO FIRE PROTECTION, INC.
901-NEW BRUNSWICK AVE.
RAHWAY, NJ 07065

CHANGE ORDER

**Note: For Payment, This VOUCHER Page Must Be Signed By Claimant (Vendor)
And Presented Along With An Original Invoice Stating Terms**

DESCRIPTION: DESCRIPTION: ANNUAL FIRE EXTINGUISHER INSPECTION AND MAINTENANC

Line Number	Quantity	UoM	Description	Unit Cost	Extended Cost
1	259.0000	EACH	ANNUAL INSPECTION AND MAINTENANCE ON ALL LITTLE FERRY , EDGEWATER AND PUMPING STATION FIRE EXTINGUISHERS.	\$6.5000	\$1,683.50

Subtotal	\$1,683.50
Purchase Order Total	\$1,683.50

I do solemnly declare and certify under the penalties of the law that the within bill is correct in all its particulars; that the articles have been furnished or services rendered as stated therein; that no bonus has been given or received by any person or persons within the knowledge of this claimant in connection with the above claim; that the amount therein stated is justly due and owing; and that the amount charged is a reasonable one.

Claimant Signature *Kevin Cerullo*

Printed Kevin Cerullo

Title President

Date 1/3/2022

Federal ID# or Social Security # 22-3244907

Send Correspondence, Invoice, Voucher, to:

Bergen County Utilities Authority
PO Box 9
Little Ferry, NJ 07643-0009
Telephone: 201-641-2552
Fax: 201-807-8681
Email: AccountsPayable@bcua.org

----- For BCUA Use Only -----

FINANCIAL APPROVAL: I certify that the goods or services indicated above were received and payment is due as claimed.

Treasurer/Chief Financial Officer: _____

Date _____



Bergen County
Utilities Authority
www.bcua.org



VOUCHER For Payment

PO Number: **00154260-001**

*This PO Number Must Appear On All
Correspondence, Invoices, and Shipments*

Date: 11/15/2021

Vendor Number: 5942

CERULLO FIRE PROTECTION, INC.
901-NEW BRUNSWICK AVE.
RAHWAY, NJ 07065

CHANGE ORDER

**Note: For Payment, This VOUCHER Page Must Be Signed By Claimant (Vendor)
And Presented Along With An Original Invoice Stating Terms**

DESCRIPTION: DESCRIPTION: ANNUAL FIRE EXTINGUISHER INSPECTION AND MAINTENANC

Line Number	Quantity	UoM	Description	Unit Cost	Extended Cost
1	259.0000	EACH	ANNUAL INSPECTION AND MAINTENANCE ON ALL LITTLE FERRY , EDGEWATER AND PUMPING STATION FIRE EXTINGUISHERS.	\$6.5000	\$1,683.50

Subtotal	\$1,683.50
Purchase Order Total	\$1,683.50

I do solemnly declare and certify under the penalties of the law that the within bill is correct in all its particulars; that the articles have been furnished or services rendered as stated therein; that no bonus has been given or received by any person or persons within the knowledge of this claimant in connection with the above claim; that the amount therein stated is justly due and owing; and that the amount charged is a reasonable one.

Claimant Signature *Kevin Cerullo*

Printed Kevin Cerullo

Title President

Date 1/3/2022

Federal ID# or Social Security # 22-3244907

Send Correspondence, Invoice, Voucher, to:

Bergen County Utilities Authority
PO Box 9
Little Ferry, NJ 07643-0009
Telephone: 201-641-2552
Fax: 201-807-8681
Email: AccountsPayable@bcua.org

----- For BCUA Use Only -----

FINANCIAL APPROVAL: I certify that the goods or services indicated above were received and payment is due as claimed.

Treasurer/Chief Financial Officer: _____

Date _____



Bergen County
Utilities Authority
www.bcua.org



VOUCHER For Payment

PO Number: **00154260-001**

*This PO Number Must Appear On All
Correspondence, Invoices, and Shipments*

Date: 11/15/2021

Vendor Number: 5942

CERULLO FIRE PROTECTION, INC.
901-NEW BRUNSWICK AVE.
RAHWAY, NJ 07065

CHANGE ORDER

**Note: For Payment, This VOUCHER Page Must Be Signed By Claimant (Vendor)
And Presented Along With An Original Invoice Stating Terms**

DESCRIPTION: DESCRIPTION: ANNUAL FIRE EXTINGUISHER INSPECTION AND MAINTENANC

Line Number	Quantity	UoM	Description	Unit Cost	Extended Cost
1	259.0000	EACH	ANNUAL INSPECTION AND MAINTENANCE ON ALL LITTLE FERRY , EDGEWATER AND PUMPING STATION FIRE EXTINGUISHERS.	\$6.5000	\$1,683.50

Subtotal	\$1,683.50
Purchase Order Total	\$1,683.50

I do solemnly declare and certify under the penalties of the law that the within bill is correct in all its particulars; that the articles have been furnished or services rendered as stated therein; that no bonus has been given or received by any person or persons within the knowledge of this claimant in connection with the above claim; that the amount therein stated is justly due and owing; and that the amount charged is a reasonable one.

Claimant Signature *Kevin Cerullo*

Printed Kevin Cerullo

Title President

Date 1/3/2022

Federal ID# or Social Security # 22-3244907

Send Correspondence, Invoice, Voucher, to:

Bergen County Utilities Authority
PO Box 9
Little Ferry, NJ 07643-0009
Telephone: 201-641-2552
Fax: 201-807-8681
Email: AccountsPayable@bcua.org

----- For BCUA Use Only -----

FINANCIAL APPROVAL: I certify that the goods or services indicated above were received and payment is due as claimed.

Treasurer/Chief Financial Officer: _____

Date _____

Cerullo Fire Protection, Inc.
901 New Brunswick Avenue
Rahway, NJ 07065
(732) 388-1949 Fax (732) 388-0096

CUSTOMER #: 1458
INVOICE #: 115233
INVOICE DATE: 12/17/21
DUE DATE: 01/16/22

BILL TO:

Bergen Co Utilities Authority
PO Box 9
Little Ferry, NJ 07643-0009

ATTN

PHONE(201) 641-2552 FAX (201) 807-8641

LOCATION: 4025

Bergen County Utilities Auth
Foot of Mehrhof Road
Little Ferry, NJ

WORK ORDER NUMBER: 39665

YOUR REFERENCE NUMBER: PO#00154260

DESCRIPTION	QUANTITY	PRICE	AMOUNT
OTHER 12/17/21 Extinguisher inspection per E5	259.00	6.5000	1,683.50
TOTAL OTHER:			1,683.50
TOTAL:			1,683.50

154260

PAYMENT DUE UPON RECEIPT

A 2% charge will be applied monthly to all past due accounts, totaling 24% per annum.

Cerullo Fire Protection, Inc.
901 New Brunswick Avenue
Rahway, NJ 07065
(732) 388-1949 Fax (732) 388-0096

CUSTOMER #: 1458
INVOICE #: 115233
INVOICE DATE: 12/17/21
DUE DATE: 01/16/22

BILL TO:

Bergen Co Utilities Authority
PO Box 9
Little Ferry, NJ 07643-0009

ATTN

PHONE(201) 641-2552 FAX (201) 807-8641

LOCATION: 4025

Bergen County Utilities Auth
Foot of Mehrhof Road
Little Ferry, NJ

WORK ORDER NUMBER: 39665

YOUR REFERENCE NUMBER: PO#00154260

DESCRIPTION	QUANTITY	PRICE	AMOUNT
OTHER 12/17/21 Extinguisher inspection per E5	259.00	6.5000	1,683.50
TOTAL OTHER:			1,683.50
TOTAL:			1,683.50

154260

PAYMENT DUE UPON RECEIPT

A 2% charge will be applied monthly to all past due accounts, totaling 24% per annum.

Cerullo Fire Protection, Inc.
901 New Brunswick Avenue
Rahway, NJ 07065
(732) 388-1949 Fax (732) 388-0096

CUSTOMER #: 1458
INVOICE #: 115233
INVOICE DATE: 12/17/21
DUE DATE: 01/16/22

BILL TO:

Bergen Co Utilities Authority
PO Box 9
Little Ferry, NJ 07643-0009

ATTN

PHONE(201) 641-2552 **FAX** (201) 807-8641

LOCATION: 4025

Bergen County Utilities Auth
Foot of Mehrhof Road
Little Ferry, NJ

WORK ORDER NUMBER: 39665

YOUR REFERENCE NUMBER: PO#00154260

DESCRIPTION	QUANTITY	PRICE	AMOUNT
OTHER 12/17/21 Extinguisher inspection per E5	259.00	6.5000	1,683.50
TOTAL OTHER:			1,683.50
TOTAL:			1,683.50

154260

PAYMENT DUE UPON RECEIPT

A 2% charge will be applied monthly to all past due accounts, totaling 24% per annum.

Cabrera, Marc

From: Cammett, Michael
Sent: Tuesday, January 04, 2022 6:19 AM
To: Cabrera, Marc
Subject: RE: PO#154260-002-1:

Yes. Looks like the adjustments were made.

Mike

From: Cabrera, Marc
Sent: Monday, January 03, 2022 3:07 PM
To: Cammett, Michael
Subject: PO#154260-002-1:

Mr. Cammett:

Question:
Can we - Close/Pay - Cerullo Fire PO#154260-001

MC

Cabrera, Marc

From: Cammett, Michael
Sent: Tuesday, January 04, 2022 6:19 AM
To: Cabrera, Marc
Subject: RE: PO#154260-002-1:

Yes. Looks like the adjustments were made.

Mike

From: Cabrera, Marc
Sent: Monday, January 03, 2022 3:07 PM
To: Cammett, Michael
Subject: PO#154260-002-1:

Mr. Cammett:

Question:
Can we - Close/Pay - Cerullo Fire PO#154260-001

MC

Cabrera, Marc

From: Cammett, Michael
Sent: Tuesday, January 04, 2022 6:19 AM
To: Cabrera, Marc
Subject: RE: PO#154260-002-1:

Yes. Looks like the adjustments were made.

Mike

From: Cabrera, Marc
Sent: Monday, January 03, 2022 3:07 PM
To: Cammett, Michael
Subject: PO#154260-002-1:

Mr. Cammett:

Question:
Can we - Close/Pay - Cerullo Fire PO#154260-001

MC

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, New Jersey 07065

Phone # 732-388-1949 / Fax # 732-388-0096

Permit # P00140

Mobil Recharge Unit

SOLD TO:

Bergen County Utilities Authority

Foot of Mehrhof Rd

Little Ferry, NJ

SHIP TO:

DATE PERFORMED	PERSON TO SEE OR REF. NO.	EMAIL	PHONE #	FAX #
12/17/2021	Michael Cammett		201-641-2552	

EQUIPMENT #	LAST / FREQ.	SERVICE CONTRACT #
		E51482

QTY.	DESCRIPTION	UNIT PRICE	AMOUNT
259	☒ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL Portable Fire Extinguisher - inspection/service	\$6.50	\$1,683.50
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00

EQUIPMENT NOTE:

SITE NOTES:

QTY.	MATERIALS/PARTS	PRICE	AMOUNT	LABOR/TECH	HOURS	RATE	AMOUNT
			\$0.00				\$0.00
			\$0.00				\$0.00
			\$0.00				\$0.00
			\$0.00				\$0.00
			\$0.00				\$0.00
	MATERIAL SUB-TOTAL		\$ 0.00	LABOR SUB-TOTAL			\$ 0.00

SERVICES AND/OR MATERIALS
SPECIFIED IN GOOD ORDER

TERMS:
CUSTOMER WILL BE RESPONSIBLE FOR ALL
COLLECTION FEES, LEGAL FEES,
COURT COSTS AND SIMILAR EXPENSES
INCURRED IN ORDER TO
COLLECT PAST DUE ACCOUNTS

X
AUTHORIZED SIGNATURE
INSTRUCTIONS:

SERVICE PERFORMED BW

MATERIAL SUB-TOTAL	\$ 0.00
TOTAL	\$ 1,683.50
TAX	
PAY THIS AMOUNT →	\$ 1,683.50

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, New Jersey 07065

Phone # 732-388-1949 / Fax # 732-388-0096

Permit # P00140

Mobil Recharge Unit

SOLD TO:

Bergen County Utilities Authority

Foot of Mehrhof Rd

Little Ferry, NJ

SHIP TO:

DATE PERFORMED	PERSON TO SEE OR REF. NO.	EMAIL	PHONE #	FAX #
12/17/2021	Michael Cammett		201-641-2552	

EQUIPMENT #	LAST / FREQ.	SERVICE CONTRACT #
		E51482

QTY.	DESCRIPTION	UNIT PRICE	AMOUNT
259	☒ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL Portable Fire Extinguisher - inspection/service	\$6.50	\$1,683.50
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00

EQUIPMENT NOTE:

SITE NOTES:

QTY.	MATERIALS/PARTS	PRICE	AMOUNT	LABOR/TECH	HOURS	RATE	AMOUNT
			\$0.00				\$0.00
			\$0.00				\$0.00
			\$0.00				\$0.00
			\$0.00				\$0.00
			\$0.00				\$0.00
	MATERIAL SUB-TOTAL		\$ 0.00	LABOR SUB-TOTAL			\$ 0.00

SERVICES AND/OR MATERIALS
SPECIFIED IN GOOD ORDER

TERMS:
CUSTOMER WILL BE RESPONSIBLE FOR ALL
COLLECTION FEES, LEGAL FEES,
COURT COSTS AND SIMILAR EXPENSES
INCURRED IN ORDER TO
COLLECT PAST DUE ACCOUNTS

X
AUTHORIZED SIGNATURE
INSTRUCTIONS:

SERVICE PERFORMED BW

MATERIAL SUB-TOTAL	\$ 0.00
TOTAL	\$ 1,683.50
TAX	
PAY THIS AMOUNT →	\$ 1,683.50

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, New Jersey 07065

Phone # 732-388-1949 / Fax # 732-388-0096

Permit # P00140

Mobil Recharge Unit

SOLD TO:

Bergen County Utilities Authority

Foot of Mehrhof Rd

Little Ferry, NJ

SHIP TO:

DATE PERFORMED	PERSON TO SEE OR REF. NO.	EMAIL	PHONE #	FAX #
12/17/2021	Michael Cammett		201-641-2552	

EQUIPMENT #	LAST / FREQ.	SERVICE CONTRACT #
		E51482

QTY.	DESCRIPTION	UNIT PRICE	AMOUNT
259	☒ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL Portable Fire Extinguisher - inspection/service	\$6.50	\$1,683.50
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00

EQUIPMENT NOTE:

SITE NOTES:

QTY.	MATERIALS/PARTS	PRICE	AMOUNT	LABOR/TECH	HOURS	RATE	AMOUNT
			\$0.00				\$0.00
			\$0.00				\$0.00
			\$0.00				\$0.00
			\$0.00				\$0.00
			\$0.00				\$0.00
	MATERIAL SUB-TOTAL		\$ 0.00	LABOR SUB-TOTAL			\$ 0.00

SERVICES AND/OR MATERIALS
SPECIFIED IN GOOD ORDER

TERMS:
CUSTOMER WILL BE RESPONSIBLE FOR ALL
COLLECTION FEES, LEGAL FEES,
COURT COSTS AND SIMILAR EXPENSES
INCURRED IN ORDER TO
COLLECT PAST DUE ACCOUNTS

X
AUTHORIZED SIGNATURE
INSTRUCTIONS:

SERVICE PERFORMED BW

MATERIAL SUB-TOTAL	\$ 0.00
TOTAL	\$ 1,683.50
TAX	
PAY THIS AMOUNT →	\$ 1,683.50

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCVA

298 Mehrhof Rd

Date: 12-3-21

Little Ferry NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
1	MWH 2	X	ABC	10			BC	
2	Shop	X	ABC	10			BA	
3		X	ABC	10			BA	
4	WH6	X	ABC	10			KID	
5		X	ABC	10			BE	
6	WH7	X	ABC	10			BA	
7	WH8	X	ABC	10			BA	
8	E2	X	ABC	20			BC	
9	E1	X	CO2	15			AM	
10		X	ABC	10			BA	
11	WH6	X	ABC	10			BE	
12		X	ABC	10			BE	
13	MA 1	X	ABC	10			BA	
14	MA 2	X	ABC	10			BE	
15	MA 3	X	ABC	10			BA	
16	WB	X	ABC	10			BA	
17	W1	X	ABC	10			BA	
18	W2	X	ABC	20			BE	
19	V1	X	ABC	10			BA	
20	V2	X	ABC	10			BE	
21	V3	X	ABC	10			BE	
22	V4	X	ABC	10			BA	
23		X	CO2	50				
24	WB 1	X	CO2	10			BC	
25	Ad Venc	X	PW	2.5			BE	
26	Admin 1	X	ABC	10			BE	
27	Finance	X	PW	2.5			BE	
28	Admin 4	X	PW	2.5			BE	
29	Admin 5	X	ABC	10			BE	
30	Admin 7	X	ABC	10			BE	
31	Conference	X	PW	2.5			BE	
32	Admin 9	X	ABC	10			BE	
33	Admin 10	X	ABC	20			BE	
34	Phone	X	CO2	15			KID	
35		X	CO2	20			KID	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCVA

298 Mehrhof Rd

Date: 12-3-21

Little Ferry NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
1	MWH 2	X	ABC	10			BC	
2	Shop	X	ABC	10			BA	
3		X	ABC	10			BA	
4	WH6	X	ABC	10			KID	
5		X	ABC	10			BE	
6	WH7	X	ABC	10			BA	
7	WH8	X	ABC	10			BA	
8	E2	X	ABC	20			BC	
9	E1	X	CO2	15			AM	
10		X	ABC	10			BA	
11	WH6	X	ABC	10			BE	
12		X	ABC	10			BE	
13	MA 1	X	ABC	10			BA	
14	MA 2	X	ABC	10			BE	
15	MA 3	X	ABC	10			BA	
16	WB	X	ABC	10			BA	
17	W1	X	ABC	10			BA	
18	W2	X	ABC	20			BE	
19	V1	X	ABC	10			BA	
20	V2	X	ABC	10			BE	
21	V3	X	ABC	10			BE	
22	V4	X	ABC	10			BA	
23		X	CO2	50				
24	WB 1	X	CO2	10			BC	
25	Ad Vendl	X	PW	2.5			BE	
26	Admin 1	X	ABC	10			BE	
27	Finance	X	PW	2.5			BE	
28	Admin 4	X	PW	2.5			BE	
29	Admin 5	X	ABC	10			BE	
30	Admin 7	X	ABC	10			BE	
31	Conference	X	PW	2.5			BE	
32	Admin 9	X	ABC	10			BE	
33	Admin 10	X	ABC	20			BE	
34	Phone	X	CO2	15			KID	
35		X	CO2	20			KID	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCVA

298 Mehrhof Rd

Date: 12-3-21

Little Ferry NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
1	MWH 2	X	ABC	10			BC	
2	Shop	X	ABC	10			BA	
3		X	ABC	10			BA	
4	WH6	X	ABC	10			KID	
5		X	ABC	10			BE	
6	WH7	X	ABC	10			BA	
7	WH8	X	ABC	10			BA	
8	E2	X	ABC	20			BC	
9	E1	X	CO2	15			AM	
10		X	ABC	10			BA	
11	WH6	X	ABC	10			BE	
12		X	ABC	10			BE	
13	MA 1	X	ABC	10			BA	
14	MA 2	X	ABC	10			BE	
15	MA 3	X	ABC	10			BA	
16	WB	X	ABC	10			BA	
17	W1	X	ABC	10			BA	
18	W2	X	ABC	20			BE	
19	V1	X	ABC	10			BA	
20	V2	X	ABC	10			BE	
21	V3	X	ABC	10			BE	
22	V4	X	ABC	10			BA	
23		X	CO2	50				
24	WB 1	X	CO2	10			BC	
25	Ad Venc	X	PW	2.5			BE	
26	Admin 1	X	ABC	10			BE	
27	Finance	X	PW	2.5			BE	
28	Admin 4	X	PW	2.5			BE	
29	Admin 5	X	ABC	10			BE	
30	Admin 7	X	ABC	10			BE	
31	Conference	X	PW	2.5			BE	
32	Admin 9	X	ABC	10			BE	
33	Admin 10	X	ABC	20			BE	
34	Phone	X	CO2	15			KID	
35		X	CO2	20			KID	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCUA

298 Mehrhof Rd
Little Ferry NJ

Date: 12-3-21

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
36	Admin	X	ABC	10			BA	
37	SW SGB1	X	CO2	10			KID	
38	SGB2	X	CO2	10			KID	
39	Scada Rn	X	ABC	10			BA	
40	CB3	X	ABC	20			BE	
41	LAD	X	PW	2.5				
42		X	ABC	10				
43		X	CO2	15				
44	Lab lunch	X	ABC	10			BE	
45	CB 28	X	ABC	10			BE	
46	CB30	X	ABC	20			BE	
47	CB31	X	ABC	10			BE	
48	CB32	X	ABC	10			BE	
49	CB34	X	ABC	10			BA	
50	CB4	X	ABC	10			BE	
51	Supervisor -	X	PW	2.5			BA	
52	CB5	X	ABC	10			BE	
53	Women	X	ABC	10			BE	
54	File Rn	X	ABC	10			BE	
55	CB 6	X	ABC	10			BE	
56	CB 2nd	X	ABC	10			BE	
57	lunch	X	ABC	10			BA	
58		X	ABC	10			BE	
59		X	ABC	10			BE	
60		X	ABC	10			BE	
61		X	ABC	10			BE	
62		X	ABC	10			BE	
63		X	ABC	10			BE	
64		X	ABC	10			BE	
65	CB lunch	X	ABC	20			BE	
66	CB 8	X	ABC	10			BE	
67	CB 11	X	ABC	10			BE	
68	CB 12	X	PW	2.5			BE	
69	CB 15	X	ABC	10			BA	
70	Switch Rn	X	ABC	10			BE	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCUA

298 Mehrhof Rd
Little Ferry NJ

Date: 12-3-21

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
36	Admin	X	ABC	10			BA	
37	SW SGB1	X	CO2	10			KID	
38	SGB2	X	CO2	10			KID	
39	Scada Rn	X	ABC	10			BA	
40	CB3	X	ABC	20			BE	
41	LAD	X	PW	2.5				
42		X	ABC	10				
43		X	CO2	15				
44	Lab lunch	X	ABC	10			BE	
45	CB 28	X	ABC	10			BE	
46	CB30	X	ABC	20			BE	
47	CB31	X	ABC	10			BE	
48	CB32	X	ABC	10			BE	
49	CB34	X	ABC	10			BA	
50	CB4	X	ABC	10			BE	
51	Supervisor -	X	PW	2.5			BA	
52	CB5	X	ABC	10			BE	
53	Women	X	ABC	10			BE	
54	File Rn	X	ABC	10			BE	
55	CB 6	X	ABC	10			BE	
56	CB 2nd	X	ABC	10			BE	
57	Lunch	X	ABC	10			BA	
58		X	ABC	10			BE	
59		X	ABC	10			BE	
60		X	ABC	10			BE	
61		X	ABC	10			BE	
62		X	ABC	10			BE	
63		X	ABC	10			BE	
64		X	ABC	10			BE	
65	CB Lunch	X	ABC	20			BE	
66	CB 8	X	ABC	10			BE	
67	CB 11	X	ABC	10			BE	
68	CB 12	X	PW	2.5			BE	
69	CB 15	X	ABC	10			BA	
70	Switch Rn	X	ABC	10			BE	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCUA

298 Mehrhof Rd
Little Ferry NJ

Date: 12-3-21

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
36	Admin	X	ABC	10			BA	
37	SW SGB1	X	CO2	10			KID	
38	SGB2	X	CO2	10			KID	
39	Scada Rn	X	ABC	10			BA	
40	CB3	X	ABC	20			BE	
41	LAD	X	PW	2.5				
42		X	ABC	10				
43		X	CO2	15				
44	Lab lunch	X	ABC	10			BE	
45	CB 28	X	ABC	10			BE	
46	CB30	X	ABC	20			BE	
47	CB31	X	ABC	10			BE	
48	CB32	X	ABC	10			BE	
49	CB34	X	ABC	10			BA	
50	CB4	X	ABC	10			BE	
51	Supervisor -	X	PW	2.5			BA	
52	CB5	X	ABC	10			BE	
53	Women	X	ABC	10			BE	
54	File Rn	X	ABC	10			BE	
55	CB 6	X	ABC	10			BE	
56	CB 2nd	X	ABC	10			BE	
57	Lunch	X	ABC	10			BA	
58		X	ABC	10			BE	
59		X	ABC	10			BE	
60		X	ABC	10			BE	
61		X	ABC	10			BE	
62		X	ABC	10			BE	
63		X	ABC	10			BE	
64		X	ABC	10			BE	
65	CB Lunch	X	ABC	20			BE	
66	CB 8	X	ABC	10			BE	
67	CB 11	X	ABC	10			BE	
68	CB 12	X	PW	2.5			BE	
69	CB 15	X	ABC	10			BA	
70	Switch Rn	X	ABC	10			BE	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCVA

298 Mehrhof Rd

Date: 12-7-21

Little Ferry NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
71	CB Main	X	PW	2.5			BE	
72		X	ABC	20			BE	
73		X	ABC	10			BE	
74		X	ABC	20			BE	
75		X	ABC	10			BE	
76		X	CO2	15			BE	
77	Digester	X	CO2	10			KID	
78		X	CO2	10			BA	
79		X	ABC	20			AM	
80		X	ABC	20			KID	
81		X	CO2	10			KID	
82	Stair	X	CO2	10			KID	
83		X	ABC	20			AM	
84	Bar Screen	X	ABC	10			BA	
85		X	ABC	10			BA	
86		X	CO2	15			BA	
87		X	CO2	10			KID	
88	OLD ADMIN	X	ABC	10			AM	
89		X	ABC	10			BA	
90		X	ABC	5			BE	
91	GAS	X	ABC	20			KID	
92	MP 1	X	CO2	15			KID	
93		X	ABC	20			KID	
94		X	ABC	10			BA	
95		X	ABC	10			BA	
96	Up	X	ABC	10			BE	
97		X	CO2	15			AN	
98		X	ABC	10			BE	
99		X	CO2	10			KID	
100	Stair	X	CO2	15			KID	
101		X	ABC	10			BA	
102	GRIT 2	X	ABC	10			AN	
103			ABC	10	—	—	BA	Recharge
104		X	ABC	10			AN	
105	CARWASH	X	CO2	20				

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCVA

298 Mehrhof Rd

Date: 12-7-21

Little Ferry NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
71	CB Main	X	PW	2.5			BE	
72		X	ABC	20			BE	
73		X	ABC	10			BE	
74		X	ABC	20			BE	
75		X	ABC	10			BE	
76		X	CO2	15			BE	
77	Digester	X	CO2	10			KID	
78		X	CO2	10			BA	
79		X	ABC	20			AM	
80		X	ABC	20			KID	
81		X	CO2	10			KID	
82	Stair	X	CO2	10			KID	
83		X	ABC	20			AM	
84	Bar Screen	X	ABC	10			BA	
85		X	ABC	10			BA	
86		X	CO2	15			BA	
87		X	CO2	10			KID	
88	OLD ADMIN	X	ABC	10			AM	
89		X	ABC	10			BA	
90		X	ABC	5			BE	
91	GAS	X	ABC	20			KID	
92	MP 1	X	CO2	15			KID	
93		X	ABC	20			KID	
94		X	ABC	10			BA	
95		X	ABC	10			BA	
96	Up	X	ABC	10			BE	
97		X	CO2	15			AN	
98		X	ABC	10			BE	
99		X	CO2	10			KID	
100	Stair	X	CO2	15			KID	
101		X	ABC	10			BA	
102	GRIT 2	X	ABC	10			AN	
103			ABC	10	—	—	BA	Recharge
104		X	ABC	10			AN	
105	CARWASH	X	CO2	20				

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCVA

298 Mehrhof Rd

Date: 12-7-21

Little Ferry NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
71	CB Main	X	PW	2.5			BE	
72		X	ABC	20			BE	
73		X	ABC	10			BE	
74		X	ABC	20			BE	
75		X	ABC	10			BE	
76		X	CO2	15			BE	
77	Digester	X	CO2	10			KID	
78		X	CO2	10			BA	
79		X	ABC	20			AM	
80		X	ABC	20			KID	
81		X	CO2	10			KID	
82	Stair	X	CO2	10			KID	
83		X	ABC	20			AM	
84	Bar Screen	X	ABC	10			BA	
85		X	ABC	10			BA	
86		X	CO2	15			BA	
87		X	CO2	10			KID	
88	OLD ADMIN	X	ABC	10			AM	
89		X	ABC	10			BA	
90		X	ABC	5			BE	
91	GAS	X	ABC	20			KID	
92	MP 1	X	CO2	15			KID	
93		X	ABC	20			KID	
94		X	ABC	10			BA	
95		X	ABC	10			BA	
96	Up	X	ABC	10			BE	
97		X	CO2	15			AN	
98		X	ABC	10			BE	
99		X	CO2	10			KID	
100	Stair	X	CO2	15			KID	
101		X	ABC	10			BA	
102	GRIT 2	X	ABC	10			AN	
103			ABC	10	—	—	BA	Recharge
104		X	ABC	10			AN	
105	CARWASH	X	CO2	20				

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCWA		298 Mehrhof Rd						
Date: 12-7-21		Little Ferry NJ						
	Location	OK	Type	Size#	Due Hydro	Due 6Yr	Brand	Service Performed
106	Paint	X	ABC	10			BE	
107	Wood Shop	X	ABC	10			KID	
108		X	ABC	10			BE	
109		X	ABC	10			AM	
110	PPRn 1	X	ABC	10			BA	
111	Elect Rm	X	ABC	20			BE	
112	Primary B	X	ABC	10			BA	
113	PB 2	X	ABC	10			DA	
114		X	ABC	20			AM	
115	UP	X	ABC	20			BA	
116		X	CO2	10			KID	
117		X	ABC	20			BE	
118	1st	X	ABC	20			BE	
119		X	ABC	20			BA	
120	2nd	X	ABC	20			BE	
121		X	ABC	10			AM	
122	GRIT 2	X	ABC	10			KID	
123		X	ABC	10			BA	
124		X	ABC	10			AM	
125		X	ABC	10			BA	
126	Blower	X	CO2	10			KID	
127		X	CO2	15			KID	
128		X	ABC	20			BE	
129		X	ABC	50			AM	
130		X	ABC	50			AM	
131		X	ABC	20			AM	
132		X	CO2	15			KID	
133		X	ABC	20			AM	
134		X	ABC	20			AM	
135		X	ABC	20			AM	
136	Co-Aen	X	CO2	10			AN	
137		X	CO2	10			AM	
138		X	CO2	15			BA	
139		X	ABC	100			AM	
140	Prim D Elect	X	CO2	15				

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCWA		298 Mehrhof Rd						
Date: 12-7-21		Little Ferry NJ						
	Location	OK	Type	Size#	Due Hydro	Due 6Yr	Brand	Service Performed
106	Paint	X	ABC	10			BE	
107	Wood Shop	X	ABC	10			KID	
108		X	ABC	10			BE	
109		X	ABC	10			AM	
110	PPRn 1	X	ABC	10			BA	
111	Elect Rm	X	ABC	20			BE	
112	Primary B	X	ABC	10			BA	
113	PB 2	X	ABC	10			DA	
114		X	ABC	20			AM	
115	UP	X	ABC	20			BA	
116		X	CO2	10			KID	
117		X	ABC	20			BE	
118	1st	X	ABC	20			BE	
119		X	ABC	20			BA	
120	2nd	X	ABC	20			BE	
121		X	ABC	10			AM	
122	GRIT 2	X	ABC	10			KID	
123		X	ABC	10			BA	
124		X	ABC	10			AM	
125		X	ABC	10			BA	
126	Blower	X	CO2	10			KID	
127		X	CO2	15			KID	
128		X	ABC	20			BE	
129		X	ABC	50			AM	
130		X	ABC	50			AM	
131		X	ABC	20			AM	
132		X	CO2	15			KID	
133		X	ABC	20			AM	
134		X	ABC	20			AM	
135		X	ABC	20			AM	
136	Co-Aen	X	CO2	10			AN	
137		X	CO2	10			AM	
138		X	CO2	15			BA	
139		X	ABC	100			AM	
140	Prim D Elect	X	CO2	15				

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCWA		298 Mehrhof Rd						
Date: 12-7-21		Little Ferry NJ						
	Location	OK	Type	Size#	Due Hydro	Due 6Yr	Brand	Service Performed
106	Paint	X	ABC	10			BE	
107	Wood Shop	X	ABC	10			KID	
108		X	ABC	10			BE	
109		X	ABC	10			AM	
110	PPRn 1	X	ABC	10			BA	
111	Elect Rm	X	ABC	20			BE	
112	Primary B	X	ABC	10			BA	
113	PB 2	X	ABC	10			DA	
114		X	ABC	20			AM	
115	UP	X	ABC	20			BA	
116		X	CO2	10			KID	
117		X	ABC	20			BE	
118	1st	X	ABC	20			BE	
119		X	ABC	20			BA	
120	2nd	X	ABC	20			BE	
121		X	ABC	10			AM	
122	GRIT 2	X	ABC	10			KID	
123		X	ABC	10			BA	
124		X	ABC	10			AM	
125		X	ABC	10			BA	
126	Blower	X	CO2	10			KID	
127		X	CO2	15			KID	
128		X	ABC	20			BE	
129		X	ABC	50			AM	
130		X	ABC	50			AM	
131		X	ABC	20			AM	
132		X	CO2	15			KID	
133		X	ABC	20			AM	
134		X	ABC	20			AM	
135		X	ABC	20			AM	
136	Co-Aen	X	CO2	10			AN	
137		X	CO2	10			AM	
138		X	CO2	15			BA	
139		X	ABC	100			AM	
140	Prim D Elect	X	CO2	15				

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: **BCVA**

298 Mehrhof Rd

Date: **12-17-21**

Little Ferry NJ

	Location	OK	Type	Size#	Due Hydro	Due 6Yr	Brand	Service Performed
141	Prime D	X	ABC	10			KID	
142	Prime 3 Elec	X	CO2	10			KID	
143	Prime 3	X	ABC	10			BA	
144	Kiosk 5	X	CO2	10			KID	
145		X	CO2	10			KID	
146		X	ABC	10			BA	
147	Thickner	X	ABC	10			BA	
148	Bsmr		ABC	10	—	—	BA	Archane
149	WAS	X	ABC	10			BA	
150		X	ABC	10			AN	
151		X	ABC	10			BE	
152		X	ABC	10			AN	
153		X	ABC	10			KID	
154	Stairs	X	ABC	10			KID	
155	UP	X	ABC	10			AM	
156		X	ABC	10			KID	
157		X	ABC	10			BE	
158		X	ABC	10			BA	
159		X	ABC	10			BE	
160	Elect	X	ABC	10			BA	
161	oil storage	X	ABC	10			KID	
162		X	ABC	20			KID	
163	Chlorine	X	ABC	10			BA	
164		X	ABC	20			AM	
165	Return 1	X	ABC	10			BA	
166	Elect 1	X	ABC	20			BE	
167	DST stair	X	ABC	10			BE	
168	Mech	X	ABC	20			BE	
169	IE	X	ABC	10			BE	
170		X	ABC	10			AM	
171		X	ABC	10			BE	
172		X	ABC	10			KID	
173	Column	X	ABC	10			BE	
174	Column	X	ABC	10			BE	
175	landing	X	ABC	10			BE	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: **BCVA**

298 Mehrhof Rd

Date: **12-17-21**

Little Ferry NJ

	Location	OK	Type	Size#	Due Hydro	Due 6Yr	Brand	Service Performed
141	Prime D	X	ABC	10			KID	
142	Prime 3 Elec	X	CO2	10			KID	
143	Prime 3	X	ABC	10			BA	
144	Kiosk 5	X	CO2	10			KID	
145		X	CO2	10			KID	
146		X	ABC	10			BA	
147	Thickner	X	ABC	10			BA	
148	Bsmr		ABC	10	—	—	BA	Archane
149	WAS	X	ABC	10			BA	
150		X	ABC	10			AN	
151		X	ABC	10			BE	
152		X	ABC	10			AN	
153		X	ABC	10			KID	
154	Stairs	X	ABC	10			KID	
155	UP	X	ABC	10			AM	
156		X	ABC	10			KID	
157		X	ABC	10			BE	
158		X	ABC	10			BA	
159		X	ABC	10			BE	
160	Elect	X	ABC	10			BA	
161	oil storage	X	ABC	10			KID	
162		X	ABC	20			KID	
163	Chlorine	X	ABC	10			BA	
164		X	ABC	20			AM	
165	Return 1	X	ABC	10			BA	
166	Elect	X	ABC	20			BE	
167	DST stair	X	ABC	10			BE	
168	Mech	X	ABC	20			BE	
169	IE	X	ABC	10			BE	
170		X	ABC	10			AM	
171		X	ABC	10			BE	
172		X	ABC	10			KID	
173	Column	X	ABC	10			BE	
174	Column	X	ABC	10			BE	
175	landing	X	ABC	10			BE	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: **BCVA**

298 Mehrhof Rd

Date: **12-17-21**

Little Ferry NJ

	Location	OK	Type	Size#	Due Hydro	Due 6Yr	Brand	Service Performed
141	Prime D	X	ABC	10			KID	
142	Prime 3 Elec	X	CO2	10			KID	
143	Prime 3	X	ABC	10			BA	
144	Kiosk 5	X	CO2	10			KID	
145		X	CO2	10			KID	
146		X	ABC	10			BA	
147	Thickner	X	ABC	10			BA	
148	Bsmr		ABC	10	—	—	BA	Archane
149	WAS	X	ABC	10			BA	
150		X	ABC	10			AN	
151		X	ABC	10			BE	
152		X	ABC	10			AN	
153		X	ABC	10			KID	
154	Stairs	X	ABC	10			KID	
155	UP	X	ABC	10			AM	
156		X	ABC	10			KID	
157		X	ABC	10			BE	
158		X	ABC	10			BA	
159		X	ABC	10			BE	
160	Elect	X	ABC	10			BA	
161	oil storage	X	ABC	10			KID	
162		X	ABC	20			KID	
163	Chlorine	X	ABC	10			BA	
164		X	ABC	20			AM	
165	Return 1	X	ABC	10			BA	
166	Elect 1	X	ABC	20			BE	
167	DST stair	X	ABC	10			BE	
168	Mech	X	ABC	20			BE	
169	IE	X	ABC	10			BE	
170		X	ABC	10			AM	
171		X	ABC	10			BE	
172		X	ABC	10			KID	
173	Column	X	ABC	10			BE	
174	Column	X	ABC	10			BE	
175	landing	X	ABC	10			BE	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

License # P00140

Little Ferry NJ

[illegible]

Print: _____

License # P00140

Little Ferry NJ

[illegible]

Print: _____

License # P00140

Little Ferry NJ

[illegible]

Print: _____



Bergen County
Utilities Authority
www.bcua.org



VOUCHER For Payment

PO Number: **00154260-001**

*This PO Number Must Appear On All
Correspondence, Invoices, and Shipments*

Date: 11/15/2021

Vendor Number: 5942

CERULLO FIRE PROTECTION, INC.
901-NEW BRUNSWICK AVE.
RAHWAY, NJ 07065

CHANGE ORDER

Note: For Payment, This VOUCHER Page Must Be Signed By Claimant (Vendor)
And Presented Along With An Original Invoice Stating Terms

DESCRIPTION: DESCRIPTION: ANNUAL FIRE EXTINGUISHER INSPECTION AND MAINTENANC

Line Number	Quantity	UoM	Description	Unit Cost	Extended Cost
1	259.0000	EACH	ANNUAL INSPECTION AND MAINTENANCE ON ALL LITTLE FERRY , EDGEWATER AND PUMPING STATION FIRE EXTINGUISHERS.	\$6.5000	\$1,683.50

Subtotal	\$1,683.50
Purchase Order Total	\$1,683.50

I do solemnly declare and certify under the penalties of the law that the within bill is correct in all its particulars; that the articles have been furnished or services rendered as stated therein; that no bonus has been given or received by any person or persons within the knowledge of this claimant in connection with the above claim; that the amount therein stated is justly due and owing; and that the amount charged is a reasonable one.

Claimant Signature _____

Printed _____

Title _____

Date _____

Federal ID# or Social Security # _____

Send Correspondence, Invoice, Voucher, to:

Bergen County Utilities Authority
PO Box 9
Little Ferry, NJ 07643-0009
Telephone: 201-641-2552
Fax: 201-807-8681
Email: AccountsPayable@bcua.org

----- For BCUA Use Only -----

FINANCIAL APPROVAL: I certify that the goods or services indicated above were received and payment is due as claimed.

Treasurer/Chief Financial Officer: _____

Date _____



Bergen County
Utilities Authority
www.bcua.org



VOUCHER For Payment

PO Number: **00154260-001**

*This PO Number Must Appear On All
Correspondence, Invoices, and Shipments*

Date: 11/15/2021

Vendor Number: 5942

CERULLO FIRE PROTECTION, INC.
901-NEW BRUNSWICK AVE.
RAHWAY, NJ 07065

CHANGE ORDER

Note: For Payment, This VOUCHER Page Must Be Signed By Claimant (Vendor)
And Presented Along With An Original Invoice Stating Terms

DESCRIPTION: DESCRIPTION: ANNUAL FIRE EXTINGUISHER INSPECTION AND MAINTENANC

Line Number	Quantity	UoM	Description	Unit Cost	Extended Cost
1	259.0000	EACH	ANNUAL INSPECTION AND MAINTENANCE ON ALL LITTLE FERRY , EDGEWATER AND PUMPING STATION FIRE EXTINGUISHERS.	\$6.5000	\$1,683.50

Subtotal	\$1,683.50
Purchase Order Total	\$1,683.50

I do solemnly declare and certify under the penalties of the law that the within bill is correct in all its particulars; that the articles have been furnished or services rendered as stated therein; that no bonus has been given or received by any person or persons within the knowledge of this claimant in connection with the above claim; that the amount therein stated is justly due and owing; and that the amount charged is a reasonable one.

Claimant Signature _____

Printed _____

Title _____

Date _____

Federal ID# or Social Security # _____

Send Correspondence, Invoice, Voucher, to:

Bergen County Utilities Authority
PO Box 9
Little Ferry, NJ 07643-0009
Telephone: 201-641-2552
Fax: 201-807-8681
Email: AccountsPayable@bcua.org

----- For BCUA Use Only -----

FINANCIAL APPROVAL: I certify that the goods or services indicated above were received and payment is due as claimed.

Treasurer/Chief Financial Officer: _____

Date _____



Bergen County
Utilities Authority
www.bcua.org



VOUCHER For Payment

PO Number: **00154260-001**

*This PO Number Must Appear On All
Correspondence, Invoices, and Shipments*

Date: 11/15/2021

Vendor Number: 5942

CERULLO FIRE PROTECTION, INC.
901-NEW BRUNSWICK AVE.
RAHWAY, NJ 07065

CHANGE ORDER

Note: For Payment, This VOUCHER Page Must Be Signed By Claimant (Vendor)
And Presented Along With An Original Invoice Stating Terms

DESCRIPTION: DESCRIPTION: ANNUAL FIRE EXTINGUISHER INSPECTION AND MAINTENANC

Line Number	Quantity	UoM	Description	Unit Cost	Extended Cost
1	259.0000	EACH	ANNUAL INSPECTION AND MAINTENANCE ON ALL LITTLE FERRY , EDGEWATER AND PUMPING STATION FIRE EXTINGUISHERS.	\$6.5000	\$1,683.50

Subtotal	\$1,683.50
Purchase Order Total	\$1,683.50

I do solemnly declare and certify under the penalties of the law that the within bill is correct in all its particulars; that the articles have been furnished or services rendered as stated therein; that no bonus has been given or received by any person or persons within the knowledge of this claimant in connection with the above claim; that the amount therein stated is justly due and owing; and that the amount charged is a reasonable one.

Claimant Signature _____

Printed _____

Title _____

Date _____

Federal ID# or Social Security # _____

Send Correspondence, Invoice, Voucher, to:

Bergen County Utilities Authority
PO Box 9
Little Ferry, NJ 07643-0009
Telephone: 201-641-2552
Fax: 201-807-8681
Email: AccountsPayable@bcua.org

----- For BCUA Use Only -----

FINANCIAL APPROVAL: I certify that the goods or services indicated above were received and payment is due as claimed.

Treasurer/Chief Financial Officer: _____

Date _____



Bergen County
Utilities Authority
www.bcua.org



PO FILE COPY

PO Number: **20222468**

JH

Date: 12/05/2022

Vendor Number: 5942

CERULLO FIRE PROTECTION, INC.
901-NEW BRUNSWICK AVE.
RAHWAY, NJ 07065

Requisition Number: 22002876

Buyer: Cammett, Michael

1
2
22

Phone: 732-388-1949

Fax: 732-388-0096

INV# 120230

DESCRIPTION: DESCRIPTION: ANNUAL FIRE EXTINGUISHER INSPECTIONS.

Line Number	Quantity	UoM	Description	Unit Cost	Extended Cost
1	259.0000	EACH	LITTLE FERRY, EDGEWATER AND PUMP STAION EXTINGUISHERS. ANNUAL INSPECTION FOR ALL GL #: 15224000 - 532610 Safety Prog - Trainng/Supplies	\$6.5000	\$1,683.50

Subtotal	\$1,683.50
Purchase Order Total	\$1,683.50

Change ↓
\$1703.⁰⁰
Me

OK TO PAY

Chris C. 12/27/22



Bergen County
Utilities Authority
www.bcua.org



PO FILE COPY

PO Number: 20222468-001

Date: 12/05/2022

Vendor Number: 5942

CERULLO FIRE PROTECTION, INC.
901-NEW BRUNSWICK AVE.
RAHWAY, NJ 07065

Requisition Number: 22002876

Buyer: Cammett, Michael

CHANGE ORDER

Phone: 732-388-1949

Fax: 732-388-0096

DESCRIPTION: DESCRIPTION: ANNUAL FIRE EXTINGUISHER INSPECTIONS.

Line Number	Quantity	UoM	Description	Unit Cost	Extended Cost
1	262.0000	EACH	LITTLE FERRY, EDGEWATER AND PUMP STAION EXTINGUISHERS. ANNUAL INSPECTION FOR ALL	\$6.5000	\$1,703.00
GL #: 15224000 - 532610 Safety Prog - Trainng/Supplies				\$1,703.00	

Subtotal	\$1,703.00
Purchase Order Total	\$1,703.00



**Bergen County
Utilities Authority**
www.bcua.org



VOUCHER For Payment

PO Number: **20222468-001**

*This PO Number Must Appear On All
Correspondence, Invoices, and Shipments*

Date: 12/05/2022

Vendor Number: 5942

CERULLO FIRE PROTECTION, INC.
901-NEW BRUNSWICK AVE.
RAHWAY, NJ 07065

**Note: For Payment, This VOUCHER Page Must Be Signed By Claimant (Vendor)
And Presented Along With An Original Invoice Stating Terms**

DESCRIPTION: DESCRIPTION: ANNUAL FIRE EXTINGUISHER INSPECTIONS.

Line Number	Quantity	UoM	Description	Unit Cost	Extended Cost
1	262.0000	EACH	LITTLE FERRY, EDGEWATER AND PUMP STAION EXTINGUISHERS. ANNUAL INSPECTION FOR ALL	\$6.5000	\$1,703.00

Subtotal	\$1,703.00
Purchase Order Total	\$1,703.00

I do solemnly declare and certify under the penalties of the law that the within bill is correct in all its particulars; that the articles have been furnished or services rendered as stated therein; that no bonus has been given or received by any person or persons within the knowledge of this claimant in connection with the above claim; that the amount therein stated is justly due and owing; and that the amount charged is a reasonable one.

Claimant Signature *Kevin Cerullo*
Printed Kevin Cerullo
Title President
Date 1/9/2023
Federal ID# or Social Security # 223244907

Send Correspondence, Invoice, Voucher, to:

Bergen County Utilities Authority
PO Box 9
Little Ferry, NJ 07643-0009
Telephone: 201-641-2552
Fax: 201-807-8681
Email: AccountsPayable@bcua.org

----- For BCUA Use Only -----

FINANCIAL APPROVAL: I certify that the goods or services indicated above were received and payment is due as claimed.

Treasurer/Chief Financial Officer: _____

Date: _____

Cerullo Fire Protection, Inc.
901 New Brunswick Avenue
Rahway, NJ 07065
(732) 388-1949 Fax (732) 388-0096

CUSTOMER #: 1458
INVOICE #: 120230
INVOICE DATE: 12/20/22
DUE DATE: 01/19/23

BILL TO:

Bergen Co Utilities Authority
PO Box 9
Little Ferry, NJ 07643-0009

ATTN

PHONE(201) 641-2552 FAX (201) 807-8641

LOCATION: 4025

Bergen County Utilities Auth
Foot of Mehrhof Road
Little Ferry, NJ

WORK ORDER NUMBER: 42636

YOUR REFERENCE NUMBER: PO#20222468

DESCRIPTION	QUANTITY	PRICE	AMOUNT
OTHER			
12/20/22 Extinguisher inspection per E53850	262.00	6.5000	1,703.00
		TOTAL OTHER:	1,703.00
		TOTAL:	1,703.00

PAYMENT DUE UPON RECEIPT

A 2% charge will be applied monthly to all past due accounts, totaling 24% per annum.

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, New Jersey 07065

Phone # 732-388-1949 / Fax # 732-388-0096

Permit # P00140

Mobile Recharge Unit

SOLD TO:

BCUA

Foot of Mehrhof Rd

Little Ferry, NJ

SHIP TO:

DATE PERFORMED	PERSON TO SEE OR REF. NO.	EMAIL	PHONE #	FAX #
12/20/2022	Michael Cammett		201-641-2552	
EQUIPMENT #			LAST / FREQ.	SERVICE CONTRACT #
				E53850

QTY.	DESCRIPTION	UNIT PRICE	AMOUNT
262	☒ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL Portable Fire Extinguisher - Inspection/service	\$6.50	\$1,703.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00

EQUIPMENT NOTE:

SITE NOTES:

QTY.	MATERIALS/PARTS	PRICE	AMOUNT	LABOR/TECH	HOURS	RATE	AMOUNT
			\$0.00				\$0.00
			\$0.00				\$0.00
			\$0.00				\$0.00
			\$0.00				\$0.00
			\$0.00				\$0.00
	MATERIAL SUB-TOTAL		\$0.00	LABOR SUB-TOTAL			\$0.00

SERVICES AND/OR MATERIALS
SPECIFIED IN GOOD ORDER

TERMS:
CUSTOMER WILL BE RESPONSIBLE FOR ALL
COLLECTION FEES, LEGAL FEES,
COURT COSTS AND SIMILAR EXPENSES
INCURRED IN ORDER TO
COLLECT PAST DUE ACCOUNTS

X

AUTHORIZED SIGNATURE
INSTRUCTIONS:

SERVICE PERFORMED BW

MATERIAL SUB-TOTAL	\$ 0.00
TOTAL	\$ 1,703.00
TAX	
PAY THIS AMOUNT →	\$ 1,703.00

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCVA

Mehrf Rd

Date: 12-19-22

Little Ferry NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
1		X	ABC	10			BA	
2		X	ABC	10			BA	
3		X	ABC	10			BE	
4		X	ABC	10			KID	
5	Office	X	ABC	10			BA	
6		X	ABC	10			BA	
7	Ceigp	X	CO2	15			AM	
8	E-2	X	ABC	20			BE	
9		X	ABC	10			BE	
10	WBR 1	X	CO2	10			BE	
11		X	ABC	10			BA	
12	WH 6	X	ABC	10			BE	
13	1/3 Lunch	X	ABC	10			BE	
14	MA 1	X	ABC	10			BA	
15	MA 2	X	ABC	10			BE	
16	MA 3	X	ABC	10			BA	
17		X	CO2	50				
18	W3	X	ABC	10			BA	
19		X	ABC	20			BE	
20	W1	X	ABC	10			BA	
21	V1	X	ABC	10			BA	
22	V2	X	ABC	10			BE	
23	V3	X	ABC	10			BE	
24		X	ABC	10			BA	
25		X	ABC	10			KID	
26		X	ABC	10			BE	
27			ABC	10	—	—	AM	Damaged Handle
28		X	ABC	5			BE	
29		X	ABC	10			BE	
30		X	ABC	10			AM	
31	Elect Rm	X	ABC	20			BC	
32		X	ABC	10			AM	
33			ABC	10	—	—	BA	
34	Old Admin	X	ABC	10			BA	
35		X	ABC	10			AM	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: Bill Willard

Print: Bill Willard

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCVA		Mehrbhof Rd						
Date: 12-19-22		Little Ferry NJ						
	Location	OK	Type	Size#	Due Hydro	Due 6Yr	Brand	Service Performed
36	Boil Screen	X	CO2	10			KID	
37		X	CO2	15			BA	
38		X	ABC	10			BA	
39		X	ABC	20			KID	
40		X	ABC	20			AM	
41	Outside	X	ABC	10			KID	
42	Switchgear	X	CO2	10				
43		X	CO2	10				
44	Admin	X	ABC	10			BE	
45		X	PW	2.5			BE	
46	7	X	ABC	10			BE	
47		X	ABC	10			BE	
48	3	X	ABC	10			BC	
49	4	X	PW	2.5			BE	
50		X	PW	2.5			BE	
51		X	PW	2.5			BE	
52		X	ABC	10			BE	
53	BSMT	X	ABC	10			BA	
54		X	CO2	20			FF	
55		X	CO2	15			FT	
56	Main R	X	ABC	10			BE	
57		X	ABC	10			AM	
58		X	ABC	10			PA	
59	10	X	ABC	20			BE	
60	CB	X	ABC	10			BA	
61	3	X	ABC	20			BC	
62	25	X	PW	2.5			BE	
63	26	X	ABC	10			BE	
64	27	X	CO2	15			KID	
65	LAD	X	ABC	10			BC	
66		X	ABC	10			BE	
67	29							Missing
68	30	X	ABC	20			BE	
69	31	X	ABC	10			BE	
70	32	X	ABC	10			BE	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCVA

Mehrhof Rd

Date: 12-19-22

Little Ferry NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
71	CB 34	X	ABC	10			BA	
72	4	X	ABC	10			BE	
73	Super	X	PW	2.5			BA	
74	5	X	ABC	10			BE	
75	7	X	ABC	10			BE	
76	Women	X	ABC	10			BE	
77		X	ABC	10			BE	
78	8	X	ABC	10			BC	
79		X	ABC	10			BE	
80		X	ABC	10			BE	
81		X	ABC	10			BE	
82		X	ABC	10			BE	
83		X	ABC	10			BE	
84		X	ABC	10			BE	
85		X	ABC	10			BE	
86	15	X	ABC	10			BA	
87		X	ABC	10			BE	
88		X	PW	2.5			BE	
89	8	X	ABC	10			BE	
90	Lunch	X	ABC	20			BE	
91		X	ABC	20			BE	
92		X	ABC	10			BE	
93		X	CO2	15			BC	
94		X	PW	2.5			BL	
95		X	ABC	20			BC	
96		X	ABC	10			BE	
97	Women	X	CO2	10			FP	
98		X	ABC	50			AM	
99		X	CO2	15			BA	
100		X	CO2	10			AN	
101	Blower	X	CO2	15			KID	
102		X	ABC	20			AM	
103		X	ABC	20			AM	
104		X	ABC	20			AM	
105		X	ABC	50			AM	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCVA

Mehrhof Rd

Date: 12-19-22

Little Falls NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
106	BLOWER	X	ABC	20			BC	
107		X	CO2	15			KID	
108		X	CO2	10			KID	
109	DIGESTER	X	ABC	20			AM	
110		X	ABC	20			KID	
111		X	CO2	15			KID	
112		X	ADL	20			AM	
113		X	CO2	10			AM	
114		X	CO2	15			KID	
115		X	ABC	20			AN	
116		X	ABC	20			AM	
117	Gnt	X	ABC	10			BA	
118	Gnt 2	X	ABC	10			KID	
119	Thickner	X	ABC	10			BA	
120		X	ABC	10			BA	
121		X	ABC	10			BA	
122		X	ADL	10			AM	
123	WAS	X	ABC	10			BA	
124		X	ABC	10			BE	
125		X	ABC	10			PI	
126		X	ABC	10			BA	
127		X	ABC	10			AM	
128		X	ABC	10			KID	
129		X	ABC	10			AN	
130		X	ABC	10			AN	
131		X	ABC	10			BA	
132		X	ABC	10			KID	
133		X	ABC	10			KID	
134		X	CO2	15			KID	
135	HD Storage	X	CO2	15			KID	
136		X	CO2	15			KID	
137	Return 2	X	CO2	10			KID	
138	Oil	X	ABC	10			AN	
139		X	ABC	10			KID	
140	Return 1	X	ABC	10			BA	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCVA

Mehrhof Rd

Date: 12-20-22

Little Ferry NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
141		X	ABC	10			BA	
142		X	ABC	20			AM	
143	Polymer	X	ABC	10			BA	
144		X	ABC	10			BA	
145		X	ABC	10			BA	
146		X	CO2	15			KID	
147		X	ABC	10			AM	
148	Return 2	X	ABC	20			BE	
149	DST 1st	X	ABC	10			BC	
150		X	ABC	10			BA	
151	Ext	X	ABC	10			BI	
152	Boiler	X	ABC	20			BE	
153		X	ABC	10			BE	
154		X	ABC	10			AM	
155		X	ABC	10			BE	
156		X	ABC	10			KIP	
157		X	ABC	10			BE	
158		X	ABC	10			PC	
159		X	ABC	10			DE	
160		X	ABC	10			DE	
161		X	ABC	10			KIP	
162	2nd F	X	ABC	10			AM	
163		X	ABC	10			BA	
164			ABC	10	—	—	BC	
165		X	ABC	10			BC	
166		X	ABC	10			AN	
167		X	ABC	10			KID	
168		X	ABC	10			BE	
169	3rd	X	ABC	10			BA	
170		X	ABC	10			BC	
171	Prime B	X	ABC	10			BA	
172	Elect	X	ABC	20			BE	
173		X	ABC	10			BA	
174	Ramp Bldg A	X	ABC	10			BC	
175		X	CO2	20			BN	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCUA		Mehrhof Rd						
Date: 12-20-22		Little Ferry NJ						
		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
176	Pump Build 1	X	CO2	15			FP	
177		X	ABC	20			KID	
178		X	CO2	10			KID	
179		X	ABC	10			BA	
180		X	ABC	10			BA	
181		X	ABC	10			BA	
182		X	CO2	15			KID	
183	Pump 2	X	ABC	10			PA	
184		X	ABC	20			AM	
185	2nd	X	ABC	20			PA	
186		X	CO2	10			KID	
187		X	ABC	20			BC	
188	Sub	X	ABC	20			BC	
189		X	ABC	20			BA	
190	Sub 2	X	ABC	20			BC	
191		X	ABC	10			AM	
192	Prime 3	X	ABC	10			PA	
193	Elect	X	CO2	15			KID	
194	Prime D	X	ABC	10			KID	
195	Elect	X	CO2	15			FP	
196		X	CO2	10			GC	
197		X	CO2	10			KID	
198		X	ABC	10			BA	
199	Pipe	X	ABC	10			KID	
200		X	ABC	11			BA	
201		X	ABC	10			KID	
202		X	ABC	10			BA	
203		X	ABC	10			BA	
204		X	ABC	10			DE	
205		X	ABC	10			BA	
206		X	ABC	10			AM	
207	Sludger 4	X	ABC	10			BA	
208		X	CO2	10			KID	
209		X	CO2	10			KID	
210	SPARE	X	CO2	10			AM	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCVA

Mehrhof Rd

Date: 12-20-22

Little Ferry NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
211	SPARES	X	CO2	10				
212		X	CO2	10				
213		X	CO2	10				
214		X	CO2	10				
215		X	CO2	10				
216		X	ABC	2.5				
217		X	ABC	5				
218		X	ABC	5				
219		X	ABC	5				
220		X	ABC	5				
221		X	ABC	5				
222		X	ABC	5				
223		X	ABC	5				
224		X	ABC	5				
225		X	ABC	5				
226		X	ABC	5				
227		X	ABC	5				
228		X	ABC	5				
229	SPARES	X	ABC	5				
230	Ramp House	X	CO2	10				
231		X	ABC	20				
232		X	ABC	5A				
233		X	ABC	10				
234		X	ABC	10				
235		X	ABC	10				
236		X	ABC	10				
237		X	ABC	10				
238		X	ABC	10				
239	Ramp House	X	ABC	10				
240	Edgewater	X	CO2	10				
241		X	CO2	10				
242		X	CO2	10				
243		X	CO2	10				
244		X	CO2	10				
245	Edgewater	X	CO2	10				

Signature: _____

Time In: _____

Print: _____

Time Out: _____

Date: _____

Tech Signature: _____

Print: _____

901 New Brunswick Avenue • Rahway, NJ 07065
Tel: (732) 388-1949 Fax: (732) 388-0096
License # P00140

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Date: 12-20-22

Mehrhof Rd
Little Ferry NJ

Signature: _____
 Print: _____
 Date: _____

Time In: _____
Time Out: _____
Tech Signature: _____
Print: _____

Cabrera, Marc

From: Cammett, Michael
Sent: Wednesday, December 28, 2022 7:05 AM
To: Cabrera, Marc
Subject: PO # 20222468
Attachments: 120230.pdf

Morning Marc,

PO # 20222468 can be paid the invoice is attached. Small increase in amount as more units were inspected than on the quote.

I received in Munis.

Mike

Michael R. Cammett
Manager of Operations & Maintenance
Bergen County Utilities Authority
Foot of Mehrhof Road
Little Ferry, NJ 07643
Phone: 201-807-5836
Mobil: 201-954-5471
mcammett@bcua.org



**Bergen County
Utilities Authority**

www.bcua.org



20232815

PO FILE COPY

PO Number: **20232815**

Date: 12/14/2023

Requisition Number: 23003217

Buyer: Cammett, Michael

Vendor Number: 5942

CERULLO FIRE PROTECTION, INC.
901-NEW BRUNSWICK AVE.
RAHWAY, NJ 07065

Phone: 732-388-1949

Fax: 732-388-0096

Inv # 132 455

DESCRIPTION: DESCRIPTION: ANNUAL FIRE EXTINGUISHER INSPECTIONS.

Line Number	Quantity	UoM	Description	Unit Cost	Extended Cost
1	262.0000	EA	ANNUAL FIRE EXTINGUISHER INSPECTION OF 262 UNITS. <i>GL #: 15224000 - 532610 Safety Prog - Trainng/Supplies</i>	\$6.7500	\$1,768.50

Subtotal	\$1,768.50
Purchase Order Total	\$1,768.50



**Bergen County
Utilities Authority**
www.bcua.org



VOUCHER For Payment

PO Number: **20232815**

*This PO Number Must Appear On All
Correspondence, Invoices, and Shipments*

Date: 12/14/2023

Vendor Number: 5942

CERULLO FIRE PROTECTION, INC.
901-NEW BRUNSWICK AVE.
RAHWAY, NJ 07065

**Note: For Payment, This VOUCHER Page Must Be Signed By Claimant (Vendor)
And Presented Along With An Original Invoice Stating Terms**

DESCRIPTION: DESCRIPTION: ANNUAL FIRE EXTINGUISHER INSPECTIONS.

Line Number	Quantity	UoM	Description	Unit Cost	Extended Cost
1	262.0000	EA	ANNUAL FIRE EXTINGUISHER INSPECTION OF 262 UNITS.	\$6.7500	\$1,768.50

Subtotal	\$1,768.50
Purchase Order Total	\$1,768.50

I do solemnly declare and certify under the penalties of the law that the within bill is correct in all its particulars; that the articles have been furnished or services rendered as stated therein; that no bonus has been given or received by any person or persons within the knowledge of this claimant in connection with the above claim; that the amount therein stated is justly due and owing; and that the amount charged is a reasonable one.

Claimant Signature Kevin Cerullo
Printed Kevin Cerullo
Title President
Date 3/4/2024
Federal ID# or Social Security # 223-244-907/000

Send Correspondence, Invoice, Voucher, to:

Bergen County Utilities Authority
PO Box 9
Little Ferry, NJ 07643-0009
Telephone: 201-641-2552
Fax: 201-807-8681
Email: AccountsPayable@bcua.org

----- For BCUA Use Only -----

FINANCIAL APPROVAL: I certify that the goods or services indicated above were received and payment is due as claimed.

Treasurer/Chief Financial Officer: _____

Date: _____



**Bergen County
Utilities Authority**
www.bcua.org



20232815

VOUCHER For Payment

PO Number: **20232815**

*This PO Number Must Appear On All
Correspondence, Invoices, and Shipments*

Date: 12/14/2023

Vendor Number: 5942

CERULLO FIRE PROTECTION, INC.
901-NEW BRUNSWICK AVE.
RAHWAY, NJ 07065


**Note: For Payment, This VOUCHER Page Must Be Signed By Claimant (Vendor)
And Presented Along With An Original Invoice Stating Terms**

DESCRIPTION: DESCRIPTION: ANNUAL FIRE EXTINGUISHER INSPECTIONS.

Line Number	Quantity	UoM	Description	Unit Cost	Extended Cost
1	262.0000	EA	ANNUAL FIRE EXTINGUISHER INSPECTION OF 262 UNITS.	\$6.7500	\$1,768.50

Subtotal	\$1,768.50
Purchase Order Total	\$1,768.50

I do solemnly declare and certify under the penalties of the law that the within bill is correct in all its particulars; that the articles have been furnished or services rendered as stated therein; that no bonus has been given or received by any person or persons within the knowledge of this claimant in connection with the above claim; that the amount therein stated is justly due and owing; and that the amount charged is a reasonable one.

Claimant Signature 

Printed Kevin Cerullo

Title Pres Ent

Date 12/26/2027

Federal ID# or Social Security # _____

Send Correspondence, Invoice, Voucher, to:

Bergen County Utilities Authority
PO Box 9
Little Ferry, NJ 07643-0009
Telephone: 201-641-2552
Fax: 201-807-8681
Email: AccountsPayable@bcua.org

----- For BCUA Use Only -----

FINANCIAL APPROVAL: I certify that the goods or services indicated above were received and payment is due as claimed.

Treasurer/Chief Financial Officer: _____

Date _____

Cerullo Fire Protection, Inc.
901 New Brunswick Avenue
Rahway, NJ 07065
(732) 388-1949 Fax (732) 388-0096

CUSTOMER #: 1458
INVOICE #: 132455
INVOICE DATE: 02/26/24
DUE DATE: 03/27/24

BILL TO:

Bergen Co Utilities Authority
PO Box 9
Little Ferry, NJ 07643-0009

ATTN: Michael Cammett
PHONE: (201) 641-2552 FAX (201) 807-8641

LOCATION: 4025

Bergen County Utilities Auth
Foot of Mehrhof Road
Little Ferry, NJ

WORK ORDER NUMBER: 45500

YOUR REFERENCE NUMBER: PO#20232815

DESCRIPTION	QUANTITY	PRICE	AMOUNT
OTHER			
02/26/23 Extinguisher inspection per E56211	262.00	6.7500	1,768.50
		TOTAL OTHER:	1,768.50
		TOTAL:	1,768.50

PAYMENT DUE UPON RECEIPT

A 2% charge will be applied monthly to all past due accounts, totaling 24% per annum.

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, New Jersey 07065

Phone # 732-388-1949 / Fax # 732-388-0096

Permit # P00140

Mobile Recharge Unit

SOLD TO:

BCUA

208 Mohr Rd

Little Ferry, NJ

SHIP TO:

DATE PERFORMED	PERSON TO SEE OR REF. NO.	EMAIL	PHONE #	FAX #
02/26/2024	Mike Cammett		201-641-2552	
EQUIPMENT #			LAST / FREQ.	SERVICE CONTRACT #
				E56211

QTY.	DESCRIPTION	UNIT PRICE	AMOUNT
282	☒ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL Portable Fire Extinguisher - inspection/service	\$0.75	\$1,708.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00

EQUIPMENT NOTE:

SITE NOTES:

QTY.	MATERIALS/PARTS	PRICE	AMOUNT	LABOR/TECH	HOURS	RATE	AMOUNT
			\$0.00				\$0.00
			\$0.00				\$0.00
			\$0.00				\$0.00
			\$0.00				\$0.00
			\$0.00				\$0.00
			\$0.00				\$0.00
	MATERIAL SUB-TOTAL		\$0.00	LABOR SUB-TOTAL			\$0.00

SERVICES AND/OR MATERIALS
SPECIFIED IN GOOD ORDER

TERMS:
CUSTOMER WILL BE RESPONSIBLE FOR ALL
COLLECTION FEES, LEGAL FEES,
COURT COSTS AND SIMILAR EXPENSES
INCURRED IN ORDER TO
COLLECT PAST DUE ACCOUNTS

X

AUTHORIZED SIGNATURE

SERVICE PERFORMED BY

INSTRUCTIONS:

MATERIAL SUB-TOTAL	\$0.00
TOTAL	\$1,768.50
TAX	
PAY THIS AMOUNT →	\$1,768.50

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue - Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCVA

Mehrf Rd

Date: 2-26-24

Little Ferry NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
1		X	ABC	10			BA	
2		X	ABC	10			BA	
3		X	ABC	10			BE	
4		X	ABC	10			KID	
5	Office	X	ABC	10			BA	
6		X	ABC	10			BA	
7	Perp	X	CO2	15			AM	
8	E-2	X	ABC	20			BE	
9		X	ABC	10			BE	
10	WB R-4	X	CO2	10			BE	
11		X	ABC	10			BA	
12	WH 6	X	ABC	10			BE	
13	W/S Lunch	X	ABC	10			BE	
14	MA 1	X	ABC	10			BA	
15	MA 2	X	ABC	10			BE	
16	MA 3	X	ABC	10			BA	
17		X	CO2	50				
18	W3	X	ABC	10			BA	
19		X	ABC	20			BE	
20	W1	X	ABC	10			BA	
21	V1	X	ABC	10			BA	
22	V2	X	ABC	10			BE	
23	V3	X	ABC	10			BE	
24		X	ABC	10			BA	
25		X	ABC	10			KID	
26		X	ABC	10			BE	
27		X	ABC	10			AM	
28		X	ABC	5			BE	
29		X	ABC	10			BE	
30		X	ABC	10			AM	
31	Elect R	X	ABC	20			BC	
32		X	ABC	10			AM	
33		X	ABC	10			BA	
34	Old Admin	X	ABC	10			BA	
35		X	ABC	10			AM	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: Bill Willard

Print: Bill Willard

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCVA

Date: 2-26-24

Mehrhof Rd
Little Ferry NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
36	Boiler Room	X	CO2	10			KID	
37		X	CO2	15			BA	
38		X	ABC	10			BA	
39		X	ABC	20			KID	
40		X	ABC	70			AM	
41	Outside	X	ABC	10			KID	
42	Swishgear	X	CO2	10				
43		X	CO2	10				
44	Admin	X	ABC	10			BE	
45		X	PW	2.5			BE	
46	7	X	ABC	10			BE	
47		X	ABC	10			BE	
48	3	X	ABC	10			BC	
49	4	X	PW	2.5			BE	
50		X	PW	2.5			BE	
51		X	PW	2.5			BE	
52		X	ABC	10			BE	
53	BSMT	X	ABC	10			BA	
54		X	CO2	70			FF	
55		X	CO2	15			IT	
56	Mail Rm	X	ABC	10			BE	
57		X	ABC	10			AM	
58		X	ABC	10			BA	
59	10	X	ABC	20			BE	
60	CB	X	ABC	10			BA	
61	3	X	ABC	20			BE	
62	25	X	PW	2.5			BE	
63	20	X	ABC	10			BE	
64	27	X	CO2	15			KID	
65	LAD	X	ABC	10			BC	
66		X	ABC	10			BE	
67	29	X	ABC	10				
68	30	X	ABC	20			BE	
69	31	X	ABC	10			BE	
70	32	X	ABC	10			BE	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCVA

Mehrhof Rd

Date: 2.26-24

Little Ferry NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
71	CB 34	X	ABC	10			BA	
72	4	X	ABC	10			BE	
73	Superv	X	PW	2.5			BA	
74	5	X	ABC	10			BE	
75	7	X	ABC	10			BE	
76	Women	X	ABC	10			BE	
77		X	ABC	10			BE	
78	8	X	ABC	10			BE	
79		X	ABC	10			BE	
80		X	ABC	10			BE	
81		X	ABC	10			BE	
82		X	ABC	10			BE	
83		X	ABC	10			BE	
84		X	ABC	10			BE	
85		X	ABC	10			BE	
86	15	X	ABC	10			BA	
87		X	ABC	10			BE	
88		X	PW	2.5			BE	
89	AB	X	ABC	10			BE	
90	Lunch	X	ABC	20			BE	
91		X	ABC	20			BE	
92		X	ABC	10			BE	
93		X	CO2	15			BC	
94		X	PW	2.5			GL	
95		X	ABC	20			BC	
96		X	ABC	10			BE	
97	Women	X	CO2	10			FP	
98		X	ABC	50			AM	
99		X	CO2	15			BA	
100		X	CO2	10			AN	
101	Blower	X	CO2	15			KID	
102		X	ABC	20			AM	
103		X	ABC	20			AM	
104		X	ABC	20			AM	
105		X	ABC	50			AM	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCVA

Mehrhof Rd

Date: 2-26-24

Little Falls NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
106	BLOWER	X	ABC	20			BC	
107		X	CO2	15			KID	
108		X	CO2	10			KID	
109	DIGESTER	X	ABC	20			AM	
110		X	ABC	20			KID	
111		X	CO2	15			KID	
112		X	ADL	20			AM	
113		X	CO2	10			AM	
114		X	CO2	15			KID	
115		X	ABC	20			AN	
116		X	ABC	20			AM	
117	Gnt	X	ABC	10			BA	
118	Gnt 2	X	ADL	10			KID	
119	Thickner	X	ABC	10			BA	
120		X	ABC	10			BA	
121		X	ABC	10			BA	
122		X	ADL	10			AF	
123	WAS	X	ABC	10			BA	
124		X	ABC	10			BE	
125		X	ABC	10			PI	
126		X	ABC	10			BA	
127		X	ABC	10			AM	
128		X	ABC	10			KID	
129		X	ABC	10			AN	
130		X	ABC	10			AN	
131		X	ABC	10			BA	
132		X	ABC	10			KID	
133		X	ABC	10			KID	
134		X	CO2	15			KID	
135	HD Spray	X	CO2	15			KID	
136		X	CO2	15			KID	
137	Return 2	X	CO2	10			KID	
138	Oil	X	ABC	10			AN	
139		X	ABC	10			KID	
140	Return 1	X	ABC	10			BA	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: **BCVA**

Mehrhof Rd

Date: **2-26-24**

Little Ferry NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
141		X	ABC	10			BA	
142		X	ABC	20			AM	
143	Polymer	X	ABC	10			BA	
144		X	ABC	10			BA	
145		X	ABC	10			BA	
146		X	CO2	15			KID	
147		X	ABC	10			AM	
148	Retina 2	X	ABC	20			BE	
149	DST 1st	X	ABC	10			BC	
150		X	ABC	10			BA	
151	Elv	X	ABC	10			BC	
152	Boiler	X	ABC	20			BE	
153		X	ABC	10			BF	
154		X	ABC	10			AM	
155		X	ABC	10			BE	
156		X	ABC	10			KID	
157		X	ABC	10			BC	
158		X	ABC	10			PC	
159		X	ABC	10			DE	
160		X	ABC	10			DE	
161		X	ABC	10			KID	
162	2nd F	X	ABC	10			AM	
163		X	ABC	10			BA	
164			ABC	10	—	—	BC	
165		X	ABC	10			BC	
166		X	ABC	10			AN	
167		X	ABC	10			KID	
168		X	ABC	10			BE	
169	3rd	X	ABC	10			BA	
170		X	ABC	10			BC	
171	Prime B	X	ABC	10			BA	
172	Elect	X	ABC	20			BC	
173		X	ABC	10			BA	
174	Ramp Bldg A	X	ABC	10			BP	
175		X	CO2	20			DA	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: **BCUA**

Mehrhof Rd

Date: **2-26-24**

Little Ferry NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
176	Pump Build 1	X	CO2	15			FF	
177		X	ABC	20			KID	
178		X	CO2	10			KID	
179		X	ABC	10			BA	
180		X	ABC	10			BA	
181		X	ABC	10			BA	
182		X	CO2	15			KID	
183	Pump 2	X	ABC	10			PA	
184		X	ABC	20			AM	
185	2nd	X	ABC	20			PA	
186		X	CO2	10			KID	
187		X	ABC	20			BC	
188	Sub	X	ABC	20			BC	
189		X	ABC	20			BA	
190	Sub 2	X	ABC	20			BC	
191		X	ABC	10			AM	
192	Prime 3	X	ABC	10			PA	
193	Elect	X	CO2	15			KID	
194	Prime P	X	ABC	10			KID	
195	Elect	X	CO2	15			FF	
196		X	CO2	10			BA	
197		X	CO2	10			KID	
198		X	ABC	10			BA	
199	Pipe	X	ABC	10			KID	
200		X	ABC	11			BA	
201		X	ABC	10			KID	
202		X	ABC	10			BA	
203		X	ABC	10			BA	
204		X	ABC	10			BC	
205		X	ABC	10			BA	
206		X	ABC	10	—	—	AM	
207	Sticker 4	X	ABC	10			BA	
208		X	CO2	10			KID	
209		X	CO2	10			KID	
210	SPARE	X	ABC	10			AM	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCVA

Mehrhof Rd

Date: 2-26-24

Little Ferry NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
211	SPARES	X	CO2	10'				
212		X	CO2	10'				
213		X	CO2	10'				
214		X	CO2	10'				
215		X	CO2	10'				
216		X	ABC	2.5'				
217		X	ABC	5'				
218		X	ABC	5'				
219		X	ABC	5'				
220		X	ABC	5'				
221		X	ABC	5'				
222		X	ABC	5'				
223		X	ABC	5'				
224		X	ABC	5'				
225		X	ABC	5'				
226		X	ABC	5'				
227		X	ABC	10'				
228		X	ABC	10'				
229	SPARES	X	ABC	10'				
230	Pump House	X	CO2	10'				
231		X	ABC	20'				
232		X	ABC	5A'				
233		X	ABC	10'				
234		X	ABC	10'				
235		X	ABC	10'				
236		X	ABC	10'				
237		X	ABC	10'				
238		X	ABC	10				
239	Pump House	X	ABC	10				
240	Edgewater	X	CO2	10'				
241		X	CO2	10'				
242		X	CO2	10'				
243		X	CO2	10'				
244		X	CO2	10'				
245	Edgewater	X	CO2	10				

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

License # P00140

Mehrhof Rd
Little Ferry NJ

[illegible]

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____



**Bergen County
Utilities Authority**
www.bcua.org



20242605

2025
PO FILE COPY

PO Number: **20242605**

Date: 12/11/2024

Requisition Number: 24002886

Buyer: Cammett, Michael

Vendor Number: 5942

CERULLO FIRE PROTECTION, INC.
901-NEW BRUNSWICK AVE.
RAHWAY, NJ 07065

Phone: 732-388-1949

Fax: 732-388-0096

Inv# 1458

DESCRIPTION: DESCRIPTION: ANNUAL FIRE EXTINGUISHER INSPECTIONS. E588512

Line Number	Quantity	UoM	Description	Unit Cost	Extended Cost
1	262.0000	EA	LITTLE FERRY, EDGEWATER AND PUMP STAION EXTINGUISHERS. ANNUAL INSPECTION FOR ALL GL #: 15224000 - 532610 Safety Prog - Trainng/Supplies	\$7.0000	\$1,834.00 \$1,834.00

Subtotal	\$1,834.00
Purchase Order Total	\$1,834.00



**Bergen County
Utilities Authority**
www.bcua.org



VOUCHER For Payment

PO Number: **20242605**

*This PO Number Must Appear On All
Correspondence, Invoices, and Shipments*

Date: 12/11/2024

Vendor Number: 5942

CERULLO FIRE PROTECTION, INC.
901-NEW BRUNSWICK AVE.
RAHWAY, NJ 07065

**Note: For Payment, This VOUCHER Page Must Be Signed By Claimant (Vendor)
And Presented Along With An Original Invoice Stating Terms**

DESCRIPTION: DESCRIPTION: ANNUAL FIRE EXTINGUISHER INSPECTIONS. E588512

Line Number	Quantity	UoM	Description	Unit Cost	Extended Cost
1	262.0000	EA	LITTLE FERRY, EDGEWATER AND PUMP STAION EXTINGUISHERS. ANNUAL INSPECTION FOR ALL	\$7.0000	\$1,834.00

Subtotal	\$1,834.00
Purchase Order Total	\$1,834.00

Please SIGN Vendor Voucher
EMAIL back to
astellato@bcua.org

I do solemnly declare and certify under the penalties of the law that the within bill is correct in all its particulars; that the articles have been furnished or services rendered as stated therein; that no bonus has been given or received by any person or persons within the knowledge of this claimant in connection with the above claim; that the amount therein stated is justly due and owing; and that the amount charged is a reasonable one.

Claimant Signature *Kevin Cerullo*
Printed Kevin Cerullo
Title President
Date 12/16/2024
Federal ID# or Social Security # ~~#~~ 22-3244907

Send Correspondence, Invoice, Voucher, to:

Bergen County Utilities Authority
PO Box 9
Little Ferry, NJ 07643-0009
Telephone: 201-641-2552
Fax: 201-807-8681
Email: AccountsPayable@bcua.org

----- For BCUA Use Only -----

FINANCIAL APPROVAL: I certify that the goods or services indicated above were received and payment is due as claimed.

Treasurer/Chief Financial Officer: _____

Date: _____

Cerullo Fire Protection, Inc.
901 New Brunswick Avenue
Rahway, NJ 07065
(732) 388-1949 Fax (732) 388-0096

CUSTOMER #: 1458
INVOICE #: 137273
INVOICE DATE: 01/21/25
DUE DATE: 02/20/25

BILL TO:

Bergen Co Utilities Authority
PO Box 9
Little Ferry, NJ 07643-0009

ATTNMichael Cammett
PHONE(201) 641-2552 **FAX** (201) 807-8641

LOCATION: 4025

Bergen County Utilities Auth
298 Foot of Mehrhof Road
Little Ferry, NJ

WORK ORDER NUMBER: 48426

YOUR REFERENCE NUMBER: PO#20242605

DESCRIPTION	QUANTITY	PRICE	AMOUNT
OTHER			
01/21/25 Extinguisher inspection	262.00	7.0000	1,834.00
TOTAL OTHER:			1,834.00
TOTAL:			1,834.00

PAYMENT DUE UPON RECEIPT

A 2% charge will be applied monthly to all past due accounts, totaling 24% per annum.

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, New Jersey 07065

Phone # 732-388-1949 / Fax # 732-388-0096

Permit # P00140

Mobile Recharge Unit

SOLD TO:

BCUA

SHIP TO:

298 Mehrhof Rd

Little Ferry, NJ

DATE PERFORMED	PERSON TO SEE / REF NO.	QUANTITY	PHONE	TAX
01/21/2025	Mike		201-641-2552	

EQUIPMENT	DATE / FREQ.	SERVICE CONTRACT

QTY	DESCRIPTION	UNIT PRICE	AMOUNT
262	☒ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL Portable Fire Extinguisher - inspection/service	\$7.00	\$1,834.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00
	☐ INSPECT ☐ RECHARGE ☐ RECHARGE HYDRO TEST ☐ NEW ☐ 6YEAR ☐ REMOVAL		\$0.00

EQUIPMENT NOTE:**SITE NOTES:**

PO# 20242605

QTY	MATERIALS/PARTS	PRICE	AMOUNT	LABOR/TECH	HOURS	RATE	AMOUNT
			\$0.00				\$0.00
			\$0.00				\$0.00
			\$0.00				\$0.00
			\$0.00				\$0.00
			\$0.00				\$0.00
	MATERIAL SUB-TOTAL		\$ 0.00	LABOR SUB-TOTAL			\$ 0.00

SERVICES AND/OR MATERIALS
SPECIFIED IN GOOD ORDER

TERMS:
CUSTOMER WILL BE RESPONSIBLE FOR ALL
COLLECTION FEES, LEGAL FEES,
COURT COSTS AND SIMILAR EXPENSES
INCURRED IN ORDER TO
COLLECT PAST DUE ACCOUNTS

SERVICE PERFORMED BY

AUTHORIZED SIGNATURE

INSTRUCTIONS:

MATERIAL SUB-TOTAL \$ 0.00

TOTAL \$ 1,834.00

TAX

PAY THIS
AMOUNT

\$ 1,834.00

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue - Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCVA

Mehwp Rd

Date: 1-21-25

Little Ferry NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
1		X	ABC	10			BA	
2		X	ABC	10			BA	
3		X	ABC	10			BE	
4		X	ABC	10			KID	
5	Office	X	ABC	10			BA	
6		X	ABC	10			BA	
7	CEG	X	CO2	15			AM	
8	E-2	X	ABC	20			BE	
9		X	ABC	10			BE	
10	WBR 1	X	CO2	16			BE	
11		X	ABC	10			BA	
12	W46	X	ABC	10			BE	
13	W5 Lunch	X	ABC	10			BE	
14	MA 1	X	ABC	10			BA	
15	MA 2	X	ABC	10			BE	
16	MA 3	X	ABC	10			BA	
17		X	CO2	50				
18	W3	X	ABC	10			BA	
19		X	ABC	20			BE	
20	W1	X	ABC	10			BA	
21	V1	X	ABC	10			BA	
22	V2	X	ABC	10			BE	
23	V3	X	ABC	10			BE	
24		X	ABC	10			BA	
25		X	ABC	10			KID	
26		X	ABC	10			BE	
27		X	ABC	10			AM	
28		X	ABC	5			BE	
29		X	ABC	10			BE	
30		X	ABC	10			AM	
31	Elect Rm	X	ABC	20			BE	
32		X	ABC	10			AM	
33		X	ABC	10			BA	
34	Old Admin	X	ABC	10			BA	
35		X	ABC	10			AM	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: Bill Willard

Print: Bill Willard

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCVA

Mehrhof Rd
Little Ferry NJ

Date: 1-21-25

		OK			Due	Due.		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
36	Boiler Room	X	CO2	10			KID	
37		X	CO2	15			BA	
38		X	ABC	10			BA	
39		X	ABC	20			KID	
40		X	ABC	70			AM	
41	Outside	X	ABC	10			KID	
42	Switchgear	X	CO2	10				
43		X	CO2	10				
44	Admin	X	ABC	10			BE	
45		X	PW	2.5			BE	
46	7	X	ABC	10			BE	
47		X	ABC	10			BE	
48	5	X	ABC	10			BC	
49	4	X	PW	2.5			BE	
50		X	PW	2.5			BE	
51		X	PW	2.5			BE	
52		X	ABC	10			BE	
53	BSMT	X	ABC	10			BA	
54		X	CO2	20			FF	
55		X	CO2	15			FF	
56	Mail Rm	X	ABC	10			BE	
57		X	ABC	10			AM	
58		X	ABC	10			BA	
59	10	X	ABC	20			BE	
60	CB	X	ABC	10			BA	
61	3	X	ABC	20			BC	
62	25	X	PW	2.5			BE	
63	20	X	ABC	10			BE	
64	27	X	CO2	15			KID	
65	LAD	X	ABC	10			BC	
66		X	ABC	10			BE	
67	29	X	ABC	10				
68	30	X	ABC	20			BE	
69	31	X	ABC	10			BE	
70	32	X	ABC	10			BE	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCVA

Mehrhof Rd

Date: 1-21-25

Little Ferry NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
71	CB 34	X	ABC	10			BA	
72	4	X	ABC	10			BE	
73	Super	X	PW	2.5			BA	
74	5	X	ABC	10			BE	
75	7	X	ABC	10			BE	
76	Women	X	ABC	10			BE	
77		X	ABC	10			BE	
78	8	X	ABC	10			BE	
79		X	ABC	10			BE	
80		X	ABC	10			BE	
81		X	ABC	10			BE	
82		X	ABC	10			BE	
83		X	ABC	10			BE	
84		X	ABC	10			BE	
85		X	ABC	10			BE	
86	15	X	ABC	10			BA	
87		X	ABC	10			BE	
88		X	PW	2.5			BE	
89	AB	X	ABC	10			BE	
90	Lunch	X	ABC	20			BE	
91		X	ABC	20			BE	
92		X	ABC	10			BE	
93		X	CO2	15			BC	
94		X	PW	1.5			BL	
95		X	ABC	20			BL	
96		X	ABC	10			BE	
97	O'Brien	X	CO2	10			FP	
98		X	ABC	50			AM	
99		X	CO2	15			BA	
100		X	CO2	10			AN	
101	Klower	X	CO2	15			KID	
102		X	ABC	20			AM	
103		X	ABC	20			AM	
104		X	ABC	20			AM	
105		X	ABC	50			AM	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCVA

Mehrhof Rd

Date: 12-25

Little Falls NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
106	BLOWER	X	ABC	20			BC	
107		X	CO2	15			KID	
108		X	CO2	10			KID	
109	DIGESTER	X	ABC	20			AM	
110		X	ABC	20			KID	
111		X	CO2	15			KID	
112		X	ADL	20			AM	
113		X	CO2	10			AM	
114		X	CO2	15			KID	
115		X	ABC	20			AN	
116		X	ABC	20			AM	
117	Gnt	X	ABC	10			BA	
118	Gnt 2	X	ABC	10			KID	
119	Thickener	X	ABC	10			BA	
120		X	ABC	10			BA	
121		X	ABC	10			BA	
122		X	ABC	10			AM	
123	WAS	X	ABC	10			BA	
124		X	ABC	10			BE	
125		X	ABC	10			PI	
126		X	ABC	10			BA	
127		X	ABC	10			AM	
128		X	ABC	10			KID	
129		X	ABC	10			AN	
130		X	ABC	10			AN	
131		X	ABC	10			BA	
132		X	ABC	10			KID	
133		X	ABC	10			KID	
134		X	CO2	15			KID	
135	HD Storage	X	CO2	15			KID	
136		X	CO2	15			KID	
137	Return 2	X	CO2	10			KID	
138	Oil	X	ABC	10			AN	
139		X	ABC	10			KID	
140	Return 1	X	ABC	10			BA	

Signature: _____

Time In: _____

Print: _____

Time Out: _____

Date: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: **BCVA**

Mehrhof Rd

Date: **1-21-25**

Little Ferry NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
141		X	ABC	10			BA	
142		X	ABC	20			AM	
143	Polymer	X	ABC	10			BA	
144		X	ABC	10			BA	
145		X	ABC	10			BA	
146		X	CO2	15			KID	
147		X	ABC	10			AM	
148	Relv 2	X	ABC	20			BE	
149	DST 1st	X	ABC	10			BC	
150		X	ABC	10			BA	
151	ERV	X	ABC	10			BC	
152	Boiler	X	ABC	20			BE	
153		X	ABC	10			BE	
154		X	ABC	10			AM	
155		X	ABC	10			BE	
156		X	ABC	10			ETP	
157		X	ABC	10			BE	
158		X	ABC	10			PC	
159		X	ABC	10			DE	
160		X	ABC	10			DE	
161		X	ABC	10			KID	
162	2nd F	X	ABC	10			AM	
163		X	ABC	10			BA	
164		X	ABC	10	—	—	BE	
165		X	ABC	10			BE	
166		X	ABC	10			AN	
167		X	ABC	10			KID	
168		X	ABC	10			BE	
169	3rd	X	ABC	10			BA	
170		X	ABC	10			BC	
171	Prime B	X	ABC	10			BA	
172	Elect	X	ABC	20			BE	
173		X	ABC	10			BA	
174	Ramp B-17A	X	ABC	10			BE	
175		X	CO2	20			AN	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCUA		Mehrhof Rd Little Ferry NJ						
Date: 1-21-25								
	Location	OK	Type	Size#	Due Hydro	Due 6Yr	Brand	Service Performed
176	Pump Build 1	X	CO2	15			FF	
177		X	ABC	20			KID	
178		X	CO2	10			KID	
179		X	ABC	10			BA	
180		X	ABC	10			BA	
181		X	ABC	10			BA	
182		X	CO2	15			KID	
183	Pump 2	X	ABC	10			PA	
184		X	ABC	20			AM	
185	2nd	X	ABC	20			BA	
186		X	CO2	10			KID	
187		X	ABC	10			BC	
188	Sub	X	ABC	20			BC	
189		X	ABC	20			BA	
190	Sub 2	X	ABC	20			BC	
191		X	ABC	10			AM	
192	Prime 3	X	ABC	10			PA	
193	Elect	X	CO2	15			KID	
194	Prime P	X	ABC	10			KID	
195	Elect	X	CO2	15			FF	
196		X	CO2	10			Gr-	
197		X	CO2	10			KID	
198		X	ABC	10			BA	
199	Pipe	X	ABC	10			KID	
200		X	ABC	11			BA	
201		X	ABC	10			KID	
202		X	ABC	10			BA	
203		X	ABC	10			BA	
204		X	ABC	10			DE	
205		X	ABC	10			BA	
206		X	ABC	10			AN	
207	Sticker 4	X	ABC	10			BA	
208		X	CO2	10			KID	
209		X	CO2	10			KID	
210	SPARE	X	ABC	10			AN	

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

CERULLO FIRE PROTECTION, INC.

901 New Brunswick Avenue • Rahway, NJ 07065

Tel: (732) 388-1949 Fax: (732) 388-0096

License # P00140

Job Site: BCVA

Mehrhof Rd

Date: 1-21-25

Little Ferry NJ

		OK			Due	Due		Service
	Location	X	Type	Size#	Hydro	6Yr	Brand	Performed
211	SPARES	X	CO2	10'				
212		X	CO2	10'				
213		X	CO2	10'				
214		X	CO2	10'				
215		X	CO2	10'				
216		X	ABC	2.5'				
217		X	ABC	5'				
218		X	ABC	5'				
219		X	ABC	5'				
220		X	ABC	5'				
221		X	ABC	5'				
222		X	ABC	5'				
223		X	ABC	5'				
224		X	ABC	5'				
225		X	ABC	5'				
226		X	ABC	5'				
227		X	ABC	10'				
228		X	ABC	10'				
229	SPARES	X	ABC	10'				
230	Pump House	X	CO2	10'				
231		X	ABC	20'				
232		X	ABC	5A'				
233		X	ABC	10'				
234		X	ABC	10'				
235		X	ABC	10'				
236		X	ABC	10'				
237		X	ABC	10'				
238		X	ABC	10'				
239	Pump House	X	ABC	10'				
240	Edgewater	X	CO2	10'				
241		X	CO2	10'				
242		X	CO2	10'				
243		X	CO2	10'				
244		X	CO2	10'				
245	Edgewater	X	CO2	10'				

Signature: _____

Print: _____

Date: _____

Time In: _____

Time Out: _____

Tech Signature: _____

Print: _____

License # P00140

Mehrhof Rd
Little Ferry NJ

Print: _____

Ortiz, Jessica

From: Chung, Christopher
Sent: Wednesday, April 8, 2026 9:20 AM
To: Ortiz, Jessica
Subject: FW: Annual fire extinguisher inspection quote and DST service call.

Good morning Jessica,

See below email from Mr. Cammett regarding fire extinguishers.
Thank you.

Chris

From: Cammett, Michael <mcammett@bcua.org>
Sent: Thursday, November 6, 2025 6:02 AM
To: Chung, Christopher <cchunx@xxxx.xxx>
Cc: Rucki, Jason <xxxxxx@xxxx.xxx>; Carroll, James <xxxxxxxx@xxxx.xxx>
Subject: RE: Annual fire extinguisher inspection quote and DST service call.

Thanks Chris. I paid \$7 per unit last year. Ill get a quote as well.

From: Chung, Christopher <cchunx@xxxx.xxx>
Sent: Wednesday, November 5, 2025 2:44 PM
To: Cammett, Michael <mcxxxxxx@xxxx.xxx>
Cc: Rucki, Jason <xxxxxx@xxxx.xxx>; Carroll, James <xxxxxxxx@xxxx.xxx>
Subject: RE: Annual fire extinguisher inspection quote and DST service call.

Hi Mike,

Pye-Barker Fire Safety (formally known as Metro Fire Safety) located in Carlstadt charges \$110 service fee and \$8 per for basic inspection.
Thank you.

Chris

From: Cammett, Michael <mcammexx@xxxx.xxx>
Sent: Wednesday, November 5, 2025 10:01 AM
To: Chung, Christopher <cchunx@xxxx.xxx>
Cc: Rucki, Jason <xxxxxx@xxxx.xxx>; Carroll, James <xxxxxxxx@xxxx.xxx>
Subject: Annual fire extinguisher inspection quote and DST service call.

Morning Chris,

Can you obtain a quote for our annual fire extinguisher inspection please from the company that performs our routine work on site? We normally inspect 262 units total here at Little ferry and will bring in the units from the pump stations and Edgewater so they are all completed here. I have been using Cerillo Fire Protection in past years and we can compare with them. We would need dates in early January for the inspections.

Also, I received a report of multiple alarms active in the DST building that's needs attention by the company.

Mike

Michael R. Cammett
Director of Water Pollution Control
Bergen County Utilities Authority
Foot of Mehrhof Road
Little Ferry, NJ 07643
Phone: 201-807-5836
Mobil: 201-954-5471
mcammett@bcua.org