

BERGEN PROTECTIVE SYSTEMS, INC.

325 Sylvan Avenue
 Englewood Cliffs, NJ 07632
 P: 201-947-3114 • F: 201-227-0113
 www.bpsalarms.com

**INVOICE**

Date 7/25/23

Please Remit Payment By: 8/04/23



Tear Off This Top Stub And Return With Payment

Page 1

Leonia Board Of Education
 Attn: Kevin Woods
 500 Broad Avenue
 Leonia, NJ 07605
 Tel: 201-461-7441 Fax:

Leonia BoE - High School
 Leonia High School
 100 Christie Street
 Leonia, NJ 07605

Account No	Invoice No	P.O Number	Sales Person	Please Pay This Amount
1491	P 53477	24-0001279		805.00

Qty	Part Number	Part Description	Price Each	Tax	Amount
		Date of Service 7/18/2023; Customer requested service for the Duct Smoke Detector on RTU-11. Technicians found a dirty detector which was out of sensitivity range and replaced the detector. System was returned to normal condition.			
2.00	LABOR-2Tech	Labor For 2 Technicians	330.00	N	660.00
	System Sensor 2D51	Conventional Duct Smoke Detector Sensor		Y	145.00

PLEASE KEEP US IN MIND FOR:**Fire Alarm Systems****Burglar Alarm Systems****CCTV Camera Systems****Access Control / Electronic Locks****UL Listed Central Station Monitoring*****Please write Account # and Invoice # on check.**

Bergen Protective Systems, Inc. Account:1491 Invoice:P 53477

Total Charges	805.00
Sales Tax	0.00
Total Due	805.00