



509 Washington Avenue
Carlstadt, NJ 07072
Phone: (201) 635-0400 - Fax: (201) 635-0410

Invoice #: SM 34937

Invoice Date: 3/22/2021

Completion Date: 3/8/2021

Technician: Colonna;Max

Bill To: Leonia Board of Education
570 Grand Avenue
Attn: Accounts Payable
Leonia, NJ 07605

Service At: Leonia Middle School
500 Broad Avenue
Leonia, NJ 07605

Division: Sprinklers - Service/Repair
Description: S-Inspection Needed

PO Number:
Alt #:

Terms: 10 Days
Due Date: 4/1/2021

WO#	Item	Description	Qty	Unit Price	Amount
<u>42179</u>	Service				
		S - Annual Sprinkler System Inspection	1.00	450.00	450.00
		(1) wet sprinkler system			
		(2) backflow devices			

Note: Panel had pre-existing trouble upon arrival - would not reset. Dialer issue

The Fire Safety Professionals Since 1962

Subtotal:	450.00
Sales Tax:	0.00
Total Due:	450.00

Please return this part with a check or money order made payable to Metro Fire & Safety.



509 Washington Avenue
Carlstadt, NJ 07072
Phone: (201) 635-0400 - Fax: (201) 635-0410

Credit Card Information

Card Number: _____

Expiration: _____ / _____

mm / yy

CVV: _____



E-mail: _____

(If Receipt is Required/Requested)

Account ID	LEOBOA	Amount Due	\$ 450.00
Invoice	34937	Amount Paid	

* 3% Credit Card Processing Fee Will Apply



509 Washington Avenue
Carlstadt, NJ 07072

Phone: (201) 635-0400 - Fax: (201) 635-0410

WORK ORDER #

42179

SERVICE ID:

LEONIABOE-MIDDLE

Leonia Middle School
500 Broad Avenue
Leonia, NJ 07605

AR ID:

LEOBOA

Leonia Board of Education
570 Grand Avenue
Attn: Accounts Payable
Leonia, NJ 07605

CONTACT: (201) 424-2847 Kevin
ALT CONTACT:

TERMS: 10 Days
PO #:

DIVISION: Sprinklers - Service/Repair
CALL TYPE: PM's
PROBLEM: S-Inspection Needed
COMMENTS: Annual Fire Sprinkler Inspection

BILLABLE LABOR:

2 Men Hours

LEAD TECHNICIAN: M.C
HELPER / RETURN: J.S
DATE COMPLETED: 03-08-21

MEMO: Woods@leoniaschools.org

SPECIAL NOTES:

EQUIPMENT:

Reliable 4" MODEL G WET Sprinkler Located in boiler/gas meter room

(2) back flows

PARTS

QTY

☒ All Control Valves Left in Wide Open Position

☒ Left System in Service

☐ Customer to Provide Fire Watch

Comments:

went over delaware's with
customer & RG

PAVEL had pre-existing trouble upon arrival
would not reset. Dialer trouble.
& RG

AMOUNT

Service	450.00
Discount	
Parts	
DOT/Hazmat	
3% Credit Card Fee	
Sub Total	450
Sales Tax	
TOTAL	450

By signing I agree to the information and description of services as explained above as well as the General Terms and Conditions that are available on our website www.metrofire.com. A hard copy will be furnished upon request.

Signature:

Name:

KALPHEN
KALPH

The Fire Safety Professionals Since 1962

NJ State Certified Contractor #: P00111

DOT Registration #: A-400



509 Washington Avenue
Carlstadt, NJ 07072

Property:

Leonia Middle School
500 Broad Avenue
Leonia, NJ 07605

Dear Sir or Madam:

Metro Fire & Safety has been authorized to perform the Sprinkler Inspection at the above listed location. The inspection will be in accordance with NFPA 25, 2014 edition.

Our inspection is made of the system as it exists on the date of the inspection. We assume, unless otherwise informed in writing prior to our inspection, that the sprinkler system has been properly maintained by the owner, or any other authorized personnel, as required by law before our inspection occurs. The Owner agrees to indemnify, defend and hold harmless Metro Fire & Safety from any damages or injuries to persons or property occurring during our inspection resulting from deficiencies in the system which were in existence at the time of our inspection, and from any costs incurred as a result of such damages or injuries.

Please note that our inspection is not an engineering evaluation of the system. If you request an engineering evaluation to ensure that the system is designed to adequately protect its occupancy, please contact our office.

RALPH
Owner/Representative's Signature

03-08-21
Date