



Invoice 152068444

adtcommercial.com

Account Number	Invoice Date	Payment Due Date	PO Number	Amount Due
949236004	09/11/2023	10/11/2023	24-00779	\$3,209.00

Take action now with eSuite

See reverse side for details.

Payment Options

Pay online 24/7

esuite.adt.com/ExpressPay

Pay by phone

1.800.606.3535

Mail by check

Include the section below

Manage Your Account

Update billing information, view past invoices and more
esuite.adt.com

Questions?

adtcommercial.com

Email: ComCare@adt.com
1.855.238.2666



Description

Qty

Unit Price

Amount

OAKLAND BOE - HEIGHTS SCHOOL 114 SEMINOLE AVENUE

Job# 282099113

Labor Charge	1	\$2,320.00	\$2,320.00
--------------	---	------------	------------

12V 7AH BATTERY	2	\$27.00	\$54.00
-----------------	---	---------	---------

FLTRD/REGULATED PWR SUPPLY/CHA	1	\$835.00	\$835.00
--------------------------------	---	----------	----------

Sub Total

\$3,209.00

INVOICE AMOUNT DUE

\$3,209.00

Oakland Board of Ed

Business Office
(S.W.)

[Handwritten Signature]
10-11-23



Thank you for choosing ADT Commercial

You will be charged a \$25.00 fee for any payment returned.

Make checks payable to ADT Commercial and please include your account number.

Log in or register for eSuite to manage most account and service needs without picking up the phone.

eSuiteSM provides immediate, user-friendly access to your ADT Commercial systems and services

Gain real-time, actionable insight into your organization and take control of your account management—all from your browser or mobile device.

Save time by logging in to eSuite to manage a variety of system-based and administrative functions, including:

- ✓ Place your system on test
- ✓ View, export, or email test and alarm event history
- ✓ Submit a service request
- ✓ Pay invoices and update billing info
- ✓ Review technician service notes

With eSuite, you also have the ability to*:

- ✓ Arm and disarm your system remotely†
- ✓ View and update system schedules
- ✓ Manage service and installations in real-time
- ✓ Manage contact lists and keypad codes



Scan this QR code with your phone's camera to log in or register, or visit esuite.adt.com

Quickly and easily manage your contact list with eSuite



Contacts are authorized employees who will be notified in the event of an alarm or have an elevated level of permission at your location. Use authority level permissions to designate the type of account access each contact should be assigned.

eSuite allows you to perform routine tasks like adding and removing contacts or changing the order of your contact notify list—all without placing a phone call!

ADT Commercial

*Some services may require additional charges. †Feature available only with compatible systems.

© 2022 ADT Commercial LLC. All rights reserved. The product/service names listed in this document are marks and/or registered marks of their respective owners and used under license. Unauthorized use strictly prohibited. License information available at www.adt.com/commercial/licenses.

Payment Options: ADT Commercial may convert your payments by check to an electronic Automated Clearinghouse (ACH) debit transaction. The debit transaction will appear on your bank statement, although your check will not be presented to your financial institution or returned to you. This ACH debit transaction will not enroll you in any ADT Commercial automatic debit process and will only occur each time a check is received.



Service Work Order

Job # 282099113

Customer OAKLAND PUBLIC SCHOOLS
Site OAKLAND BOE - HEIGHTS SCHOOL
CS#
Address 114 SEMINOLE AVENUE

Customer# 949236004
Site# 949043392

OAKLAND, NJ 07436-

Site Phone 973 390-7433

Requested By

Service Plan D635F-T&M D635 - Fire/Gen Bank

Warranty Status Parts and Labor

System Type SUN2-FIRE_SYSTEM

Panel Location

Job Request

Commitment 09/01/2023 73:00-73:00

Phone

SALESAGREEMENTID:891693967 SYSTEMDESIGNID:891841385 RETROFIT/ADD-ON/UPGRADE; QUOTED WORK ORDER; FIRE ALARM: AD HOC -

Comment

Job integration is completed

Internal Scope Of Work: Shall install power booster and rewire NAC circuits to sync A/V units Please send back

Abraham 2 men 1 day****Score Lead from Abraham Regis**** contact Joe

Kumminia973-390-7433Tumminia@oaklandschoolsnj.org

install power booster and rewire NAC circuits to sync A/V units Please send back Abraham 2 men 1 day ****Score Lead from Abraham Regis**** contact Joe Kumminia 973-390-7433 PICK UP IN EDSION

{1 of 4} Mounted Wheelock Booster Panel next to FACP. Used Conduit for AC Voltage run and another for Horn Strobe Circuits. Ran AC Voltage wire from FACP to Booster and connected. Ran 4 14/2 Wires from Horn Strobe Circuits to booster and connected. Ran 1

{2 of 4} 14/2 wire from FACP NAC 1 to Booster panel input 1 and connected. Traced out all End of Line Resistors and replaced with 10K Resistors to satisfy Wheelock Outputs. Put 15K Resistors in NACs 2 3 and 4 on FACP. Put 15K Resistor on Trouble

{3 of 4} contacts of Wheelock Booster and Wired so troubles from booster are sent to FACP. Installed Batteries on Wheelock Booster and all troubles cleared from panel. Tested Horn Strobes on Sync and on Temporal but the Strobes will not Synchronize.

{4 of 4} Called Wheelock Tech Support and found that the Horn Strobes that are in the Building are from before the days of Synchronizing and do not have the capability to do so. The Horn Strobes on the building will need to be replaced.

System Instructions

Service Company Instructions

Site Instructions