



JOHNSON CONTROLS
Building Efficiency
Federal ID 39-0380010

ORIGINAL INVOICE

Invoice #:	1-136250804389	Invoice Date:	08/12/2025
PO #/Auth:	P202600205	Service Request:	1-136211484165
Customer WO#:		SR Type:	L&M
Customer Acct:	1887822	Branch Name:	JOHNSON CONTROLS UNION NJ CB - 0N35

Bill To:
BETHLEHEM TOWNSHIP BOARD OF EDUCATION
280 ASBURY WEST PORTAL ROAD
ABURY NJ 08802

Service Site:
BETHLEHEM TOWNSHIP SCHOOL
DISTRICT
940 IRON BRIDGE RD ,
ASBURY NJ 08802-1135

Contractor/License Information :

Requested By: Stewart (Stu) Schendel

Phone:

Proposal : 25A-0801 Thomas Conley
Network Troubleshooting
Proposal Date: 08/01/2025
Accepted By: Stewart (Stu) Schendel

Service Requested: Johnson Controls will provide 8 hours of Technician labor to troubleshoot N2 bus network
(Work Scope) issues at Thomas Conley School. Overtime labor and materials not included in this quote.

Service Provided: Scheduled Repair Visit Metasys
Checked in and out with Facilities Department for JCI daily work assignments.
Thomas Conley School
Troubleshoot N2 communication network with electrical multi meter due to several controllers being offline. Located N2 communication network issue between Classrooms 143 and 141, corrected wiring. All controllers except Classroom 142 communicating normally, this unit turned off due to unit mechanical issues.
Room 141 - AirDale unit turned off at disconnect. Reconnected all unit wiring, checked online status of FEC controller. Unit has issues with mechanical cooling which is not operational. Unit providing ventilation to classroom.
Room 143 - Troubleshoot AirDale unit freezestat alarm with electrical multimeter. Located faulty low temperature control, replaced device from customer stock inventory. Reset high pressure switch on refrigeration circuit. Troubleshoot unreliable Zone Temperature sensor, reseated connectors at UNT and AirDale unit locations, temperature now reading reliable, accurate information. Checked and verified unit operation , returned to normal service.
Room 136 - Reset high pressure switch on refrigeration circuit. Check and verified operation of cooling. Operating as expected.
Complete
Thank you for your business.

Total Quote Price		\$3,669.82	
Sales Tax		\$0.00	
Total Amount Due		USD	\$3,669.82

Direct Billing Inquiries: (866) 589-8652

Terms: Unless otherwise agreed in the contract between Johnson Controls and Customer, payment shall be due full upon receipt, and interest shall be due at a rate of 1.5% per month (18% annually) on invoices not timely paid along with any other recoverable costs of collection.

Disposable, Environmental & Usage (DEU) fee listed on this invoice may include charges for one or more of the following miscellaneous: Electrical,



JOHNSON CONTROLS
Building Efficiency
Federal ID 39-0380010

ORIGINAL INVOICE

Invoice #:	1-136250804389	Invoice Date:	08/12/2025
PO #/Auth:	P202600205	Service Request:	1-136211484165
Customer WO#:		SR Type:	L&M
Customer Acct:	1887822	Branch Name:	JOHNSON CONTROLS UNION NJ CB - 0N35

pneumatic, welding supplies, hardware materials, cleaning supplies, or refrigerant reclaim disposal. A lump sum charge was applied rather than itemizing usage.

We hereby certify that these goods are produced in compliance with all applicable requirements of sections 6, 7 and 12 of the Fair Labor Standards Act of 1938, as amended, and of regulations and orders of the Administrator of the Wage and Hour Division issued under section 14 thereof.

Please reference our Invoice Number and amount with your payment and send ONLY to the address on this invoice.

Payment Terms: NET 30
Direct Billing Inquiries: (866) 589-8652

To Remit Via Credit Card:

Due to increasing credit card processing costs, we impose a surcharge* on the total transaction amount on credit card transactions of 2.6%, which is not greater than our credit card processing fee. We do not surcharge debit cards.

*Due to statutory restrictions, we do not impose a surcharge on customers located in Connecticut, Maine, Massachusetts, New York or Colorado.

Remit Payment To:

JOHNSON CONTROLS
PO BOX 730068
DALLAS, TX, 75373-0068

To Remit Via ACH Wire Transfers:

JP Morgan Chase
One Chase Manhattan Plaza
New York, NY 10005
Credit to: Johnson Controls Inc.
ABA# 071-000013 Depositor Acct #55-14347
Type of Account: Checking
co-cashappusa@jci.com

INVOICE#: 1-136250804389
AMOUNT DUE: USD \$3,669.82