



517 GREEN GROVE ROAD
PO BOX 607
NEPTUNE, NEW JERSEY 07754
P: 732.922.3399 | F: 732.918.8668
ALLIEDFIRESAFETY.COM



Work Order
#155052

Service Location		AR Customer	
Service Location:	Borough of Mantoloking	Customer:	MANBOR - Borough of Mantoloking
Address:	202 Downer Avenue	Address	340 Drum Point Road, 2nd Floor
City, State, Zip:	Mantoloking NJ 087380247	City, State, Zip	Brick NJ 08723
Contact:	Scott Hulse	Main Phone:	(732)899-9643
Contact Phone:	(732)899-6600	Payment Terms:	Terms

Work Order Details	
Call Type:	PM's
Problem Type:	E-Extinguisher Inspection Needed
Job Status:	Completed
Date Scheduled:	6/23/2022
WO # / FCO #:	155052
Alt WO#:	
Customer PO #:	
Technician:	Fedorczyk,Joshua

Description of Service
Annual Fire Extinguisher Insp

Work Order Comments
Date: 6/16/2022, Entered By: Fedorczyk,Joshua, Subject: Fire Extinguisher Inspection Fire Extinguisher Inspection Completed as per NFPA 10 and the State of New Jersey Uniform Fire Code.
Date: 6/21/2022, Entered By: EXT SHOP, Subject: Non COMPLIANT 10LB CO2 Non Complaint with UL711
Date: 6/23/2022, Entered By: Fedorczyk,Joshua, Subject: Form Attachment

Work Order Items		
Date	Description	Qty
6/16/2022	E - Fire Extinguisher Service Call	1.00
6/16/2022	E - Fire Extinguisher Inspection	35.00
6/16/2022	E - 10# ABC Dry Chem Recharge	1.00
6/16/2022	E - 2.5 Gal Water Recharge	1.00
6/16/2022	E - 5# ABC Dry Chem 6 Year Tear Down	1.00
6/16/2022	E - 5# ABC Dry Chem Recharge	1.00
6/16/2022	E - 5# CO2 Hydro/Recharge	1.00
6/16/2022	E - 5# PK Dry Chem Hydro/Recharge	1.00
6/16/2022	E - CO2 Continuity Test	4.00
6/21/2022	E - Dry Chem Valve Rebuilt	4.00
6/21/2022	E - Dry Chem Valve Stem	4.00
6/21/2022	E - Dry Chem O-Ring	4.00
6/21/2022	E - Water Valve Rebuilt	1.00
6/21/2022	E - Water Valve Stem	1.00
6/21/2022	E - Water O-Ring	1.00
6/21/2022	E - CO2 O-Ring	1.00

Parts Items		
Date	Description	Qty

By signing I agree to the information and description of services as explained above as well as the General Terms and Conditions that are available on our website at <https://www.alliedfiresafety.com/Site/ServiceTerms>. A hard copy will be furnished upon request.

Customer Signature					
Signature		Signed By	Scott Hulse	Date	6/23/2022

NJ FIRE PERMIT # P00166 - DOT REGISTRATION # A010 - NJ ELECTRICAL LICENSE # 11327 - NJ CERTIFIED SBE



517 GREEN GROVE ROAD
PO BOX 607
NEPTUNE, NEW JERSEY 07754
P: 732.922.3399 | F: 732.918.8668
ALLIEDFIRESAFETY.COM




Fire Extinguisher Inspection

Tech:	Fedorczyk,Joshua	Customer Id:	MANBOR
Service Site:	Borough of Mantoloking		
Address:	202 Downer Avenue Mantoloking, NJ 087380247		
Date:	6/16/2022	Work Order:	155052

FIRE EXTINGUISHER LOCATION SHEET									
TYPE	MFG	MFG YEAR	LOCATION	SERVICE			ADDITIONAL / NOTES		
Select Number of Extinguishers >> 41									
5# ABC	Kidde	2017	PD	☒ Inspection	☐ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New 6yr2023
5# ABC	Kidde	2013	PD	☐ Inspection	☐ Recharge	☒ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New Hydro2025
10# ABC	Amerex	2018	PD	☒ Inspection	☐ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New 6yr2024
10# ABC	Amerex	2018	PD	☒ Inspection	☐ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New 6yr2024
10# ABC	Amerex	2015	PD	☒ Inspection	☐ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New Hydro2027
5# CO2	Amerex	2001	PD	☐ Inspection	☐ Recharge	☐ 6 Year Maint.	☒ Hydrotest	☐ Non-Compliant	☐ New Hydro2027
5# ABC	Kidde	2017	PD	☒ Inspection	☐ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New 6yr2023
10# CO2	Kidde	1979	DPW	☒ Inspection	☐ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New Hydro2025
2½# ABC	Kidde	2017	DPW	☒ Inspection	☐ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New 6yr2023
5# ABC	Kidde	2006	DPW	☒ Inspection	☐ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New 6yr2024
10# ABC	Badger	2008	DPW	☒ Inspection	☐ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New 6yr2027
10# ABC	Badger	2008	DPW	☒ Inspection	☐ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New 6yr2027
5# ABC	Kidde	2004	DPW	☐ Inspection	☒ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New Leaker
15# CO2	Kidde	1995	DPW	☒ Inspection	☐ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New Hydro2025
10# ABC	Amerex	1990	DPW	☒ Inspection	☐ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New Hydro2027
10# ABC	Amerex	2000	DPW	☒ Inspection	☐ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New Hydro2026
2½ Gal Water	Ansul	2010	FD	☒ Inspection	☐ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New Hydro2025
20# ABC	Amerex	2011	FD	☒ Inspection	☐ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New 6yr2023
15# CO2	Badger	2010	FD	☒ Inspection	☐ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New Hydro2026
6L Wet Chemical	Amerex	2016	FD	☒ Inspection	☐ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New Hydro2026
10# ABC	Amerex	2018	FD	☐ Inspection	☒ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New 6yr2024
2½ Gal Water	Amerex	2015	FD	☒ Inspection	☐ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New Hydro2025
5# BC	Amerex	2006	FD	☒ Inspection	☐ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New 6yr2026
5# CO2	Amerex	2007	FD	☒ Inspection	☐ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New Hydro2025
10# CO2	Kidde	1979	FD	☐ Inspection	☐ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☒ Non-Compliant	☐ New Non compliant with UL711
20# ABC	Kidde	1996	FD	☒ Inspection	☐ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New 6yr2026
20# ABC	Buckeye	1996	FD	☒ Inspection	☐ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New 6yr2026
10# ABC	Amerex	2018	DPW	☒ Inspection	☐ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New 6yr2024
10# ABC	Amerex	2015	Town Hall	☒ Inspection	☐ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New Hydro2027
10# ABC	Amerex	2015	Town Hall	☒ Inspection	☐ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New Hydro2027
10# ABC	Amerex	1990	Town Hall	☒ Inspection	☐ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New Hydro2027
10# ABC	Amerex	2014	Town Hall	☒ Inspection	☐ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New Hydro2026
10# ABC	Amerex	2018	Town Hall	☒ Inspection	☐ Recharge	☐ 6 Year Maint.	☐ Hydrotest	☐ Non-Compliant	☐ New 6yr2024

FIRE EXTINGUISHER SERVICE SUMMARY																				
	2½ Gal PW	2½# ABC	5# ABC	6# ABC	10# ABC	20# ABC	6L WC	5# CO2	10# CO2	15# CO2	20# CO2	5# Halotron	11# Halotron	5# BC	6# BC	10# BC	20# BC	Other	Totals	
Inspection	2	1	5	0	17	3	1	1	1	2	0	0	0	1	0	0	0	0	34	
Recharge	1	0	1	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	3	
6-Year Maint.	0	0	1	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	1	
Hydrotest	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	1	2	
New	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	
Non-Compliant	0	0	0	0	0	0	0	0	1	0	0	0	0	0	0	0	0	0	1	
CO2 Conductivity									2	2	0									4

INSPECTOR'S INFORMATION	
I state that the information on this form is correct at the time and place of my inspection, and that all equipment tested at this time was left in operating condition upon completion of this inspection except as noted above.	
Inspector Name:	Josh Fedorczyk
Inspector Signature:	
Date:	6/16/22