



INVOICE

Absolute Protective Systems

51 Suttons Lane
Piscataway NJ 08854
(732) 287-4500
apsar@sciensbuildingsolutions.com

Invoice No: 25171**Date:** 1/22/2026**Customer #:** OCLIBRS001**Bill To:**

Ocean County Library
101 Washington Street

Toms River, NJ 08753
Joe Cahill

Job No: D032779**Project:** Lakewood Library**PO No:****Requested by:** Joe Cahill**Date Completed** 1/19/2026**Site Address:**

Lakewood Library
301 Lexington Avenue
Lakewood, NJ 08701

Description	Quantity	Rate	Amount
Ground fault trouble on fire alarm system. Need Service. Authorized by Matt Nolan.	14.75	165.00	2,433.75

Locked in ground fault to prevent run away signals. We will return

Note: completed service call to troubleshoot facp. Upon arrival found facp in trouble reading ground fault started troubleshooting SLC to locate ground. Broke loop in multiple locations to locate found ground between rear office and front office. Ran 30ft of new 18/2 fire wire above drop ceiling to reconnected ckt removed damaged wire. Reconnected all wiring system restored to normal. Tested new phone system is not allowing me to dial out. Spoke with tech support, they will contact me to see whats happening made Matt aware of issues..all systems normal upon completion..

Remit to/AR questions email address: apsar@sciensbuildingsolutions.com

Send Checks Payments to:

Absolute Protective Systems, Inc.
51 Suttons Lane Piscataway, NJ 08854

For ACH Payments:

Bank Name: JP Morgan Chase

Routing #: 322271627

Account #: 772916885

Account Name: ABSOLUTE PROTECTIVE SYSTEMS, INC.

Thank You For Your Business!**Payment Due Upon Receipt.****Credit Card Payments please add 3%****Tax Amount:** 0.00**Invoice Amount:** 2,433.75**Total Amount Due:** 2,433.75



A DIVISION OF:

sciens
Building Solutions**INVOICE****Absolute Protective Systems**

51 Suttons Lane
Piscataway NJ 08854
(732) 287-4500
apsar@sciensbuildingsolutions.com

Invoice No: 26031

Date: 3/9/2026

Customer #: OCLIBRS001

Bill To:

Ocean County Library
101 Washington Street

Toms River, NJ 08753
Joe Cahill

Job No: D033579

Project: Long Beach Island Library

PO No:

Requested by: Joe Cahill

Date Completed 3/3/2026

Site Address:

Long Beach Island Library
217 South Central Avenue
Surf City, NJ 08008

Description	Quantity	Rate	Amount
Work as per proposal# 4600048.	1.00	7,060.00	7,060.00

1. We have included furnishing and installing (1) new Vista-20P control panel.
2. We have included furnishing and installing (1) new 6160C keypads.
3. We have included furnishing and installing (4) new IS3035V motion detectors.
4. We have included testing after installing.

3/2/2026 - Completed removal of old burg system. Installed and programmed new system. Entered user defined codes. Tested arming and disarming with all codes. Tested all points and confirmed all signals with OCPD. Used two keypads instead of one. All systems normal at time of departure. Justin G Corey W

Remit to/AR questions email address: apsar@sciensbuildingsolutions.com

Send Checks Payments to:

Absolute Protective Systems, Inc.
51 Suttons Lane Piscataway, NJ 08854

For ACH Payments:

Bank Name: JP Morgan Chase

Routing #: 322271627

Account #: 772916885

Account Name: ABSOLUTE PROTECTIVE SYSTEMS, INC.

Thank You For Your Business!

Payment Due Upon Receipt.

Credit Card Payments please add 3%

Tax Amount: 0.00

Invoice Amount: 7,060.00

Total Amount Due: 7,060.00



A DIVISION OF:

sciens
Building Solutions**INVOICE****Absolute Protective Systems**

51 Suttons Lane
Piscataway NJ 08854
(732) 287-4500
apsar@sciensbuildingsolutions.com

Invoice No: 26276
Date: 3/16/2026
Customer #: OCLIBRS001

Bill To:
Ocean County Library
101 Washington Street

Toms River, NJ 08753
Joe Cahill

Job No: D034446
Project: Jackson Library
PO No:
Requested by: Joe Cahill
Date Completed: 3/9/2026

Site Address:
Jackson Library
2 Jackson Drive
Jackson, NJ 08527

Description	Quantity	Rate	Amount
Check out burglar alarm system. Keypad not working. Authorized by Matt	6.80	165.00	1,122.00

Note: Completed service call to troubleshoot burglarly system. Upon arrival found system working correctly spoke with library manager and showed them how to use system to confirm working correctly also troubleshoot communication to Phoenix system. System not communicating at this time. Will need two Ademco monitor modules for fire and trouble and system needs to be programmed into phoenix system office made aware.

Remit to/AR questions email address: apsar@sciensbuildingsolutions.com

Send Checks Payments to:

Absolute Protective Systems, Inc.
51 Suttons Lane Piscataway, NJ 08854

For ACH Payments:

Bank Name: JP Morgan Chase
Routing #: 322271627
Account #: 772916885

Account Name: ABSOLUTE PROTECTIVE SYSTEMS, INC.

Thank You For Your Business!

Payment Due Upon Receipt.

Credit Card Payments please add 3%

Tax Amount: 0.00
Invoice Amount: 1,122.00

Total Amount Due: 1,122.00



A DIVISION OF:

sciens
Building Solutions

INVOICE

Absolute Protective Systems

51 Suttons Lane
Piscataway NJ 08854
(732) 287-4500
apsar@sciensbuildingsolutions.com

Invoice No: 26549
Date: 3/24/2026
Customer #: OCLIBRS001

Bill To:
Ocean County Library
101 Washington Street

Toms River, NJ 08753
Joe Cahill

Site Address:
Jackson Library
2 Jackson Drive
Jackson, NJ 08527

Job No: D034455
Project: Jackson Library
PO No:
Requested by: Joe Cahill
Date Completed 3/16/2026

Description	Quantity	Rate	Amount
Connect fire alarm relays to Ademco panel inputs for communication, alarm and Trouble. (Vplex 4193sn) (Note: Completed service call to install 2 new monitor modules for ademco system to monitor fire alarm and fire trouble. Upon arrival found facp and burgaly panel normal. Note; cleaned up wiring in burgaly panel, install 2 new modules inside ademco panel for fire alarm and fire trouble. Reprogrammed ademco panel to communicate with phoenix system at 911, also had to program phoenix system with other tech to see all new zones, also needed to change keypad addresses.	5.00	165.00	825.00
Parts used 2 new Ademco 4193sn modules). Transfer from Radionics panel to Ademco panel for communication to 911 Center.			
Note: Completed service call to install 2 new monitor modules for ademco system to monitor fire alarm and fire trouble. Upon arrival found facp and burgaly panel normal. Note; cleaned up wiring in burgaly panel, install 2 new modules inside ademco panel for fire alarm and fire trouble. Reprogrammed ademco panel to communicate with phoenix system at 911, also had to program phoenix system with other tech to see all new zones, also needed to change keypad addresses.			
Parts used 2 new Ademco 4193sn modules			



A DIVISION OF:

sciens
Building Solutions**INVOICE****Absolute Protective Systems**

51 Suttons Lane
Piscataway NJ 08854
(732) 287-4500
apsar@sciensbuildingsolutions.com

Invoice No: 26549
Date: 3/24/2026
Customer #: OCLIBRS001

Bill To:

Ocean County Library
101 Washington Street

Toms River, NJ 08753
Joe Cahill

Job No: D034455**Project:** Jackson Library**PO No:****Requested by:** Joe Cahill**Date Completed** 3/16/2026**Site Address:**

Jackson Library
2 Jackson Drive
Jackson, NJ 08527

Description	Quantity	Rate	Amount
Ademco Vplex-4193SN modules \$35.58+10%= \$39.58	2.00	39.58	79.16

Remit to/AR questions email address: apsar@sciensbuildingsolutions.com

Send Checks Payments to:

Absolute Protective Systems, Inc.
51 Suttons Lane Piscataway, NJ 08854

For ACH Payments:

Bank Name: JP Morgan Chase
Routing #: 322271627
Account #: 772916885

Account Name: ABSOLUTE PROTECTIVE SYSTEMS, INC.**Thank You For Your Business!****Payment Due Upon Receipt.****Credit Card Payments please add 3%**

Tax Amount: 0.00
Invoice Amount: 904.16

Total Amount Due: 904.16



A DIVISION OF:

sciens
Building Solutions**INVOICE****Absolute Protective Systems**

51 Suttons Lane
Piscataway NJ 08854
(732) 287-4500
apsar@sciensbuildingsolutions.com

Invoice No: 26549

Date: 3/24/2026

Customer #: OCLIBRS001

Bill To:

Ocean County Library
101 Washington Street

Toms River, NJ 08753
Joe Cahill

Site Address:

Jackson Library
2 Jackson Drive
Jackson, NJ 08527

Job No: D034455

Project: Jackson Library

PO No:

Requested by: Joe Cahill

Date Completed 3/16/2026

Description	Quantity	Rate	Amount
Ademco Vplex-4193SN modules \$35.58+10%= \$39.58	2.00	39.58	79.16

Remit to/AR questions email address:

apsar@sciensbuildingsolutions.com

Send Checks Payments to:

Absolute Protective Systems, Inc.
51 Suttons Lane Piscataway, NJ 08854

For ACH Payments:

Bank Name: JP Morgan Chase
Routing #: 322271627
Account #: 772916885

Account Name: ABSOLUTE PROTECTIVE SYSTEMS, INC.

Thank You For Your Business!

Payment Due Upon Receipt.

Credit Card Payments please add 3%

Tax Amount: 0.00

Invoice Amount: 904.16

Total Amount Due: 904.16



A DIVISION OF:

sciens
Building Solutions**INVOICE****Absolute Protective Systems**

51 Suttons Lane
Piscataway NJ 08854
(732) 287-4500
apsar@sciensbuildingsolutions.com

Invoice No: 26549

Date: 3/24/2026

Customer #: OCLIBRS001

Bill To:

Ocean County Library
101 Washington Street

Toms River, NJ 08753
Joe Cahill

Job No: D034455

Project: Jackson Library

PO No:

Requested by: Joe Cahill

Date Completed 3/16/2026

Site Address:

Jackson Library
2 Jackson Drive
Jackson, NJ 08527

Description	Quantity	Rate	Amount
Connect fire alarm relays to Ademco panel inputs for communication, alarm and Trouble. (Vplex 4193sn) (Note: Completed service call to install 2 new monitor modules for ademco system to monitor fire alarm and fire trouble. Upon arrival found facp and burgaly panel normal. Note; cleaned up wiring in burgaly panel, install 2 new modules inside ademco panel for fire alarm and fire trouble. Reprogrammed ademco panel to communicate with phoenix system at 911, also had to program phoenix system with other tech to see all new zones, also needed to change keypad addresses.	5.00	165.00	825.00

Parts used 2 new Ademco 4193sn modules). Transfer from Radionics panel to Ademco panel for communication to 911 Center.

Note: Completed service call to install 2 new monitor modules for ademco system to monitor fire alarm and fire trouble. Upon arrival found facp and burgaly panel normal. Note; cleaned up wiring in burgaly panel, install 2 new modules inside ademco panel for fire alarm and fire trouble. Reprogrammed ademco panel to communicate with phoenix system at 911, also had to program phoenix system with other tech to see all new zones, also needed to change keypad addresses.

Parts used 2 new Ademco 4193sn modules