

Encore Fire Protection
P.O. Box 25811
New York, NY 10087-5811
(800) 966-0000



Bill To
CAPE MAY WEST SCHOOL
301 Moore St
West Cape May, NJ 08204-1129

<https://www.encorefireprotection.com/>
servicelocation8@encorefireprotection.com

Invoice No.	13338521	Service Location	WEST CAPE MAY ELEMENTARY SCHOOL
Customer PO No.	26000131		301 MOORE ST
Invoice For	Inspection Job #44101712 (02/05/2026)		WEST CAPE MAY, NJ 00000
Transaction Date	2/9/2026		
Due Date	3/11/2026 (Net 30)		

Item	Svc	Qty	Unit Price	Amt
Full Functional Fire Alarm Inspection	AL	1	\$1,150.00	\$1,150.00
			GRAND TOTAL	\$1,150.00

Additional Customer Information

Sage Timberline ID # CMW112

Notes

HONEYWELL FIRELITE MS-10UD ELECTRICAL / HVAC / FACP ROOM D8-1086: Full Functional Fire Alarm Test and Inspection

Technicians: Thomas MacNeir

Tech's comments: System placed on test D8-1086. Initiating devices tested. Notification devices tested. Batteries tested. Test signals verified. Device listing updated. Report completed. System put back online.

No deficiencies noted.

Please note: Inspection report is attached under "Service Details" link.

Terms & Conditions

For the easiest way to pay, visit <https://www.termsync.com/>.

We'd love your feedback! Please take our short survey - <https://encorefireprotection.com/csat-survey> - and let us know about your recent experience with us. Thank you!