

ALL INVOICES AND
CORRESPONDENCE MUST BE SENT
TO ABOVE ADDRESS REGARDLESS
OF SHIPPING POINT

WOODBINE BOARD OF EDUCATION
BUSINESS OFFICE
1076 Almond Road
Pittsgrove, NJ 08318
856-358-3094 ext. 4023

PURCHASE ORDER NO. **200097**

PO# AND ORDERED BY
NAME MUST APPEAR ON
ALL LABELS, CARTONS &
INVOICES

Page 1 of 1

Copy 4

Ship to

WOODBINE ELEMENTARY
801 Webster Street
Woodbine, NJ 08270

To

GENRON FIRE PROTECTION
P.O. BOX 556
SOUTH SEAVILLE, NJ 08246

1278

Account Code

Amount

11-000-262-420-050-0

511.80

Date: 08/24/21 Dept: acctpay

Notice: The purchaser is exempt by statute from paying all Federal, State
and Municipal Excise Sales & other taxes

Qty	Unit	Description	Unit Price	Amount
1.		fire extinguisher inspection and cert	511.800	511.80

Total for Lines **\$511.80**

NOTICE TO VENDOR OR CONTRACTOR

1. Order invalid unless signed by the Secretary of the Board of Education
2. Shipping statement must accompany delivery of materials
3. Voucher provided by the Board of Education must be forwarded to the secretary to process payment
4. Please submit invoice as soon as order is completed
5. Must have NJ Reg. on file with us in order to receive payment

SCHOOL OFFICE USE ONLY

I certify that the goods or services itemized have been received



Signature

9/9/2021

Title

Date

NO ORDER VALID UNLESS SIGNED BY THE SECRETARY



SECRETARY, BOARD OF EDUCATION

RECEIVING COPY

**GENRON Fire**

PO Box 556
South Seaville, NJ 08246
609-624-3000

PLEASE REMIT TO:
GENRON INC.
P.O. Box 556
South Seaville NJ 08246

Invoice

DATE	INVOICE
8/16/2021	43778

BILL TO:

Woodbine Board of Education
801 Webster Street
Woodbine, NJ 08270

WORK LOCATION:

Woodbine Board of Education
801 Webster Street
Woodbine, NJ 08270

P.O.	TERMS	DUE	TECH	PHONE	SER DATE	TYPE	SYSTEM	H/T DATE
	Due o...	8/16/2021	5	609-861-5174	7-28-2021	S/A		
ITEM	QTY	DESCRIPTION				RATE	AMOUNT	
CS10ABC	7	Certification of 10lb ABC Fire Extinguishers per NFPA 10.6.1				6.25	43.75	
CS20ABC	1	Check and Service 20lb ABC Fire Extinguisher per NFPA 10.6.1				6.25	6.25	
CS5ABC	18	Certification of 5lb ABC fire extinguishers per NFPA 10.6.1				6.25	112.50	
CS5FE36	1	Certification of 5lb. FE-36 fire extinguisher per NFPA 10.6.1				6.25	6.25	
CS6LITER	1	Certification of 6 Liter Wet Chemical per NFPA 10.6.1				6.25	6.25	
ABC5	2	5lb ABC Recharge and Certification				27.00	54.00	
ABC10	2	10lb ABC Recharge and Certification				29.90	59.80	
FIELD	1	Field Extinguisher Service				78.00	78.00	
FIRESYS	1	Inspection, Certification and Service Fire Suppression System Pursuant to NFPA 17A Para 7.3.2				125.00	125.00	
360FS	2	360 Degree Heat Link for Fire System				10.00	20.00	
REPORT	1	System report provided with invoice. (NO CHARGE)				0.00	0.00	

Total \$511.80

WOULD YOU LIKE TO PAY YOUR
INVOICE BY CREDIT CARD? PLEASE
CALL THE OFFICE AND WE WILL
PROCESS YOUR PAYMENT.

E-mail

ggburnell@genronfire.net

PLEASE NOTE
OUR NEW
REMITTANCE
ADDRESS

Making Morality

☒ System is Compliant with NJAC-5:70-3				☐ System is Non-Compliant										
Genron Fire Protection 1066 Route 83, Clermont, NJ 08210 Phone: 609-624-3000 Fax: 609-624-2999 NJ Contractor Permit # P00254 US DOT Requalifier Facility RIN G821				WORK ORDER NO 1782		DATE 7-28-21		HAZARD AREA PROTECTED DPA						
				SYSTEM MFG ANSUL		SYS CAPACITY 3		SYS TYPE 40		# OF CYLS 1				
CUSTOMER WOODBINE BOE				CONTACT Officer		PHONE 609 861-5174		FAX						
ADDRESS 801 WEBSTER ST				CITY WOODBINE		STATE AND ZIP CODE NJ								
AHJ/PROTECTION DISTRICT				INSPECTION TYPE		☐ INITIAL ☐ ANNUAL ☒ SEMI-ANNUAL								
INITIAL ACTIONS/OBSERVATIONS				Y	N	N/A	HAZARD INSPECTION			Y	N	N/A		
1	Last serviced by: GENRON						18	Hazard configuration appeared to remain unchanged?			☒	☐	☐	
2	Were building personnel notified of the inspection?			☒	☐	☐	19	Are all observable penetrations to the hood and duct sealed?			☒	☐	☐	
3	Was the monitoring company notified?			☐	☐	☒	20	No readily observable obstructions or interference that could impact effectiveness of the suppression system?			☒	☐	☐	
4	System found charged and functioning at the time of tech's arrival?			☒	☐	☐	SYSTEM FUNCTIONAL TEST			Y	N	N/A		
5	System un-tampered since last visit?			☒	☐	☐	21	System disarmed per manufacturer's recommendations?			☒	☐	☐	
6	System found to be at proper pressure upon arrival?			☒	☐	☐	22	Mechanical detection line tested and found to operate properly?			☒	☐	☐	
VISUALLY CHECK SYSTEM				Y	N	N/A	23	Proper number and placement of detectors/links?			☒	☐	☐	
7	Baffle-type filters installed in hood?			☒	☐	☐	24	Did the system operate properly from activation of a manual pull station?			☒	☐	☐	
8	System [and appliance] appear unchanged since last service?			☒	☐	☐	25	Gas shut-off valve installed and working properly? (Note location) KITCHEN			☒	☐	☐	
9	Were the nozzle caps in place at time of arrival?			☒	☐	☐	26	Replaced links with proper temperature rating? (List the number of links and degrees below)						
10	Visible piping and nozzles properly connected, braced and free of damage?			☒	☐	☐		Links	2	Deg	360	Links		Deg
11	Piping/conduit/cabling free from observable obstructions?			☒	☐	☐		Links		Deg		Links		Deg
12	Nozzle(s) inspected and found to be clear of obstructions?			☒	☐	☐	27	Is the manual reset for electric gas valves operational?			☒	☐	☐	
13	Correct Nozzle type(s) for protected equipment, plenum and ducts?			☒	☐	☐	28	Did all electrical appliances shut off upon system operation?			☒	☐	☐	
14	Nozzle(s) properly positioned over appliances?			☒	☐	☐	29	Did all gas appliances shut off upon system operation?			☒	☐	☐	
15	Nozzles properly positioned in duct(s) and plenum(s)?			☒	☐	☐	30	Did the make-up air shut down?			☐	☐	☒	
16	Is there a fan warning sign on hood?			☒	☐	☐	31	Did the alarm system activate when the system tripped?			☐	☐	☒	
17	Flow points/extinguishing agent, with mfg's allowed maximums?			☒	☐	☐	32	Did control head(s)/cylinder releasing device(s) operate properly?			☒	☐	☐	
NOTIFICATION OF DEFICIENCIES				CUSTOMER INITIALS _____										
☐ A mark made in the adjacent box indicates that deficiencies exist with the current condition of the Fire Suppression System. If this is the case, the customer's authorized representative, by his or her signature and initials acknowledges these deficiencies represent an IMMEDIATE AND SERIOUS SAFETY CONCERN that the customer must correct. Service Company shall not be responsible if the Fire Suppression malfunctions or fails to function. It is the owner's responsibility to ensure that all deficiencies are removed or repaired.														

CUSTOMER			CONTACT			PHONE			FAX			
ADDRESS			CITY			STATE AND ZIP CODE						
CYLINDERS AND AGENTS			Y	N	N/A	SYSTEM ACTIVATION			Y	N	N/A	
33	Cylinder Pressure	psi	☐	☐	☒	45	Were all filters reinstalled?			☒	☐	☐
34	Hydrostatic test date of cylinder checked: Date:		☒	☐	☐	46	Were all cartridges reinstalled? (if applicable)			☒	☐	☐
35	Were all cylinders free of signs of external corrosion and/or damage?		☒	☐	☐	47	Tandem/slave releasing device(s) reset properly?			☐	☐	☒
36	Are all cylinders securely mounted?		☒	☐	☐					☐	☐	☐
37	Cartridge inspected or replaced within mfg's recommended interval? Weight		☒	☐	☐	FINAL			Y	N	N/A	
SYSTEM REACTIVATION			Y	N	N/A	48	Operator's manual on site?			☒	☐	☐
38	Test adapters, keeper pins, etc. removed from system?		☒	☐	☐	49	Class K portable extinguisher available and properly serviced?			☒	☐	☐
39	Detection [link] line has proper tension?		☒	☐	☐	50	Remote manual release free from obstruction & operable?			☒	☐	☐
40	Was the control head reset?		☒	☐	☐	51	Has the system been placed back in service?			☒	☐	☐
41	Were all fuel sources supplied by the gas valve relit?		☒	☐	☐	52	Monitoring company notified that the system is back in full service?			☐	☐	☒
42	Were all pilot lights supplied by the gas valve relit?		☐	☐	☒	53	Were building personnel notified of the system condition?			☒	☐	☐
43	Microswitch/relay(s)-electric appliances "on"?		☒	☐	☐	54	Have you received a signature from the building personnel?			☒	☐	☐
44	Are all nozzle caps in place?		☒	☐	☐	55	Inspection tag affixed to system?			☒	☐	☐
DESCRIPTION OF DEFICIENCIES												
COMMENTS AND RECOMMENDATIONS												
NOTIFICATION OF EXHAUST SYSTEM GREASE BUILD UP						CUSTOMER INITIALS _____						
☐ A mark made in the adjacent box indicates that we recommend that the entire exhaust and ventilation control system as well all appliances be inspected by a properly trained, qualified, and certified company or person(s) acceptable to the authority having jurisdiction to determine if cleaning is required. Any visual observations or comments noted by our Service Technician regarding grease build up are for informational purposes only and are based readily observable conditions at the time of service												
AUTHORIZED CUSTOMER REPRESENTATIVE						AUTHORIZED COMPANY REPRESENTATIVE						
Signature _____						Signature <u>Ron BURNE II</u>						
Print Name <u>Monica Moore</u>						Print Name & Certification Number <u>P00254</u>						

CUSTOMER	CONTACT	PHONE	FAX
ADDRESS	CITY	STATE AND ZIP CODE	


HOOD SIZE

8'


DUCT QUANTITY & SIZE

14x14

(1)



LABEL ALL APPLIANCES



SIZE

NOTES/COMMENTS

INCLUDE ALL APPLIANCES. LABEL SIZE AND TYPE

SYSTEM CONNECTED TO ALARM? ☐ YES ☒ NOGAS VALVE: ☒ YES ☐ NO SIZE

NOZZLE QUANTITY

GAS VALVE STYLE:

DUCT / PLENUM / APPLIANCE 3

☒ ELECTRICAL☐ MECHANICALREMOTE PULL ☒ YES ☐ NO
LOCATIONTYPE: ☐ RELEASE☐ PULL

EGRESS

ALL CONDITIONS ARE LIMITED TO ONLY THOSE THAT COULD BE OBSERVED AT THE TIME OF INSPECTION

Genron Fire Protection				CUSTOMER		Woodbine BOE	
				DATE		July 28-2021	
No.	Manufacturer	S/N	Size and Type	HT Date	6 YR. Date	Location	
			20lb ABC		2020	Science Rm	
			5lb ABC		2019	Nurse	
			5lb ABC		2019	Hall	
			5lb ABC		2019	Music	
			5lb ABC		2019	Hall	
			5lb ABC		2019	Science Rm	
			5lb ABC		2000	Hall	
			5lb ABC		2018	Stage	
			5lb ABC		2019	Supply Closet	
			5lb ABC		2019	Hall	
			5lb ABC		2019		
			5lb ABC		2019	Hall	
			5lb ABC		2017	Hall	
			5lb ABC		2019	Hall	
			5lb ABC		2017	Boiler Rm	
			5lb ABC		2018	Spare	
			5lb ABC		2018	Spare	
			5lb ABC		2018	Office	
			ABC		2019	Spare	
			10lb ABC		2017	Boiler Rm	
			10lb ABC		2020	Stage	
			10lb ABC		2019	Hall	
Sheet ()							

ALL INVOICES AND
CORRESPONDENCE MUST BE SENT
TO ABOVE ADDRESS REGARDLESS
OF SHIPPING POINT

**WOODBINE BOARD OF EDUCATION
BUSINESS OFFICE**
1076 Almond Road
Pittsgrove, NJ 08318
856-358-3094 ext. 4023

PURCHASE ORDER NO. **200291**

PO# AND ORDERED BY
NAME MUST APPEAR ON
ALL LABELS, CARTONS &
INVOICES

Page 1 of 1

Copy 3

Ship to

WOODBINE ELEMENTARY
801 Webster Street
Woodbine, NJ 08270

To

GENRON FIRE PROTECTION
P.O. BOX 556
SOUTH SEAVILLE, NJ 08246

1278

Account Code

11-000-262-420-050-0

Amount

150.00

Date: 03/02/22 Dept: acctpay

Notice: The purchaser is exempt by statute from paying all Federal, State
and Municipal Excise Sales & other taxes

Qty	Unit	Description	Unit Price	Amount
1.		02/11/22 inspection	150.000	150.00
✓# 12255 3/14/22				

Total for Lines \$150.00

NOTICE TO VENDOR OR CONTRACTOR

1. Order invalid unless signed by the Secretary of the Board of Education
2. Shipping statement must accompany delivery of materials
3. Voucher provided by the Board of Education must be forwarded to the secretary to process payment
4. Please submit invoice as soon as order is completed
5. Must have NJ Reg. on file with us in order to receive payment

SCHOOL OFFICE USE ONLY

I certify that the goods or services itemized have been received

Signature

Title

Date

NO ORDER VALID UNLESS SIGNED BY THE SECRETARY

SECRETARY, BOARD OF EDUCATION

ALL INVOICES AND
CORRESPONDENCE MUST BE SENT
TO ABOVE ADDRESS REGARDLESS
OF SHIPPING POINT

**WOODBINE BOARD OF EDUCATION
BUSINESS OFFICE**
1076 Almond Road
Pittsgrove, NJ 08318
856-358-3094 ext. 4023

PURCHASE ORDER NO. **200291**

PO# AND ORDERED BY
NAME MUST APPEAR ON
ALL LABELS, CARTONS &
INVOICES

Page 1 of 1

Copy 1

Ship to

WOODBINE ELEMENTARY
801 Webster Street
Woodbine, NJ 08270

To

GENRON FIRE PROTECTION
P.O. BOX 556
SOUTH SEAVILLE, NJ 08246

1278

Account Code

Amount

11-000-262-420-050-0

150.00

Date: 03/02/22 Dept: acctpay

Notice: The purchaser is exempt by statute from paying all Federal, State
and Municipal Excise Sales & other taxes

Qty	Unit	Description	Unit Price	Amount
1.		02/11/22 inspection	150.000	150.00

Total for Lines \$150.00

NOTICE TO VENDOR OR CONTRACTOR

1. Order invalid unless signed by the Secretary of the Board of Education
2. Shipping statement must accompany delivery of materials
3. Voucher provided by the Board of Education must be forwarded to the secretary to process payment
4. Please submit invoice as soon as order is completed
5. Must have NJ Reg. on file with us in order to receive payment

INVOICES MUST BE RENDERED ON THE VOUCHER

Claimant's Certification and Declaration

I do solemnly declare and certify under the penalties of the law that the within bill is correct in all its particulars; that the articles have been furnished or services rendered as stated therein; that no bonus has been given or received by any person or persons within the knowledge of the claimant in connection with the above claim; that the amount therein stated is justly due and owing; and that the amount charged is a reasonable one.

(X)

Vendor Sign Here

Official Position

Date

NO ORDER VALID UNLESS SIGNED BY THE SECRETARY



SECRETARY, BOARD OF EDUCATION

VOUCHER COPY - RETURN FOR PAYMENT

ALL INVOICES AND
CORRESPONDENCE MUST BE SENT
TO ABOVE ADDRESS REGARDLESS
OF SHIPPING POINT

**WOODBINE BOARD OF EDUCATION
BUSINESS OFFICE**
1076 Almond Road
Pittsgrove, NJ 08318
856-358-3094 ext. 4023

PURCHASE ORDER NO. **200291**

PO# AND ORDERED BY
NAME MUST APPEAR ON
ALL LABELS, CARTONS &
INVOICES

Page 1 of 1

Copy 2

Ship to

WOODBINE ELEMENTARY
801 Webster Street
Woodbine, NJ 08270

To

GENRON FIRE PROTECTION
P.O. BOX 556
SOUTH SEAVILLE, NJ 08246

1278

Account Code

11-000-262-420-050-0

Amount

150.00

Date: 03/02/22 Dept: acctpay

Notice: The purchaser is exempt by statute from paying all Federal, State
and Municipal Excise Sales & other taxes

Qty	Unit	Description	Unit Price	Amount
1.		02/11/22 inspection	150.000	150.00

Total for Lines **\$150.00**

NOTICE TO VENDOR OR CONTRACTOR

1. Order invalid unless signed by the Secretary of the Board of Education
2. Shipping statement must accompany delivery of materials
3. Voucher provided by the Board of Education must be forwarded to the secretary to process payment
4. Please submit invoice as soon as order is completed
5. Must have NJ Reg. on file with us in order to receive payment

Claimant's Certification and Declaration

I do solemnly declare and certify under the penalties of the law that the within bill is correct in all its particulars; that the articles have been furnished or services rendered as stated therein; that no bonus has been given or received by any person or persons within the knowledge of the claimant in connection with the above claim; that the amount therein stated is justly due and owing; and that the amount charged is a reasonable one.

(X)

Vendor Sign Here

Official Position

Date

NO ORDER VALID UNLESS SIGNED BY THE SECRETARY

SECRETARY, BOARD OF EDUCATION

VENDOR COPY

11-000-262-420

**GENRON Fire**

PO Box 556
South Seaville, NJ 08246
609-624-3000

PLEASE REMIT TO:
GENRON INC.
P.O. Box 556
South Seaville NJ 08246

RECEIVED**FEB 14 2022****Invoice**

DATE	INVOICE
2/11/2022	44520

BILL TO:

Woodbine Board of Education
801 Webster Street
Woodbine, NJ 08270

WORK LOCATION:

Woodbine Board of Education
801 Webster Street
Woodbine, NJ 08270

P.O.	TERMS	DUE	TECH	PHONE	SER DATE	TYPE	SYSTEM	H/T DATE
	Due o...	2/11/2022	5	609-861-5174	2-9-2022	S/A		
ITEM	QTY	DESCRIPTION				RATE	AMOUNT	
FIRESYS	1	Inspection, Certification and Service Fire Suppression System Pursuant to NFPA 17A Para 7.3.2				130.00	130.00	
360FS	2	360 Degree Heat Link for Fire System				10.00	20.00	
REPORT	1	System report provided with invoice. (NO CHARGE)				0.00	0.00	

Total \$150.00

WOULD YOU LIKE TO PAY YOUR
INVOICE BY CREDIT CARD? PLEASE
CALL THE OFFICE AND WE WILL
PROCESS YOUR PAYMENT.

E-mail


ggburnell@genronfire.net

PLEASE NOTE
OUR NEW
REMITTANCE
ADDRESS

Monica Morales

☒ System is Compliant with NJAC-5:70-3				☐ System is Non-Compliant								
Genron Fire Protection 1066 Route 83, Clermont, NJ 08210 Phone: 609-624-3000 Fax: 609-624-2999 NJ Contractor Permit # P00254 US DOT Requalifer Facility RIN G821			WORK ORDER NO 1782		DATE 2/9/22		HAZARD AREA PROTECTED DPA					
			SYSTEM MFG Ansul		SYS CAPACITY 3		SYS TYPE Wet		# OF CYLS 1			
CUSTOMER Woodbine Board of Education			CONTACT Office		PHONE 609-861-5174		FAX					
ADDRESS 801 Webster Street			CITY Woodbine			STATE AND ZIP CODE NJ						
AHJ/PROTECTION DISTRICT			INSPECTION TYPE ☐ INITIAL ☐ ANNUAL ☒ SEMI-ANNUAL									
INITIAL ACTIONS/OBSERVATIONS				Y	N	N/A	HAZARD INSPECTION					
1	Last serviced by: Genron Fire Protection						18	Hazard configuration appeared to remain unchanged?	☒	☐	☐	
2	Were building personnel notified of the inspection?			☒	☐	☐	19	Are all observable penetrations to the hood and duct sealed?	☒	☐	☐	
3	Was the monitoring company notified?			☐	☐	☒	20	No readily observable obstructions or interference that could impact effectiveness of the suppression system?	☒	☐	☐	
4	System found charged and functioning at the time of tech's arrival?			☒	☐	☐	SYSTEM FUNCTIONAL TEST			Y	N	N/A
5	System un-tampered since last visit?			☒	☐	☐	21	System disarmed per manufacturer's recommendations?	☒	☐	☐	
6	System found to be at proper pressure upon arrival?			☐	☐	☒	22	Mechanical detection line tested and found to operate properly?	☒	☐	☐	
VISUALLY CHECK SYSTEM				Y	N	N/A	23	Proper number and placement of detectors/links?	☒	☐	☐	
7	Baffle-type filters installed in hood?			☒	☐	☐	24	Did the system operate properly from activation of a manual pull station	☒	☐	☐	
8	System [and appliance] appear unchanged since last service?			☒	☐	☐	25	Gas shut-off valve installed and working properly? (Note location)	☒	☐	☐	
9	Were the nozzle caps in place at time of arrival?			☒	☐	☐	26 abdue sink Electric w/valve Replaced links with proper temperature rating? (List the number of links and degrees below)					
10	Visible piping and nozzles properly connected, braced and free of damage?			☒	☐	☐						
11	Piping/conduit/cabling free from observable obstructions?			☒	☐	☐						
12	Nozzle(s) inspected and found to be clear of obstructions?			☒	☐	☐	27	Is the manual reset for electric gas valves operational?	☒	☐	☐	
13	Correct Nozzle type(s) for protected equipment, plenum and ducts?			☒	☐	☐	28	Did all electrical appliances shut off upon system operation?	☒	☐	☐	
14	Nozzle(s) properly positioned over appliances?			☒	☐	☐	29	Did all gas appliances shut off upon system operation?	☒	☐	☐	
15	Nozzles properly positioned in duct(s) and plenum(s)?			☒	☐	☐	30	Did the make-up air shut down?	☐	☐	☒	
16	Is there a fan warning sign on hood?			☐	☒	☐	31	Did the alarm system activate when the system tripped?	☐	☐	☒	
17	Flow points/extinguishing agent with mfg's allowed maximums?			☒	☐	☐	32	Did control head(s)/cylinder releasing device(s) operate properly?	☒	☐	☐	
NOTIFICATION OF DEFICIENCIES							CUSTOMER INITIALS _____					
☐ A mark made in the adjacent box indicates that deficiencies exist with the current condition of the Fire Suppression System. If this is the case, the customer's authorized representative, by his or her signature and initials acknowledges these deficiencies represent an IMMEDIATE AND SERIOUS SAFETY CONCERN that the customer must correct. Service Company shall not be responsible if the Fire Suppression malfunctions or fails to function. It is the owner's responsibility to ensure that all deficiencies are removed or repaired.												

CUSTOMER Woodbine Board of Education			CONTACT Office			PHONE 609-861-5174			FAX			
ADDRESS 801 Webster Street			CITY Woodbine			STATE AND ZIP CODE NJ						
CYLINDERS AND AGENTS			Y	N	N/A	SYSTEM ACTIVATION			Y	N	N/A	
33	Cylinder Pressure	psi	☐	☐	☒	45	Were all filters reinstalled?			☒	☐	☐
34	Hydrostatic test dates(s) of cylinder checked: Due: <u>2023</u>		☒	☐	☐	46	Were all cartridges reinstalled? (if applicable)			☒	☐	☐
35	Were all cylinders free of signs of external corrosion and/or damage?		☒	☐	☐	47	Tandem/slave releasing device(s) reset properly?			☐	☐	☒
36	Are all cylinders securely mounted?		☒	☐	☐							
37	Cartridge inspected or replaced within mfg's recommended interval? Weight		☒	☐	☐	FINAL			Y	N	N/A	
SYSTEM REACTIVATION			Y	N	N/A	48	Operator's manual on site?			☒	☐	☐
38	Test adapters, keeper pins, etc. removed from system?		☒	☐	☐	49	Class K portable extinguisher available and properly serviced?			☒	☐	☐
39	Detection [link] line has proper tension?		☒	☐	☐	50	Remote manual release free from obstruction & operable?			☒	☐	☐
40	Was the control head reset?		☒	☐	☐	51	Has the system been placed back in service?			☒	☐	☐
41	Were all fuel sources supplied by the gas valve relit?		☒	☐	☐	52	Monitoring company notified that the system is back in full service?			☐	☐	☒
42	Were all pilot lights supplied by the gas valve relit?		☐	☐	☒	53	Were building personnel notified of the system condition?			☒	☐	☐
43	Microswitch/relay(s)-electric appliances "on"?		☒	☐	☐	54	Have you received a signature from the building personnel?			☒	☐	☐
44	Are all nozzle caps in place?		☒	☐	☐	55	Inspection tag affixed to system?			☒	☐	☐
DESCRIPTION OF DEFICIENCIES												
COMMENTS AND RECOMMENDATIONS												
NOTIFICATION OF EXHAUST SYSTEM GREASE BUILD UP						CUSTOMER INITIALS _____						
☐ A mark made in the adjacent box indicates that we recommend that the entire exhaust and ventilation control system as well all appliances be inspected by a properly trained, qualified, and certified company or person(s) acceptable to the authority having jurisdiction to determine if cleaning is required. Any visual observations or comments noted by our Service Technician regarding grease build up are for informational purposes only and are based readily observable conditions at the time of service												
AUTHORIZED CUSTOMER REPRESENTATIVE						AUTHORIZED COMPANY REPRESENTATIVE						
Signature <u>Monica Morales</u>						Signature <u>F. CARLIN</u>						
Print Name <u>Monica Morales</u>						Print Name & Certification Number <u>P00254</u>						

CUSTOMER Woodbine Board of Education	CONTACT Office	PHONE 609-861-5174	FAX
ADDRESS 801 Webster Street	CITY Woodbine	STATE AND ZIP CODE NJ	
HOOD SIZE 8'		DUCT QUANTITY & SIZE 14X14	
			
LABEL ALL APPLIANCES			
 KENNEL 6 B RANGE 36x 34 2 CON VEC OVEN 40x30 CON VEC OVEN ② 24x25			
SIZE ②3 36x 34 40x30 ② 24x25			
NOTES/COMMENTS			
INCLUDE ALL APPLIANCES. LABEL SIZE AND TYPE			
SYSTEM CONNECTED TO ALARM? ☐ YES ☒ NO NOZZLE QUANTITY DUCT 1 PLENUM 1 APPLIANCE 3 REMOTE PULL LOCATION ☐ YES ☐ NO OTHER:		GAS VALVE: ☒ YES ☐ NO SIZE GAS VALVE STYLE: ☒ ELECTRICAL ☐ MECHANICAL TYPE: ☐ RELEASE ☐ PULL	
ALL CONDITIONS ARE LIMITED TO ONLY THOSE THAT COULD BE OBSERVED AT THE TIME OF INSPECTION			

ALL INVOICES AND
CORRESPONDENCE MUST BE SENT
TO ABOVE ADDRESS REGARDLESS
OF SHIPPING POINT

WOODBINE BOARD OF EDUCATION
BUSINESS OFFICE
1076 Almond Road
Pittsgrove, NJ 08318
856-358-3094 ext. 4023

PURCHASE ORDER NO.

200291

PO# AND ORDERED BY
NAME MUST APPEAR ON
ALL LABELS, CARTONS &
INVOICES

Page 1 of 1

Copy 4

Ship to

WOODBINE ELEMENTARY
801 Webster Street
Woodbine, NJ 08270

To

GENRON FIRE PROTECTION
P.O. BOX 556
SOUTH SEAVILLE, NJ 08246

1278

Account Code

Amount

11-000-262-420-050-0

150.00

Date: 03/02/22

Dept: acctpay

Notice: The purchaser is exempt by statute from paying all Federal, State
and Municipal Excise Sales & other taxes

Qty	Unit	Description	Unit Price	Amount
1.		02/11/22 inspection	150.000	150.00

Total for Lines **\$150.00**

NOTICE TO VENDOR OR CONTRACTOR

1. Order invalid unless signed by the Secretary of the Board of Education
2. Shipping statement must accompany delivery of materials
3. Voucher provided by the Board of Education must be forwarded to the secretary to process payment
4. Please submit invoice as soon as order is completed
5. Must have NJ Reg. on file with us in order to receive payment

SCHOOL OFFICE USE ONLY

I certify that the goods or services itemized have been received



Signature

3/11/2022

Date

Title

NO ORDER VALID UNLESS SIGNED BY THE SECRETARY



SECRETARY, BOARD OF EDUCATION

RECEIVING COPY