

Elevator Inspection

Identification

South Tower

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Date: 2/29/24
BLDG.REG # 0102-00157-001
Elevator #: **STP-1**
Capacity: 3500 lbs STOPS: 22

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: **6Mo.:** **Passenger:X**
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:
Traction:X D/W:

If FA, Permit No.:

Block #:30 Lot #: 2 5 Year. Test Due: 2025

Hydro:

Year Built: MFGR.: Westinghouse Orig. Code: 1984 Mod.Year: Code Certification Expires: **2/28/25**

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA
1. Enclosure/Lighting/Vents	X		
2. Machine/Brake/Gears/Motor	X		
3. Hydro Power Motor Unit			X
4. Motor Generator Set/SCR Drive	X		
5. Controller/Selector	X		
6. Governor(s)	X		
7. Relief & Check Valves			X
8. Required Disconnects	X		
9. Oil/Hydro Fluid, Leaks, Level			X
10. Hydro Fluid Hoses or Pipe			X
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
12. Routine Maintenance			
13.			
B. ELEVATOR CAR AND COUNTERWEIGHT			
1. Car Enclosure/Platform/Sling/Flooring	X		
2. Guide Shoes/Rollers	X		
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X		
4. Car Gate or Door Operator	X		
5. Car Lighting/Standard & Emergency	X		
6. Rope Hitches/Platen Hitch	X		
7. Top-of-Car Operating Station/Stop Switch	X		
8. Car Operating Station/Stop Switch/Indicators	X		
9. Emergency Signals & Communication	X		
10. Emergency Exits/Top/Side	X		
11. Safeties & Accessories	X		
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
13. Firefighter Service PH I & II	X		
14. Counterweight/Car & Counterweight Sheaves	X		
15. Routine Maintenance			
16.			
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT			
1. Enclosure	X		
2. Door, Closers & Accessories	X		
3. Door Interlocks/Emergency Key/Access Keys	X		
4. Guide Rails: Main & Counterweight	X		
5. Switches and Cams	X		
6. Pit/Stop Switch/Light/Ladder	X		
7. Counterweight Guard	X		
8. Buffers: Spring or Oil	X		
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X		
10. Traveling Cable and Wiring	X		
11. Plunger, Cylinder and Gland			X
12. Governor Rope Tension Sheave & Assembly	X		

13. Compensating Sheave or Chain	X			
14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Car Rated Speed				
3. Overspeed Switch	563			
4. Tripping Speed	610			
5. Capacity	3500			
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Working Pressure				
3. Relief Pressure				
4. Capacity				
5. Tags				
F. APPLICABLE CODES				
ASME A17.1				
ACTION TAKEN				
1. Device Number	STP-1			
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached
 BUD GRANT # 8812

Inspector's Name (print) and License No.

Inspector's Signature **BUD GRANT**

Elevator Inspection

Identification

South Tower

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Date: 2/29/24
BLDG.REG # 0102-00157-001
Elevator #: STP-2
Capacity: 3500 lbs STOPS: 21

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: 6Mo.: Passenger:X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:
Traction:X D/W: Hydro:
Certification Expires: 2/28/25

If FA, Permit No.:

Block #:30 Lot #: 2 **5 Year. Test Due: 2025**
Year Built: MFGR.: Westinghouse Orig. Code: 1984 Mod.Year: Code

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA	
1. Enclosure/Lighting/Vents	X			
2. Machine/Brake/Gears/Motor	X			
3. Hydro Power Motor Unit			X	
4. Motor Generator Set/SCR Drive	X			
5. Controller/Selector	X			
6. Governor(s)	X			
7. Relief & Check Valves			X	
8. Required Disconnects	X			
9. Oil/Hydro Fluid, Leaks, Level			X	
10. Hydro Fluid Hoses or Pipe			X	
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
12. Routine Maintenance				
13.				
B. ELEVATOR CAR AND COUNTERWEIGHT				
1. Car Enclosure/Platform/Sling/Flooring	X			
2. Guide Shoes/Rollers	X			
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X			
4. Car Gate or Door Operator	X			
5. Car Lighting/Standard & Emergency	X			
6. Rope Hitches/Platen Hitch	X			
7. Top-of-Car Operating Station/Stop Switch	X			
8. Car Operating Station/Stop Switch/Indicators	X			
9. Emergency Signals & Communication	X			
10. Emergency Exits/Top/Side	X			
11. Safeties & Accessories	X			
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
13. Firefighter Service PH I & II	X			
14. Counterweight/Car & Counterweight Sheaves	X			
15. Routine Maintenance				
16.				
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT				
1. Enclosure	X			
2. Door, Closers & Accessories	X			
3. Door Interlocks/Emergency Key/Access Keys	X			
4. Guide Rails: Main & Counterweight	X			
5. Switches and Cams	X			
6. Pit/Stop Switch/Light/Ladder	X			
7. Counterweight Guard	X			
8. Buffers: Spring or Oil	X			
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail				
10. Traveling Cable and Wiring	X			
11. Plunger, Cylinder and Gland			X	
12. Governor Rope Tension Sheave & Assembly	X			
13. Compensating Sheave or Chain	X			

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Car Rated Speed				
3. Overspeed Switch	472			
4. Tripping Speed	613			
5. Capacity	3500			
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Working Pressure				
3. Relief Pressure				
4. Capacity				
5. Tags				
F. APPLICABLE CODES				
ASME A17.1 1984				
ACTION TAKEN				
1. Device Number	STP-2			
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812

Inspector's Name (print) and License No.

Inspector's Signature

BUD GRANT

Elevator Inspection

Identification

South Tower

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Date: 2/29/24
BLDG.REG # 0102-00157-001
Elevator #: STP-3
Capacity: 3500 lbs STOPS: 21

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: 6Mo.: Passenger:X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope\H:
Traction:X D/W: Hydro:
Certification Expires: 2/28/25

If FA, Permit No.:

Block #:30 Lot #: 2 5 Year. Test Due: 2025

Year Built: MFGR.: Westinghouse Orig. Code: 1984 Mod.Year: Code

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA
1. Enclosure/Lighting/Vents	X		
2. Machine/Brake/Gears/Motor	X		
3. Hydro Power Motor Unit			X
4. Motor Generator Set/SCR Drive	X		
5. Controller/Selector	X		
6. Governor(s)	X		
7. Relief & Check Valves			X
8. Required Disconnects	X		
9. Oil/Hydro Fluid, Leaks, Level			X
10. Hydro Fluid Hoses or Pipe			X
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
12. Routine Maintenance			
13.			
B. ELEVATOR CAR AND COUNTERWEIGHT			
1. Car Enclosure/Platform/Sling/Flooring	X		
2. Guide Shoes/Rollers	X		
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X		
4. Car Gate or Door Operator	X		
5. Car Lighting/Standard & Emergency	X		
6. Rope Hitches/Platen Hitch	X		
7. Top-of-Car Operating Station/Stop Switch	X		
8. Car Operating Station/Stop Switch/Indicators	X		
9. Emergency Signals & Communication	X		
10. Emergency Exits/Top/Side	X		
11. Safeties & Accessories	X		
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
13. Firefighter Service PH I & II	X		
14. Counterweight/Car & Counterweight Sheaves	X		
15. Routine Maintenance			
16.			
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT			
1. Enclosure	X		
2. Door, Closers & Accessories	X		
3. Door Interlocks/Emergency Key/Access Keys	X		
4. Guide Rails: Main & Counterweight	X		
5. Switches and Cams	X		
6. Pit/Stop Switch/Light/Ladder	X		
7. Counterweight Guard	X		
8. Buffers: Spring or Oil	X		
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X		
10. Traveling Cable and Wiring	X		
11. Plunger, Cylinder and Gland			X
12. Governor Rope Tension Sheave & Assembly	X		
13. Compensating Sheave or Chain	X		

Elevator Inspection

Identification

Name: Tropicana Hotel & Casino

South Tower

Date: 2/29/24

Address: 2821 Boardwalk

BLDG.REG # 0102-00157-001

City/State/Zip: ATLANTIC CITY, NJ 08401

Elevator #: STP-4

Capacity: 3500 lbs STOPS: 21

Type of Inspection/Test

FA: 1Yr: X Alteration:

5Yr.: 6Mo.: Passenger:X

3 Yr.: Reinsp: Freight:

Escl: Chairlift: Rope/H:

Traction:X D/W: Hydro:

Certification Expires: 2/28/25

If FA, Permit No.:

Block #:30 Lot #: 2

5 Year. Test Due: 2025

Year Built:

MFGR.: Westinghouse

Orig. Code: 1984

Mod. Year: Code

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA	
1. Enclosure/Lighting/Vents	X			
2. Machine/Brake/Gears/Motor	X			
3. Hydro Power Motor Unit			X	
4. Motor Generator Set/SCR Drive	X			
5. Controller/Selector	X			
6. Governor(s)	X			
7. Relief & Check Valves			X	
8. Required Disconnects	X			
9. Oil/Hydro Fluid, Leaks, Level			X	
10. Hydro Fluid Hoses or Pipe			X	
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
12. Routine Maintenance				
13.				
B. ELEVATOR CAR AND COUNTERWEIGHT				
1. Car Enclosure/Platform/Sling/Flooring	X			
2. Guide Shoes/Rollers	X			
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X			
4. Car Gate or Door Operator	X			
5. Car Lighting/Standard & Emergency	X			
6. Rope Hitches/Platen Hitch	X			
7. Top-of-Car Operating Station/Stop Switch	X			
8. Car Operating Station/Stop Switch/Indicators	X			
9. Emergency Signals & Communication	X			
10. Emergency Exits/Top/Side	X			
11. Safeties & Accessories	X			
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
13. Firefighter Service PH I & II	X			
14. Counterweight/Car & Counterweight Sheaves	X			
15. Routine Maintenance				
16.				
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT				
1. Enclosure	X			
2. Door, Closers & Accessories	X			
3. Door Interlocks/Emergency Key/Access Keys	X			
4. Guide Rails: Main & Counterweight	X			
5. Switches and Cams	X			
6. Pit/Stop Switch/Light/Ladder	X			
7. Counterweight Guard	X			
8. Buffers: Spring or Oil	X			
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X			
10. Traveling Cable and Wiring	X			
11. Plunger, Cylinder and Gland			X	
12. Governor Rope Tension Sheave & Assembly	X			

13. Compensating Sheave or Chain	X			
14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Car Rated Speed	FPM 500			
3. Overspeed Switch	472			
4. Tripping Speed	613			
5. Capacity				
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Working Pressure				
3. Relief Pressure				
4. Capacity				
5. Tags				
F. APPLICABLE CODES				
ASME A17.1				
ACTION TAKEN				
1. Device Number	STP-4			
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812
Inspector's Name (print) and License No.

Inspector's Signature

BUD GRANT

Elevator Inspection

Identification

South Tower

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Date: 2/29/24
BLDG.REG # 0102-00157-001
Elevator #: STP-5
Capacity: 3500 lbs STOPS: 21

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: X 6Mo.: Passenger:X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:
Traction:X D/W: Hydro:
Certification Expires: 2/28/25

If FA, Permit No.:

Block #:30 Lot #: 2 5 Year. Test Due: 2025
Year Built: MFGR.: Westinghouse Orig. Code: 1984 Mod.Year: Code

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA	
1. Enclosure/Lighting/Vents	X			
2. Machine/Brake/Gears/Motor	X			
3. Hydro Power Motor Unit			X	
4. Motor Generator Set/SCR Drive	X			
5. Controller/Selector	X			
6. Governor(s)	X			
7. Relief & Check Valves			X	
8. Required Disconnects	X			
9. Oil/Hydro Fluid, Leaks, Level			X	
10. Hydro Fluid Hoses or Pipe			X	
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
12. Routine Maintenance				
13.				
B. ELEVATOR CAR AND COUNTERWEIGHT				
1. Car Enclosure/Platform/Sling/Flooring	X			
2. Guide Shoes/Rollers	X			
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X			
4. Car Gate or Door Operator	X			
5. Car Lighting/Standard & Emergency	X			
6. Rope Hitches/Platen Hitch	X			
7. Top-of-Car Operating Station/Stop Switch	X			
8. Car Operating Station/Stop Switch/Indicators	X			
9. Emergency Signals & Communication	X			
10. Emergency Exits/Top/Side	X			
11. Safeties & Accessories	X			
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
13. Firefighter Service PH I & II	X			
14. Counterweight/Car & Counterweight Sheaves	X			
15. Routine Maintenance				
16.				
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT				
1. Enclosure	X			
2. Door, Closers & Accessories	X			
3. Door Interlocks/Emergency Key/Access Keys	X			
4. Guide Rails: Main & Counterweight	X			
5. Switches and Cams	X			
6. Pit/Stop Switch/Light/Ladder	X			
7. Counterweight Guard	X			
8. Buffers: Spring or Oil	X			
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X			
10. Traveling Cable and Wiring	X			
11. Plunger, Cylinder and Gland			X	
12. Governor Rope Tension Sheave & Assembly	X			
13. Compensating Sheave or Chain	X			

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Car Rated Speed 500				
3. Overspeed Switch 413				
4. Tripping Speed 615				
5. Capacity 3500				
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Working Pressure				
3. Relief Pressure				
4. Capacity				
5. Tags				
F. APPLICABLE CODES				
ASME A17.1				
ACTION TAKEN				
1. Device Number STP-5				
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812
Inspector's Name (print) and License No.

Inspector's Signature

BUD GRANT

Elevator Inspection

Identification

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

South Tower

Date: 3/4/24
BLDG.REG # 0102-00157-001
Elevator #: STP-8
Capacity: 3500 lbs STOPS: 3

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: 6Mo. Passenger: X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:
Traction: D/W: Hydro: X
Certification Expires: 2/28/25

If FA, Permit No.:

Block #:30 Lot #: 2 5 Year. Test Due:
Year Built: MFGR.: Eastern Elev Orig. Code: 1984 Mod.Year: Code

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT				S	U	NA
1. Enclosure/Lighting/Vents	X					
2. Machine/Brake/Gears/Motor	X					
3. Hydro Power Motor Unit	X					
4. Motor Generator Set/SCR Drive			X			
5. Controller/Selector	X					
6. Governor(s)			X			
7. Relief & Check Valves	X					
8. Required Disconnects	X					
9. Oil/Hydro Fluid, Leaks, Level	X					
10. Hydro Fluid Hoses or Pipe	X					
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X					
12. Routine Maintenance						
13.						
B. ELEVATOR CAR AND COUNTERWEIGHT						
1. Car Enclosure/Platform/Sling/Flooring	X					
2. Guide Shoes/Rollers	X					
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X					
4. Car Gate or Door Operator	X					
5. Car Lighting/Standard & Emergency	X					
6. Rope Hitches/Platen Hitch	X					
7. Top-of-Car Operating Station/Stop Switch	X					
8. Car Operating Station/Stop Switch/Indicators	X					
9. Emergency Signals & Communication	X					
10. Emergency Exits/Top/Side	X					
11. Safeties & Accessories			X			
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X					
13. Firefighter Service PH I & II	X					
14. Counterweight/Car & Counterweight Sheaves			X			
15. Routine Maintenance						
16.						
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT						
1. Enclosure	X					
2. Door, Closers & Accessories	X					
3. Door Interlocks/Emergency Key/Access Keys	X					
4. Guide Rails: Main & Counterweight	X					
5. Switches and Cams	X					
6. Pit/Stop Switch/Light/Ladder	X					
7. Counterweight Guard			X			
8. Buffers: Spring or Oil	X					
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail			X			
10. Traveling Cable and Wiring	X					
11. Plunger, Cylinder and Gland	X					
12. Governor Rope Tension Sheave & Assembly	X					
13. Compensating Sheave or Chain			X			

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Car Rated Speed				
3. Overspeed Switch				
4. Tripping Speed				
5. Capacity				
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Working Pressure	350			
3. Relief Pressure	RP 400			
4. Capacity	3500			
5. Tags				
F. APPLICABLE CODES				
ASME A17.1-1984				
ACTION TAKEN				
1. Device Number	STP-8			
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812

Inspector's Name (print) and License No.

Inspector's Signature **BUD GRANT**

Elevator Inspection

Identification

South Tower

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Date: 3/4/24
BLDG.REG # 0102-00157-001
Elevator #: STP-11
Capacity: 2500 lbs STOPS: 2

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: 6Mo.: Passenger: X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:
Traction: D/W: Hydro: X
Certification Expires: 2/28/25

If FA, Permit No.:

Block #:30

Lot #: 2

5 Year. Test Due:

Year Built:

MFGR.: ESCO

Orig. Code: 1984

Mod.Year: Code

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT				S	U	NA
1. Enclosure/Lighting/Vents	X					
2. Machine/Brake/Gears/Motor	X					
3. Hydro Power Motor Unit	X					
4. Motor Generator Set/SCR Drive			X			
5. Controller/Selector	X					
6. Governor(s)			X			
7. Relief & Check Valves	X					
8. Required Disconnects	X					
9. Oil/Hydro Fluid, Leaks, Level	X					
10. Hydro Fluid Hoses or Pipe	X					
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X					
12. Routine Maintenance						
13.						
B. ELEVATOR CAR AND COUNTERWEIGHT						
1. Car Enclosure/Platform/Sling/Flooring	X					
2. Guide Shoes/Rollers	X					
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X					
4. Car Gate or Door Operator	X					
5. Car Lighting/Standard & Emergency	X					
6. Rope Hitches/Platen Hitch	X					
7. Top-of-Car Operating Station/Stop Switch	X					
8. Car Operating Station/Stop Switch/Indicators	X					
9. Emergency Signals & Communication	X					
10. Emergency Exits/Top/Side	X					
11. Safeties & Accessories			X			
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X					
13. Firefighter Service PH I & II	X					
14. Counterweight/Car & Counterweight Sheaves			X			
15. Routine Maintenance						
16.						
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT						
1. Enclosure	X					
2. Door, Closers & Accessories	X					
3. Door Interlocks/Emergency Key/Access Keys	X					
4. Guide Rails: Main & Counterweight	X					
5. Switches and Cams	X					
6. Pit/Stop Switch/Light/Ladder	X					
7. Counterweight Guard			X			
8. Buffers: Spring or Oil	X					
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail			X			
10. Traveling Cable and Wiring	X					
11. Plunger, Cylinder and Gland	X					
12. Governor Rope Tension Sheave & Assembly	X					

13. Compensating Sheave or Chain			X	
14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Car Rated Speed				
3. Overspeed Switch				
4. Tripping Speed				
5. Capacity				
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number STP-11				
2. Working Pressure 350				
3. Relief Pressure 400				
4. Capacity 3500				
5. Tags				
F. APPLICABLE CODES				
ASME A17.1-1984				
ACTION TAKEN				
1. Device Number STP-11				
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812

Inspector's Name (print) and License No.

Inspector's Signature **BUD GRANT**

Elevator Inspection

Identification

South Tower

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Date: 2/29/24
BLDG.REG # 0102-00157-001
Elevator #: STS-6
Capacity: 3500 lbs STOPS: 22

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: 6Mo.: Passenger: X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:
Traction: X D/W: Hydro:
Certification Expires: 2/28/25

If FA, Permit No.:

Block #:30 Lot #: 2 5 Year. Test Due: 2025
Year Built: MFGR.: Westinghouse Orig. Code: 1996 Mod. Year: Code

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA
1. Enclosure/Lighting/Vents	X		
2. Machine/Brake/Gears/Motor	X		
3. Hydro Power Motor Unit			X
4. Motor Generator Set/SCR Drive	X		
5. Controller/Selector	X		
6. Governor(s)	X		
7. Relief & Check Valves			X
8. Required Disconnects	X		
9. Oil/Hydro Fluid, Leaks, Level			X
10. Hydro Fluid Hoses or Pipe			X
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
12. Routine Maintenance			
13.			
B. ELEVATOR CAR AND COUNTERWEIGHT			
1. Car Enclosure/Platform/Sling/Flooring	X		
2. Guide Shoes/Rollers	X		
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X		
4. Car Gate or Door Operator	X		
5. Car Lighting/Standard & Emergency	X		
6. Rope Hitches/Platen Hitch	X		
7. Top-of-Car Operating Station/Stop Switch	X		
8. Car Operating Station/Stop Switch/Indicators	X		
9. Emergency Signals & Communication	X		
10. Emergency Exits/Top/Side	X		
11. Safeties & Accessories	X		
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
13. Firefighter Service PH I & II	X		
14. Counterweight/Car & Counterweight Sheaves	X		
15. Routine Maintenance			
16.			
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT			
1. Enclosure	X		
2. Door, Closers & Accessories	X		
3. Door Interlocks/Emergency Key/Access Keys	X		
4. Guide Rails: Main & Counterweight	X		
5. Switches and Cams	X		
6. Pit/Stop Switch/Light/Ladder	X		
7. Counterweight Guard	X		
8. Buffers: Spring or Oil	X		
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X		
10. Traveling Cable and Wiring	X		
11. Plunger, Cylinder and Gland			X
12. Governor Rope Tension Sheave & Assembly	X		
13. Compensating Sheave or Chain	X		

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Car Rated Speed				
3. Overspeed Switch	437			
4. Tripping Speed	506			
5. Capacity	3500			
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Working Pressure				
3. Relief Pressure				
4. Capacity				
5. Tags				
F. APPLICABLE CODES				
ASME A17.1				
ACTION TAKEN				
1. Device Number	STS-6			
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812
Inspector's Name (print) and License No.

Inspector's Signature **BUD GRANT**

Elevator Inspection

Identification

South Tower

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Date: 2/29/24
BLDG.REG # 0102-00157-001
Elevator #: STS-7
Capacity: 3500 lbs STOPS: 22

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: 6Mo. Passenger: X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:
Traction: X D/W: Hydro:
Certification Expires: 2/28/25

If FA, Permit No.:

Block #:30 Lot #: 2

5YR DUE: 2025

Year Built: MFGR.: Westinghouse Orig. Code: 1996 Mod.Year: Code

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA
1. Enclosure/Lighting/Vents	X		
2. Machine/Brake/Gears/Motor	X		
3. Hydro Power Motor Unit			X
4. Motor Generator Set/SCR Drive	X		
5. Controller/Selector	X		
6. Governor(s)	X		
7. Relief & Check Valves			X
8. Required Disconnects	X		
9. Oil/Hydro Fluid, Leaks, Level			X
10. Hydro Fluid Hoses or Pipe			X
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
12. Routine Maintenance			
13.			
B. ELEVATOR CAR AND COUNTERWEIGHT			
1. Car Enclosure/Platform/Sling/Flooring	X		
2. Guide Shoes/Rollers	X		
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X		
4. Car Gate or Door Operator	X		
5. Car Lighting/Standard & Emergency	X		
6. Rope Hitches/Platen Hitch	X		
7. Top-of-Car Operating Station/Stop Switch	X		
8. Car Operating Station/Stop Switch/Indicators	X		
9. Emergency Signals & Communication	X		
10. Emergency Exits/Top/Side	X		
11. Safeties & Accessories	X		
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
13. Firefighter Service PH I & II	X		
14. Counterweight/Car & Counterweight Sheaves	X		
15. Routine Maintenance			
16.			
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT			
1. Enclosure	X		
2. Door, Closers & Accessories	X		
3. Door Interlocks/Emergency Key/Access Keys	X		
4. Guide Rails: Main & Counterweight	X		
5. Switches and Cams	X		
6. Pit/Stop Switch/Light/Ladder	X		
7. Counterweight Guard	X		
8. Buffers: Spring or Oil	X		
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X		
10. Traveling Cable and Wiring	X		
11. Plunger, Cylinder and Gland			X
12. Governor Rope Tension Sheave & Assembly	X		
13. Compensating Sheave or Chain	X		

Elevator Inspection

Identification

South Tower

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Date: 3/4/24
BLDG.REG # 0102-00157-001
Elevator #: STS-10
Capacity: 6000 lbs STOPS: 5

Type of Inspection/Test
FA: 1Yr.: X
5Yr.: 6Mo. Alteration:
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:
Traction: D/W: Hydro: X
Certification Expires: 2/28/25

If FA, Permit No.:

Block #:30 Lot #: 2

5 Year. Test Due:

Year Built: MFGR.: Eastern Elev

Orig. Code: 1984

Mod.Year: Code

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT				S	U	NA
1. Enclosure/Lighting/Vents	X					
2. Machine/Brake/Gears/Motor	X					
3. Hydro Power Motor Unit	X					
4. Motor Generator Set/SCR Drive			X			
5. Controller/Selector	X					
6. Governor(s)			X			
7. Relief & Check Valves	X					
8. Required Disconnects	X					
9. Oil/Hydro Fluid, Leaks, Level	X					
10. Hydro Fluid Hoses or Pipe	X					
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X					
12. Routine Maintenance						
13.						
B. ELEVATOR CAR AND COUNTERWEIGHT						
1. Car Enclosure/Platform/Sling/Flooring	X					
2. Guide Shoes/Rollers	X					
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X					
4. Car Gate or Door Operator	X					
5. Car Lighting/Standard & Emergency	X					
6. Rope Hitches/Platen Hitch	X					
7. Top-of-Car Operating Station/Stop Switch	X					
8. Car Operating Station/Stop Switch/Indicators	X					
9. Emergency Signals & Communication	X					
10. Emergency Exits/Top/Side	X					
11. Safeties & Accessories			X			
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X					
13. Firefighter Service PH I & II	X					
14. Counterweight/Car & Counterweight Sheaves			X			
15. Routine Maintenance						
16.						
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT						
1. Enclosure	X					
2. Door, Closers & Accessories	X					
3. Door Interlocks/Emergency Key/Access Keys	X					
4. Guide Rails: Main & Counterweight	X					
5. Switches and Cams	X					
6. Pit/Stop Switch/Light/Ladder	X					
7. Counterweight Guard			X			
8. Buffers: Spring or Oil	X					
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail			X			
10. Traveling Cable and Wiring	X					
11. Plunger, Cylinder and Gland	X					
12. Governor Rope Tension Sheave & Assembly	X					
13. Compensating Sheave or Chain			X			

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Car Rated Speed				
3. Overspeed Switch				
4. Tripping Speed				
5. Capacity				
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number	STS-10			
2. Working Pressure				
3. Relief Pressure	520			
4. Capacity	6000			
5. Tags				
F. APPLICABLE CODES				
ASME A17.1-1984				
ACTION TAKEN				
1. Device Number	STS-10			
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812

Inspector's Name (print) and License No.

Inspector's Signature **BUD GRANT**

Elevator Inspection

Identification

South Tower

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Date: 4/2/24
BLDG.REG # 0102-00157-001
Elevator #: STS-12
Capacity: 6000 lbs STOPS: 4

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: 6Mo.: Passenger: X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:
Traction: D/W: Hydro: X
Certification Expires: 2/28/25

If FA, Permit No.:

Block #:30 Lot #: 2 5 Year. Test Due:

Year Built: MFGR.: Schindler Elev Orig. Code: 1993 Mod.Year: Code

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA	
1. Enclosure/Lighting/Vents	X			
2. Machine/Brake/Gears/Motor	X			
3. Hydro Power Motor Unit	X			
4. Motor Generator Set/SCR Drive			X	
5. Controller/Selector	X			
6. Governor(s)			X	
7. Relief & Check Valves	X			
8. Required Disconnects	X			
9. Oil/Hydro Fluid, Leaks, Level	X			
10. Hydro Fluid Hoses or Pipe	X			
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
12. Routine Maintenance				
13.				
B. ELEVATOR CAR AND COUNTERWEIGHT				
1. Car Enclosure/Platform/Sling/Flooring	X			
2. Guide Shoes/Rollers	X			
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X			
4. Car Gate or Door Operator	X			
5. Car Lighting/Standard & Emergency	X			
6. Rope Hitches/Platen Hitch	X			
7. Top-of-Car Operating Station/Stop Switch	X			
8. Car Operating Station/Stop Switch/Indicators	X			
9. Emergency Signals & Communication		X		NO PHONE
10. Emergency Exits/Top/Side	X			
11. Safeties & Accessories			X	
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
13. Firefighter Service PH I & II	X			
14. Counterweight/Car & Counterweight Sheaves			X	
15. Routine Maintenance				
16.				
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT				
1. Enclosure	X			
2. Door, Closers & Accessories	X			
3. Door Interlocks/Emergency Key/Access Keys	X			
4. Guide Rails: Main & Counterweight	X			
5. Switches and Cams	X			
6. Pit/Stop Switch/Light/Ladder	X			
7. Counterweight Guard			X	
8. Buffers: Spring or Oil	X			
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail			X	
10. Traveling Cable and Wiring	X			
11. Plunger, Cylinder and Gland	X			
12. Governor Rope Tension Sheave & Assembly	X			
13. Compensating Sheave or Chain			X	

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Car Rated Speed				
3. Overspeed Switch				
4. Tripping Speed				
5. Capacity				
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number	STS-12			
2. Working Pressure	475			
3. Relief Pressure	600			
4. Capacity	6000			
5. Tags				
F. APPLICABLE CODES				
ASME A17.1-1984				
ACTION TAKEN				
1. Device Number	STS-12			
2. Recommended Type of Certification (Cyclical Inspections Only)				TCC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812

Inspector's Name (print) and License No.

BUD GRANT

Inspector's Signature

City of Atlantic City
LICENSE and INSPECTIONS
DIVISION OF CONSTRUCTION
ELEVATOR SAFETY UNIT

Notice of Violation and Order to Terminate

Date: 4/2/24 Inspector: BUD GRANT Owner Name: Tropicana Hotel & Casino Device
Regist. #: 0102-00157-001 Owner address: 2821 Boardwalk
Project Location: Same ATLANTIC CITY, NJ 08401

Name of Person, Contractor/Maintenance Co. Performing Tests: Otis Elevator

Unit ID # STS-12

Be advised that during today's inspection/test, the following irregularities/nonconformances/violations were noted, and you are Required to ensure that they be corrected before: 30 DAYS TO REPAIR EMERG PHONE IN CAR, 30 DAYS TO REPAIR OR SHALL BE REMOVED FROM SERVICE.

(X)The elevator device may be operated during repairs/corrections

()The elevator device is locked out until the repairs/corrections are satisfactorily completed, the device is reinspected, and applicable certificate is received

Penalty Item	Repeat Item	ASME A17.1-1984	BOCA	NJAC 5:23-2009
		B9- NO EMERG PHONE		

A penalty item indicates that a violation is in penalty. A repeat item indicates the amount of times a violation has been repeated. **FAILURE TO COMPLY WITH THIS ORDER WILL SUBJECT YOU TO A PENALTY OF \$500 to \$2000 PER VIOLATION.**

If you wish to contest the validity of the above action, you may request a hearing before the Construction Board of Appeals of the County of Atlantic, within 20 business days of the receipt of these orders. The Application to the Construction Board of Appeals may be used for this purpose. Your application for your appeal must be in writing, stating your name and address, the address of the violation, the specific reason for your appeal and the nature of the relief sought by you. Forward to Construction Board of Appeals, PO Box 719, New Road & Dolphin Ave, Northfield, NJ 08225. The fee for an appeal is \$100. to be forwarded with your application.

When work to abate the violations requires a construction permit, the owner is responsible for securing such a permit. Maintenance violation (Part 12) can be found in the newest adopted code.

If you have any questions concerning this matter, please call the Elevator Safety Unit at (609) 347-6126.

Our mailing address is:

City of Atlantic City, Division of Construction, Elevator Safety,
1301 Bacharach Blvd.
Atlantic City, NJ 08401

SIGNATURE OF SUBCODE OFFICIAL _____

Elevator Inspection

Identification

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

North Tower

Date: 3/22/24
BLDG.REG # 0102-00157-002
Elevator #: NTP -2
Capacity: 3500 lbs

STOPS: 19

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: 6Mo. Passenger:X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:
Traction: X D/W: Hydro:
Certification Expires: 2/28/25

If FA, Permit No.:

Block #:30 Lot #: 2

Year Built: 1982 MFGR.: Dover-Swift

5 Year. Test Due:2025

Orig. Code: 1978 Mod. Year Code:1996

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA
1. Enclosure/Lighting/Vents	X		
2. Machine/Brake/Gears/Motor	X		
3. Hydro Power Motor Unit			X
4. Motor Generator Set/SCR Drive	X		
5. Controller/Selector	X		
6. Governor(s)	X		
7. Relief & Check Valves			X
8. Required Disconnects	X		
9. Oil/Hydro Fluid, Leaks, Level			X
10. Hydro Fluid Hoses or Pipe			X
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
12. Routine Maintenance			
13.			
B. ELEVATOR CAR AND COUNTERWEIGHT			
1. Car Enclosure/Platform/Sling/Flooring	X		
2. Guide Shoes/Rollers	X		
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X		
4. Car Gate or Door Operator	X		
5. Car Lighting/Standard & Emergency	X		
6. Rope Hitches/Platen Hitch	X		
7. Top-of-Car Operating Station/Stop Switch	X		
8. Car Operating Station/Stop Switch/Indicators	X		
9. Emergency Signals & Communication	X		
10. Emergency Exits/Top/Side	X		
11. Safeties & Accessories	X		
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
13. Firefighter Service PH I & II	X		
14. Counterweight/Car & Counterweight Sheaves	X		
15. Routine Maintenance			
16.			
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT			
1. Enclosure	X		
2. Door, Closers & Accessories	X		
3. Door Interlocks/Emergency Key/Access Keys	X		
4. Guide Rails: Main & Counterweight	X		
5. Switches and Cams	X		
6. Pit/Stop Switch/Light/Ladder	X		
7. Counterweight Guard	X		
8. Buffers: Spring or Oil	X		
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X		
10. Traveling Cable and Wiring	X		
11. Plunger, Cylinder and Gland			X
12. Governor Rope Tension Sheave & Assembly	X		
13. Compensating Sheave or Chain	X		

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number NTP2				
2. Car Rated Speed				
3. Overspeed Switch				
4. Tripping Speed				
5. Capacity 3500				
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Working Pressure				
3. Relief Pressure				
4. Capacity				
5. Tags				
F. APPLICABLE CODES				
ASME A17.1				
ACTION TAKEN				
1. Device Number NTP-2				
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attach

BUD GRANT # 8812

Inspector's Name (print) and License No.

Inspector's Signature

BUD GRANT

SCO

Elevator Inspection

Identification

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

North Tower

Date: 3/22/24
BLDG.REG # 0102-00157-002
Elevator #: **NTP-3**
Capacity: 3500 lbs STOPS: 19

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: **6Mo.** **Passenger: X**
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:
Traction: X D/W: Hydro:
Certification Expires: **2/28/25**

If FA, Permit No.:

Block #:30 Lot #: 2 **5 Year. Test Due: 2025**
Year Built: 1982 MFGR.: Dover-Swift Orig. Code: 1978 **Mod.Year Code: 1993**

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA	
1. Enclosure/Lighting/Vents	X			
2. Machine/Brake/Gears/Motor	X			
3. Hydro Power Motor Unit			X	
4. Motor Generator Set/SCR Drive	X			
5. Controller/Selector	X			
6. Governor(s)	X			
7. Relief & Check Valves			X	
8. Required Disconnects	X			
9. Oil/Hydro Fluid, Leaks, Level			X	
10. Hydro Fluid Hoses or Pipe			X	
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
12. Routine Maintenance	X			
13.				
B. ELEVATOR CAR AND COUNTERWEIGHT				
1. Car Enclosure/Platform/Sling/Flooring	X			
2. Guide Shoes/Rollers	X			
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X			
4. Car Gate or Door Operator	X			
5. Car Lighting/Standard & Emergency	X			
6. Rope Hitches/Platen Hitch	X			
7. Top-of-Car Operating Station/Stop Switch	X			
8. Car Operating Station/Stop Switch/Indicators	X			
9. Emergency Signals & Communication	X			
10. Emergency Exits/Top/Side	X			
11. Safeties & Accessories	X			
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
13. Firefighter Service PH I & II	X			
14. Counterweight/Car & Counterweight Sheaves	X			
15. Routine Maintenance				
16.				
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT				
1. Enclosure	X			
2. Door, Closers & Accessories	X			
3. Door Interlocks/Emergency Key/Access Keys	X			
4. Guide Rails: Main & Counterweight	X			
5. Switches and Cams	X			
6. Pit/Stop Switch/Light/Ladder	X			
7. Counterweight Guard	X			
8. Buffers: Spring or Oil	X			
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X			
10. Traveling Cable and Wiring	X			
11. Plunger, Cylinder and Gland			X	
12. Governor Rope Tension Sheave & Assembly	X			
13. Compensating Sheave or Chain	X			

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Car Rated Speed				
3. Overspeed Switch				
4. Tripping Speed				
5. Capacity				
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number	NTP-3			
2. Working Pressure				
3. Relief Pressure				
4. Capacity				
5. Tags				
F. APPLICABLE CODES				
ASME A17.1-1993				
ACTION TAKEN				
1. Device Number	NTP-3			
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812

Inspector's Name (print) and License No.

BUD GRANT

SCO

Elevator Inspection

Identification

North Tower

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Date: 3/22/24
BLDG.REG # 0102-00157-002
Elevator #: NTP-4
Capacity: 3500 lbs STOPS: 19

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: 6Mo. Passenger: X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:

If FA, Permit No.:

Block #:30 Lot #: 2

5 Year. Test Due: 2025

Traction:X D/W: Hydro:

Year Built: 1982 MFGR.: Dover-Swift Orig. Code: 1978 Mod.Year Code: 1993

Certification Expires: 2/28/25

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA	
1. Enclosure/Lighting/Vents	X			
2. Machine/Brake/Gears/Motor	X			
3. Hydro Power Motor Unit			X	
4. Motor Generator Set/SCR Drive	X			
5. Controller/Selector	X			
6. Governor(s)	X			
7. Relief & Check Valves			X	
8. Required Disconnects	X			
9. Oil/Hydro Fluid, Leaks, Level			X	
10. Hydro Fluid Hoses or Pipe			X	
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
12. Routine Maintenance				
13.				
B. ELEVATOR CAR AND COUNTERWEIGHT				
1. Car Enclosure/Platform/Sling/Flooring	X			
2. Guide Shoes/Rollers	X			
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X			
4. Car Gate or Door Operator	X			
5. Car Lighting/Standard & Emergency	X			
6. Rope Hitches/Platen Hitch	X			
7. Top-of-Car Operating Station/Stop Switch	X			
8. Car Operating Station/Stop Switch/Indicators	X			
9. Emergency Signals & Communication	X			
10. Emergency Exits/Top/Side	X			
11. Safeties & Accessories	X			
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
13. Firefighter Service PH I & II	X			
14. Counterweight/Car & Counterweight Sheaves	X			
15. Routine Maintenance				
16.				
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT				
1. Enclosure	X			
2. Door, Closers & Accessories	X			
3. Door Interlocks/Emergency Key/Access Keys	X			
4. Guide Rails: Main & Counterweight	X			
5. Switches and Cams	X			
6. Pit/Stop Switch/Light/Ladder	X			
7. Counterweight Guard	X			
8. Buffers: Spring or Oil	X			
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X			
10. Traveling Cable and Wiring	X			
11. Plunger, Cylinder and Gland			X	
12. Governor Rope Tension Sheave & Assembly	X			
13. Compensating Sheave or Chain	X			

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Car Rated Speed				
3. Overspeed Switch				
4. Tripping Speed				
5. Capacity				
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number NTP-4				
2. Working Pressure				
3. Relief Pressure				
4. Capacity				
5. Tags				
F. APPLICABLE CODES				
ASME A17.1-1993				
ACTION TAKEN				
1. Device Number NTP-4				
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812

Inspector's Name (print) and License No. Inspector's Signature

BUD GRANT

SCO

Elevator Inspection

Identification

North Tower

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Date: 3/25/24
BLDG.REG # 0102-00157-002
Elevator #: NTP -5
Capacity: 3500 lbs

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: 6Mo. Passenger:X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:
Traction: X D/W: Hydro:
Certification Expires: 2/28/25

If FA, Permit No.:

Block #:30 Lot #: 2

5 Year. Test Due:2024

Year Built: 1982 MFGR.: Dover-Swift

Orig. Code: 1978

Mod. Year Code:1996

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA
1. Enclosure/Lighting/Vents	X		
2. Machine/Brake/Gears/Motor	X		
3. Hydro Power Motor Unit			X
4. Motor Generator Set/SCR Drive	X		
5. Controller/Selector	X		
6. Governor(s)	X		
7. Relief & Check Valves			X
8. Required Disconnects	X		
9. Oil/Hydro Fluid, Leaks, Level			X
10. Hydro Fluid Hoses or Pipe			X
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
12. Routine Maintenance			
13.			
B. ELEVATOR CAR AND COUNTERWEIGHT			
1. Car Enclosure/Platform/Sling/Flooring	X		
2. Guide Shoes/Rollers	X		
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X		
4. Car Gate or Door Operator	X		
5. Car Lighting/Standard & Emergency	X		
6. Rope Hitches/Platen Hitch	X		
7. Top-of-Car Operating Station/Stop Switch	X		
8. Car Operating Station/Stop Switch/Indicators	X		
9. Emergency Signals & Communication	X		
10. Emergency Exits/Top/Side	X		
11. Safeties & Accessories	X		
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
13. Firefighter Service PH I & II	X		
14. Counterweight/Car & Counterweight Sheaves	X		
15. Routine Maintenance			
16.			
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT			
1. Enclosure	X		
2. Door, Closers & Accessories	X		
3. Door Interlocks/Emergency Key/Access Keys	X		
4. Guide Rails: Main & Counterweight	X		
5. Switches and Cams	X		
6. Pit/Stop Switch/Light/Ladder	X		
7. Counterweight Guard	X		
8. Buffers: Spring or Oil	X		
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X		
10. Traveling Cable and Wiring	X		
11. Plunger, Cylinder and Gland			X
12. Governor Rope Tension Sheave & Assembly	X		
13. Compensating Sheave or Chain	X		

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number NTP-5				
2. Car Rated Speed				
3. Overspeed Switch				
4. Tripping Speed				
5. Capacity 3500				
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Working Pressure				
3. Relief Pressure				
4. Capacity				
5. Tags				
F. APPLICABLE CODES				
ASME A17.1				
ACTION TAKEN				
1. Device Number NTP-5				
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attach

BUD GRANT # 8812

Inspector's Name (print) and License No. Inspector's Signature **BUD GRANT**

SCO

Elevator Inspection

Identification

North Tower

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Date: 3/25/24
BLDG.REG # 0102-00157-002
Elevator #: NTS-6
Capacity: 4500 lbs STOPS: 19

Type of Inspection/Test

FA: 1Yr.: Alteration:
5Yr.: X 6Mo: Passenger: X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:

If FA, Permit No.:

Block #:30 Lot #: 2 5 Year. Test Due: 2025

Year Built: 1982 MFGR.: Dover-Swift Orig. Code: 1978

Traction: X

D/W: Hydro:

Mod.Year: Code 1993

Certification Expires: 2/28/25

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA	
1. Enclosure/Lighting/Vents	X			
2. Machine/Brake/Gears/Motor	X			
3. Hydro Power Motor Unit			X	
4. Motor Generator Set/SCR Drive	X			
5. Controller/Selector	X			
6. Governor(s)	X			
7. Relief & Check Valves			X	
8. Required Disconnects	X			
9. Oil/Hydro Fluid, Leaks, Level			X	
10. Hydro Fluid Hoses or Pipe			X	
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
12. Routine Maintenance				
13.				
B. ELEVATOR CAR AND COUNTERWEIGHT				
1. Car Enclosure/Platform/Sling/Flooring	X			L
2. Guide Shoes/Rollers	X			
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X			
4. Car Gate or Door Operator	X			
5. Car Lighting/Standard & Emergency	X			
6. Rope Hitches/Platen Hitch	X			
7. Top-of-Car Operating Station/Stop Switch	X			
8. Car Operating Station/Stop Switch/Indicators	X			
9. Emergency Signals & Communication	X			
10. Emergency Exits/Top/Side	X			
11. Safeties & Accessories	X			
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
13. Firefighter Service PH I & II	X			
14. Counterweight/Car & Counterweight Sheaves	X			
15. Routine Maintenance				
16.				
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT				
1. Enclosure	X			
2. Door, Closers & Accessories	X			
3. Door Interlocks/Emergency Key/Access Keys	X			
4. Guide Rails: Main & Counterweight	X			
5. Switches and Cams	X			
6. Pit/Stop Switch/Light/Ladder	X			
7. Counterweight Guard	X			
8. Buffers: Spring or Oil	X			
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X			
10. Traveling Cable and Wiring	X			
11. Plunger, Cylinder and Gland			X	
12. Governor Rope Tension Sheave & Assembly	X			
13. Compensating Sheave or Chain	X			

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number	NTS-6			
2. Car Rated Speed	400			
3. Overspeed Switch	455			
4. Tripping Speed	510			
5. Capacity	6000			
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Working Pressure				
3. Relief Pressure				
4. Capacity				
5. Tags				
F. APPLICABLE CODES				
ASME A17.1 -1993				
ACTION TAKEN				
1. Device Number	NTS-6			
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812

Inspector's Name (print) and License No.

Inspector's Signature

BUD GRANT

00Elevator Inspection

Identification

North Tower

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Date: **3/25/24**
BLDG.REG # 0102-00157-002
Elevator #: **NTS-7**
Capacity: 4500 lbs STOPS: 19

Type of Inspection/Test
FA: **1Yr.: X** Alteration:
5Yr.: 6Mo: Passenger: X
3 Yr.: Reinsp: Freight:
BscI: Chairlift: Rope\H:
D/W: Hydro:
Certification Expires: **2/28/25**

If FA, Permit No.:

Block #:30 Lot #: 2 5 Year. Test Due: 2025 Traction: X
Year Built: 1982 MFGR.: Dover-Swift Orig. Code: 1978 **Mod.Year: Code 1993**

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA	
1. Enclosure/Lighting/Vents	X			
2. Machine/Brake/Gears/Motor	X			
3. Hydro Power Motor Unit			X	
4. Motor Generator Set/SCR Drive	X			
5. Controller/Selector	X			
6. Governor(s)	X			
7. Relief & Check Valves			X	
8. Required Disconnects	X			
9. Oil/Hydro Fluid, Leaks, Level			X	
10. Hydro Fluid Hoses or Pipe			X	
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
12. Routine Maintenance				
13.				
B. ELEVATOR CAR AND COUNTERWEIGHT				
1. Car Enclosure/Platform/Sling/Flooring	X			
2. Guide Shoes/Rollers	X			
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X			
4. Car Gate or Door Operator	X			
5. Car Lighting/Standard & Emergency	X			
6. Rope Hitches/Platen Hitch	X			
7. Top-of-Car Operating Station/Stop Switch	X			
8. Car Operating Station/Stop Switch/Indicators	X			
9. Emergency Signals & Communication	X			
10. Emergency Exits/Top/Side	X			
11. Safeties & Accessories	X			
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
13. Firefighter Service PH I & II	X			
14. Counterweight/Car & Counterweight Sheaves	X			
15. Routine Maintenance				
16.				
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT				
1. Enclosure	X			
2. Door, Closers & Accessories	X			
3. Door Interlocks/Emergency Key/Access Keys	X			
4. Guide Rails: Main & Counterweight	X			
5. Switches and Cams	X			
6. Pit/Stop Switch/Light/Ladder	X			
7. Counterweight Guard	X			
8. Buffers: Spring or Oil	X			
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X			
10. Traveling Cable and Wiring	X			
11. Plunger, Cylinder and Gland			X	
12. Governor Rope Tension Sheave & Assembly	X			
13. Compensating Sheave or Chain	X			

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number	NTS-7			
2. Car Rated Speed	400			
3. Overspeed Switch	455			
4. Tripping Speed	510			
5. Capacity	6000			
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Working Pressure				
3. Relief Pressure				
4. Capacity				
5. Tags				
F. APPLICABLE CODES				
ASME A17.1 -1993				
ACTION TAKEN				
1. Device Number	NTS-7			
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812

Inspector's Name (print) and License No.

Inspector's Signature

BUD GRANT

Elevator Inspection

Identification

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

North Tower

Date: 3/25/24
BLDG.REG # 0102-00157-002
Elevator #: NTS-8
Capacity: 6000 lbs STOPS: 4

Type of Inspection/Test

FA: 1Yr: X Alteration:
5Yr.: 6Mo. Passenger: X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:
Traction: X D/W: Hydro:
Certification Expires: 2/28/25

If FA, Permit No.:

Block #:30 Lot #: 2

Year Built: 1982 MFGR.: Dover-Swift

5 Year. Test Due:2025

Orig. Code: 1978 Mod.Year: Code

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA	
1. Enclosure/Lighting/Vents	X			
2. Machine/Brake/Gears/Motor	X			
3. Hydro Power Motor Unit			X	
4. Motor Generator Set/SCR Drive	X			
5. Controller/Selector	X			
6. Governor(s)	X			
7. Relief & Check Valves			X	
8. Required Disconnects	X			
9. Oil/Hydro Fluid, Leaks, Level			X	
10. Hydro Fluid Hoses or Pipe			X	
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
12. Routine Maintenance				
13.				
B. ELEVATOR CAR AND COUNTERWEIGHT				
1. Car Enclosure/Platform/Sling/Flooring	X			
2. Guide Shoes/Rollers	X			
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X			
4. Car Gate or Door Operator	X			
5. Car Lighting/Standard & Emergency	X			
6. Rope Hitches/Platen Hitch	X			
7. Top-of-Car Operating Station/Stop Switch	X			
8. Car Operating Station/Stop Switch/Indicators	X			
9. Emergency Signals & Communication	X			
10. Emergency Exits/Top/Side	X			
11. Safeties & Accessories	X			
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
13. Firefighter Service PH I & II	X			
14. Counterweight/Car & Counterweight Sheaves	X			
15. Routine Maintenance				
16.				
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT				
1. Enclosure	X			
2. Door, Closers & Accessories	X			
3. Door Interlocks/Emergency Key/Access Keys	X			
4. Guide Rails: Main & Counterweight	X			
5. Switches and Cams	X			
6. Pit/Stop Switch/Light/Ladder	X			
7. Counterweight Guard	X			
8. Buffers: Spring or Oil	X			
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X			
10. Traveling Cable and Wiring	X			
11. Plunger, Cylinder and Gland			X	
12. Governor Rope Tension Sheave & Assembly	X			
13. Compensating Sheave or Chain	X			

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number	NTS-8			
2. Car Rated Speed	200			
3. Overspeed Switch	247			
4. Tripping Speed	269			
5. Capacity	6000			
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Working Pressure				
3. Relief Pressure				
4. Capacity				
5. Tags				
F. APPLICABLE CODES				
ASME A17.1				
ACTION TAKEN				
1. Device Number	NTS-8			
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812

Inspector's Name (print) and License No.

Inspector's Signature

Elevator Inspection

Identification

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

North Tower

Date: 3/19/24
BLDG.REG # 0102-00157-002
Elevator #: NTS-9
Capacity: 6000 lbs STOPS: 4

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: 6Mo.: Passenger: X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:
Traction: X D/W: Hydro:
Certification Expires: 2/28/25

If FA, Permit No.:

Block #:30 Lot #: 2

Year Built: 1982 MFGR.: Dover-Swift

5 Year. Test Due:2025

Orig. Code: 1978 Mod.Year: Code

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA
1. Enclosure/Lighting/Vents	X		
2. Machine/Brake/Gears/Motor	X		
3. Hydro Power Motor Unit			X
4. Motor Generator Set/SCR Drive	X		
5. Controller/Selector	X		
6. Governor(s)	X		
7. Relief & Check Valves			X
8. Required Disconnects	X		
9. Oil/Hydro Fluid, Leaks, Level			X
10. Hydro Fluid Hoses or Pipe			X
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
12. Routine Maintenance	X		
13.			
B. ELEVATOR CAR AND COUNTERWEIGHT			
1. Car Enclosure/Platform/Sling/Flooring	X		
2. Guide Shoes/Rollers	X		
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X		
4. Car Gate or Door Operator	X		
5. Car Lighting/Standard & Emergency	X		
6. Rope Hitches/Platen Hitch	X		
7. Top-of-Car Operating Station/Stop Switch	X		
8. Car Operating Station/Stop Switch/Indicators	X		
9. Emergency Signals & Communication	X		
10. Emergency Exits/Top/Side	X		
11. Safeties & Accessories	X		
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
13. Firefighter Service PH I & II	X		
14. Counterweight/Car & Counterweight Sheaves	X		
15. Routine Maintenance	X		
16.			
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT			
1. Enclosure	X		
2. Door, Closers & Accessories	X		
3. Door Interlocks/Emergency Key/Access Keys	X		
4. Guide Rails: Main & Counterweight	X		
5. Switches and Cams	X		
6. Pit/Stop Switch/Light/Ladder	X		
7. Counterweight Guard	X		
8. Buffers: Spring or Oil	X		
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X		
10. Traveling Cable and Wiring	X		
11. Plunger, Cylinder and Gland			X
12. Governor Rope Tension Sheave & Assembly	X		
13. Compensating Sheave or Chain	X		

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance	X			
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Car Rated Speed	200			
3. Overspeed Switch	249			
4. Tripping Speed	269			
5. Capacity	6000			
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Working Pressure				
3. Relief Pressure				
4. Capacity				
5. Tags				
F. APPLICABLE CODES				
ASME A17.1				
NTS-9				
ACTION TAKEN				
1. Device Number	X			CC
2. Recommended Type of Certification (Cyclical Inspections Only)	X			
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT #8812

Inspector's Name (print) and License No.

Inspector's Signature

Elevator Inspection

Identification

North Tower

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Date: 4/1/24
BLDG.REG #: 0102-00157-002
Elevator #: NTS-11
Capacity: 6000 lbs STOPS: 2

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: 6Mo.: Passenger: X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:
Traction: Dumbwaiter: Hydro: X
Certification Expires: 2/28/25

If FA, Permit No.:

Block #:30 Lot #: 2 5 Year. Test Due:
Year Built: MFGR.: Dover Elev Orig. Code: 1978 Mod.Year: Code

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA	MONEY ELEVATOR
1. Enclosure/Lighting/Vents	X			
2. Machine/Brake/Gears/Motor	X			
3. Hydro Power Motor Unit			X	
4. Motor Generator Set/SCR Drive	X			
5. Controllor/Selector	X			
6. Governor(s)	X			
7. Relief & Check Valves			X	
8. Required Disconnects	X			
9. Oil/Hydro Fluid, Leaks, Level	X			
10. Hydro Fluid Hoses or Pipe			X	
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
12. Routine Maintenance				
13.				
B. ELEVATOR CAR AND COUNTERWEIGHT				
1. Car Enclosure/Platform/Sling/Flooring	X			
2. Guide Shoes/Rollers	X			
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X			
4. Car Gate or Door Operator	X			
5. Car Lighting/Standard & Emergency	X			
6. Rope Hitches/Platen Hitch	X			
7. Top-of-Car Operating Station/Stop Switch	X			
8. Car Operating Station/Stop Switch/Indicators	X			
9. Emergency Signals & Communication	X			
10. Emergency Exits/Top/Side	X			
11. Safeties & Accessories	X			
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
13. Firefighter Service PH I & II	X			
14. Counterweight/Car & Counterweight Sheaves	X			
15. Routine Maintenance				
16.				
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT				
1. Enclosure	X			
2. Door, Closers & Accessories	X			
3. Door Interlocks/Emergency Key/Access Keys	X			
4. Guide Rails: Main & Counterweight	X			
5. Switches and Cams	X			
6. Pit/Stop Switch/Light/Ladder	X			
7. Counterweight Guard	X			
8. Buffers: Spring or Oil	X			
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X			
10. Traveling Cable and Wiring	X			
11. Plunger, Cylinder and Gland			X	
12. Governor Rope Tension Sheave & Assembly	X			
13. Compensating Sheave or Chain	X			

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Car Rated Speed				
3. Overspeed Switch				
4. Tripping Speed				
5. Capacity				
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number	NTS-11			
2. Working Pressure				
3. Relief Pressure	400			
4. Capacity	6000			
5. Tags				
F. APPLICABLE CODES				
ASME A17.1				
ACTION TAKEN				
1. Device Number	NTS-11			
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812

Inspector's Name (print) and License No.

Inspector's Signature

BUD GRANT

Elevator Inspection

Identification

North Tower

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Date: 4/1/24
BLDG.REG #: 0102-00157-002
Elevator #: **NTF-12**
Capacity: 12000 lbs STOPS: 4

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: **6Mo.:** Passenger:
3 Yr.: Reinsp: **Freight: X**
Escl: Chairlift: Rope/H: X
Traction: Dumbwaiter:

If FA, Permit No.:

Block #:30 Lot #: 2 5 Year. Test Due: 2019

Hydro: X

Year Built: MFGR.: Dover Elev Orig. Code: 1971 Mod.Year: Code Certification Expires: **2/28/25**

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA
1. Enclosure/Lighting/Vents	X		
2. Machine/Brake/Gears/Motor	X		
3. Hydro Power Motor Unit	X		
4. Motor Generator Set/SCR Drive	X		
5. Controller/Selector	X		
6. Governor(s)	X		
7. Relief & Check Valves	X		
8. Required Disconnects	X		
9. Oil/Hydro Fluid, Leaks, Level	X		
10. Hydro Fluid Hoses or Pipe	X		
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
12. Routine Maintenance			
13.			
B. ELEVATOR CAR AND COUNTERWEIGHT			
1. Car Enclosure/Platform/Sling/Flooring	X		
2. Guide Shoes/Rollers	X		
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X		
4. Car Gate or Door Operator	X		
5. Car Lighting/Standard & Emergency	X		
6. Rope Hitches/Platen Hitch	X		
7. Top-of-Car Operating Station/Stop Switch	X		
8. Car Operating Station/Stop Switch/Indicators	X		
9. Emergency Signals & Communication	X		
10. Emergency Exits/Top/Side	X		
11. Safeties & Accessories	X		
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
13. Firefighter Service PH I & II	X		
14. Counterweight/Car & Counterweight Sheaves	X		
15. Routine Maintenance			
16.			
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT			
1. Enclosure	X		
2. Door, Closers & Accessories	X		
3. Door Interlocks/Emergency Key/Access Keys	X		
4. Guide Rails: Main & Counterweight	X		
5. Switches and Cams	X		
6. Pit/Stop Switch/Light/Ladder	X		
7. Counterweight Guard	X		
8. Buffers: Spring or Oil	X		
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X		
10. Traveling Cable and Wiring	X		
11. Plunger, Cylinder and Gland	X		

12. Governor Rope Tension Sheave & Assembly	X			
13. Compensating Sheave or Chain	X			
14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Car Rated Speed				
3. Overspeed Switch				
4. Tripping Speed				
5. Capacity				
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number	NTF-12			
2. Working Pressure				
3. Relief Pressure	RP 600			
4. Capacity	12000			
5. Tags				
F. APPLICABLE CODES				
ASME A17.1				
ACTION TAKEN				
1. Device Number	NTF-12			
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

Elevator Inspection

Identification

North Tower

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Date: 3/26/24
BLDG.REG #: 0102-00157-002
Elevator #: NTS-13
Capacity: 2500 lbs STOPS: 3

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: 6Mo.: Passenger: X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:
Traction: Dumbwaiter: Hydro: X
Certification Expires: 2/28/25

If FA, Permit No.:

Block #:30 Lot #: 2

5 Year. Test Due:

Year Built: MFGR.: Dover Elev

Orig. Code: 1971

Mod.Year: Code

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA
1. Enclosure/Lighting/Vents	X		
2. Machine/Brake/Gears/Motor			X
3. Hydro Power Motor Unit	X		
4. Motor Generator Set/SCR Drive			X
5. Controller/Selector	X		
6. Governor(s)			X
7. Relief & Check Valves	X		
8. Required Disconnects	X		
9. Oil/Hydro Fluid, Leaks, Level	X		
10. Hydro Fluid Hoses or Pipe	X		
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
12. Routine Maintenance			
13.			
B. ELEVATOR CAR AND COUNTERWEIGHT			
1. Car Enclosure/Platform/Sling/Flooring	X		
2. Guide Shoes/Rollers	X		
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X		
4. Car Gate or Door Operator	X		
5. Car Lighting/Standard & Emergency	X		
6. Rope Hitches/Platen Hitch	X		
7. Top-of-Car Operating Station/Stop Switch	X		
8. Car Operating Station/Stop Switch/Indicators	X		
9. Emergency Signals & Communication	X		
10. Emergency Exits/Top/Side	X		
11. Safeties & Accessories			X
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
13. Firefighter Service PH I & II	X		
14. Counterweight/Car & Counterweight Sheaves			X
15. Routine Maintenance			
16.			
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT			
1. Enclosure	X		
2. Door, Closers & Accessories	X		
3. Door Interlocks/Emergency Key/Access Keys	X		
4. Guide Rails: Main & Counterweight	X		
5. Switches and Cams	X		
6. Pit/Stop Switch/Light/Ladder	X		
7. Counterweight Guard			X
8. Buffers: Spring or Oil	X		
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail			X
10. Traveling Cable and Wiring	X		
11. Plunger, Cylinder and Gland	X		
12. Governor Rope Tension Sheave & Assembly			X
13. Compensating Sheave or Chain			X

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Car Rated Speed				
3. Overspeed Switch				
4. Tripping Speed				
5. Capacity				
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number	NTS-13			
2. Working Pressure	285			
3. Relief Pressure	420			
4. Capacity	2500			
5. Tags				
F. APPLICABLE CODES				
ASME A17.1 -1971				
ACTION TAKEN				
1. Device Number	NTS-13			
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812

Inspector's Name (print) and License No.

Inspector's Signature

BUD GRANT

Elevator Inspection

Identification

North Tower

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Date: **3/26/24**
BLDG.REG #: 0102-00157-002
Elevator #: **NTS-14**
Capacity: 2500 lbs STOPS: 3

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: **6Mo.:** **Passenger: X**
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:
Traction: Dumbwaiter: **Hydro: X**
Certification Expires: **2/28/25**

If FA, Permit No.:

Block #:30 Lot #: 2 5 Year. Test Due:
Year Built: MFGR.: Dover Elev Orig. Code: 1971 Mod.Year: Code

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA	
1. Enclosure/Lighting/Vents	X			
2. Machine/Brake/Gears/Motor			X	
3. Hydro Power Motor Unit	X			
4. Motor Generator Set/SCR Drive			X	
5. Controllor/Selector	X			
6. Governor(s)			X	
7. Relief & Check Valves	X			
8. Required Disconnects	X			
9. Oil/Hydro Fluid, Leaks, Level	X			
10. Hydro Fluid Hoses or Pipe	X			
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
12. Routine Maintenance				
13.				
B. ELEVATOR CAR AND COUNTERWEIGHT				
1. Car Enclosure/Platform/Sling/Flooring	X			
2. Guide Shoes/Rollers	X			
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X			
4. Car Gate or Door Operator	X			
5. Car Lighting/Standard & Emergency	X			
6. Rope Hitches/Platen Hitch	X			
7. Top-of-Car Operating Station/Stop Switch	X			
8. Car Operating Station/Stop Switch/Indicators	X			
9. Emergency Signals & Communication	X			
10. Emergency Exits/Top/Side	X			
11. Safeties & Accessories			X	
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
13. Firefighter Service PH I & II	X			
14. Counterweight/Car & Counterweight Sheaves			X	
15. Routine Maintenance				
16.				
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT				
1. Enclosure	X			
2. Door, Closers & Accessories	X			
3. Door Interlocks/Emergency Key/Access Keys	X			
4. Guide Rails: Main & Counterweight	X			
5. Switches and Cams	X			
6. Pit/Stop Switch/Light/Ladder	X			
7. Counterweight Guard			X	
8. Buffers: Spring or Oil	X			
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail			X	
10. Traveling Cable and Wiring	X			
11. Plunger, Cylinder and Gland	X			
12. Governor Rope Tension Sheave & Assembly			X	
13. Compensating Sheave or Chain			X	

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance	X			
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Car Rated Speed				
3. Overspeed Switch				
4. Tripping Speed				
5. Capacity				
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number	NTS-14			
2. Working Pressure	285			
3. Relief Pressure	400			
4. Capacity	2500			
5. Tags				
F. APPLICABLE CODES				
ASME A17.1-1971				
NTS-14				
ACTION TAKEN				
1. Device Number				
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT

BUD GRANT # 8812
Inspector's Name (print) and License No.

Inspector's Signature

Elevator Inspection

Identification

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

TRANS CENTER

Date: 4/2/24
BLDG.REG # 0102-00157-003
Elevator #: AP-3
Capacity: 3000 lbs Stops: 10

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: 6Mo.: Passenger:
3 Yr.: Reinsp: Freight:
Escalator: Chairlift: Rope/H:
Traction: X D/W: Hydro:
Certification Expires: 2/28/25

If FA, Permit No.:

Block #:30 Lot #: 2

5 Year. Test Due:2025

Year Built: MFGR.: SCH- BELT Orig. Code: 1984 Mod.Year: Code

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA	BELT DRIVE
1. Enclosure/Lighting/Vents	X			
2. Machine/Brake/Gears/Motor	X			
3. Hydro Power Motor Unit			X	
4. Motor Generator Set/SCR Drive	X			
5. Controller/Selector	X			
6. Governor(s)	X			
7. Relief & Check Valves			X	
8. Required Disconnects	X			
9. Oil/Hydro Fluid, Leaks, Level			X	
10. Hydro Fluid Hoses or Pipe			X	
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
12. Routine Maintenance				
13.				
B. ELEVATOR CAR AND COUNTERWEIGHT	X			
1. Car Enclosure/Platform/Sling/Flooring	X			
2. Guide Shoes/Rollers	X			
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X			
4. Car Gate or Door Operator	X			
5. Car Lighting/Standard & Emergency	X			
6. Rope Hitches/Platen Hitch	X			
7. Top-of-Car Operating Station/Stop Switch	X			
8. Car Operating Station/Stop Switch/Indicators	X			
9. Emergency Signals & Communication	X			
10. Emergency Exits/Top/Side	X			
11. Safeties & Accessories	X			
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
13. Firefighter Service PH I & II	X			
14. Counterweight/Car & Counterweight Sheaves	X			
15. Routine Maintenance				
16.				
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT				
1. Enclosure	X			
2. Door, Closers & Accessories	X			
3. Door Interlocks/Emergency Key/Access Keys	X			
4. Guide Rails: Main & Counterweight	X			
5. Switches and Cams	X			
6. Pit/Stop Switch/Light/Ladder	X			
7. Counterweight Guard	X			
8. Buffers: Spring or Oil	X			
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X			
10. Traveling Cable and Wiring	X			
11. Plunger, Cylinder and Gland	X			
12. Governor Rope Tension Sheave & Assembly	X			

13. Compensating Sheave or Chain				
14. Clearances and Runby				
15. Seals, Plates, Labels, Tags				
16. Hall Station/Hall Position Indicator (if required), Hall Lantern				
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number	AP-3			
2. Car Rated Speed	350			
3. Overspeed Switch	360			
4. Tripping Speed	415			
5. Capacity	3000			
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Working Pressure				
3. Relief Pressure				
4. Capacity				
5. Tags				
F. APPLICABLE CODES				
ASME A17.1 -1984				
ACTION TAKEN				
1. Device Number	AP-3			
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812
Inspector's Name (print) and License No.

BUD GRANT
Inspector's Signature

Elevator Inspection

Identification

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

TRANS CENTER

Date: 4/2/24
BLDG.REG # 0102-00157-003
Elevator #: AP-4
Capacity: 3000 lbs Stops: 10

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: 6Mo.: Passenger:
3 Yr.: Reinsp: Freight:
Escalator: Chairlift: Rope/H:
Traction: X D/W: Hydro:
Certification Expires: 2/28/25

If FA, Permit No.:

Block #:30 Lot #: 2

Year Built: MFGR.: SCH-BELT Orig. Code: 1984 Mod.Year: Code

5 Year. Test Due:2015

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA	BELT DRIVE
1. Enclosure/Lighting/Vents	X			
2. Machine/Brake/Gears/Motor	X			
3. Hydro Power Motor Unit			X	
4. Motor Generator Set/SCR Drive	X			
5. Controller/Selector	X			
6. Governor(s)	X			
7. Relief & Check Valves			X	
8. Required Disconnects	X			
9. Oil/Hydro Fluid, Leaks, Level			X	
10. Hydro Fluid Hoses or Pipe			X	
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
12. Routine Maintenance				
13.				
B. ELEVATOR CAR AND COUNTERWEIGHT	X			
1. Car Enclosure/Platform/Sling/Flooring	X			
2. Guide Shoes/Rollers	X			
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X			
4. Car Gate or Door Operator	X			
5. Car Lighting/Standard & Emergency	X			
6. Rope Hitches/Platen Hitch	X			
7. Top-of-Car Operating Station/Stop Switch	X			
8. Car Operating Station/Stop Switch/Indicators	X			
9. Emergency Signals & Communication	X			
10. Emergency Exits/Top/Side	X			
11. Safeties & Accessories	X			
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
13. Firefighter Service PH I & II	X			
14. Counterweight/Car & Counterweight Sheaves	X			
15. Routine Maintenance				
16.				
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT				
1. Enclosure	X			
2. Door, Closers & Accessories	X			
3. Door Interlocks/Emergency Key/Access Keys	X			
4. Guide Rails: Main & Counterweight	X			
5. Switches and Cams	X			
6. Pit/Stop Switch/Light/Ladder	X			
7. Counterweight Guard	X			
8. Buffers: Spring or Oil	X			
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X			
10. Traveling Cable and Wiring	X			
11. Plunger, Cylinder and Gland	X			
12. Governor Rope Tension Sheave & Assembly	X			

13. Compensating Sheave or Chain			X	
14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number	AP-4			
2. Car Rated Speed	350			
3. Overspeed Switch	334			
4. Tripping Speed	385			
5. Capacity	3000			
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Working Pressure				
3. Relief Pressure				
4. Capacity				
5. Tags				
F. APPLICABLE CODES				
ASME A17.1 -1984				
ACTION TAKEN				
1. Device Number	AP-4			
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812
Inspector's Name (print) and License No.

BUD GRANT
Inspector's Signature

Elevator Inspection

Identification

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

West Tower

Date: 3/5/24
BLDG.REG # 0102-00157-004
Elevator #: WTP-1
Capacity: 3000 lbs STOPS: 23

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: 6Mo.: Passenger X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:

If FA, Permit No.:

Block #:30 Lot #: 2

5 Year. Test Due:2024

Traction: X

D/W: Hydro:

Year Built: MFGR.: MCE

Orig. Code: 1993

Mod.Year: Code

Certification Expires: 2/28/25

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA
1. Enclosure/Lighting/Vents	X		
2. Machine/Brake/Gears/Motor	X		
3. Hydro Power Motor Unit			X
4. Motor Generator Set/SCR Drive	X		
5. Controllor/Selector	X		
6. Governor(s)	X		
7. Relief & Check Valves			X
8. Required Disconnects	X		
9. Oil/Hydro Fluid, Leaks, Level			X
10. Hydro Fluid Hoses or Pipe			X
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
12. Routine Maintenance			
13.			
B. ELEVATOR CAR AND COUNTERWEIGHT			
1. Car Enclosure/Platform/Sling/Flooring	X		
2. Guide Shoes/Rollers	X		
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X		
4. Car Gate or Door Operator	X		
5. Car Lighting/Standard & Emergency	X		
6. Rope Hitches/Platen Hitch	X		
7. Top-of-Car Operating Station/Stop Switch	X		
8. Car Operating Station/Stop Switch/Indicators	X		
9. Emergency Signals & Communication	X		
10. Emergency Exits/Top/Side	X		
11. Safeties & Accessories	X		
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
13. Firefighter Service PH I & II	X		
14. Counterweight/Car & Counterweight Sheaves	X		
15. Routine Maintenance			
16.			
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT			
1. Enclosure	X		
2. Door, Closers & Accessories	X		
3. Door Interlocks/Emergency Key/Access Keys	X		
4. Guide Rails: Main & Counterweight	X		
5. Switches and Cams	X		
6. Pit/Stop Switch/Light/Ladder	X		
7. Counterweight Guard	X		
8. Buffers: Spring or Oil	X		
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X		
10. Traveling Cable and Wiring	X		
11. Plunger, Cylinder and Gland			X
12. Governor Rope Tension Sheave & Assembly	X		
13. Compensating Sheave or Chain	X		

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number	WTP-1			
2. Car Rated Speed	700			
3. Overspeed Switch	812			
4. Tripping Speed	849			
5. Capacity	3000			
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Working Pressure				
3. Relief Pressure				
4. Capacity				
5. Tags				
F. APPLICABLE CODES				
ASME A17.1				
ACTION TAKEN				
1. Device Number	WTP-1			
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812

Inspector's Name (print) and License No. Inspector's Signature

BUD GRANT

SCO

Elevator Inspection

Identification

West Tower

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Date: 3/5/24
BLDG.REG # 0102-00157-004
Elevator #: WTP-2
Capacity: 3000 lbs STOPS: 23

Type of Inspection/Test
FA: 1Yr.: X Alteration:
5Yr.: 6Mo.: Passenger X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:

If FA, Permit No.:

Block #:30 Lot #: 2

5 Year. Test Due:2025

Traction: X D/W: Hydro:

Year Built: MFGR.: MCE Orig. Code: 1993 Mod.Year: Code

Certification Expires: 2/28/25

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA
1. Enclosure/Lighting/Vents	X		
2. Machine/Brake/Gears/Motor	X		
3. Hydro Power Motor Unit			X
4. Motor Generator Set/SCR Drive	X		
5. Controller/Selector	X		
6. Governor(s)	X		
7. Relief & Check Valves			X
8. Required Disconnects	X		
9. Oil/Hydro Fluid, Leaks, Level			X
10. Hydro Fluid Hoses or Pipe			X
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
12. Routine Maintenance			
13.			
B. ELEVATOR CAR AND COUNTERWEIGHT			
1. Car Enclosure/Platform/Sling/Flooring	X		
2. Guide Shoes/Rollers	X		
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X		
4. Car Gate or Door Operator	X		
5. Car Lighting/Standard & Emergency	X		
6. Rope Hitches/Platen Hitch	X		
7. Top-of-Car Operating Station/Stop Switch	X		
8. Car Operating Station/Stop Switch/Indicators	X		
9. Emergency Signals & Communication	X		
10. Emergency Exits/Top/Side	X		
11. Safeties & Accessories	X		
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
13. Firefighter Service PH I & II	X		
14. Counterweight/Car & Counterweight Sheaves	X		
15. Routine Maintenance			
16.			
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT			
1. Enclosure	X		
2. Door, Closers & Accessories	X		
3. Door Interlocks/Emergency Key/Access Keys	X		
4. Guide Rails: Main & Counterweight	X		
5. Switches and Cams	X		
6. Pit/Stop Switch/Light/Ladder	X		
7. Counterweight Guard	X		
8. Buffers: Spring or Oil	X		
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X		
10. Traveling Cable and Wiring	X		
11. Plunger, Cylinder and Gland			X
12. Governor Rope Tension Sheave & Assembly	X		
13. Compensating Sheave or Chain	X		

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number	WTP-2			
2. Car Rated Speed	700			
3. Overspeed Switch	820			
4. Tripping Speed	855			
5. Capacity	3000			
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Working Pressure				
3. Relief Pressure				
4. Capacity				
5. Tags				
F. APPLICABLE CODES				
ASME A17.1				
ACTION TAKEN				
1. Device Number	WTP-2			
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812

Inspector's Name (print) and License No. Inspector's Signature **BUD GRANT**

SCO

Elevator Inspection

Identification

West Tower

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Date: 3/5/24
BLDG.REG # 0102-00157-004
Elevator #: WTP-3
Capacity: 3000 lbs STOPS: 23

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: 6Mo.: Passenger X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:

If FA, Permit No.:

Block #:30 Lot #: 2

5 Year. Test Due:2025

Traction: X

D/W:

Hydro:

Year Built: MFGR.: MCE

Orig. Code: 1993

Mod.Year: Code

Certification Expires: 2/28/25

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA
1. Enclosure/Lighting/Vents	X		
2. Machine/Brake/Gears/Motor	X		
3. Hydro Power Motor Unit			X
4. Motor Generator Set/SCR Drive	X		
5. Controller/Selector	X		
6. Governor(s)	X		
7. Relief & Check Valves			X
8. Required Disconnects	X		
9. Oil/Hydro Fluid, Leaks, Level			X
10. Hydro Fluid Hoses or Pipe			X
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
12. Routine Maintenance			
13.			
B. ELEVATOR CAR AND COUNTERWEIGHT			
1. Car Enclosure/Platform/Sling/Flooring	X		
2. Guide Shoes/Rollers	X		
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X		
4. Car Gate or Door Operator	X		
5. Car Lighting/Standard & Emergency	X		
6. Rope Hitches/Platen Hitch	X		
7. Top-of-Car Operating Station/Stop Switch	X		
8. Car Operating Station/Stop Switch/Indicators	X		
9. Emergency Signals & Communication	X		
10. Emergency Exits/Top/Side	X		
11. Safeties & Accessories	X		
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
13. Firefighter Service PH I & II	X		
14. Counterweight/Car & Counterweight Sheaves	X		
15. Routine Maintenance			
16.			
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT			
1. Enclosure	X		
2. Door, Closers & Accessories	X		
3. Door Interlocks/Emergency Key/Access Keys	X		
4. Guide Rails: Main & Counterweight	X		
5. Switches and Cams	X		
6. Pit/Stop Switch/Light/Ladder	X		
7. Counterweight Guard	X		
8. Buffers: Spring or Oil	X		
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X		
10. Traveling Cable and Wiring	X		
11. Plunger, Cylinder and Gland			X
12. Governor Rope Tension Sheave & Assembly	X		
13. Compensating Sheave or Chain	X		

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number	WTP-3			
2. Car Rated Speed	700			
3. Overspeed Switch	813			
4. Tripping Speed	845			
5. Capacity	3000			
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Working Pressure				
3. Relief Pressure				
4. Capacity				
5. Tags				
F. APPLICABLE CODES				
ASME A17.1				
ACTION TAKEN				
1. Device Number	WTP-3			
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812

Inspector's Name (print) and License No. Inspector's Signature **BUD GRANT**

SCO

Elevator Inspection

Identification

West Tower

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Date: 3/5/24
BLDG.REG # 0102-00157-004
Elevator #: WTP-4
Capacity: 3000 lbs
STOPS: 23

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: 6Mo.: Passenger X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:

If FA, Permit No.:

Block #:30 Lot #: 2

Year Built: MFGR.: MCE

5 Year. Test Due: 2025

Orig. Code: 1993 Mod.Year: Code

Traction: X D/W: Hydro:

Certification Expires: 2/28/25

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA	
1. Enclosure/Lighting/Vents	X			
2. Machine/Brake/Gears/Motor	X			
3. Hydro Power Motor Unit			X	
4. Motor Generator Set/SCR Drive	X			
5. Controller/Selector	X			
6. Governor(s)	X			
7. Relief & Check Valves			X	
8. Required Disconnects	X			
9. Oil/Hydro Fluid, Leaks, Level			X	
10. Hydro Fluid Hoses or Pipe			X	
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
12. Routine Maintenance	X			
13.				
B. ELEVATOR CAR AND COUNTERWEIGHT				
1. Car Enclosure/Platform/Sling/Flooring	X			
2. Guide Shoes/Rollers	X			
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X			
4. Car Gate or Door Operator	X			
5. Car Lighting/Standard & Emergency	X			
6. Rope Hitches/Platen Hitch	X			
7. Top-of-Car Operating Station/Stop Switch	X			
8. Car Operating Station/Stop Switch/Indicators	X			
9. Emergency Signals & Communication	X			
10. Emergency Exits/Top/Side	X			
11. Safeties & Accessories	X			
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
13. Firefighter Service PH I & II	X			
14. Counterweight/Car & Counterweight Sheaves	X			
15. Routine Maintenance				
16.				
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT				
1. Enclosure	X			
2. Door, Closers & Accessories	X			
3. Door Interlocks/Emergency Key/Access Keys	X			
4. Guide Rails: Main & Counterweight	X			
5. Switches and Cams	X			
6. Pit/Stop Switch/Light/Ladder	X			
7. Counterweight Guard	X			
8. Buffers: Spring or Oil	X			
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X			
10. Traveling Cable and Wiring	X			
11. Plunger, Cylinder and Gland			X	
12. Governor Rope Tension Sheave & Assembly	X			
13. Compensating Sheave or Chain	X			

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number	WTP-4			
2. Car Rated Speed	700			
3. Overspeed Switch	811			
4. Tripping Speed	855			
5. Capacity	3000			
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Working Pressure				
3. Relief Pressure				
4. Capacity				
5. Tags				
F. APPLICABLE CODES				
Original Code:	ASME A17.1-1993			
Modernization:	2009			
Mod. Code:	2004			
ACTION TAKEN				
1. Device Number	WTP-4			
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812

Inspector's Name (print) and License No. Inspector's Signature *BUD GRANT*

SCO

Elevator Inspection

Identification

West Tower

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Date: 3/5/24
BLDG.REG # 0102-00157-004
Elevator #: WTS-5
Capacity: 4500 lbs
STOPS: 23

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: 6Mo.: Passenger X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:
Traction: X D/W: Hydro:

If FA, Permit No.:

Block #:30 Lot #: 2

5 Year. Test Due: 2025

Year Built: MFGR.: MCE

Orig. Code: 1993

Mod.Year: Code

Certification Expires: 2/28/25

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA
1. Enclosure/Lighting/Vents	X		
2. Machine/Brake/Gears/Motor	X		
3. Hydro Power Motor Unit			X
4. Motor Generator Set/SCR Drive	X		
5. Controller/Selector	X		
6. Governor(s)	X		
7. Relief & Check Valves			X
8. Required Disconnects	X		
9. Oil/Hydro Fluid, Leaks, Level			X
10. Hydro Fluid Hoses or Pipe			X
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
12. Routine Maintenance			
13.			
B. ELEVATOR CAR AND COUNTERWEIGHT			
1. Car Enclosure/Platform/Sling/Flooring	X		
2. Guide Shoes/Rollers	X		
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X		
4. Car Gate or Door Operator	X		
5. Car Lighting/Standard & Emergency	X		
6. Rope Hitches/Platen Hitch	X		
7. Top-of-Car Operating Station/Stop Switch	X		
8. Car Operating Station/Stop Switch/Indicators	X		
9. Emergency Signals & Communication	X		
10. Emergency Exits/Top/Side	X		
11. Safeties & Accessories	X		
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
13. Firefighter Service PH I & II	X		
14. Counterweight/Car & Counterweight Sheaves	X		
15. Routine Maintenance			
16.			
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT			
1. Enclosure	X		
2. Door, Closers & Accessories	X		
3. Door Interlocks/Emergency Key/Access Keys	X		
4. Guide Rails: Main & Counterweight	X		
5. Switches and Cams	X		
6. Pit/Stop Switch/Light/Ladder	X		
7. Counterweight Guard	X		
8. Buffers: Spring or Oil	X		
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X		
10. Traveling Cable and Wiring	X		
11. Plunger, Cylinder and Gland			X
12. Governor Rope Tension Sheave & Assembly	X		
13. Compensating Sheave or Chain	X		

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number WTS-5				
2. Car Rated Speed 500				
3. Overspeed Switch 525				
4. Tripping Speed 625				
5. Capacity 4500				
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Working Pressure				
3. Relief Pressure				
4. Capacity				
5. Tags				
F. APPLICABLE CODES				
ASME A17.1				
ACTION TAKEN				
1. Device Number WTS-5				
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812

Inspector's Name (print) and License No. Inspector's Signature **BUD GRANT**

SCO

Elevator Inspection

Identification

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

West Tower

Date, 3/5/24
BLDG.REG # 0102-00157-004
Elevator #: WTS-6
Capacity: 4500 lbs STOPS: 23

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: 6Mo.: Passenger X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:
Traction: X D/W: Hydro:

If FA, Permit No.:

Block #:30 Lot #: 2 5 Year. Test Due: 2024
Year Built: MFGR.: MCE Orig. Code: 1993 Mod.Year:2009 Code:2004 Certification Expires: 2/28/25

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA
1. Enclosure/Lighting/Vents	X		
2. Machine/Brake/Gears/Motor	X		
3. Hydro Power Motor Unit			X
4. Motor Generator Set/SCR Drive	X		
5. Controller/Selector	X		
6. Governor(s)	X		
7. Relief & Check Valves			X
8. Required Disconnects	X		
9. Oil/Hydro Fluid, Leaks, Level			X
10. Hydro Fluid Hoses or Pipe			X
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
12. Routine Maintenance	X		
13.			
B. ELEVATOR CAR AND COUNTERWEIGHT			
1. Car Enclosure/Platform/Sling/Flooring	X		
2. Guide Shoes/Rollers	X		
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X		
4. Car Gate or Door Operator	X		
5. Car Lighting/Standard & Emergency	X		
6. Rope Hitches/Platen Hitch	X		
7. Top-of-Car Operating Station/Stop Switch	X		
8. Car Operating Station/Stop Switch/Indicators	X		
9. Emergency Signals & Communication	X		
10. Emergency Exits/Top/Side	X		
11. Safeties & Accessories	X		
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
13. Firefighter Service PH I & II	X		
14. Counterweight/Car & Counterweight Sheaves	X		
15. Routine Maintenance	X		
16.			
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT			
1. Enclosure	X		
2. Door, Closers & Accessories	X		
3. Door Interlocks/Emergency Key/Access Keys	X		
4. Guide Rails: Main & Counterweight	X		
5. Switches and Cams	X		
6. Pit/Stop Switch/Light/Ladder	X		
7. Counterweight Guard	X		
8. Buffers: Spring or Oil	X		
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X		
10. Traveling Cable and Wiring	X		
11. Plunger, Cylinder and Gland			X
12. Governor Rope Tension Sheave & Assembly	X		
13. Compensating Sheave or Chain	X		

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number WTS-6				
2. Car Rated Speed 500				
3. Overspeed Switch 550				
4. Tripping Speed 615				
5. Capacity 4500				
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Working Pressure				
3. Relief Pressure				
4. Capacity				
5. Tags				
F. APPLICABLE CODES				
ASME A17.1-1993				
ACTION TAKEN				
1. Device Number WTS-6				
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812

Inspector's Name (print) and License No. Inspector's Signature

BUD GRANT

SCO

Elevator Inspection

Identification

Quarter

I - MAX THEATER

Name: Tropicana Hotel & Casino

Date: 3/19/24

Type of Inspection/Test

Address: 2821 Boardwalk

BLDG.REG # 0102-00157-008

FA: 1Yr.: X Alteration:

City/State/Zip: ATLANTIC CITY, NJ 08401

Elevator #: QP-15 IMAX

5Yr.: 6Mo.: Passenger: X

Capacity: 2100 lbs STOPS: 5

3 Yr.: Reinsp: Freight:

If FA, Permit No.:

Escl: Chairlift: Rope/H: X

Block #:30

Lot #: 2

5 Year, Test Due: 2024

Traction: Dumbwaiter: Hydro:

Year Built:

MFGR.: Otis Elev

Orig. Code: 1993

Mod.Year: Code

Certification Expires: 2/28/25

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA
1. Enclosure/Lighting/Vents	X		
2. Machine/Brake/Gears/Motor			X
3. Hydro Power Motor Unit	X		
4. Motor Generator Set/SCR Drive			X
5. Controller/Selector	X		
6. Governor(s)	X		
7. Relief & Check Valves	X		
8. Required Disconnects	X		
9. Oil/Hydro Fluid, Leaks, Level	X		
10. Hydro Fluid Hoses or Pipe	X		
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
12. Routine Maintenance			
13.			
B. ELEVATOR CAR AND COUNTERWEIGHT			
1. Car Enclosure/Platform/Sling/Flooring	X		
2. Guide Shoes/Rollers	X		
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X		
4. Car Gate or Door Operator	X		
5. Car Lighting/Standard & Emergency	X		
6. Rope Hitches/Platen Hitch	X		
7. Top-of-Car Operating Station/Stop Switch	X		
8. Car Operating Station/Stop Switch/Indicators	X		
9. Emergency Signals & Communication	X		
10. Emergency Exits/Top/Side	X		
11. Safeties & Accessories	X		
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
13. Firefighter Service PH I & II	X		
14. Counterweight/Car & Counterweight Sheaves			X
15. Routine Maintenance			
16.			
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT			
1. Enclosure	X		
2. Door, Closers & Accessories	X		
3. Door Interlocks/Emergency Key/Access Keys	X		
4. Guide Rails: Main & Counterweight	X		
5. Switches and Cams	X		
6. Pit/Stop Switch/Light/Ladder	X		
7. Counterweight Guard			X
8. Buffers: Spring or Oil	X		
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X		
10. Traveling Cable and Wiring	X		
11. Plunger, Cylinder and Gland			X
12. Governor Rope Tension Sheave & Assembly	X		
13. Compensating Sheave or Chain	X		

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Car Rated Speed				
3. Overspeed Switch				
4. Tripping Speed				
5. Capacity				
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number	QP-15			
2. Working Pressure	535			
3. Relief Pressure	680			
4. Capacity	2100			
5. Tags				
F. APPLICABLE CODES				
ASME A17.1 - 1993				
ACTION TAKEN				
1. Device Number	QP-15			
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812

Inspector's Name (print) and License No.

Inspector's Signature **BUD GRANT**

Elevator Inspection

Identification

Quarter

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Date: 3/14/24
BLDG.REG # 0102-00157-008
Elevator #: QP-3
Capacity: 3500 lbs
STOPS: 19

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: 6Mo.: Passenger: X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:
Traction: X Dumbwaiter: Hydro:
Certification Expires: 2/28/25

If FA, Permit No.:

Block #:30 Lot #: 2

5 Year. Test Due: 2025

Year Built: MFGR.: Otis Elev Orig. Code: 1993 Mod.Year: Code

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA
1. Enclosure/Lighting/Vents	X		
2. Machine/Brake/Gears/Motor	X		
3. Hydro Power Motor Unit			X
4. Motor Generator Set/SCR Drive	X		
5. Controller/Selector	X		
6. Governor(s)	X		
7. Relief & Check Valves			X
8. Required Disconnects	X		
9. Oil/Hydro Fluid, Leaks, Level			X
10. Hydro Fluid Hoses or Pipe			X
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
12. Routine Maintenance			
13.			
B. ELEVATOR CAR AND COUNTERWEIGHT			
1. Car Enclosure/Platform/Sling/Flooring	X		
2. Guide Shoes/Rollers	X		
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X		
4. Car Gate or Door Operator	X		
5. Car Lighting/Standard & Emergency	X		
6. Rope Hitches/Platen Hitch	X		
7. Top-of-Car Operating Station/Stop Switch	X		
8. Car Operating Station/Stop Switch/Indicators	X		
9. Emergency Signals & Communication	X		
10. Emergency Exits/Top/Side	X		
11. Safeties & Accessories	X		
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
13. Firefighter Service PH I & II	X		
14. Counterweight/Car & Counterweight Sheaves	X		
15. Routine Maintenance			
16.			
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT			
1. Enclosure	X		
2. Door, Closers & Accessories	X		
3. Door Interlocks/Emergency Key/Access Keys	X		
4. Guide Rails: Main & Counterweight	X		
5. Switches and Cams	X		
6. Pit/Stop Switch/Light/Ladder	X		
7. Counterweight Guard	X		
8. Buffers: Spring or Oil	X		
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X		
10. Traveling Cable and Wiring	X		
11. Plunger, Cylinder and Gland			X
12. Governor Rope Tension Sheave & Assembly	X		
13. Compensating Sheave or Chain	X		

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number	QP-3			
2. Car Rated Speed	700			
3. Overspeed Switch	762			
4. Tripping Speed	810			
5. Capacity	3500			
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Working Pressure				
3. Relief Pressure				
4. Capacity				
5. Tags				
F. APPLICABLE CODES				
ASME A17.1 -1993				
ACTION TAKEN				
1. Device Number	QP-3			
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812

Inspector's Name (print) and License No. Inspector's Signature **BUD GRANT**

SCO

Elevator Inspection

Identification

Quarter

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Date: 3/14/24
BLDG.REG # 0102-00157-008
Elevator #: QP-2
Capacity: 3500 lbs
STOPS: 19

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: 6Mo.: Passenger: X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:
Traction: X Dumbwaiter: Hydro:
Certification Expires: 2/28/25

If FA, Permit No.:

Block #:30 Lot #: 2

5 Year. Test Due: 2025

Year Built: MFGR.: Otis Elev Orig. Code: 1993 Mod.Year: Code

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA
1. Enclosure/Lighting/Vents	X		
2. Machine/Brake/Gears/Motor	X		
3. Hydro Power Motor Unit			X
4. Motor Generator Set/SCR Drive	X		
5. Controller/Selector	X		
6. Governor(s)	X		
7. Relief & Check Valves			X
8. Required Disconnects	X		
9. Oil/Hydro Fluid, Leaks, Level			X
10. Hydro Fluid Hoses or Pipe			X
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
12. Routine Maintenance			
13.			
B. ELEVATOR CAR AND COUNTERWEIGHT			
1. Car Enclosure/Platform/Sling/Flooring	X		
2. Guide Shoes/Rollers	X		
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X		
4. Car Gate or Door Operator	X		
5. Car Lighting/Standard & Emergency	X		
6. Rope Hitches/Platen Hitch	X		
7. Top-of-Car Operating Station/Stop Switch	X		
8. Car Operating Station/Stop Switch/Indicators	X		
9. Emergency Signals & Communication	X		
10. Emergency Exits/Top/Side	X		
11. Safeties & Accessories	X		
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
13. Firefighter Service PH I & II	X		
14. Counterweight/Car & Counterweight Sheaves	X		
15. Routine Maintenance			
16.			
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT			
1. Enclosure	X		
2. Door, Closers & Accessories	X		
3. Door Interlocks/Emergency Key/Access Keys	X		
4. Guide Rails: Main & Counterweight	X		
5. Switches and Cams	X		
6. Pit/Stop Switch/Light/Ladder	X		
7. Counterweight Guard	X		
8. Buffers: Spring or Oil	X		
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X		
10. Traveling Cable and Wiring	X		
11. Plunger, Cylinder and Gland			X
12. Governor Rope Tension Sheave & Assembly	X		
13. Compensating Sheave or Chain	X		

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number	QP-2			
2. Car Rated Speed	700			
3. Overspeed Switch	750			
4. Tripping Speed	830			
5. Capacity	3500			
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Working Pressure				
3. Relief Pressure				
4. Capacity				
5. Tags				
F. APPLICABLE CODES				
ASME A17.1				
ACTION TAKEN				
1. Device Number	QP-2			
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT #8812

Inspector's Name (print) and License No.

Inspector's Signature **BUD GRANT**

Elevator Inspection

Identification

Quarter

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Date: 3/14/24
BLDG.REG # 0102-00157-008
Elevator #: QP-1
Capacity: 3500 lbs
STOPS: 19
5 Year. Test Due: 2025

Type of Inspection/Test

FA: 1Yr. X Alteration:
5Yr. 6Mo.: Passenger: X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:
Traction: X Dumbwaiter:

If FA, Permit No.:

Block #:30 Lot #: 2

Hydro:

Year Built: MFGR.: Otis Elev Orig. Code: 1993 Mod.Year: Code Certification Expires: 2/28/25

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA	
1. Enclosure/Lighting/Vents	X			
2. Machine/Brake/Gears/Motor	X			
3. Hydro Power Motor Unit			X	
4. Motor Generator Set/SCR Drive	X			
5. Controller/Selector	X			
6. Governor(s)	X			
7. Relief & Check Valves			X	
8. Required Disconnects	X			
9. Oil/Hydro Fluid, Leaks, Level			X	
10. Hydro Fluid Hoses or Pipe			X	
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
12. Routine Maintenance				
13.				
B. ELEVATOR CAR AND COUNTERWEIGHT				
1. Car Enclosure/Platform/Sling/Flooring	X			
2. Guide Shoes/Rollers	X			
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X			
4. Car Gate or Door Operator	X			
5. Car Lighting/Standard & Emergency	X			
6. Rope Hitches/Platen Hitch	X			
7. Top-of-Car Operating Station/Stop Switch	X			
8. Car Operating Station/Stop Switch/Indicators	X			
9. Emergency Signals & Communication	X			
10. Emergency Exits/Top/Side	X			
11. Safeties & Accessories	X			
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
13. Firefighter Service PH I & II	X			
14. Counterweight/Car & Counterweight Sheaves	X			
15. Routine Maintenance				
16.				
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT				
1. Enclosure	X			
2. Door, Closers & Accessories	X			
3. Door Interlocks/Emergency Key/Access Keys	X			
4. Guide Rails: Main & Counterweight	X			
5. Switches and Cams	X			
6. Pit/Stop Switch/Light/Ladder	X			
7. Counterweight Guard	X			
8. Buffers: Spring or Oil	X			
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X			
10. Traveling Cable and Wiring	X			
11. Plunger, Cylinder and Gland			X	
12. Governor Rope Tension Sheave & Assembly	X			

13. Compensating Sheave or Chain	X			
14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number	QP-1			
2. Car Rated Speed	700			
3. Overspeed Switch	780			
4. Tripping Speed	845			
5. Capacity	3500			
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Working Pressure				
3. Relief Pressure				
4. Capacity				
5. Tags				
F. APPLICABLE CODES				
ASME A17.1 -1993				
ACTION TAKEN				
1. Device Number	QP-1			
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812

Inspector's Name (print) and License No.

Inspector's Signature

BUD GRANT

Elevator Inspection

Identification

Quarter

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Date: 3/14/24
BLDG.REG # 0102-00157-008
Elevator #: OP-5
Capacity: 3500 lbs STOPS: 19

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: 6Mo.: Passenger: X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:
Traction: X Dumbwaiter:

If FA, Permit No.:

Block #:30 Lot #: 2 5 Year. Test Due: 2025

Hydro:

Year Built: MFGR.: Otis Elev Orig. Code: 1993 Mod.Year: Code Certification Expires: 2/28/25

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA
1. Enclosure/Lighting/Vents	X		
2. Machine/Brake/Gears/Motor	X		
3. Hydro Power Motor Unit			X
4. Motor Generator Set/SCR Drive	X		
5. Controller/Selector	X		
6. Governor(s)	X		
7. Relief & Check Valves			X
8. Required Disconnects	X		
9. Oil/Hydro Fluid, Leaks, Level			X
10. Hydro Fluid Hoses or Pipe			X
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
12. Routine Maintenance	X		
13.			
B. ELEVATOR CAR AND COUNTERWEIGHT			
1. Car Enclosure/Platform/Sling/Flooring	X		
2. Guide Shoes/Rollers	X		
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X		
4. Car Gate or Door Operator	X		
5. Car Lighting/Standard & Emergency	X		
6. Rope Hitches/Platen Hitch	X		
7. Top-of-Car Operating Station/Stop Switch	X		
8. Car Operating Station/Stop Switch/Indicators	X		
9. Emergency Signals & Communication	X		
10. Emergency Exits/Top/Side	X		
11. Safeties & Accessories	X		
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
13. Firefighter Service PH I & II	X		
14. Counterweight/Car & Counterweight Sheaves	X		
15. Routine Maintenance	X		
16.			
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT			
1. Enclosure	X		
2. Door, Closers & Accessories	X		
3. Door Interlocks/Emergency Key/Access Keys	X		
4. Guide Rails: Main & Counterweight	X		
5. Switches and Cams	X		
6. Pit/Stop Switch/Light/Ladder	X		
7. Counterweight Guard	X		
8. Buffers: Spring or Oil	X		
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X		
10. Traveling Cable and Wiring	X		
11. Plunger, Cylinder and Gland			X
12. Governor Rope Tension Sheave & Assembly	X		

13. Compensating Sheave or Chain	X			
14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number	QP-5			
2. Car Rated Speed	700			
3. Overspeed Switch	812			
4. Tripping Speed	855			
5. Capacity	3500			
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Working Pressure				
3. Relief Pressure				
4. Capacity				
5. Tags				
F. APPLICABLE CODES				
ASME A17.1 -				
ACTION TAKEN				
1. Device Number	QP-5			
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812

Inspector's Name (print) and License No.

BUD GRANT

Inspector's Signature

Elevator Inspection

Identification

Quarter

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Date: 3/18/24
BLDG.REG # 0102-00157-008
Elevator #: QP-6
Capacity: 3500 lbs STOPS: 3

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: 6Mo.: Passenger: X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:
Traction: Dumbwaiter: Hydro: X
Certification Expires: 2/28/25

If FA, Permit No.:

Block #:30 Lot #: 2 5 Year. Test Due:
Year Built: MFGR.: Otis Elev Orig. Code: 1993 Mod.Year: Code

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA
1. Enclosure/Lighting/Vents	X		
2. Machine/Brake/Gears/Motor	X		
3. Hydro Power Motor Unit			X
4. Motor Generator Set/SCR Drive	X		
5. Controller/Selector	X		
6. Governor(s)	X		
7. Relief & Check Valves			X
8. Required Disconnects	X		
9. Oil/Hydro Fluid, Leaks, Level			X
10. Hydro Fluid Hoses or Pipe			X
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
12. Routine Maintenance	X		
13.			
B. ELEVATOR CAR AND COUNTERWEIGHT			
1. Car Enclosure/Platform/Sling/Flooring	X		
2. Guide Shoes/Rollers	X		
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X		
4. Car Gate or Door Operator	X		
5. Car Lighting/Standard & Emergency	X		
6. Rope Hitches/Platen Hitch	X		
7. Top-of-Car Operating Station/Stop Switch	X		
8. Car Operating Station/Stop Switch/Indicators	X		
9. Emergency Signals & Communication	X		
10. Emergency Exits/Top/Side	X		
11. Safeties & Accessories	X		
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
13. Firefighter Service PH I & II	X		
14. Counterweight/Car & Counterweight Sheaves	X		
15. Routine Maintenance			
16.			
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT			
1. Enclosure	X		
2. Door, Closers & Accessories	X		
3. Door Interlocks/Emergency Key/Access Keys	X		
4. Guide Rails: Main & Counterweight	X		
5. Switches and Cams	X		
6. Pit/Stop Switch/Light/Ladder	X		
7. Counterweight Guard	X		
8. Buffers: Spring or Oil	X		
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X		
10. Traveling Cable and Wiring	X		
11. Plunger, Cylinder and Gland			X
12. Governor Rope Tension Sheave & Assembly	X		
13. Compensating Sheave or Chain	X		

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Car Rated Speed				
3. Overspeed Switch				
4. Tripping Speed				
5. Capacity				
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number QP-6				
2. Working Pressure 350				
3. Relief Pressure 460				
4. Capacity 3500				
5. Tags				
F. APPLICABLE CODES				
ASME A17.1-1993				
ACTION TAKEN				
1. Device Number QP-6				
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812

Inspector's Name (print) and License No. Inspector's Signature

BUD GRANT

SCO

Elevator Inspection

Identification

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Quarter

Date: 3/18/24

BLDG.REG # 0102-00157-008

Elevator #: QP-7
Capacity: 3500 lbs

STOPS: 3

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: 6Mo.: Passenger: X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:

If FA, Permit No.:

Block #:30 Lot #: 2

Year Built: MFGR.: Schindler Elev

Orig. Code: 1993

Mod.Year: Code

Traction: Dumbwaiter: Hydro: X

Certification Expires: 2/28/25

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA
1. Enclosure/Lighting/Vents	X		
2. Machine/Brake/Gears/Motor	X		
3. Hydro Power Motor Unit			X
4. Motor Generator Set/SCR Drive	X		
5. Controller/Selector	X		
6. Governor(s)	X		
7. Relief & Check Valves			X
8. Required Disconnects	X		
9. Oil/Hydro Fluid, Leaks, Level			X
10. Hydro Fluid Hoses or Pipe			X
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
12. Routine Maintenance			
13.			
B. ELEVATOR CAR AND COUNTERWEIGHT			
1. Car Enclosure/Platform/Sling/Flooring	X		
2. Guide Shoes/Rollers	X		
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X		
4. Car Gate or Door Operator	X		
5. Car Lighting/Standard & Emergency	X		
6. Rope Hitches/Platen Hitch	X		
7. Top-of-Car Operating Station/Stop Switch	X		
8. Car Operating Station/Stop Switch/Indicators	X		
9. Emergency Signals & Communication	X		
10. Emergency Exits/Top/Side	X		
11. Safeties & Accessories	X		
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
13. Firefighter Service PH I & II	X		
14. Counterweight/Car & Counterweight Sheaves	X		
15. Routine Maintenance			
16.			
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT			
1. Enclosure	X		
2. Door, Closers & Accessories	X		
3. Door Interlocks/Emergency Key/Access Keys	X		
4. Guide Rails: Main & Counterweight	X		
5. Switches and Cams	X		
6. Pit/Stop Switch/Light/Ladder	X		
7. Counterweight Guard	X		
8. Buffers: Spring or Oil	X		
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X		
10. Traveling Cable and Wiring	X		
11. Plunger, Cylinder and Gland			X
12. Governor Rope Tension Sheave & Assembly	X		
13. Compensating Sheave or Chain	X		

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Car Rated Speed				
3. Overspeed Switch				
4. Tripping Speed				
5. Capacity				
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number	QP-7			
2. Working Pressure	660			
3. Relief Pressure	600			
4. Capacity	3500			
5. Tags				
F. APPLICABLE CODES				
ASME A17.1				
ACTION TAKEN				
1. Device Number	QP-7			
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812
Inspector's Name (print) and License No.

BUD GRANT

Inspector's Signature

Elevator Inspection

Identification

Quarter

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Date: 3/18/24
BLDG.REG # 0102-00157-008
Elevator #: QP-12
Capacity: 3500 lbs STOPS: 3

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: 6 Mo: Passenger: X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H: X
Traction: Dumbwaiter: Hydro:
Certification Expires: 2/28/25

If FA, Permit No.:

Block #:30 Lot #: 2 5 Year. Test Due: 2024
Year Built: MFGR.: Otis Elev Orig. Code: 1993 Mod.Year: Code

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA
1. Enclosure/Lighting/Vents	X		
2. Machine/Brake/Gears/Motor			X
3. Hydro Power Motor Unit	X		
4. Motor Generator Set/SCR Drive			X
5. Controller/Selector	X		
6. Governor(s)	X		
7. Relief & Check Valves	X		
8. Required Disconnects	X		
9. Oil/Hydro Fluid, Leaks, Level	X		
10. Hydro Fluid Hoses or Pipe	X		
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
12. Routine Maintenance			
13.			
B. ELEVATOR CAR AND COUNTERWEIGHT			
1. Car Enclosure/Platform/Sling/Flooring	X		
2. Guide Shoes/Rollers	X		
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X		
4. Car Gate or Door Operator	X		
5. Car Lighting/Standard & Emergency	X		
6. Rope Hitches/Platen Hitch	X		
7. Top-of-Car Operating Station/Stop Switch	X		
8. Car Operating Station/Stop Switch/Indicators	X		
9. Emergency Signals & Communication	X		
10. Emergency Exits/Top/Side	X		
11. Safeties & Accessories	X		
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
13. Firefighter Service PH I & II	X		
14. Counterweight/Car & Counterweight Sheaves			X
15. Routine Maintenance			
16.			
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT			
1. Enclosure	X		
2. Door, Closers & Accessories	X		
3. Door Interlocks/Emergency Key/Access Keys	X		
4. Guide Rails: Main & Counterweight	X		
5. Switches and Cams	X		
6. Pit/Stop Switch/Light/Ladder	X		
7. Counterweight Guard			X
8. Buffers: Spring or Oil	X		
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X		
10. Traveling Cable and Wiring	X		
11. Plunger, Cylinder and Gland	X		
12. Governor Rope Tension Sheave & Assembly	X		
13. Compensating Sheave or Chain			X

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Car Rated Speed	125			
3. Overspeed Switch	150			
4. Tripping Speed	150			
5. Capacity				
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number	QP-12			
2. Working Pressure	660			
3. Relief Pressure	850			
4. Capacity	3500			
5. Tags				
F. APPLICABLE CODES				
ASME A17.1-1993				
ACTION TAKEN				
1. Device Number	QP-12			
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812 BUD GRANT
Inspector's Name (print) and License No. Inspector's Signature

SCO

Elevator Inspection

Identification

Quarter

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Date: 3/14/24
BLDG.REG # 0102-00157-008
Elevator #: QS-1
Capacity: 4500 lbs STOPS: 19

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: 6Mo.: Passenger: X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:
Traction: X Dumbwaiter: Hydro:
Certification Expires: 2/28/25

If FA, Permit No.:

Block #:30 Lot #: 2 5 Year. Test Due: 2019

Year Built: MFGR.: Otis Elev Orig. Code: 1993 Mod.Year: Code

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA
1. Enclosure/Lighting/Vents	X		
2. Machine/Brake/Gears/Motor	X		
3. Hydro Power Motor Unit			X
4. Motor Generator Set/SCR Drive	X		
5. Contoller/Selector	X		
6. Governor(s)	X		
7. Relief & Check Valves			X
8. Required Disconnects	X		
9. Oil/Hydro Fluid, Leaks, Level			X
10. Hydro Fluid Hoses or Pipe			X
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
12. Routine Maintenance			
13.			
B. ELEVATOR CAR AND COUNTERWEIGHT			
1. Car Enclosure/Platform/Sling/Flooring	X		
2. Guide Shoes/Rollers	X		
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X		
4. Car Gate or Door Operator	X		
5. Car Lighting/Standard & Emergency	X		
6. Rope Hitches/Platen Hitch	X		
7. Top-of-Car Operating Station/Stop Switch	X		
8. Car Operating Station/Stop Switch/Indicators	X		
9. Emergency Signals & Communication	X		
10. Emergency Exits/Top/Side	X		
11. Safeties & Accessories	X		
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
13. Firefighter Service PH I & II	X		
14. Counterweight/Car & Counterweight Sheaves	X		
15. Routine Maintenance			
16.			
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT			
1. Enclosure	X		
2. Door, Closers & Accessories	X		
3. Door Interlocks/Emergency Key/Access Keys	X		
4. Guide Rails: Main & Counterweight	X		
5. Switches and Cams	X		
6. Pit/Stop Switch/Light/Ladder	X		
7. Counterweight Guard	X		
8. Buffers: Spring or Oil	X		
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X		
10. Traveling Cable and Wiring	X		
11. Plunger, Cylinder and Gland			X
12. Governor Rope Tension Sheave & Assembly	X		
13. Compensating Sheave or Chain	X		

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number	QS-1			
2. Car Rated Speed	700			
3. Overspeed Switch	812			
4. Tripping Speed	855			
5. Capacity	4000			
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Working Pressure				
3. Relief Pressure				
4. Capacity				
5. Tags				
F. APPLICABLE CODES				
ASME A17.1				
ACTION TAKEN				
1. Device Number	QS-1			
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812

Inspector's Name (print) and License No. Inspector's Signature **BUD GRANT**

SCO

Elevator Inspection

Identification

Quarter

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Date: 3/18/24
BLDG.REG #: 0102-00157-008
Elevator #: **QS-3**
Capacity: 4500 lbs STOPS: 4

Type of Inspection/Test

FA: 1Yr.: X Alteration:
5Yr.: **6Mo.** **Passenger: X**
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:
Traction: Dumbwaiter: **Hydro: X**
Certification Expires: **2/28/25**

If FA, Permit No.:

Block #:30 Lot #: 2 5 Year. Test Due:

Year Built: MFGR.: Otis Elev Orig. Code: 1993 Mod.Year: Code

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA	
1. Enclosure/Lighting/Vents	X			
2. Machine/Brake/Gears/Motor	X			
3. Hydro Power Motor Unit			X	
4. Motor Generator Set/SCR Drive	X			
5. Controller/Selector	X			
6. Governor(s)	X			
7. Relief & Check Valves			X	
8. Required Disconnects	X			
9. Oil/Hydro Fluid, Leaks, Level			X	
10. Hydro Fluid Hoses or Pipe			X	
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
12. Routine Maintenance				
13.				
B. ELEVATOR CAR AND COUNTERWEIGHT				
1. Car Enclosure/Platform/Sling/Flooring	X			
2. Guide Shoes/Rollers	X			
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X			
4. Car Gate or Door Operator	X			
5. Car Lighting/Standard & Emergency	X			
6. Rope Hitches/Platen Hitch	X			
7. Top-of-Car Operating Station/Stop Switch	X			
8. Car Operating Station/Stop Switch/Indicators	X			
9. Emergency Signals & Communication	X			
10. Emergency Exits/Top/Side	X			
11. Safeties & Accessories	X			
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X			
13. Firefighter Service PH I & II	X			
14. Counterweight/Car & Counterweight Sheaves	X			
15. Routine Maintenance				
16.				
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT				
1. Enclosure	X			
2. Door, Closers & Accessories	X			
3. Door Interlocks/Emergency Key/Access Keys	X			
4. Guide Rails: Main & Counterweight	X			
5. Switches and Cams	X			
6. Pit/Stop Switch/Light/Ladder	X			
7. Counterweight Guard	X			
8. Buffers: Spring or Oil	X			
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail	X			
10. Traveling Cable and Wiring	X			
11. Plunger, Cylinder and Gland			X	
12. Governor Rope Tension Sheave & Assembly	X			
13. Compensating Sheave or Chain	X			

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Car Rated Speed				
3. Overspeed Switch				
4. Tripping Speed				
5. Capacity				
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Working Pressure				
3. Relief Pressure	520			
4. Capacity	4500			
5. Tags				
F. APPLICABLE CODES				
ASME A17.1				
ACTION TAKEN				
1. Device Number	QS-3			
2. Recommended Type of Certification (Cyclical Inspections Only)				CC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812

Inspector's Name (print) and License No. Inspector's Signature **BUD GRANT**

SCO

Elevator Inspection

Identification

Quarter

Name: Tropicana Hotel & Casino
Address: 2821 Boardwalk
City/State/Zip: ATLANTIC CITY, NJ 08401

Date: 3/19/24
BLDG.REG #: 0102-00157-008
Elevator #: QS-4
Capacity: 4500 lbs STOPS: 3

Type of Inspection/Test

FA: 1Yr.:X Alteration:
5Yr.: 6Mo.: Passenger: X
3 Yr.: Reinsp: Freight:
Escl: Chairlift: Rope/H:
Traction: Dumbwaiter: Hydro: X
Certification Expires: 2/28/25

If FA, Permit No.:

Block #:30 Lot #: 2 5 Year. Test Due: N/A
Year Built: MFGR.: Otis Elev Orig. Code: 1993

Mod.Year: Code

A. MACHINE ROOM & MACHINE ROOM EQUIPMENT	S	U	NA
1. Enclosure/Lighting/Vents	X		
2. Machine/Brake/Gears/Motor			X
3. Hydro Power Motor Unit	X		
4. Motor Generator Set/SCR Drive			X
5. Controller/Selector	X		
6. Governor(s)			X
7. Relief & Check Valves	X		
8. Required Disconnects	X		
9. Oil/Hydro Fluid, Leaks, Level	X		
10. Hydro Fluid Hoses or Pipe	X		
11. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
12. Routine Maintenance			
13.			
B. ELEVATOR CAR AND COUNTERWEIGHT			
1. Car Enclosure/Platform/Sling/Flooring		X	
2. Guide Shoes/Rollers	X		
3. Car Gate/Door/Accessories/Car Door Reopening Device(s)	X		
4. Car Gate or Door Operator	X		
5. Car Lighting/Standard & Emergency	X		
6. Rope Hitches/Platen Hitch	X		
7. Top-of-Car Operating Station/Stop Switch	X		
8. Car Operating Station/Stop Switch/Indicators	X		
9. Emergency Signals & Communication	X		
10. Emergency Exits/Top/Side	X		
11. Safeties & Accessories			X
12. Seals, Plates, Labels, Unit ID, Tags, Signs	X		
13. Firefighter Service PH I & II	X		
14. Counterweight/Car & Counterweight Sheaves			X
15. Routine Maintenance			
16.			
C. HOISTWAY, HOISTWAY ENTRANCES AND PIT			
1. Enclosure	X		
2. Door, Closers & Accessories	X		
3. Door Interlocks/Emergency Key/Access Keys	X		
4. Guide Rails: Main & Counterweight	X		
5. Switches and Cams	X		
6. Pit/Stop Switch/Light/Ladder	X		
7. Counterweight Guard			X
8. Buffers: Spring or Oil	X		
9. Ropes: Hoist, Governor, Counterweight, Compensating, Tail			X
10. Traveling Cable and Wiring	X		
11. Plunger, Cylinder and Gland			X
12. Governor Rope Tension Sheave & Assembly			X
13. Compensating Sheave or Chain	X		

14. Clearances and Runby	X			
15. Seals, Plates, Labels, Tags	X			
16. Hall Station/Hall Position Indicator (if required), Hall Lantern	X			
17. Routine Maintenance				
18.				
D. ESCALATOR/MOVING WALKS (Device Type)				
1. Stair Treads/Comb Plates				
2. Balustrade/Handrails				
3. Shear Points Protection				
4. Emergency Stop Switches				
5. Steps, Rollers & Tracks				
6. Chains & Sprockets				
7. Safety Devices				
8. Kiosk/Wellway/Safety Zone				
9. Clearances				
10. Protection of Trusses & Machinery Space (Fire)				
11. Skirt & Steps Clearance				
12. Machinery Access Space & Lighting				
13. Escalator Brakes				
14. Machine/Brakes/Gears/Motor				
15. Starting & Switches				
16. Speed Governor				
17. Rolling Shutter Device				
18. Signs, Seals, Planks, Labels, Unit ID, Tags				
19. Step Lighting				
20. Required Disconnect				
21. Routine Maintenance				
22. Tests				
23.				
E. TESTS: TRACTION ELEVATOR DEVICES (Pass or Fail)				
1. Device Number				
2. Car Rated Speed				
3. Overspeed Switch				
4. Tripping Speed				
5. Capacity				
HYDRO ELEVATOR DEVICES (Pass or Fail)				
1. Device Number	QS-4			
2. Working Pressure	400			
3. Relief Pressure	500			
4. Capacity	4500			
5. Tags				
F. APPLICABLE CODES				
ASME A17.1 - 1993				
ACTION TAKEN				
1. Device Number	QS-4			
2. Recommended Type of Certification (Cyclical Inspections Only)				TCC
3. Removed from Operation				

Note: When unsatisfactory conditions are noted, see "Notice" attached

BUD GRANT # 8812

Inspector's Name (print) and License No. Inspector's Signature **BUD GRANT** SCO

City of Atlantic City
LICENSE and INSPECTIONS
DIVISION OF CONSTRUCTION
ELEVATOR SAFETY UNIT

Notice of Violation and Order to Terminate

Date: 3/18/24_ Inspector: BUD GRANT
Device Regist. #: 0102-00157-008
Project Location: Same

Owner Name: Tropicana Hotel & Casino
Owner address: 2821 Boardwalk
ATLANTIC CITY, NJ 08401

Name of Person, Contractor/Maintenance Co. Performing Tests: Schindler Elevator

Be advised that during today's inspection/test, the following irregularities/nonconformances/violations were noted, and you are Required to ensure that they be corrected before : work to be complete 60 days from inspection date
Unit ID # QS-4

(X)The elevator device may be operated during repairs/corrections

()The elevator device is locked out until the repairs/corrections are satisfactorily completed, the device is reinspected, and applicable certificate is received

Penalty Item	Repeat Item	ASME A17.1-1993	BOCA	NJAC 5:23- 2009
	3X	A5, ALL PARTS OF THE INSTALLATION SHALL WORK. NJAC 5:23-12.2b		
		B1, Replace handrail that is missing in elevator.		

A penalty item indicates that a violation is in penalty. A repeat item indicates the amount of times a violation has been repeated. **FAILURE TO COMPLY WITH THIS ORDER WILL SUBJECT YOU TO A PENALTY OF \$500 to \$2000 PER VIOLATION.**

If you wish to contest the validity of the above action, you may request a hearing before the Construction Board of Appeals of the County of Atlantic, within 20 business days of the receipt of these orders. The Application to the Construction Board of Appeals may be used for this purpose. Your application for your appeal must be in writing, stating your name and address, the address of the violation, the specific reason for your appeal and the nature of the relief sought by you. Forward to Construction Board of Appeals, PO Box 719, New Road & Dolphin Ave, Northfield, NJ 08225. The fee for an appeal is \$100. to be forwarded with your application.

When work to abate the violations requires a construction permit, the owner is responsible for securing such a permit. Maintenance violation (Part 12) can be found in the newest adopted code.

If you have any questions concerning this matter, please call the Elevator Safety Unit at (609) 347-6126.
Our mailing address is:
City of Atlantic City, Division of Construction, Elevator Safety,
1301 Bacharach Blvd.
Atlantic City, NJ 08401

SIGNATURE OF SUBCODE OFFICIAL _____