



Union City
Fire Prevention Bureau
3715 Palisade Ave, 3rd Floor
Union City, NJ 07087
Phone: (201)351-5960

All Violations Associated with 8/19/2022 Inspection

Location

Block: 41.02 Lot: 9 Qualifier: _____ Street Address: 609 10th Street

Business Name Premio Foods INC.

Use Group _____

Unit Number _____

☐ Life Hazard Use

State Number _____

Inspection Violations

NO.	Location	Nature & Description	Code Reference	Inspection Summary
FPVIO 22 04380	Building Fire Alarm System	Supply Written NFPA 72 Alarm Report - No Deficiencies A copy of the report can be emailed to xxxxxxxx@xxxx.xxx	907.8.2	Abate by: 9/19/2022
				I-(Moises Valdes)8/19/2022
				A-FPI-22-08485(Moises Valdes)9/7/2022
FPVIO 22 04381	Building Fire Sprinkler System	Supply Written NFPA 25 Sprinkler Report - No Deficiencies A copy of the report can be emailed to xxxxxxxx@xxxx.xxx	903.5	Abate by: 9/19/2022
				I-(Moises Valdes)8/19/2022
				A-FPI-22-08485(Moises Valdes)9/7/2022
FPVIO 22 04382	Business	Provide a copy of the most recent Life Hazard Use Registration Certificate from the State of NJ	5:70-2.6(g)	Abate by: 9/19/2022
				I-(Moises Valdes)8/19/2022
				A-FPI-22-08485(Moises Valdes)9/7/2022
FPVIO 22 04383	Boiler room on the 2nd floor loft	Install Carbon Monoxide zone in vicinity of fuel burning appliances, As Per Union City Municipal City Ordinance 22-02-01-8 Monitored CO detector to be installed in-line with the automatic fire alarm system	N.J.A.C. 5:70-4.9(d)	Abate by: 9/19/2022
				I-(Moises Valdes)8/19/2022
				A-FPI-22-08485(Moises Valdes)9/7/2022

Inspection Summary Key:

I - Initial U - Violation Unabated A - Violation Abated R - Repeat Violation W - Withdrawn
Violation Status - Inspection Number (Inspector ID) Inspection Date

Note: The numbering of violation(s) is for identification purposes only and shall not be construed as bearing in anyway on the seriousness of any violation.

5:71-3.7(b)3.

N.J.A.C. 5:70-3.2(a), modifications to articles and sections of the State Fire Prevention Code.

N.J.A.C. 5:70-4, Subchapter 4 Retrofit Requirements