



Union City
Fire Prevention Bureau
3715 Palisade Ave, 3rd Floor
Union City, NJ 07087
Phone: (201)351-5960

All Violations Associated with 11/28/2023 Inspection

Location

Block: 41.02 Lot: 9 Qualifier: _____ Street Address: 609 10th Street

Business Name Premio Foods INC.

Use Group _____

Unit Number _____

☐ Life Hazard Use

State Number _____

Inspection Violations

NO.	Location	Nature & Description	Code Reference	Inspection Summary
FPVIO 23 08720	Building	Submit certification report for the servicing testing of all exit and emergency lights.		Abate by: 12/28/2023
				I-(Louis Miranda)11/28/2023
				A-FPI-23-16866(Louis Miranda)12/28/2023
FPVIO 23 08721	Building	Submit current NFPA 25 fire sprinkler system certification report.	903.5	Abate by: 12/28/2023
				I-(Louis Miranda)11/28/2023
				A-FPI-23-16866(Louis Miranda)12/28/2023
FPVIO 23 08722	Building	Submit current NFPA 72 fire alarm system certification report with a 24 hour timer test or transmission as proof the system is connectd to a central station monitoring service.	901.6	Abate by: 12/28/2023
				I-(Louis Miranda)11/28/2023
				A-FPI-23-16866(Louis Miranda)12/28/2023

Inspection Summary Key:

I - Initial U - Violation Unabated A - Violation Abated R - Repeat Violation W - Withdrawn
Violation Status - Inspection Number (Inspector ID) Inspection Date

Note: The numbering of violation(s) is for identification purposes only and shall not be construed as bearing in anyway on the seriousness of any violation.

5:71-3.7(b)3.

N.J.A.C. 5:70-3.2(a), modifications to articles and sections of the State Fire Prevention Code.

N.J.A.C. 5:70-4, Subchapter 4 Retrofit Requirements