



Union City
Fire Prevention Bureau
3715 Palisade Ave, 3rd Floor
Union City, NJ 07087
Phone: (201)351-5960

All Violations Associated with 10/16/2025 Inspection

Location

Block: 41.02 Lot: 9 Qualifier: _____ Street Address: 609 10th Street

Business Name Premio Foods INC.

Use Group _____

Unit Number _____

☐ Life Hazard Use

State Number _____

Inspection Violations

NO.	Location	Nature & Description	Code Reference	Inspection Summary
FPVIO 25 08938	Throughout building	Provide NFPA 72 Alarm report- No Deficiencies with a 24 hour timer test as proof that the fire alarm system is connected to a central station monitoring service.	907.8	Abate by: 11/16/2025
				I-(Jorge Ponce)10/16/2025
				U-FPI-25-14355(Jorge Ponce)11/16/2025
				U-FPI-26-07369(Jorge Ponce)5/27/2026
FPVIO 25 08939	Throughout building	Provide written NFPA 25 Sprinkler Report - No Deficiencies. A copy of the report can be emailed.	903.5	Abate by: 11/16/2025
				I-(Jorge Ponce)10/16/2025
				U-FPI-25-14355(Jorge Ponce)11/16/2025
				U-FPI-26-07369(Jorge Ponce)5/27/2026

Inspection Summary Key:

I - Initial U - Violation Unabated A - Violation Abated R - Repeat Violation W - Withdrawn
Violation Status - Inspection Number (Inspector ID) Inspection Date

Note: The numbering of violation(s) is for identification purposes only and shall not be construed as bearing in anyway on the seriousness of any violation.

5:71-3.7(b)3.

N.J.A.C. 5:70-3.2(a), modifications to articles and sections of the State Fire Prevention Code.

N.J.A.C. 5:70-4, Subchapter 4 Retrofit Requirements