

Pam Borghi <pborghi@redbanknj.org>

Fwd: Water Quality

1 message

Michael Ballard <mballard@redbanknj.org>
To: Pam Borghi <pborghi@redbanknj.org>

Sun, Jun 9, 2019 at 7:58 AM

Re: Water Quality OPRA Request

----- Forwarded message -----

From: **Michael Ballard** <mballard@redbanknj.org>
Date: Sat, Jun 1, 2019 at 7:31 PM
Subject: Re: Water Quality
To: Ziad Shehady <ZShehady@redbanknj.org>

Thanks for the update. Did you respond to Mr. Wiecezrak as well?

Regards,

Michael

On Fri, May 31, 2019, 9:36 PM Ziad Shehady <zshehady@redbanknj.org> wrote:
Mayor & Council,

We learned today that there was a fire suppression system test at a private development which seems to have resulted in a large volume of water flowing through the water system in a short period of time. It seems that that may have caused some water discoloration for some residents which should clear up by running the water in the household. Had we known about this beforehand, we may have been able to predict this would occur and could have notified residents in advance. If anyone contacts you, they can be advised of same and should be instructed to just run the water until it is clear.

Respectfully,

Z

Ziad Andrew Shehady
Business Administrator
Borough of Red Bank
[90 Monmouth Street](http://www.redbanknj.org)
Red Bank, New Jersey 07701
T: +1 (732) 530-2748
<http://www.redbanknj.org>
zshehady@redbanknj.org

Councilman Michael K. Ballard
732.829.3962