



WATER QUALITY REPORT

2017 Results from the Year 2016
LIVINGSTON, NEW JERSEY

Lawn Watering Restrictions

In accordance with Township Ordinance 19-2016, the following water restrictions have been imposed and are enforceable year round:

Properties may water 3 days per week.

- Even: Tuesday, Thursday & Saturday

- Odd: Wednesday, Friday & Sunday

- No address: Tuesday, Thursday & Sunday

Hose or hose-end sprinkler

- Allowed: 6 p.m.—9 a.m.

- 30 minute max. per area per day

Automatic Conventional Irrigation System

- Allowed: 12 midnight—9 a.m.

- Mist: 15 minute max. per area per day

- Rotary sprinkler: 50 minute max. per area per day

**WaterSense certified
systems are exempt.**

We are pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources.


Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

EPA requires monitoring for over 80 drinking water contaminants. The Township of Livingston Water Department and New Jersey American Water routinely monitor for contaminants in your drinking water according to Federal and State laws. The tables show the results of that monitoring for the period of January 1st to December 31st, 2016. The contaminants listed in the tables are the only contaminants detected in your water. The state allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

Water Department
Township of Livingston

IMPORTANT INFORMATION

This report contains important information about your drinking water. If you do not understand it, please have someone translate it for you.



The Township of Livingston's water supply is derived from fourteen production wells located within the Township and water purchased from New Jersey American Water (NJAW). The water purchased from NJAW is a blend of sources that includes groundwater from the Brunswick Shale Formations, the Buried Valley Aquifer System, the Gneiss Rock Formations, and surface water from the Canoe Brook Reservoirs, Passaic River, Raritan River and the Wanaque Reservoir.

The New Jersey Department of Environmental Protection (NJDEP) has completed and issued the Source Water Assessment Report and Summary for the Township of Livingston Water System and New Jersey American Water System which is available at www.state.nj.us/dep/swap or by contacting NJDEP's Bureau of Safe Drinking Water at (609) 292-5550. You may also contact your public water system to obtain information regarding your water system's Source Water Assessment. Livingston Township's Water System's source water susceptibility ratings and a list of potential contaminant sources is included.

If you have any questions about this report or concerning your water, please contact the Township of Livingston Water Department at 973-535-7951 or at 357 S Livingston Avenue, Livingston, New Jersey 07039. We want our valued customers to be informed about their drinking water. If you want to learn more, please attend any of our regularly scheduled Township Council meetings at Municipal Building. For a meeting schedule please see the Township website at www.livingstonnj.org.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up

substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can, also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at (800) 426-4791.

Township of Livingston Test Results						
PWS ID # NJ0710001						
Contaminant	Violation Y/N	Level Detected	Units of Measurement	MC LG	MCL	Likely Source of Contamination
Inorganic Contaminants:						
Arsenic Test results Yr. 2014	N	Range = ND – 1.5 Highest detect = 1.5	ppb	0	5	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium Test results Yr. 2014	N	Range = 0.2 – 0.6 Highest detect = 0.6	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Chromium Test results Yr. 2014	N	Range = ND – 3.7 Highest detect = 3.7	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
Copper Test results Yr. 2015 Result at 90 th Percentile	N	0.2 No samples exceeded the action level	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Fluoride Test results Yr. 2014	N	Range = ND – 0.2 Highest detect = 0.2	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead Test results Yr. 2015 Result at 90 th Percentile	N	2.6 No samples exceeded the action level	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Mercury (inorganic) Test results Yr. 2014	N	Range = ND – 0.1 Highest detect = 0.1	ppb	2	2	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland
Nitrate (as Nitrogen) Test results Yr. 2016	N	Range = 0.8-2.2 Highest detect = 2.2	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nickel Test results Yr. 2014	N	Range = ND – 2.6 Highest detect = 2.6	ppb	N/A	N/A	Erosion of natural deposits
Volatile Organic Contaminants:						
Carbon Tetrachloride* Test results Yr. 2014	N	Range = ND – 1.4 Highest Avg. level detected = 0.4	ppb	0	2	Discharge from chemical plants and other industrial activities
Tetrachloroethylene* Test results Yrs. 2014 2015& 2016	N	Range = ND – 0.9 Highest Avg. level detected = 0.5	ppb	0	1	Discharge from factories and dry cleaners
Trichloroethylene* Test results Yr. 2014	N	Range = ND – 2.9 Highest Avg level detected = 1.3	ppb	0	1	Discharge from metal degreasing sites and other factories
Disinfection Byproducts:						
TTHM Total Trihalomethanes Test results Yr. 2016	N	Range = 8 - 60 Highest LRAA = 35	ppb	N/A	80	By-product of drinking water disinfection
HAA5 Haloacetic Acids Test results Yr. 2016	N	Range = –ND - 58 Highest LRAA = 25	ppb	N/A	60	By-product of drinking water disinfection
Radioactive Contaminants:						
Gross Alpha Test results Yr. 2014	N	Range = ND – 8.4 Highest detect = 8.4	pCi/1	0	15	Erosion of natural deposits
Uranium Test results Yr. 2014	N	Range = ND – 3.3 Highest detect = 3.3	ppb	0	30	Erosion of natural deposits
Regulated Disinfectants	Level Detected		MRDL	MRDLG	Likely Source of Contamination	
Chlorine	Average = 0.3 ppm		4.0 ppm	4.0 ppm	Water additive used to control microbes	

*Increased Volatile Organic Contaminant results were due to elevated levels at Well 6, which has been shut down since 2014. Tetrachloroethylene was detected in Well 4. The LRAA calculation is based on four yearly quarters of results. Total Haloacetic Acids (HAA5) and Total Trihalomethanes (TTHM) compliance is based on a Locational Running Annual Average (LRAA), calculated at each monitoring location.

Township of Livingston - Unregulated Contaminant Monitoring Rule (UCMR) The Township of Livingston Water participated in the UCMR program. Unregulated contaminants are those for which the EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist the EPA in determining the occurrence of unregulated contaminants in drinking water and whether regulation is warranted. Our results are listed below and available upon request.

Contaminant	Level Detected	Units of Measurement	Likely Source
1,1Dichloroethane	Range = ND – 0.06	ppb	Halogenated alkane; used as a solvent
1,4Dioxane	Range = ND – 1.2	ppb	Cyclic aliphatic ether; used as a solvent or solvent stabilizer in manufacturing and processing of paper, cotton, textile products, automotive coolant, cosmetics and shampoos
Chlorate	Range = ND – 1690	ppb	Agricultural defoliant or desiccant; disinfection byproduct; used in the production of chloride dioxide
Chromium (Total)	Range = ND – 3.0	ppb	Naturally-occurring element; used in the making of steel and other alloys; chromium -3 or -6 are used for chrome plating, dyes and pigments, leather tanning, and other wood preservation
Chromium (VI)	Range = ND – 2.8	ppb	Naturally-occurring element; used in the making of steel and other alloys; chromium -3 or -6 are used for chrome plating, dyes and pigments, leather tanning, and other wood preservation
Strontium	Range = 65 – 1180	ppb	Naturally-occurring element; historically commercial use of strontium has been in the faceplate glass of cathode-ray tube televisions to block x-ray emissions
Vanadium	Range = ND – 9.2	ppb	Naturally-occurring element metal; used as vanadium pentoxide which is a chemical intermediate and a catalyst

DEFINITIONS

In the following table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

NonDetects (ND) laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) picocuries per liter is a measure of the radioactivity in water.

Nephelometric Turbidity Unit (NTU) nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Action Level the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Secondary Contaminant Substances that do not have an impact on health. Secondary Contaminants affect aesthetic qualities such as odor, taste or appearance. Secondary standards are recommendations, not mandates.

Recommended Upper Limit (RUL) Recommended maximum concentration of secondary contaminants. These reflect aesthetic qualities such as odor, taste or appearance. RUL's are recommendations, not mandates.

Maximum Residual Disinfectant Level (MRDL) The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) The level of a drinking water disinfectant, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination

Total Organic Carbon (TOC) We are required to remove a certain percentage of (TOC) from our drinking water on a monthly basis. Total Organic Carbon has no adverse health effects. However, TOC provides a medium for the formation of disinfection byproducts.

Turbidity A measure of the particulate matter or "cloudiness" of the water. High turbidity can hinder the effectiveness of disinfectants.

Purchased Water from New Jersey American Water In addition to producing water from our own well water sources, the Township purchases water from New Jersey American Water (NJAW). Information about NJAW water quality results is summarized in the table below.

New Jersey American Water – Short Hills System - 2016 Test Results						
PWS ID # NJ0712001						
Contaminant	Violation Y/N	Level Detected	Units of Measure- ment	MC LG	MCL	Likely Source of Contamination
Microbiological Contaminants:						
Total Organic Carbon	N	Range = 1.31 – 3.19 Highest detect = 3.19	ppm	N/A	TT % of removal	Naturally present in the environment.
Inorganic Contaminants:						
Arsenic	N	Range = ND – 2 Highest detect = 2	ppb	0	5	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium	N	Range = ND – 0.3 Highest detect = 0.3	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Copper Result at 90 th Percentile	N	0.406 1 sample exceeded the action level	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits
Lead Result at 90 th Percentile	N	3 2 samples exceeded the action level	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Nickel	N	Range = ND – 8 Highest detect = 8	ppb	N/A	N/A	Erosion of natural deposits
Nitrate (as Nitrogen)	N	Range = 0.24 – 5.81 Highest Avg. level detected = 4.6	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Disinfection Byproducts:						
TTHM Total Trihalomethanes	N	Range = 10.1 – 93.1 Highest LRAA = 74	ppb	N/A	80	By-product of drinking water disinfection
HAA5 Haloacetic Acids	N	Range = 4.4 – 38.3 Highest LRAA = 30	ppb	N/A	60	By-product of drinking water disinfection
Bromate	N	Range = ND – 2 Highest detect = 2	ppb	N/A	10	By-product of drinking water disinfection
Radioactive Contaminants:						
Gross Alpha Test results Yr. 2014	N	Range = ND – 12 Highest detect = 12	pCi/l	0	15	Erosion of natural deposits
Combined Radium 228 & 226 Test results Yr. 2014	N	Range = ND – 2.1 Highest detect = 2.1	pCi/l	0	5	Erosion of natural deposits
Regulated Disinfectants;		Level Detected	MRDL		MRDLG	Likely Source of Contamination
Chlorine		Range = 0.50 – 1.0 ppm Highest detect = 0.88	4.0 ppm		4.0 ppm	Water additive used to control microbes
Chloramines		Range = 0.5 – 1.4 ppm	4.0 ppm		4.0 ppm	Water additive used to control microbes

New Jersey American Water conducts annual sampling to determine the radon levels in all sources of our water supply. Our water showed radon levels ranging from non-detectable to 1059 pCi/l in the Short Hills System. The EPA is developing regulations to reduce Radon in drinking water. Radon in the air is inexpensive to test and easy to remediate. For Additional information, call the EPA's Radon Hotline at 1-800-SOS-Radon. Radon is a radioactive gas that occurs naturally in some groundwater.

Cryptosporidium: is a microbial pathogen found in surface water throughout the United States. Although filtration removes Cryptosporidium, the most commonly-used filtration methods cannot guarantee 100% removal. Ingestion of Cryptosporidium may cause cryptosporidiosis, an abdominal infection. Symptoms of infection include nausea, diarrhea, and abdominal cramps. Most healthy individuals can overcome the disease within a few weeks. However, immuno-compromised people, infants and small children, and the elderly are at a greater risk of developing life-threatening illness. We encourage immuno-compromised individuals to consult their doctor regarding appropriate precautions to take to avoid infection. Cryptosporidium must be ingested to cause disease, and it may be spread through means other than drinking water. New Jersey American Water conducted a two year study of their water supply to determine the amount of Cryptosporidium in untreated raw water. Monthly samples were taken from July 2003 to June 2005 and analyzed. Cryptosporidium was not detected in any samples.

New Jersey American Water – Short Hills System Test Results Year 2016 PWS ID # NJ0712001			
Secondary Contaminant	Level Detected	Units of Measurement	RUL
Sodium	Range = 12.9 – 99.6	ppm	50
Manganese	Range = ND – 0.137	ppm	0.05

New Jersey American Water – Short Hills System exceeded the Recommended Upper Limit (RUL) for Sodium. For healthy individuals the sodium intake from water is not important, because a much greater intake of sodium takes place from salt in the diet. However, sodium levels above the Recommended Upper Limit (RUL) may be of concern to individuals on a sodium restricted diet.

New Jersey American Water – Short Hills System exceeded the secondary Recommended Upper Limit (RUL) for manganese which is based on staining of laundry. Manganese is an essential nutrient, and toxicity is not expected from levels which would be encountered in drinking water. Manganese is a naturally occurring element in soil, groundwater, and some surface waters. Manganese is considered harmless to health, however, they may give water an off taste or color, cause splotchy yellow stains on laundry, and clog water systems.

New Jersey American Water - Unregulated Contaminant Monitoring Rule (UCMR) New Jersey American Water participated in the UCMR program. Unregulated contaminants are those for which the EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist the EPA in determining the occurrence of unregulated contaminants in drinking water and whether regulation is warranted. Our results are available upon request. For testing conducted in the Short Hills System, we found the substances listed.

Contaminant	Level Detected	Units of Measurement	Likely source
1,4-Dioxane Test results Yrs. 2013, 2014 & 2015	Range = ND – 0.24	ppb	Cyclic aliphatic ether; used as a solvent or solvent stabilizer in manufacturing and processing of paper, cotton, textile products, automotive coolant, cosmetics and shampoos
Chlorate Test results Yrs. 2013, 2015	Range = ND – 200	ppb	Agricultural defoliant of desiccant; disinfection byproduct; used in the production of chloride dioxide
Chromium (VI) Test results Yrs. 2013 & 2015	Range = ND – 1.71	ppb	Naturally-occurring element; used in the making of steel and other alloys; chromium -3 or -6 are used for chrome plating, dyes and pigments, leather tanning, and other wood preservation
Cobalt Test results Yrs. 2013 & 2015	Range = ND – 2.3	ppb	Naturally-occurring element found in the earth's crust and at low concentrations in seawater, and in some surface and ground water; cobaltous chloride was formally used in medicine as a germicide
Molybdenum Test results Yrs. 2013 & 2015	Range = ND – 1.8	ppb	Naturally-occurring element found in ores and present in plants, animals and bacteria; commonly used form molybdenum trioxide used as a chemical reagent
Strontium Test results Yrs. 2013 & 2015	Range = 76- 689.8	ppb	Naturally-occurring element; historically commercial use of strontium has been in the faceplate glass of cathode-ray tube televisions to block x-ray emissions
Vanadium Test results Yrs. 2013 & 2015	Range = ND – 22.4	ppb	Naturally-occurring element metal; used as vanadium pentoxide which is a chemical intermediate and a catalyst
N-nitrosopyrrolidine (NPYR)	Range = ND-0.0023	ppb	Can form as intermediates and byproducts in chemical synthesis and manufacture of rubber, leather, and plastics; can form spontaneously by reaction of precursor amines with nitrosating agents (nitrate and related compounds), or by action of nitrate-reducing bacteria.
Perfluorooctanic Acid (PFOA) Test results Yrs. 2011& 2015	Range = 0.007 – 0.021	ppb	Man –made chemical used in the manufacture of fluoropolymers.

Livingston Township Division of Water - PWSID # NJ0710001

Livingston Township Division of Water is a public community water system consisting of 14 wells and 1 purchased surface water source. This system's source water comes from the following aquifer Brunswick Aquifer System, Glacial Sand and Gravel. This system purchases water from the following water system: NJ American Water / Short Hills System.

Susceptibility Ratings for Livingston Township Division of Water Sources

The table below illustrates the susceptibility ratings for the seven contaminant categories (and radon) for each source in the system. The table provides the number of wells and intakes that rated high (H), medium (M), or low (L) for each contaminant category. For susceptibility ratings of purchased water, refer to the specific water system's source water assessment report.

The seven contaminant categories are defined at the bottom of this page. DEP considered all surface water highly susceptible to pathogens, therefore all intakes received a high rating for the pathogen category. For the purpose of Source Water Assessment Program, radionuclides are more of a concern for ground water than surface water. As a result, surface water intakes' susceptibility

to radionuclides was not determined and they all received a low rating.

If a system is rated highly susceptible for a contaminant category, it does not mean a customer is or will be consuming contaminated drinking water. The rating reflects the potential for contamination of source water, not the existence of contamination. Public water systems are required to monitor for regulated contaminants and to install treatment if any contaminants are detected at frequencies and concentrations above allowable levels. As a result of the assessments, DEP may customize (change existing) monitoring schedules based on the susceptibility ratings.

	Pathogens			Nutrients			Pesticides			Volatile Organic Compounds			Inorganics			Radionuclides			Radon			Disinfection Byproduct Precursors		
Sources	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L
Wells - 14		8	6	4	10			2	12	14			9	5		1	13		14			3	11	

We at the Township of Livingston Water Department work hard to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future. Please call our office if you have questions.

Pathogens: Disease-causing organisms such as bacteria and viruses. Common sources are animal and human fecal wastes.

Nutrients: Compounds, minerals and elements that aid growth, that are both naturally occurring and man-made. Examples include nitrogen and phosphorus.

Volatile Organic Compounds: Man-made chemicals used as solvents, degreasers, and gasoline components. Examples include benzene, methyl tertiary butyl ether (MTBE), and vinyl chloride.

Pesticides: Man-made chemicals used to control pests, weeds and fungus. Common sources include land application and manufacturing centers of pesticides. Examples include herbicides such as atrazine, and insecticides such as chlordane.

Inorganics: Mineral-based compounds that are both naturally occurring and man-made. Examples include arsenic, asbestos, copper, lead, and nitrate.

Radionuclides: Radioactive substances that are both naturally occurring and man-made. Examples include radium and uranium.

Radon: Colorless, odorless, cancer-causing gas that occurs naturally in the environment. For more information go to <http://www.nj.gov/dep/rpp/radon/index.htm> or call (800) 648-0394.

Disinfection Byproduct Precursors: A common source is naturally occurring organic matter in surface water. Disinfection byproducts are formed when the disinfectants (usually chlorine) used to kill pathogens react with dissolved organic material (for example leaves) present in surface water.

Outdoor Water Use Tips

Use less water.

- Water your lawn as little as possible. If you step on grass and it springs back, it doesn't need watering. (Ask a nursery about letting your grass go dormant.)
- Landscape with drought-tolerant native plants.
- Sweep dirt or debris rather than rinsing it away.

Use every drop wisely.

- Water by hand to target areas that need it.
- Use shut-off nozzles on hoses.
- Consider watering with a drip system, not a sprinkler. (Check restrictions.) Make sure watering systems do not leak and go on only when needed.
- To wash your vehicle, use a bucket of soapy water. Only use a hose to rinse. Or visit a carwash that recycles water.

Limit evaporation.

- It's best to water (if allowed) in the early morning or at night. Don't water when it's hot or windy.
- Cover your pool or spa when it's not in use.
- Use mulch around plants and trees to help soil stay moist. Similarly, leave grass clippings on the lawn after mowing.



With just a few small changes, we can build a sustainable future together and protect our most precious resource- water.

TOTAL ANNUAL WATER SAVINGS:

157,200 gallons per year!

www.mwdoc.com/services/water-saving-tips

TIPS

How Can You Use Water More Efficiently Every Day?



Swap a 15 minute shower for a 5 minute shower. Saves 9,000 gallons a year!



Switch to high-efficiency. Saves nearly 7,000 gallons a year per person!



Use short blasts to rinse dishes instead of running water. Saves nearly 5,000 gallons a year!



Set your lawn mower to the highest setting. Saves over 2,000 gallons a year!



Turn off the water while brushing your teeth. Saves over 2,000 gallons a year!



Turn off the water while shaving. Saves over 3,000 gallons a year!



Run your clothes and dishwasher only when full. Save nearly 12,000 gallons each year!



Fix leaks right away. Saves 10,000 gallons each year!



Turn off water from the hose when not in use. Saves 10 gallons a minute!



Use a broom instead of a hose to clean your driveway. Saves over 7,000 gallons a year!



Install a "Smart" irrigation controller. Saves 15,000 gallons a year!



Cover your pool. Nearly 15,000 gallons are lost to evaporation each year!



Install rotating nozzles. Saves over 60,000 gallons a year!



Take your car to a carwash that recycles water. Saves over 5,000 gallons a year!

WATER: DO MORE WITH LESS